



NOTES

1. The property owner is responsible for any adjustment to structures including, but not limited to, manholes and water valves.
2. Concrete temperature may not exceed 90°F.
3. All sidewalk replacement must meet ADA requirements.
4. Expansion material shall be bituminous fiber material or as approved by the Engineer.
5. Contractor shall saw and remove barrier curb. If rollover curb exists, contractor may match back of curb or saw and replace rollover curb.
6. Sidewalk shall be located 5 ft. behind the curb on new construction; or where appropriate to match existing conditions.
7. Driveway must be paved from street pavement to property line (or to existing sidewalk); with 3000# Portland Cement concrete.
8. A permit is required for making new curb opening and work on Right-of-Way.

RESIDENTIAL DRIVEWAY STANDARD

The City of Enid
 401 West Owen K. Garriott Road
 Enid, Oklahoma 73702
 Telephone: (580) 234-0400 Fax: (580) 234-8846

CITY OF ENID OKLAHOMA

REVISIONS	Number	Date	Description

Project Number: PS - 8
 Project Location: ENID, OKLAHOMA

Sheet Title: RESIDENTIAL DRIVEWAY STANDARD
 Project Title: CONCRETE DRIVEWAY STANDARD

Engr. Seal:
 LICENSED PROFESSIONAL ENGINEER
 MURALI KM KATTA
 25852
 OKLAHOMA

Date: JULY 2020
 Scale: None
 H:\STDS\STREETS\DRIVEWAYS.DWG
 Drawn By: SY
 Designed By: SY
 Approved By: MK
 Sheet: