

CITY OF ENID ENID, OKLAHOMA

SANITARY SEWER MASTER PLAN



SEPTEMBER 2008

TABLE OF CONTENTS

EXECUTIVE SUMMARY i - xx

TECHNICAL MEMORANDUM NO. 1:

EVALUATION OF THE EXISTING WATER POLLUTION CONTROL FACILITY

Introduction 1-1
 Study Area..... 1-1
 Planning Horizon 1-2
 Population Projections 1-3
 Land Use Map..... 1-4
 Wastewater Characteristics 1-4
 Industrial Discharges and Pretreatment..... 1-8
 Design Information for the Plan year 1-10
 Effluent Discharge Limitations 1-11
 Existing Wastewater Treatment Facility Overview 1-11
 Evaluation of Existing Treatment Plant and Condition Assessment..... 1-14

TECHNICAL MEMORANDUM NO. 2:

EVALUATION OF THE EXISTING COLLECTION SYSTEM AND RECOMMENDED IMPROVEMENTS

Introduction 2-1
 Existing Collection System..... 2-1
 Flow Metering and Analysis 2-2
 Adequacy of Existing System 2-7
 Future Collection System Evaluation..... 2-11
 Conclusions..... 2-14

TECHNICAL MEMORANDUM NO. 3:

WASTEWATER TREATMENT SYSTEM ALTERNATIVES

Development Needs 3-1
 Description of Alternatives 3-1
 Evaluation Methodology 3-3
 Process Alternatives 3-4
 Preferred Alternatives 3-5
 Recommended Alternative..... 3-8

APPENDICES

Appendix TM 1-1 Raw Data from Facility Records
 Appendix TM 1-2 Information about Industries
 Appendix TM 1-3 City of Enid OPDES Permit
 Appendix TM 1-4 Template for Condition Rating
 Appendix TM 1-5 Nitrification Clarifier (Traveling Bridge) Operational Issues
 Appendix TM 2-1 Flow Meters
 Appendix TM 2-2 Sanitary Sewer Inflows
 Appendix TM 2-3 Sub-basin Calculations
 Appendix TM 2-4 Storm Events
 Appendix TM 2-5 I/I Calculations
 Appendix TM 2-6 SWMM Model and Output

Appendix TM 2-7	February 2007 – Evaluation of Sanitary Sewer Pipeline Extension for the Oklahoma Ethanol Plant
Appendix TM 3-1	Cost Analysis Worksheets

LIST OF TABLES

Table TM 1-1	Population Projection
Table TM 1-2	Developed Area within the City
Table TM 1-3	Per Capita Wastewater Generation Rate
Table TM 1-4	Historical Flow Peaking Data
Table TM 1-5	Influent Wastewater Quality
Table TM 1-6	Influent Loading Data for BOD ₅ , TSS and Ammonia
Table TM 1-7	Significant Industrial Users Information
Table TM 1-8	Wastewater Flow Projection for Year 2030
Table TM 1-9	OPDES Effluent Discharge Limitations
Table TM 1-10	Summary of Major Liquid Process Treatment Units and their Sizes
Table TM 1-11	Summary of Major Solids Handling Units
Table TM 1-12	Summary of Treatment Capacity and Condition of Major Liquid Process Treatment Units
Table TM 1-13	Treatment Capacity Summary
Table TM 2-1	Summary of Stations not Included in the Model Comparison
Table TM 2-2	Comparison of Modeled Values vs Actual Recorded Values for Dry Flow Conditions
Table TM 2-3	Summary of Monitoring Point Infiltration Values
Table TM 2-4	Pipelines and Associated Flow Data and Capacities
Table TM 2-5	Capital Improvement Summary
Table TM 3-1	Top Selected Options for Detailed Analysis
Table TM 3-2	Summary of Capital and Operations and Maintenance Cost
Table TM 3-3	Summary of Present Worth Cost
Table TM 3-4	Capital Construction Cost for Recommended Alternative, Option 3B

LIST OF FIGURES

Figure TM 1-1	Enid Location Map
Figure TM 1-2	Sanitary Sewer Collection System Basin
Figure TM 1-3	2025 Land Use Map
Figure TM 1-4	Influent Wastewater Flow
Figure TM 1-5	Site Plan – Enid Wastewater Treatment Facility
Figure TM 1-6	Liquid Process Treatment Units – Current Process
Figure TM 1-7	Current Operation of Solids Handling facility
Figure TM 1-8	Proposed Improvements to Solids Handling Facility
Figure TM 2-1	Sanitary Sewer Basins Schematic
Figure TM 2-2	Sanitary Sewer Monitoring Locations
Figure TM 2-3	High Inflow and Infiltration Basins
Figure TM 2-4	Sanitary Sewer Investigation Schematic
Figure TM 2-5	Capital Improvement Map
Figure TM 3-1	Option 1A: 14 MGD Conventional Activated Sludge Treatment System
Figure TM 3-2	Option 1B: 14 MGD Sequencing Batch Reactor (SBR) System
Figure TM 3-3	Option 3A: 12 MGD Conventional Activated Sludge Treatment System Expanded to 14 MGD
Figure TM 3-4	Option 3B: 12 MGD Sequencing Batch Reactor (SBR) System with Expansion to 14 MGD

Figure TM 3-5	Option 4A: Using Existing Treatment Facility and Building a new 7 MGD Conventional Activated Sludge Treatment System with Expansion to 14 MGD
Figure TM 3-6	Option 4B: Using Existing Treatment Facility and Building a new 7 MGD Sequencing Batch Reactor (SBR) System with Expansion to 14 MGD
Figure TM 3-7	Site Plan for Future Expansion

INTRODUCTION

The City of Enid is located in the north central part of Oklahoma in the Garfield County along the eastern edge of the Great Plains. Growth of industries in and around the City of Enid plays a vital role in the employment and economic development of Enid. The expansion and construction of two major industries as well as additional population growth resulting from these expansions has prompted the City of Enid to evaluate its existing sanitary sewer collection and treatment system and develop a Sanitary Sewer Master Plan to make the improvements to its existing sanitary sewer collection and treatment system.

PSA-Dewberry and its consulting engineer ENVIROTECH was retained to provide engineering services required to complete a master plan for the City of Enid sanitary sewer water collection and treatment system. The purpose of the master plan was to evaluate the existing system, project the future needs, and provide the improvement plan over the planning horizon. The master plan was developed through three major tasks which culminated in following Technical Memoranda:

- TM 1: Evaluation of the Existing Water Pollution Control Facility (WPCF)
- TM 2: Evaluation of the Existing Collection System and Recommended Improvements
- TM 3: Wastewater Treatment System Alternatives and Recommended Improvements

The following sections provide a summary of the above technical memoranda, including the capital improvement plan for the recommended improvements.

PLANNING HORIZON

The planning period or planning horizon is the time span over which the sanitary sewer collection and treatment facility needs are forecasted. Therefore, proposed facilities are planned to meet the system's needs projected over the planning timeframe. Most utility master plans are prepared for medium-term planning horizons, which range from 20 to 25 years. This period is based on the longest term in which reasonable detailed forecasts for growth and capacity can be made. For this master plan the planning horizon of 25 years has been chosen. Future wastewater loads and flows will be projected for the design year 2030.

POPULATION PROJECTIONS

Our review of the available population and community development data indicated that the City's recent population is relatively stable. For population projection, this report uses 0.005 rule adopted by Enid Vision 2025 Committee. The rule 0.005 assumes straight line growth compounded at one-half of one (0.5) percent per year. This is a reasonable assumption based on the recent trend in population growth and is not likely to change unless there are any significant shifts in the City's economic market sectors. The projection for the year 2030 based on this rule is 54,638 whereas the Oklahoma Department of Commerce projection for the same year is 50,860. This report will use the population figure of 54,638 for flow projections and wastewater facility expansions.

LAND USE

Land use map for the Enid Metropolitan area is shown in the City of Enid Metropolitan Area Comprehensive Plan 2025. Enid Metropolitan area includes area within the City limits as well as outside. Most of the land outside the City limits is designated as agricultural land. The developed and undeveloped

area within the City limits as of July 2002 as shown in the Enid Metropolitan Area Comprehensive Plan is tabulated below in **Table ES 1-1**.

Table ES 1-1: Developed Area within the City			
Land use	Total Area (acre)	Developed (acre)	Undeveloped (acre)
Residential	10,595	6,707	3,888
Commercial	2,186	1,400	786
Industrial	3,678	1,127	2,551
Agricultural	10,916	384	10,532
Special use	1,352	811	541

For the industrial land development calculations, it is more prudent to use the employment growth rate than the population growth. As per the U.S. Census Bureau information, the work force in the City of Enid has grown from 19,100 to 20,680, equivalent to 0.84% annual growth between the year 1990 and 2000. Assuming 1% employment growth rate, in the design year 2030 there will be a 30% aggregate industrial growth. However as the nature of the new industries and their water consumption and wastewater production rates are highly variable, this report assumes development of all undeveloped area within industrial land use category (100% development). This allows for conservative projection of industrial flows and provides flexibility in allowing diverse nature of industries within the City.

WASTEWATER CHARACTERISTICS AND PLANT FLOW PROJECTION

It is important to determine the flow rates and understand the nature of wastewater in order to evaluate the existing wastewater treatment facility and propose alternative treatment technologies appropriate for the City of Enid. The wastewater treatment facility plant records were evaluated to determine the historic loadings for flow, organic, suspended solids, and ammonia nitrogen. This information was then used along with population projections, land use and future industrial users information to determine the design loadings.

Flow Analysis

Plant flow records for the years 1996 through 2004 were obtained from the plant operations staff. Daily average wastewater flows (DAF) have fluctuated for the past nine years with the years 1999 and 2003 being the highest at 9.44 MGD and lowest with 5.91 MGD, respectively. Wastewater flows (DAF) for the past nine years have averaged 6.92 MGD with a standard deviation of 1.02 MGD.

The total per capita wastewater generation rate (GPCD) have fluctuated for the past nine years with the years 1999 and 2003 being the highest at 209 GPCD and lowest with 127 GPCD, respectively. The per capita wastewater generation rate for the past nine years has averaged 151 GPCD.

Our review of the available population and community development data indicated that the City's population tends to be relatively stable and there has been a steady reduction in the wastewater flow rate over the past five (5) years. The review of the existing documents indicate that the City has studied the effect of infiltration and inflow (I/I) on its collection system and implemented an aggressive program to

significantly reduce those flows. If these I/I control strategies continue to be implemented, the DAF to the facility and per capita generation rate should stabilize and may actually decrease. Since the City's implementation program to correct I/I in the collection system (years 2000 to present) the per capita flow have decreased and stabilized at an average of 133 GPCD. Therefore, for the purposes of this study, the average per capita wastewater generation rate of 130 GPCD has been assumed in addition to any anticipated future industrial flows.

It is also important to determine the peaking factors for the influent wastewater. Peaking factors are used to determine the size of the various treatment processes. Our review of historical flow data related to peaking factors for the total service area revealed that the average peaking factors for the maximum month and maximum day for the past nine (9) years are 1.14 and 1.51, respectively. For the purposes of this report, the peaking factor used for maximum month and maximum day are 1.25 and 2.0, respectively.

The City of Enid has eleven (11) major institutions/hospitals or industries within its drainage boundary. Their combined average flow discharge to the City's collection system is about 0.726 MGD at an average Five Day Biochemical Oxygen Demand (BOD₅) concentration of 645 mg/l and Total Suspended Solids (TSS) of 389 mg/l. Land use map for the City of Enid for the year 2025 classifies about 3,678 acres of land for industrial development. Currently, existing industries occupied 1,127 acres of land leaving approximately 2,551 acres for future industrial development. Non-domestic wastewater flow rates from industrial sources vary with the type and size of industry, the degree of water reuse, and onsite wastewater treatment methods, if any. Typical design values for estimating the flows from industrial areas that have no or little wet-process type industries are 1,000-1,500 gal/acre-day for light industrial developments. Typical design values for medium industrial developments are 1,500 to 3,000 gal/acre-day. Currently, average wastewater contribution from the existing industries is estimated to be 643 gal/acre-day. As the natures of future industries are unknown, this report assumes a design value of 1,200 gal/acre.day for future industrial flow projection.

Conversations with City of Enid staff have indicated that one of the existing industries, Advance Food is planning to expand in 2007. The City also anticipates the establishment of two new Ethanol plants in the area. Expansion of Advance Food industry will likely discharge an additional flow of 0.5 mgd at 664 mg/l BOD₅ and 382 mg/l TSS by year 2007. The proposed discharges from new Ethanol plants are expected to be 0.144 MGD and 0.15 MGD respectively at the concentration of 1,000 mg/l BOD₅ and 350 mg/l TSS in the year 2008.

Analysis of wastewater characteristics

The City conducts extensive measurements of influent wastewater quality prior to the existing WPCF. These influent quality parameters include Five Day Biochemical Oxygen Demand (BOD₅), Total Suspended Solids (TSS), Ammonia (NH₃), Dissolved Oxygen (DO), and Total Alkalinity. The influent wastewater quality data reveals that the average per capita BOD₅ in the past nine (9) years is 0.30 lbs per capita per day. The per capita BOD₅ loading for domestic wastewater is typically in the range of 0.18 to 0.26 pounds (lb) of BOD₅ per capita per day. This suggests that there is significant BOD₅ loading from industrial sources.

The per capita suspended solids and total kjeldahl nitrogen (TKN) loadings for domestic wastewater are typically in the range of 0.20 to 0.33 and 0.022 to 0.044 lbs per capita per day, respectively. The influent data for the past nine (9) years reveals that the average per capita loadings of suspended solids and ammonia nitrogen in influent wastewater are 0.314 and 0.019 lbs per capita per day, respectively. The suspended solids and nitrogen loading in the influent wastewater are within suggested normal range.

The BOD5 concentration for an equivalent flow of 130 GPCD and a BOD5 loading of 0.302 lb per capita per day equates to 278 mg/l. The suspended solids concentration for the same flow at per capita solids loading of 0.314 lb per capita per day is 289 mg/l. The ammonia nitrogen concentration for the equivalent flow of 130 GPCD at 0.019 lb per capita per day equates to 17 mg/l.

Based on the analysis of influent loadings as presented above, this master plan will use the concentrations of BOD5, TSS and ammonia nitrogen as 300 mg/l, 300 mg/l and 25 mg/l respectively for the purpose of evaluating possible treatment alternatives.

Wastewater Flow Projection for Year 2030

Based on an analysis of the flow information presented above and the additional anticipated growth, the design information that will be used for evaluation of treatment alternatives is summarized in **Table ES 1-2.**

TABLE ES 1-2: Wastewater Flow Projection for Year 2030	
Estimated Population	54,638
Design Per Capita for Wastewater Generation	130 GPCD
Domestic Wastewater Flow	7.10 MGD
Industrial Flow	
Advance Food Plant Expansion	0.50 MGD
Ethanol Plant (OE)	0.15 MGD
Ethanol Plant (Orion)	0.15 MGD
From Future Industrial Growth (2551 acres @ 1200 gpd/acres)	3.06 MGD
	3.86 MGD
Average Daily Wastewater Flow	10.96 MGD
Maximum Month Flow (factor 1.25)	14.00 MGD
Peak Daily Flow (factor 2.0)	28.00 MGD
Influent BOD5	300 mg/l
Influent TSS	300 mg/l
Influent NH4-N	25 mg/l

EFFLUENT DISCHARGE LIMITATIONS

The Oklahoma Department of Environmental Quality (ODEQ) has issued an OPDES permit to the City of Enid on August 1, 2003. The current discharge permit will expire on July 31, 2008. The OPDES permit is based on a plant design flow of 8.5 MGD and allows the treatment facility to discharge the effluent through two outfalls into Boggy Creek.

EXISTING WASTEWATER TREATMENT EVALUATION

The City of Enid Wastewater Treatment Facility began its operation in 1954 with an initial capacity of 3.5 MGD conventional activated sludge plant, known as South Plant. In 1970, the City of Enid expanded its treatment facility to 8.50 MGD by building another 5.0 MGD conventional activated sludge plant known

as North Plant to the north of the existing 3.5 MGD South Plant. In 1991, the City of Enid built a 8.50 MGD Tertiary Treatment Plant for the removal of ammonia nitrogen from the effluent produced from the North and South Plants. The 1991 plant improvements also included upgrading of the existing sludge processing facilities. With the series of improvements described above, the existing wastewater treatment plant has a designed capacity of 8.50 MGD.

Plant Headworks

The plant headworks consist of two aerated grit chambers, two screen channels, a parshall flume and a lift station. The headwork units are designed for a peak flow of 21 MGD and split the flow to the North and South plants. The available capacities of individual treatment units are evaluated based on the current ODEQ regulations and standard design criteria and are presented in **Table ES 1-3**. In general, all units in the headworks appear to be in poor conditions. Some of the units like bar screen and parshall flume do not meet current design criteria. The plant headworks may require either major rehabilitation or replacement to meet the proposed flows in future.

South Plant

The South Plant was constructed in 1954 and consists of two primary sedimentation tanks, two aeration tanks, two secondary sedimentation tanks and other associated appurtenances such as air diffusers, blowers, sludge pumps, etc. The available capacities of individual treatment units are evaluated based on the current ODEQ regulations and standard design criteria and are presented in **Table ES 1-3**.

The Plant has operated well beyond its life expectancy without significant maintenance and improvements performed to its treatment units and equipment. The current improvements to the South Plant undertaken by the City of Enid are very critical to handle the current flow as well as industrial growth expected in near future and will extend the life of this plant for few more years before it is replaced.

North Plant

The North Plant was constructed in 1970 and consists of two primary clarifiers, two aeration tanks, two secondary clarifiers and other associated appurtenances such as air diffusers, blowers, sludge pumps, etc. The available capacities of individual treatment units are evaluated based on the current ODEQ regulations and standard design criteria and are presented in **Table ES 1-3**.

In regard to the condition of the North Plant, this facility was constructed in 1970 and has been in operation for over 30 years. The Plant is currently operating well even though it is operated well over its rated capacity (4.62 MGD). With some structural repairs to the walls of the primary clarifiers and the ongoing maintenance program for replacing worn out parts. The North Plant could have a useful life of another 10 to 15 years without major significant improvements.

Nitrification Plant

The Nitrification Plant was built in the year 1991 and was designed to treat 8.5 MGD of secondary treated effluent from the North and South Plants for the removal of ammonia nitrogen. The Nitrification Plant consist of a nitrification basin, four rectangular clarifiers and other associated appurtenances such as lime and methanol feeders, disc aerators, sludge pumping etc.

Table ES 1-3 Summary of Treatment Capacity and Condition of Major Liquid Process Treatment Units

Unit Process	No. of units	Design Capacity		Treatment Capacity, per ODEQ criteria		Condition Rating
		Ave. MGD	Peak MGD	Ave. MGD	Peak MGD	Peak MGD
Headworks						
Grit chamber	2	-	21.0	-	21.0	Poor
Bar screen	2	-	21.0	-	17.0	Poor
Parshall flume	1	-	21.0	-	15.9	Poor
Lift station (two 75 HP & two 100 HP)	-	-	21.0	-	21.0	Poor
North Plant						
Primary clarifiers	2	5.0	-	5.0	-	Fair
Aeration basins	2	5.0	-	4.66	-	Fair
Final clarifiers	2	5.0	-	4.62	9.24	Fair
South Plant						
Primary sedimentation tank	2	3.5	-	3.5	-	Fair
Aeration basins	2	3.5	-	3.23	-	Fair
Secondary sedimentation tank	2	3.5	-	3.5	7.0	Fair
Nitrification Plant						
Nitrification basins	1	8.5	-	8.5	-	Good
Nitrification clarifiers	4	8.5	-	8.5	-	Good

Based on the above evaluation, the Nitrification Plant can handle the average daily flow of 8.5 MGD as designed. However, conversations with plant personnel have revealed that solids carry over occur when the plant flow exceeds 7 MGD. They also have experienced problems with the operation of the traveling bridge on the nitrification clarifiers, especially during snow and ice periods. The Nitrification Plant, in overall, needs some improvements to correct all operational problems.

Solids Handling Units

The solids handling facility at the City of Enid originally consists of two anaerobic digesters, two aerobic digesters, two thickeners, two one-meter belt presses, and forty (40) sludge drying beds (total drying bed area 68,700 square foot). These sludge handling units were constructed at different times, some in 1956, some in 1978 and the rest in 1991.

Due to the age and deterioration of many existing solids process units, the bio-solids treatment system at the treatment facility was in jeopardy of becoming non-complaint. Therefore, the City of Enid made major improvements to its bio-solids treatment system in 2006. The improvements to the bio-solids treatment system included selective demolition and improvements to the existing aerobic digesters and equipment, selective demolition and converting the existing anaerobic digesters to aerobic digesters and equipment, new blower facility, modification to the existing blower facility, a new 2 meter belt filter press

and dewatered sludge conveyors, improvements to the filter press feed pump system, polymer dosing system, flow measurement equipments, controls, yard piping, electrical and instrumentation work, and other appurtenances. With the completion of these improvements, the solids handling capacity of the treatment facility will increase to about 15,490 pounds/ day on dry solids basis which is equivalent to solids produced from treating wastewater flow of about 10 MGD at the exiting liquid process treatment units.

EVALUATION OF EXISTING COLLECTION SYSTEM AND RECOMMENDED IMPROVEMENTS

Existing Collection System

The City of Enid sanitary sewer collection system for the study area is hydraulically divided into two watersheds, Watershed No. 1 and Watershed No. 2. Watershed No. 1 contains sixteen (16) collection basins which have been designated (1A) through (1P). Watershed No.2 contains eleven (11) collection basins which have been designated (2A) through (2K). All discharges in to the city collection system are conveyed to the City Water Pollution Control Facility located in the extreme southeast corner of the City.

A total of eleven (11) pump stations and force mains are located on the City of Enid's sanitary sewer collection system. Of the eleven (11) pump stations, only the pump station located at 541 South 54th Street appears on the model. The remaining pump stations either exist outside the mapped parameters of the City of Enid's sanitary sewer basins or are located far upstream and utilized for isolated residential districts and therefore, these pump stations are inconsequential to the system.

A total of three (3) modeled wet weather peak holding facilities are located in the City of Enid. The first holding facility is located at 658 West Willow on the 1-O line and a second facility is located at 1901 East Randolph on the 1-C line. Both facilities were modeled as a 500,000-gal. facilities with appropriate control structures. The third holding facility is located at the City of Enid's sanitary sewer treatment plant for wet weather overflow. The sanitary sewer department estimates the volume of this holding basin to be approximately 280-ac-ft.

Flow Metering and Analysis

For the determination of inflow and infiltration (I/I) in to the collection system, Flo Tote sanitary sewer monitoring devices were utilized to measure the flow at strategic locations throughout the City of Enid for both dry and wet weather conditions. The flow meters were initially placed on trunk and secondary trunk lines. As flow information was assimilated, the flow meters were relocated to tertiary lines that were suspected sources of inflow and infiltration.

The flow-monitoring program provided both dry and wet weather flows. Each meter remained in-place until the line experienced a significant wet weather flow before being relocated to isolate the suspected sources of inflow and infiltration. This data was utilized in conjunction with a hydraulic model to predict sanitary sewer flows throughout the City of Enid. In addition, the City of Enid provided the daily sanitary sewer treatment rates (i.e., amount of treated sewage from all sources) which are on file at the City of Enid's 54th Street treatment facility. For the project's duration, the facility treated an average of 6.8 MGD of sanitary sewage.

The City of Enid's sanitary sewer system was modeled utilizing the United States Environmental Protection Agency Sanitary Water Management Model (USEPA SWMM) (version 5.0.011), based on sanitary sewer collection system data and calculated dry flow usage rates provided by the City of Enid.

Following completion of the SWMM model, the model was calibrated utilizing flow documentation recorded by the Flo Tote sanitary sewer monitoring devices.

Adequacy of Existing System

An analysis of the SWMM model pipeline was conducted to identify problem areas during both dry and wet weather flow conditions. Although the current system is old, it is in a fairly well-preserved condition. Much of the system continues to receive less than 200-gal./pipe dia./mi./day of infiltration. With the exception of a few isolated lines, infiltration exceeds 200-gal./pipe dia./mi./day by relatively small amounts. Additional sanitary sewer investigations will assist in decreasing the amount of inflow and infiltration into the system. However, some upgrades are necessary in the immediate future to accommodate wet flows and new industrial flows as the City of Enid develops.

Dry Flow Condition Analysis:

During periods of no precipitation, Line 1 Basin A (1A) and Line 1 Basin P (1P) pipes appear to be flowing at or near capacity and therefore, the City of Enid intends to construct an additional pipeline adjacent to the current 1P pipe for increased flow capacity. Although the 1A pipeline performs at or above capacity during dry flow conditions, plans should be implemented to increase this pipeline's capacity as well.

There is some confusion regarding the 1N pipeline that extends toward North Enid. Two (2) lines converge in the vicinity of the 1N008 manhole, but neither City of Enid nor ENVIROTECH engineers could determine the exact path of the sanitary sewer manholes. In the current model set-up, the manhole connecting the two (2) branches of the 1N pipeline surcharges during dry flow conditions.

The 1N pipeline in the vicinity of North Van Buren receives inordinately high flow rates for the businesses and residents served in the area. This pipeline was recently upgraded to accommodate these higher flow rates. Although an additional investigation may help identify the source of these flows, the new pipeline can adequately manage these higher flow rates.

The 1-J pipeline trunk line flows above capacity during dry periods. Both the 1-J and 1-K Basins feed this pipeline. Plans should be made to increase the capacity of this pipeline.

Wet Flow Condition Analysis:

During precipitation events, flows in the sanitary sewer pipelines greatly increase due to Inflow and Infiltration (I/I). According to the wet condition model, the capacity of most pipelines is sufficient to accommodate the increased flow rates. However, flow back-ups occur in the 1A and 2A pipelines due to sanitary sewer treatment plant and pipeline capacity limitations associated with the additional flows. Due to the increased flows, additional back-ups will also occur in lower portions of the 1B, 1D, and 2B pipelines.

The 1N pipeline appears to experience additional surcharging during storm events in addition to the surcharging experienced during dry events. In addition, the 1-J pipeline remains surcharged for extended periods during wet events due to increased flow.

Inadequacies in the Existing System:

Currently, the City of Enid's sanitary sewer collection system experiences an annual peak dry flow of approximately 7-MGD. Several collection basins exhibit the need for investigation, rehabilitation, or increased capacity.

Currently, the 12-in. trunk line serving the 1P Basin is operating at capacity and therefore, system expansion should be considered to allow for continued growth in east Enid. Therefore, we recommend construction of a second, minimum 24-in.-dia. pipeline adjacent to the existing 12 in. dia. pipeline. This upgrade will accommodate flows from both the new Advanced Foods facility and Ethanol plants. The cost for this upgrade will be approximately \$2.5 million.

The City of Enid has experienced overflow events in the 1A and 2A pipelines near the WPCF at Boggy Creek. Based on both the physical evidence and SWMM modeled flows, this trend will continue to occur and therefore, construction of a peak flow holding tank appears to be the most effective solution. Although additional study and design is necessary, we recommend utilizing the old sanitary sewer treatment facility as an appropriate site. The overflow tank's capacity should be approximately 800,000-gal. and the cost is estimated to be \$1.5 million.

The 1-J pipeline flows above capacity during dry periods and remains surcharged for long periods during wet events. Therefore, ENVIROTECH recommends that an investigation of the I/I sources utilizing smoke testing, door-to-door surveys, and video monitoring, where appropriate, be conducted. In addition, the pipe capacity needs to be expanded and may include a few small pipe and manhole replacements to the entire pipeline replacement. Based on the results of the I/I study, this project will cost between \$100,000 and \$600,000.

Basin 2H receives little inflow during small storm events and exceedingly high amounts of inflow during large events. Since the pipeline is located near a stormwater channel, a possibility exists that the line is receiving inflow from the channel. Therefore, we recommend that a more detailed I/I study be conducted in this basin to include smoke testing and video monitoring, where appropriate.

The exact configuration of Basin 1N near the confluence with the 24-in. cross-town main is not known. In addition, the 1N basin receives high amounts of inflow during storm events. Therefore, we recommend that a more detailed investigation of the 1N basin be conducted to include smoke testing, door-to-door surveys, and video monitoring, where appropriate.

Basins 2G and 2K receive higher than EPA recommended rates of infiltration. Therefore, we recommend conducting additional sanitary sewer inflow and infiltration investigations in these basins to include smoke testing and video monitoring, where appropriate.

Future Collection System Evaluation

Recent trends in the City of Enid's expansion efforts reflect growth to the east, northwest and west, with each direction of growth representing a different type of development. Industry in east Enid has expanded as a result of construction of the Advanced Foods Processing Plant and the proposed Ethanol production facilities. Residential development is steadily expanding northwest of Enid while a combination of commercial and residential development dominates westward expansion along Owen K. Garriott Road. As a result of this growth, recommendations for expanding the affected sanitary sewer basins are summarized in the following sections of this report.

Hydraulic Capacity Evaluation - Year 2010 (9-MG)

Basins 2H and 2K Expansion Recommendations: Residential expansion northwest of Enid poses minimal short-term problems regarding the sanitary sewer system's capacity. Although Basins 2H and 2K have not yet reached total flow volume capacity, additional residential growth may require system expansion in the future. Expansion recommendations for Basins 2H and 2K are as follows:

BASIN 2H. Since several collection lines will eventually reach capacity, alternative collection lines may be required to service the expanding community. The 12-in. line that services Sub-basin 2H-2 will most likely reach capacity and subsequently, the 18-, 21-, 24- and 27-in. collection pipelines will also near capacity. In addition, some of these lines may require improvement. The cost to upgrade the 12-in. pipeline alone is estimated to be \$500,000. Additional upgrades to the 18- and 21-in. collection pipelines will cost approximately \$1.3 million.

BASIN 2K. The 12-in. collection line that services Basin 2K and flows north-south down Cleveland Road will eventually reach capacity. This will subsequently affect the same 24- and 27-in. collection lines referenced above for Basin 2H, resulting in surcharging and backup in the pipelines. Depending upon peak flow rates, the 30-in. Frantz Street line may also require improvement. The cost to upgrade the 12-in. pipeline is estimated to be \$1.3 million. Additional upgrades to the 24- and 27-in. pipelines will cost approximately \$1.8 million. The cost to improve the 30-in. Frantz Street pipeline is estimated between \$2 million and \$7 million, depending on the extent of pipeline replacement required.

Basin 2G Expansion Recommendations. Continued commercial and residential growth westward along Owen K. Garriott Road may be impeded by the existing sanitary sewer system that services this area. Currently, the Basin 2 pipeline that transverses the southern portion of the City has sufficient capacity to easily accommodate expansion both west and northwest of Enid. However, once the pipelines reach Oakwood Road, the sizes decrease to 12- and 8-in.-dia. beyond Bob's Farm residential development. Therefore, it is recommended that the pipeline network capacity be expanded from the Bob's Farm complex westward along Oakwood Road to accommodate additional growth. This can be accomplished by either expanding the 12-in. pipeline that services Bob's Farm further west, or installing a second 12-in. pipeline westward on the north side of Owen K. Garriott Road. The cost to complete this work is estimated to be \$800,000. In addition, the 12- and 18-in. collection pipelines that service the Bob's Farm pipeline will require improvement. The cost to upgrade the 12- and 18-in. collection pipelines is estimated to be \$2 million.

Hydraulic Capacity Evaluation - Year 2015 (11-MGD)

In the event the City of Enid continues to develop/expand and flows increase to 11-MGD, several of the main lines will begin to back-up and flows will push into residential lines. Most lines above 18-in.-dia., including some select lines below 18-in.-dia., will require upgrading to accommodate the increased flows. Alternatively, additional collection lines paralleling existing lines would be required to alleviate the increased flows.

These upgrades represent improvements that must be made to the system in addition to those already summarized above.

Sanitary Sewer Main Expansion: Several sanitary sewer mains that transverse the City will experience increased flows and therefore, many will need to be replaced and include (a) 1A and 2A main lines south

of the City; (b) north-south 36-in. main from 11TH Street to Van Buren and Willow; (c) Frantz Street 30-in. cross-town main; and (d) 2D line servicing Vance Air Force Base (VAFB). The cost for this expansion is estimated to be in the \$20 million range.

The secondary collection pipelines that will require improvements are as follows:

The Oakwood pipeline will require an additional \$1 million expansion north of Owen K. Garriott Road.

The north-south 36-in. main will require that a collection pipe be extended to the north along Van Buren. This line will most likely require construction of an additional pump station and therefore, the expansion will cost approximately \$2.5 million.

The 1N pipeline will require improvement, both east and north, at an approximate cost of \$2 million.

The Basin 2D 10-in. pipeline that services southeast Van Buren will require improvement at an approximate cost of \$2 million.

Although additional flows north of Basin 1C will burden the existing pipelines, they should maintain below full-capacity.

Peak Storage Basins: As a result of high flow rates, the occurrence of stormwater seepage will be significant and therefore, construction of two (2) additional stormwater peak storage basins should be considered. One (1) tank should be located on south Cleveland Road where the Oakwood and Cleveland sanitary sewer systems converge; and the second tank should be located where the 2D and 2A pipelines merge. Each facility should detain approximately 800,000- to 1-million-gal. Estimated Cost to Construct Both Facilities will be \$4 million.

WASTEWATER TREATMENT SYSTEM ALTERNATIVES AND RECOMMENDED IMPROVEMENTS

The wastewater treatment system alternatives are developed based on the needs identified during the analysis and evaluation of previous reports and facility plans, the inspection and evaluation of the existing units and facilities at the Water Pollution Control Facility, and interviews/meetings with City personnel.

Description of Alternatives

The alternatives are developed with the objective of meeting the projected design capacity of the WPCF for the year 2030 is 14 MGD. The projected design capacity for the years 2010, 2015 and 2020 will be 9.00 MGD and 10.50 MGD and 12.00 MGD, respectively. The above projection include domestic flows from projected population, future flows from the expansion of Advance Foods, two new Ethanol Plants and other industries which are unknown at this time. The options for Plant expansions will be phased in stages that provide flexibility during expansion. The alternatives were developed based on the premise that the existing WPCF with the exception of bio-solids processing facility will be decommissioned either in 2010 or in 2020 after utilizing its useful life. The existing renovated sludge processing facility capable of processing the sludge generated from a 10 MGD wastewater treatment facility will be expanded to 14 MGD as and when necessary based on the plant capacity of the given alternative. The alternatives considered are as follows:

Option 1: New 14 MGD treatment facility

This Option consists of building a new 14 MGD treatment plant by in the year 2010 that would cater to the projected ultimate flow for 2030. The bio-solids processing facility would be expanded from the current capacity of 10 MGD to 14 MGD in the year 2020.

Option 2: New 14 MGD treatment facility with an ability to treat industrial wastes directly without pretreatment

This Option consists of building a new 14 MGD treatment plant to treat wastewater with a high organic loading. This Option was developed with the purpose of receiving the industrial wastes within the City without significant pretreatment. Option 2 is identical to Option 1 with the exception of its design to treat the high strength wastewater. Under this Option, the existing bio-solids processing facility will be upgraded immediately as a result of increased bio-solids production from the high strength wastewater.

Option 3: New 12 MGD treatment facility with expansion to 14 MGD

This Option consists of building a new 12 MGD treatment plant in the year 2010 and expanding to 14 MGD in the year 2020 to meet the projected ultimate flow. The expansion to 14 MGD and upgrading of the existing bio-solids processing facility will occur in year 2020.

Option 4: Using existing treatment facility and building a new 7 MGD treatment facility with expansion to 14 MGD

This Option consists of building a new treatment plant in two stages, 7 MGD treatment facility in the year 2010 and expanding it to 14 MGD in the year 2020. Building a first stage 7 MGD plant will allow for the replacement of existing headworks and South Plant. The second stage expansion to 14 MGD plant will allow for the replacement of existing North Plant and BNR Plant.

Option 5: New 9 MGD treatment facility for domestic flows and a separate new 5 MGD treatment facility for industrial flows

This Option consists of building two new treatment plants at two different sites, the first, a new 9 MGD treatment facility in the year 2010 for treating domestic flows and a second a 5 MGD treatment facility in the year 2010 for treating industrial flows.

Option 6: New 9 MGD treatment facility for domestic flows and a separate new 2.5 MGD treatment facility for industrial flows with expansion to 5 MGD

This Option is similar to Option 5 except that the 5 MGD treatment facility for industrial flows is expanded in two stages of 2.5 MGD (2.5 MGD each, in the year 2010 and 2020 respectively) treatment capacity each.

Evaluation of Alternatives

The Options developed in the previous sections were presented to the City staff and after discussions on each of these Options, the following three (3) Options to proceed further with detailed analysis.

TABLE ES 1-4: Top Selected Options for Detailed Analysis.

Option	Description
1	New 14 MGD treatment facility
3	New 12 MGD treatment facility with expansion to 14 MGD
4	Using existing treatment facility and building new 7 MGD treatment facility with expansion to 14 MGD

Each of the selected Options in **Table ES 1-4** were further divided into two Options based on the two chosen process types namely, conventional activated sludge process and sequential batch reactor process, and analyzed in detail for capital and operation and maintenance costs. Process selection is very important step in the design of wastewater treatment plant as it provides an opportunity to implement the treatment system that suits local environmental conditions, construction and operation costs, energy considerations, operator’s skills, process flexibility, etc. In this study, a conventional activated sludge process and sequential batch reactor process were considered and the top three selected options were expanded to six alternatives, each Option using two different processes, conventional activated sludge and sequencing batch reactor processes. These Options are as follows.

Option 1A: New 14 MGD treatment facility using conventional activated sludge process

This process is a two stage treatment process, first stage for BOD removal and the second stage for the removal of ammonia. The Option is designed to handle the projected ultimate design flow of 14 MGD, and replaces the existing WPCF facility in totality with the exception of the biosolids processing facility.

Option 1B: New 14 MGD treatment facility using sequencing batch reactor process

The designed capacity of this plant is the same as Option 1A except it uses SBR process. The BOD and ammonia removal are accomplished in several steps using the same basin/tank.

Option 3A: New 12 MGD treatment facility using conventional activated sludge process with expansion to 14 MGD

This Option uses conventional activated sludge process. The preliminary treatment unit consisting of screen, grit removal, parshall flume and lift station, primary clarifier and UV disinfection system are designed for an ultimate design flow of 14 MGD and the remaining treatment units are designed for 12 MGD with the Option to expand to 14 MGD in the year 2020. This Option also replaces the existing WPCF facility in totality with the exception of bio-solids processing facility.

Option 3B: New 12 MGD treatment facility using sequencing batch reactor process with expansion to 14 MGD

The designed capacities and expansion phasing of this Option is the same as Option 3A except it uses SBR process.

Option 4A: Using the existing treatment facility and building a new 7 MGD treatment facility using conventional activated sludge process with expansion to 14 MGD

This Option uses conventional activated sludge process. The preliminary treatment unit consisting of screen, grit removal, parshall flume and lift station, and UV disinfection system are designed for ultimate design flow of 14 MGD and the remaining treatment units are designed for 7 MGD with the Option to expand to them to 14 MGD in the year 2020. This Option will still use the North Plant until 2020. As a result it will require some rehabilitation work to existing primary and secondary clarifiers in the North Plant and construction of new nitrification clarifiers at existing BNR system.

Option 4B Using the existing treatment facility and building a new 7 MGD treatment facility using sequencing batch reactor process with expansion to 14 MGD

The designed capacities and expansion phasing of this Option is the same as Option 3A except it uses SBR process.

Summary of capital cost and operation and maintenance cost for each of the above six Options is shown in **Table ES 1-5**.

TABLE ES 1-5: Summary of capital and operation and maintenance cost

OPTION	DESCRIPTION	CAPITAL COST		O & M COST	
		2010	2020	2010 - 2020	2020 - 2030
1A	14 MGD New Plant Conventional Activated Sludge Process	\$ 48,316,100	\$ 4,935,100	\$ 1,717,680	\$ 1,888,480
1B	14 MGD New Plant SBR Process	\$ 46,580,700	\$ 4,935,100	\$ 1,442,030	\$ 1,612,830
3A	12 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 42,796,500	\$ 11,077,500	\$ 1,514,290	\$ 1,888,480
3B	12 MGD New Plant SBR Process W/ Expansion to 14 MGD	\$ 42,121,600	\$ 9,430,200	\$ 1,289,790	\$ 1,612,830
4A	Using Existing Treatment Facility and building new 7 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 33,039,300	\$ 26,421,000	\$ 1,627,910	\$ 1,888,480
4B	Using Existing Treatment Facility and building new 7 MGD New Plant SBR Process W/Expansion to 14 MGD	\$ 31,930,500	\$ 24,026,400	\$ 1,577,340	\$ 1,612,830

From the capital and operations costs listed in **Table ES 1-5**, the Present Worth Cost for each Option was calculated. A summary of the Present Worth Costs can be seen below in **Table ES 1-6**. The following assumptions were used in the Present Worth Cost Analysis.

1. Present Worth Analysis was performed for the year 2006
2. Evaluation period used is 20 years, between years 2010 and 2030
3. Capital costs were expected to occur in two stages, year 2010 and 2020. Capital cost for the year 2020 includes additional expansion to meet the ultimate condition.
4. Annual operations and maintenance costs were divided in to two time periods, one for the period 2010-2020 and the other for the period 2020-2030 as the expansion at 2020 would increase the operation and maintenance cost.
5. Inflation factor of 4.5% per year was used for Present worth Analysis.

TABLE ES 1-6: Summary of present worth cost

Option	Description	Present Worth Cost
1 A	14 MGD New Plant Conventional Activated Sludge Process	\$ 62,646,975
1 B	14 MGD New Plant SBR Process	\$ 58,184,959
3 A	12 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 59,985,628
3 B	12 MGD New Plant SBR Process W/ Expansion To 14 MGD	\$ 55,862,804
4 A	Using Existing Treatment Facility and Building a 7 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 60,842,593
4 B	Using Existing Treatment Facility and Building a 7 MGD New Plant SBR Process W/ Expansion To 14 MGD	\$ 57,106,473

Normally the recommended alternative selection is based upon the Present Worth Cost Analysis described and summarized above. The Present Worth Cost information presented in **Table ES 1-6**, worth indicates that Option 3B has the lowest present worth cost among all of the alternatives evaluated. Therefore it is recommended that Option 3B be considered by the City of Enid for implementation. This Option is discussed in more detail in the following section.

Recommended Alternative

The recommendations below are based on an extensive evaluation of the existing treatment units and the introduction of new treatment concepts. During this evaluation, the basis for selection was the cost

effectiveness of the system process. Generally, the alternative with the lowest present worth cost was recommended. In this evaluation, *Option 3B* has the lowest present worth cost, and therefore fore it is recommended that *Option 3B* be considered by the City of Enid for implementation.

The proposed improvements under *Option 3B* will provide the City of Enid Water Pollution Control Facility with the following attributes:

- Replaces the existing WPCF facility in totality with the exception of the bio-solids processing facility;
- Less / no disruption to current plant operations while new facility is being built;
- Improved effluent quality;
- Elimination of primary, secondary clarifiers and return sludge recirculation, elimination of short circuiting;
- Ability to handle shock in hydraulic and organic loading;
- Ability to remove nutrients;
- Easy to expand and replicate the additional reactors;
- Less land requirements than other processes.

The improvements recommended under *Option 3B* consist of expanding the plant in two stages as follows:

Improvements at 2010:

- New headworks including screening, grit removal and flow measurement to handle ultimate peak flow of 28 MGD;
- New low lift pump station to handle ultimate peak flow of 28 MGD;
- SBR reactors to treat an average daily flow of 12 MGD;
- New sludge holding basins;
- Disinfection system;
- Effluent flow measurement structure;
- Influent/effluent outfall; site work, piping, electrical, instrumentation & controls;
- Decommissioning of the existing WPCF facility in totality except bio-solids processing facility.

Improvements at 2020:

- One additional SBR reactor to increase the design capacity of the SBR reactors from 12 MGD to 14 MGD of average daily flow;
- Expanding the capacity of the existing bio-solids processing facility from 10 MGD to 14 MGD by building two new aerobic digesters and additional dewatering system consisting of belt press, polymer dosing system, sludge conveyor, etc.;
- Sitework, piping, electrical, instrumentation & controls.

The approximate capital construction cost to build all recommended improvements has been estimated to be \$42,121,600 and \$9,430,200 for the years 2010 and 2020, respectively. **Table ES 1-7** shows the breakdown of these estimated capital costs for the recommended improvements. The estimated construction costs are based on August 2006, Engineering News Record (ENR) construction cost index (7722).

TABLE ES 1-7: Capital construction cost for recommended alternative, Option 3B

Unit Description	Capital Construction Cost	
	2010	2020
Mobilization	\$ 773,900	\$ 224,800
Sitework	\$ 2,220,600	\$ 680,600
Headworks		
Screening	\$ 510,400	-
Grit Removal	\$ 783,100	-
Parshall Flume	\$ 240,500	-
Low Lift Pump Station	\$ 1,383,900	-
SBR Reactors	\$ 16,590,200	\$ 2,370,100
Sludge Holding Basins	\$ 1,174,100	-
Disinfection System	\$ 1,975,300	-
Aerobic Digesters	-	\$ 1,295,800
Dewatering System	-	\$ 1,200,300
Electrical	\$ 2,251,500	\$ 608,800
Instrumentation & Controls	\$ 1,187,700	\$ 293,600
Piping	\$ 2,560,000	\$ 580,000
Influent / Effluent outfall	\$ 750,000	-
SUB TOTAL	\$ 32,401,200	\$ 7,254,000
Non-Construction Cost (15%)	\$ 4,860,200	\$ 1,088,100
Contingency (15%)	\$ 4,860,200	\$ 1,088,100
TOTAL	\$ 42,121,600	\$ 9,430,200

The annual operation and maintenance cost for the years 2010-2020 and 2020-2030 are \$1,289,790 and \$1,612,830 respectively.

SUMMARY OF RECOMMENDED IMPROVEMENTS

To guide the City of Enid in implementation of recommended improvements, the phasing and cost for recommended improvements are summarized and is shown in **Table ES 1-8**. The improvements shown are based on the evaluation of the existing system and the projected future needs. As with any master plan, as the city grows and the needs change, the master plan should be continually updated to accommodate such changes.

TABLE ES 1-8: Summary of recommended improvements

IMPROVEMENT DESCRIPTION	ESTIMATED COST INVESTMENTS			
	2007	2010	2015	2020
Wastewater Treatment System Improvements				
Construction of new 12 MGD wastewater treatment system		\$ 42,121,600		
Expansion to 14 MGD				\$ 9,430,200
Wastewater Collection System Improvements				
Basin 1P Expansions				
Construction of new 24-inch line	\$ 2,500,000			
Basin 1A and 2A Peak Holding Tank				
Peak holding tank, 800,000 gallon	\$ 1,500,000			
Basin 1J and 1K Expansions	\$ 300,000			
Basin 2H and 2K Expansions				
Basin 2H - 12 inch line upgrade		\$ 500,000		
Basin 2H - 18 and 21 inch line upgrade		\$ 1,300,000		
Basin 2K - 12 inch line upgrade		\$ 1,300,000		
Basin 2K - 24 and 27 inch upgrade		\$ 1,800,000		
Basin 2K - 30 inch Frantz Street pipeline		\$ 4,000,000		
Basin 2G Expansions				
12 inch line westward on north of Owen K. Garriot Road		\$ 800,000		
12 and 18 inch line upgrade - Bob's Farm		\$ 2,000,000		
Sanitary Sewer Main Expansion			\$ 20,000,000	
1A and 2A main lines south of City				
North-south 36-in. main (11TH Street to Van Buren & Willow)				
Frantz Street 30-inch cross-town main				
2D line servicing Vance Air Force Base (VAFB).				
Sanitary Sewer Collection Mains				
Oakwood pipeline			\$ 1,000,000	
North-south 36-inch extension (along Van Buren)			\$ 2,500,000	
1N pipeline improvement			\$ 2,000,000	
Basin 2D 10-inch pipe improvement (southeast of Van Buren)			\$ 2,000,000	
Peak Storage Basins				
South Cleveland Road			\$ 2,000,000	
At 2D and 2A pipeline merge			\$ 2,000,000	

EVALUATION OF THE EXISTING WATER POLLUTION CONTROL FACILITY

INTRODUCTION

The purpose of this technical memorandum is to summarize the work efforts performed in connection with the evaluation of the existing City of Enid Water Pollution Control Facility (WPCF). This technical memorandum will also serve as a basis for the development of treatment alternatives during this study. The specific components of this technical memorandum include a review of the plant records, an analysis of wastewater flows and its characteristics, limitations on the effluent discharges and evaluation of existing liquid treatment and sludge treatment units.


In preparation for this task, previous documents were reviewed for background information and they are listed below:

- Facility Plan Wastewater Collection and Treatment System, Eagle Consultants, Inc., April 2000
- Wastewater Facility Plan for Bio-Solids System, Dewberry, April 2004
- Enid Metropolitan Area Comprehensive Plan, Enid Vision 2025 Committee, April 2005
- Sanitary Sewer Collection System Study – Final Report Phase III and IV, Wilson & Company, July 1990
- Inflow and Infiltration Program: 1990-1993 – Summary Report, Envirotech Services, Inc., August 1993
- Sanitary Sewer System Master Plan, City of Enid Engineering Department, January 1996
- Year 2000 Flow Monitoring Report, Rowe Porterfield, LLC, July 2000
- Chapter 656. Water Pollution Control Facility Construction Standards, Oklahoma Department of Environmental Quality, 2001.

STUDY AREA

The City of Enid is located in the north central part of Oklahoma in the Garfield County along the eastern edge of the Great Plains as seen in **Figure TM 1-1**. The study area consists of the incorporated limits of the City of Enid and those unincorporated areas that drain or utilize the City's sanitary sewer collection system. The sanitary sewer collection system for the study area is hydraulically divided into two watersheds, Watershed No. 1 and Watershed No. 2. Watershed No. 1 contains sixteen collection basins

Figure TM 1-1: Enid Location Map



which have been designated (1A) through (1P). Watershed No.2 contains eleven collection basins which have been designated (2A) through (2K). The location and boundaries of the 27 collection basins are illustrated on the basin location map presented in **Figure TM 1-2**. All discharges in to the city collection system are conveyed to the City Water Pollution Control Facility located in the extreme southeast corner of the City.

The topography of the study area varies from gently rolling to flat prairie. Drainage ways regularly dissect the level prairie at approximately mile intervals. The predominant drainage direction is from northwest to southeast. The major streams in the county generally have wide floodplains of up to 2 miles. The elevation in the County varies between 1300 feet to 1100 feet mean sea level.

The area's climate is sub-humid, continental and temperate with well defined seasons. The winter is cool to cold with average temperatures ranging from 50° F and 29° F for winter daily average and daily minimum, respectively, and a record low of -20° F. Likewise, the area's climate is hot in the summer with average temperatures ranging from 94° F and 70° F for summer daily average and daily minimum, respectively, and a record high of 118° F.

Average rainfall for the area is 29-inches and average snowfall is 8-inches. Rainfall is fairly constant throughout the year with 70 percent coming from April through September. The prevailing wind direction is from the south during the March to November time period with a significant northerly shift during the winter months. The highest monthly average is 13 mph during March and April. The yearly gross lake evaporation rate for the study area is 62-inches per year.

PLANNING HORIZON

The planning period or planning horizon is the time span over which the wastewater facility needs are forecasted. Therefore, proposed facilities are planned to meet the system's needs projected over the planning timeframe and the alternative's costs are amortized over this planning horizon which is typically referred to as the facility's life. Thus, the planning horizon is used as a method of equalization of the

Legend

- 1P BASIN DESIGNATION
- BASIN BOUNDARY




FIGURE TM 1-2: SANITARY SEWER COLLECTION SYSTEM BASIN

various alternatives. It should be noted, the term "life" does not imply the useful life of the project, which is typically greater than the planning horizon.

Most utility master plans are prepared for medium-term planning horizons, which range from 20 to 25 years. This period is based on the longest term in which reasonable detailed forecasts for growth and capacity can be made. For this facility plan the planning horizon of 25 years has been chosen. Future wastewater loads and flows will be projected for the year 2030.

POPULATION PROJECTIONS

Our review of the available population and community development data indicated that the City's recent population is relatively stable. Population Projections were made utilizing the United States Census Bureau's data and growth rate used in Enid Metropolitan Area Comprehensive Plan 2000 – 2025. The projections were also compared with the Oklahoma Department of Commerce projections. The summary of this data is shown in **Table TM 1-1**.


Table TM 1-1 Population Projection						
Year	US Census Bureau Population		Oklahoma Department of Commerce Projections		Projection for this Master Plan	
	Population	Percent increase	Population	Percent increase	Population	Percent increase
1950	36,000					
1960	38,900	+ 0.81				
1970	44,986	+ 1.56				
1980	50,636	+ 1.26				
1990	45,309	- 1.06				
2000	47,045	+ 0.38				
2010			48,170	+ 0.24	49,451	+ 0.50
2020			49,640	+ 0.31	51,980	+0.50
2030			50,860	+ 0.25	54,638	+0.50

For population projection, this report uses 0.005 rule adopted by Enid Vision 2025 Committee. The rule 0.005 assumes straight line growth compounded at one-half of one percent per year. This is a reasonable assumption based on the recent trend in population growth and is not likely to change unless there are any significant shifts in the City's economic market sectors. The projection for the year 2030 based on this rule is 54,638 whereas the Oklahoma Department of Commerce projection for the same year is 50,860. This report will use the population figure of 54,638 for flow projections and wastewater facility expansions.

FIGURE TM 1-3
2025 LAND USE MAP
 Enid, Oklahoma

LAND USE CLASSIFICATIONS

- Public Institutions
- Police, Open Space & Recreation
- Low Intensity - Residential/Commercial
- Residential
- Commercial
- Medium Intensity - Commercial/Residential
- Community Commercial Node (CCN)
- Community Commercial Node (CCN)
- Community Commercial Node (CCN)
- Local Commercial
- Residential
- High Intensity - City Center/Industrial
- City Center
- Industrial
- COMMUNITY FACILITIES
- Park (Community/Secretary)
- Park
- Fire Station
- Other Public
- TRAFFICWAYS
- 100% of ADA (Front/Back/Drive)
- City Limits
- Proposed City Limits



© 2005 Enid, Oklahoma. All rights reserved. 2005 Edition map 1-10-05-000

LAND USE MAP

Land use map for the Enid Metropolitan area as shown in the City of Enid Metropolitan Area Comprehensive Plan 2025 can be seen in **Figure TM 1-3**. Enid Metropolitan area includes area within the City limits as well as outside. Most of the land outside the City limits is designated as agricultural land. The developed and undeveloped area within the City limits as on July 2002 as shown in Enid Metropolitan Area Comprehensive Plan is tabulated below in **Table TM 1-2**.

Table TM 1-2: Developed Area within the City as of July 2002			
Land use	Total area (acre)	Developed (acre)	Undeveloped (acre)
Residential	10,595	6,707	3,888
Commercial	2,186	1,401	786
Industrial	3,678	1,127	2,551
Agricultural	10,916	384	10,532
Special use	1,352	811	541

For the industrial land development calculations, it is more prudent to use the employment growth rate than the population growth. As per the U.S. Census Bureau information, the work force in the City of Enid has grown from 19,100 to 20,680, equivalent to 0.84% annual growth between the year 1990 and 2000. Assuming 1% employment growth rate, in the design year 2030 there will be 30% aggregate industrial growth. However as the nature of the new industries and their water consumption and wastewater production rates are highly variable, this report assumes development of all undeveloped area within industrial land use category (100% development). This allows for conservative projection of industrial flows and provides flexibility in allowing diverse nature of industries within the City.


WASTEWATER CHARACTERISTICS

It is important to determine the flow rates and understand the nature of wastewater in order to evaluate the existing wastewater treatment facility and propose alternative treatment technologies appropriate for the City of Enid. The wastewater treatment facility plant records were evaluated to determine the historic loadings for flow, organic, suspended solids, and ammonia nitrogen. This information was then used along with population projections, land use and future industrial users information to determine the design loadings.

Flow Analysis

Plant flow records for the years 1996 through 2004 were obtained from the plant operations staff (See **Appendix TM 1-1**). Daily average wastewater flows (DAF) have fluctuated for the past nine years with the years 1999 and 2003 being the highest at 9.44 MGD and lowest with 5.91 MGD, respectively. **Figure TM 1-4** shows the actual fluctuation. Wastewater flows (DAF) for the past nine years have averaged 6.92 MGD with a standard deviation of 1.02 MGD.

Figure TM 1-4: Influent Wastewater Flow (MGD)



The population of the service area for the years 1996 through 2004 and the per capita wastewater generation rate is shown in **Table TM 1-3**. The total per capita wastewater generation rate (GPCD) have fluctuated for the past nine years with the years 1999 and 2003 being the highest at 209 GPCD and lowest with 127 GPCD, respectively. The per capita wastewater generation rate for the past nine years has averaged 151 GPCD. It should be noted that this per capita wastewater generation rate includes residential, industrial and commercial wastewater as well as infiltration and inflow (I/I) into the collection system.

Our review of the available population and community development data indicated that the City's population tends to be relatively stable and there has been a steady reduction in the wastewater flow rate over the past five (5) years. The review of the existing documents indicate that the City has studied the effect of infiltration and inflow (I/I) on its collection system and implemented an aggressive program to significantly reduce those flows. If these I/I control strategies continue to be implemented, the DAF to the facility and per capita generation rate should stabilize and may actually decrease.

TABLE TM 1-3: Per Capita Wastewater Generation Rate			
Year	Total Service Population	Average Annual Flow (MGD)	Per capita flow rate (GPCD)
1996	45,320	6.264	138
1997	45,190	7.396	164
1998	45,250	7.937	175
1999	45,200	9.439	209
2000	47,045	6.804	145
2001	46,590	6.384	137
2002	46,530	6.015	129
2003	46,480	5.912	127
2004	46,630	6.121	131

The Oklahoma Department of Environmental Quality (ODEQ) construction standards indicate that new sewage systems shall be designed on the basis of an average daily per capita flow of sewage not less than 100 gpcd. The 100 gpcd is assumed to cover normal infiltration. However an additional allowance should be made if conditions are unfavorable. A total dry-weather base flow of 120 gpcd has been established by EPA as a historical average where infiltration is not excessive. This base flow includes 70 gpcd for domestic flows, 10 gpcd for commercial and small industrial flows, and 40 gpcd for infiltration.

Since the City's implementation program to correct I/I in the collection system (years 2000 to present), the per capita flow have decreased and stabilized at an average of 133 gpcd. Therefore, for the purposes of this study, the average per capita wastewater generation rate of 130 gpcd has been assumed in addition to any anticipated future industrial flows. Flows from existing industries, projections for industrial flows and impact of industrial discharges on the existing treatment facility are discussed separately in this report.

It is also important to determine the peaking factors for the influent wastewater. Peaking factors are used to determine the size of the various treatment processes. The historical flow data related to peaking factors for the total service area is presented in **Table TM 1-4**. It shows that the average peaking factors for the maximum month and maximum day for the past nine years are 1.14 and 1.51, respectively. However, this peaking factor may not be a true value, since during high flow conditions excess flow is conveyed to the equalization basin, and latter processed through the plant, when flows resumed to normal. For the purposes of this report, the peaking factor used for maximum month and maximum day are 1.25 and 2.0, respectively.

TABLE TM 1-4: Historical Flow Peaking Data					
Year	Average Annual Flow (MGD)	Maximum Month Flow (MGD)	Maximum Day Flow (MGD)	Maximum Month Factor	Maximum Day Factor
1996	6.264	7.064	11.922	1.13	1.90
1997	7.396	7.866	8.846	1.06	1.20
1998	7.937	9.637	14.724	1.21	1.86
1999	9.439	12.780	15.407	1.35	1.63
2000	6.804	8.207	11.387	1.21	1.67
2001	6.384	7.250	8.362	1.14	1.31
2002	6.015	6.358	8.887	1.06	1.48
2003	5.912	6.401	7.380	1.08	1.25
2004	6.121	6.400	7.800	1.05	1.27

Analysis of wastewater characteristics

Presently, the City conducts extensive measurements of influent wastewater prior to the existing WPCF. Influent pollutant concentrations for the past nine (9) years are shown in **Table TM 1-5** and include the following pollutants Five Day Biochemical Oxygen Demand (BOD₅), Total Suspended Solids (TSS), Ammonia (NH₃), Dissolved Oxygen (DO), and Total Alkalinity. The mean and standard deviation are also shown.

TABLE TM 1-5: Influent Wastewater Quality					
Year	Influent BOD ₅ (mg/l)	Influent TSS (mg/l)	Influent NH ₃ (mg/l)	Influent DO (mg/l)	Influent Alkalinity (mg/l)
1996	333	274	15.8	2.3	368
1997	245	257	14.6	1.2	359
1998	222	261	12.8	1.1	356
1999	196	227	11.1	1.0	354
2000	206	222	15.9	1.1	357
2001	268	283	16.7	-	-
2002	230	254	17.4	-	-
2003	220	248	18.3	-	-
2004	271	234	17.5	1.3	359
Mean	243	251	15.6	1.3	359
Stan. Dev	42	21	2.4	0.5	5

Historical loading data for BOD₅, suspended solids and ammonia nitrogen for the last nine years and the equivalent per capita contribution of each is shown in **Table TM 1-6**. The per capita BOD₅ loading is typically in the range of 0.18 to 0.26 pounds (lb) of BOD₅ per capita per day (Metcalf & Eddy). The influent loading data reveals that the average per capita BOD₅ in the past 9 years is 0.30 lbs per capita per day which suggests that there is significant BOD₅ loading from industrial sources.

The per capita suspended solids and total kjeldahl nitrogen (TKN) loadings are typically in the range of 0.20 to 0.33 and 0.022 to 0.044 lbs per capita per day, respectively (Metcalf & Eddy). The average per capita loadings of suspended solids and ammonia nitrogen in influent wastewater are 0.314 and 0.019 lbs per capita per day, respectively. The suspended solids and nitrogen loading in the influent wastewater are within suggested normal range.

The BOD₅ concentration for an equivalent flow of 130 gpcd and a BOD₅ loading of 0.302 lb per capita per day equates to 278 mg/l. The suspended solids concentration for the same flow at per capita solids loading of 0.314 lb per capita per day is 289 mg/l. The ammonia nitrogen concentration for the equivalent flow of 130 gpcd at 0.019 lb per capita per day equates to 17 mg/l.

TABLE TM 1-6: Influent Loading Data for Organic(BOD), Solids and Ammonia Nitrogen

Year	BOD ₅		TSS		NH ₃	
	lb/d	lb/d/capita	lb/d	lb/d/capita	lb/d	lb/d/capita
1996	17,397	0.384	14,314	0.316	825	0.018
1997	15,112	0.334	15,852	0.351	901	0.020
1998	14,695	0.325	17,277	0.382	847	0.019
1999	15,429	0.341	17,870	0.395	874	0.019
2000	11,690	0.248	12,597	0.268	902	0.019
2001	14,269	0.306	15,058	0.323	888	0.019
2002	11,538	0.248	12,742	0.274	871	0.019
2003	10,847	0.233	12,228	0.263	902	0.019
2004	13,834	0.297	11,945	0.256	892	0.019
Mean	13,868	0.302	14,443	0.314	878	0.019

Based on the analysis of influent loadings as presented above, this facility plan will use the concentrations of BOD₅, TSS and ammonia nitrogen as 300 mg/l, 300 mg/l and 25 mg/l respectively for the purpose of evaluating possible treatment alternatives.

INDUSTRIAL DISCHARGES AND PRETREATMENT

Growth of industries in and around the City of Enid plays a vital role in the employment and economic development of Enid. Enid Metropolitan and Comprehensive Plan 2000-2025 has established polices for future land use patterns such as residential, manufacturing/industrial uses, commercial, recreational and mixed uses. For the purpose of this report, the land use map of the Enid Metropolitan and Comprehensive Plan 2000-2025 will serve as a basis for projection of industrial flows.

The City of Enid has eleven major institutions/hospitals or industries within its drainage boundary. Their combined average flow discharge to the City's collection system is about 0.726 MGD at an average BOD₅ concentration of 645 mg/l and TSS of 389 mg/l. The individual flows and wastewater characteristics for each industry are summarized in **Table TM 1-7**.

TABLE TM 1-7: SIGNIFICANT INDUSTRIAL USERS INFORMATION						
No.	Industrial User	Avg Daily Flow (MGD)	Average BOD₅		Average TSS	
			mg/l	lbs/d	mg/l	lbs/d
1	INTEGRIS HOSPITAL	0.052	294	127.5	99	42.9
2	LANDFILL LEACHATE	0.028	59	13.8	315	73.6
3	CHEM-CAN	0.010	5,040	420.3	159	13.3
4	BROADWAY TEXACO	0.004	10	0.3	8	0.3
5	ADVANCE-E WILLOW	0.030	661	165.4	144	36.0
6	ADVANCE-RALEIGH RD	0.274	838	1,915.0	499	1,140.3
7	ADVANCE-PINE ST	0.079	1,172	772.2	1,047	689.8
8	ST MARY'S HOSPITAL	0.069	373	214.6	226	130.1
9	VANCE AFB	0.171	173	246.7	151	215.3
10	SEABOARD FARMS	0.005	642	26.8	254	10.6
11	RED CARPET LANDFILL	0.004	77	2.6	20	0.7
TOTAL		0.726		3,905.2		2,352.8
Industrial Flow, Average:		0.726 MGD				
Composite BOD₅:		645 mg/l				
Composite TSS:		389 mg/l				

Although the existing industries contribute about 10% of the total flow to the City of Enid Water Pollution Control Facility, the amount of organic load they contribute is about 30% of the total loading contributed to the City's WPCF. This was the main reason that the per capita BOD₅ contribution based on the population equivalent as indicated earlier in this report was higher (0.30 lbs per capita per day) than typical ranges (0.18 to 0.26).

Industrial Pretreatment is a requirement of the Federal Clean Water Act for public wastewater treatment facilities treating over 5 MGD of wastewater. The Act is intended to protect sewerage facilities and worker's health, to prevent inhibition of the treatment processes and violations of surface water quality standards, and to maintain biosolids quality within USEPA's "Clean Sludge" criteria for trace metals. The City of Enid has an approved industrial pretreatment program that regulates the discharge of industrial users. The industrial pretreatment program has established local limits to certain pollutants like arsenic, cadmium, chromium, copper, lead, nickel, silver, zinc, mercury, cyanide, phenol & phenolic compounds pH, temperature and oil and grease. The City's industrial pretreatment program has not established any specific limit for oxygen-demanding pollutants (BOD₅). However, it prohibits discharge of any pollutants including oxygen -demanding pollutants (BOD₅) released in a discharge rate and/or pollutant concentration which will cause interference to the Publicly Owned Treatment Works (POTW). The City also reserves the right to increase the restrictions or to adopt more stringent limitations or requirements on industrial discharges that allows the City to protect its treatment system.

Land use map for the city of Enid for the year 2025 classifies about 3,678 acres of land for industrial development. Currently, existing industries occupied 1,127 acres of land leaving approximately 2,551 acres for future industrial development. Non-domestic wastewater flow rates from industrial sources vary

with the type and size of industry, the degree of water reuse, and onsite wastewater treatment methods, if any. Typical design values for estimating the flows from industrial areas that have no or little wet-process type industries are 1,000-1,500 gal/acre-day for light industrial developments. Typical design values for medium industrial developments are 1,500 to 3,000 gal/acre-day (Metcalf & Eddy). Currently, average wastewater contribution from the existing industries is estimated to be 643 gal/acre-day. As the nature of future industries are unknown, this report assumes a design value of 1,200 gal/acre.day for future industrial flow projection.

Conversations with City of Enid staff have indicated that one of the existing industries, Advance Food is planning to expand in 2007. The City also anticipates the establishment of two new Ethanol plants in the area. Expansion of Advance Food industry will likely discharge an additional flow of 0.5 mgd at 664 mg/l BOD5 and 382 mg/l TSS by year 2007. The proposed discharges from new Ethanol plants are expected to be 0.144 MGD and 0.15 MGD respectively at the concentration of 1,000 mg/l BOD5 and 350 mg/l TSS in the year 2008. As these industries are expected to go online soon, the impacts of these proposed discharges on the existing wastewater treatment units were reviewed and addressed to the City separately in a letter memorandum. A copy of which is enclosed in **Appendix TM 1-2**.

The industrial flow projected for the year 2030 is shown in **Table TM 1-8**. However, the organic loading from the industries varies significantly based on its manufacturing activity. As a result, the City may have to review the industries discharge loading with respect to the total wastewater plant loading and impose the limit on organic loading as and when necessary to protect its WPCF from any interference to its treatment process.

DESIGN INFORMATION FOR THE PLAN YEAR 2030

Based on an analysis of the flow information presented above and the additional anticipated growth, the design information that will be used for evaluation of treatment alternatives is summarized in **Table TM 1-8**.

Estimated Population	54,638
Design Per Capita for Wastewater Generation	130 gpcd
Domestic Wastewater Flow	7.10 mgd
Industrial Flow	
Advance Food Plant Expansion	0.50 mgd
Ethanol Plant (OE)	0.15 mgd
Ethanol Plant (Orion)	0.15 mgd
From Future Industrial Growth (2551 acres @ 1200 gpd/acres)	3.06 mgd
	3.86 mgd
Average Daily Wastewater Flow	10.96 mgd
Maximum Month Flow (factor 1.25)	14.00 mgd
Peak Daily Flow (factor 2.0)	28.00 mgd
Influent BOD5	300 mg/l
Influent TSS	300 mg/l
Influent NH4-N	25 mg/l

EFFLUENT DISCHARGE LIMITATIONS

The Oklahoma Department of Environmental Quality (ODEQ) has issued an Oklahoma Discharge Elimination System OPDES permit to the City of Enid on August 1, 2003. The current discharge permit will expire on July 31, 2008 (See **Appendix TM 1-3**). The OPDES permit is based on a plant design flow of 8.5 MGD and allows the treatment facility to discharge the effluent through two outfalls into Boggy Creek. **Table TM 1-9** below shows the OPDES effluent discharge limitations on various effluent parameters.

Table TM 1-9: OPDES Effluent discharge limitations						
Effluent characteristics	Outfall 002 only		Outfall 002 only		Outfall 001 and or Outfall 002	
	April – May		June – October		November – March	
	mg/l	Lbs/d	Mg/l	lbs/d	mg/l	lbs/d
CBOD ₅	20	1417.8	15	1063.4	20	1417.8
TSS	30	2126.7	30	2126.7	30	2126.7
NH ₃ -N	2	141.8	2	141.8	4.1	290.6
DO	6	-	5	-	5	-

*Outfall 001 and 002 are located west and east of the treatment facility respectively

The City of Enid is currently meeting the OPDES requirements with the existing treatment facility. It may be noted that the City of Enid has seasonal and stricter limitations on BOD₅ and NH₃-N during certain portions of the year. Therefore, it is anticipated that there may not be any change in effluent limitation in the near future and the evaluation of treatment alternatives will be based on the current discharge limitations. However, ongoing conversations with ODEQ will continue to ensure that future limits are considered in the final recommendation for the City of Enid WPCF expansion.

EXISTING WASTEWATER TREATMENT FACILITY OVERVIEW

The City of Enid Wastewater Treatment Facility began its operation in 1954 with an initial capacity of 3.5 MGD conventional activated sludge plant, known as South Plant. In 1970, the City of Enid expanded its treatment facility to 8.50 MGD by building another 5.0 MGD conventional activated sludge plant (North Plant) to the north of the existing 3.5 MGD South Plant. In 1991, the City of Enid built a 8.50 MGD Tertiary Treatment Plant for the removal of ammonia nitrogen from the effluent produced from the North and South Plants. The 1991 plant improvements also included upgrading of the existing sludge processing facilities. With the series of improvements described above, the existing wastewater treatment plant has a designed capacity of 8.50 MGD.

The City of Enid Water Pollution Control Facility is located in the Northwest quarter of section 14, Township 22 North, Range 6 west of the Indian Meridian, Garfield County, Oklahoma. The treatment facility is positioned between the East Market Avenue and Boggy Creek. A site plan showing the actual

location of the process treatment units is shown in **Figure TM 1-5**. The process flow diagram showing the current operation of the individual treatment units is shown in **Figure TM 1-6**.

Existing Liquid Process Treatment Units

The wastewater generated in the City of Enid reaches the existing wastewater treatment facility through a 36-inch reinforced concrete pipe (RCP) gravity main from the west, a 33-inch RCP gravity main from the north and an 8-inch force main from the east. Flows in excess of the Treatment Facility capacity overflow in to an existing 10 million gallon storm water holding basin. Influent wastewater from the 36-inch and 33 gravity sewer mains and 8-inch sewer force main are combined in a manhole west of the treatment facility and conveyed to the plant headworks by gravity.

The plant headworks consist of two aerated grit chambers, two screen channels, a parshall flume and a low lift pump station. Record information obtained from the City, revealed that the headwork units were designed for a peak flow of 21 MGD. Sizes of the individual units are shown in **Table TM 1-10**. Wastewater influent first passes through the grit chambers where the inorganic grit materials are removed. The forward flow from the grit chambers enters the bar screen for the removal of floating and other larger objects. One of the bar screen is mechanically cleaned with clear spacing of 1 inch and the other is a manually cleaned with clear bar spacing of 3 inches. The screened wastewater flows through an 18-inch throat width Parshall flume which measures the influent flow to the treatment plant. The forward flow from the parshall flume enters the low lift pump station wet well where influent is split and pumped to the North and South Plants for primary and secondary treatment. The raw sewage low lift pump station is equipped with two 75 HP and two 100 HP centrifugal pumps.

The South Plant is a conventional activated sludge treatment plant which has a treatment capacity of 3.5 MGD. The South Plant consist of two primary sedimentation tanks, two aeration tanks, two secondary sedimentation tanks and other associated appurtenances such as air diffusers, blowers, sludge pumps, etc. Sizes of the major individual units are shown in **Table TM 1-10**. The wastewater from the headworks low lift pump station flows through the primary sedimentation tanks for the removal of suspended solids. Following the primary clarification, the wastewater flows in to the conventional activated sludge aeration basins. Sufficient air is provided to the aeration basins through coarse bubble diffusers by centrifugal blowers. The treated effluent from the aeration basin flows through the secondary sedimentation tanks for solids separation. The clear treated effluent which overflows from the sedimentation tanks is conveyed to the low lift station. The settled solids from the secondary sedimentation tanks are returned to the aeration basins for maintaining desired level of mixed liquor suspended solids (MLSS). The excess sludge is pumped to the bio-solids processing facility for bio-solids stabilization and dewatering.

The North Plant is designed for an average flow of 5.0 MGD and uses conventional activated sludge process. The North Plant consists of two primary clarifiers, two aeration tanks, two secondary clarifiers and other associated appurtenances such as air diffusers, blowers, sludge pumps, etc. Sizes of the major individual units are shown in the **Table TM 1-10**. The influent from the headworks low lift pump station flows through the primary clarifiers for the removal of suspended solids. Following the primary clarification, the wastewater flows in to the conventional activated sludge aeration basins. Sufficient air is provided to the aeration basins through coarse bubble diffusers by the centrifugal blowers. The treated effluent from the aeration basin is conveyed to the secondary clarifiers for solids separation and the clear supernatant flows to the low lift station. Solids separated from the secondary clarifiers are recirculated back to the aeration basins and the excess solids are pumped to the bio-solids processing facility for bio-solids stabilization and dewatering.




FIGURE TM 1-5: SITE PLAN - ENID WASTEWATER TREATMENT FACILITY




FIGURE TM 1-6: LIQUID PROCESS TREATMENT UNITS - CURRENT PROCESS

The secondary treated effluent from the North and South Plants flows to a low lift pump station from where it is pumped to the nitrification plant for removal of ammonia nitrogen and effluent polishing. The low lift pump station is equipped with a total of four (4) pumps, one driven by a 75Hp, another by a 60HP motor and the remaining pumps each by a 30HP motor. The low lift pump station has a firm pumping capacity of about 25.3 MGD. The low lift pump station also has bypass arrangements with necessary piping and valves to discharge the secondary treated effluent directly to Outfall 001 west of the existing treatment plant, during the permitted seasonal period.

Table TM 1-10 Summary of the major liquid process treatments units and their sizes							
Unit process	No. of Units	Size of each unit				Design Capacity	
		Length, Ft	Width, ft	Dia., Ft	SWD, ft	Ave. MGD	Peak MGD
<u>Headworks</u>							
Grit chamber	2	20	10	-	10	-	21
Bar screen	2	-	5	-	6	-	21
Parshall flume	1	-	1.5	-	-	-	21
Lift pump station (two 75 HP & two 100 HP)	-	-	-	-	-	-	21
<u>North Plant</u>							
Primary clarifiers	2	-	-	65	8.5	5	-
Aeration basins	2	360	18	-	15	5	-
Final clarifiers	2	-	-	70	10.5	5	-
<u>South Plant</u>							
Primary sedimentation tank	2	72	27	-	11	3.5	-
Aeration basins	2	150	29	-	15.5	3.5	-
Secondary sedimentation tank	2	97	30	-	7.5	3.5	-
<u>Nitrification Plant(BNR)</u>							
Nitrification basins	1	-	-	-	12	8.5	-
Nitrification clarifiers	4	120	30	-	12	8.5	-

The nitrification plant was designed to treat 8.5 MGD of secondary treated effluent from the North and South Plants for the removal of ammonia nitrogen. The nitrification plant consist of a nitrification basin, four rectangular clarifiers and other associated appurtenances such as lime feeders, disc aerators, sludge pumping, etc. The nitrification basin is an oxidation ditch facility with three concentric channels equipped with disc aerators. The nitrified effluent from the nitrification basin flows to the four rectangular clarifies where solids are separated and the effluent is conveyed to the Farm Land lift pump station and to the existing outfall structure where the final effluent is disinfected and discharged to Boggy Creek through Outfall 002. The outfall structure has a 24-inch wide Parshall flume and sonic flow meter for recording flow discharges. The Farmland Industry lift pump station, located ahead of the outfall structure, conveys the final treated effluent to the Farm Land Industries for reuse.

Existing Solids Handling Units

The bio-solids (sludge) generated at the City of Enid Water Pollution Control Facility comes from the primary sedimentation tanks / primary clarifiers, secondary sedimentation tanks / secondary clarifiers and nitrification clarifiers. Originally when the South and North Plants were commissioned, the sludge generated from the liquid treatment process were stabilized either anaerobically or aerobically in the digesters and dewatered in the sludge drying beds before they were hauled off to an approved land fill. In 1991, the City of Enid upgraded its solids processing facility by changing the existing mode of operation of solids handling with new additional equipment for solids handling. **Figure TM 1-7** illustrates the current operation of solids treatment facility.

The primary sludge from the primary clarifiers and biological sludge from the secondary clarifiers and nitrification clarifiers are thickened in the gravity belt thickener. The concentrated solids from the gravity belt thickener are stored in the anaerobic digesters where it is stabilized. The stabilized sludge is fed in to the belt filter press for dewatering. The dewatered sludge from the belt filter press is transported to an approved land fill for final disposal. **Table TM 1-11** shows the available solids handling units and their sizes.

Table TM 1-11 Summary of the major solids handling units		
Solid handling unit	No. of Units	Size and description
Anaerobic digesters	2	70 ft diameter and 24.25 ft WSD each
Aerobic digesters	2	65 ft diameter and 17 ft SWD each
Gravity belt thickeners	2	Aquabelt type 85-size II (Belt width 67.5")
Belt filter press	2	Ashbrook winklepress 1.0 m belt filter press
Sludge drying beds, south	12	Total bed area 29,700 sq.ft.
Sludge drying beds, north	28	Total bed area 39,000 sq.ft.

Data obtained from the plant records indicates that the amount of solids disposed to the landfill averages 7000 lb/day on dry basis (See **Appendix TM 1-1**). Assuming volatile suspended (VSS) solids concentration of 50% and VSS reduction of 40% in the digesters, the sludge generated at the plant averages 8,750 lb/day dry basis, which is equivalent to 1,265 pounds of sludge / MGD of flow. Typical sludge generation rate for an activated sludge plant with primary sedimentation ranges from 1,500 to 2,200 pounds of sludge / MGD of flow. The sludge production rate at the existing facility is slightly lower than typical suggested ranges, but this variation is not unusual as the solids production rate is influenced by many factors like the actual quantity of solids entering the plant, removal efficiencies of various processes, etc. However, this facility plan will use the sludge production rate of 1,500 pounds of sludge on dry basis/ day/MGD of flow for evaluation of treatment alternatives.

EVALUATION OF EXISTING TREATMENT PLANT AND CONDITION ASSESSMENT

As a part of the master planning process, it is important to evaluate the available capacity of each major treatment unit and its condition to address the deficiencies in the existing treatment system and plan for future expansions. For the purpose of the capacity evaluation, the current ODEQ criteria for the water pollution control facility construction have been used as a bench mark. The following paragraphs discuss the condition and available capacity of each treatment units.

Primary Clarifiers



Secondary Clarifiers




Tertiary Clarifiers




Polymer



Belt Thickeners




Anaerobic Digesters
Used As Holding Tanks



Belt Filter Press

Sludge
Drying Beds



Sludge for
Landfill
Disposal



Sludge for
Landfill
Disposal

FIGURE TM 1-7: CURRENT OPERATION OF SOLIDS HANDLING FACILITY

LIQUID PROCESS TREATMENT UNITS

As discussed in the previous section, the wastewater reaching the City of Enid Water Pollution Control Facility is treated in four stages which include preliminary treatment, primary treatment, secondary treatment and tertiary treatment.

Headworks

Preliminary treatment at the City of Enid Pollution Control facility consists of grit chamber and bar screen located in the Headworks. The grit chamber was constructed in 1954 and designed to handle a peak flow of 21 mgd. There is significant wear and tear on the grit chamber equipments. The bar screens were originally designed for a peak flow of 21 mgd but the maximum flow they can handle based on ODEQ design standards is 17 mgd. The clear open space between the bars in the manual cleaned bar screen is 3 inches which exceeds the ODEQ standard of 1.75 inches.

After the preliminary treatment, the influent flow is measured in the Parshall flume and is pumped to the North and South plants by the Low lift pump station. The Parshall flume has a throat width of 18 inches which has a recommended maximum flow of 15.9 MGD. Flows in excess of 15.9 MGD could result in submerged flow condition leading to inaccurate flow measurement. The headworks lift station is equipped with two 60 HP pumps and two 100 HP pumps and has a firm pumping capacity of 29.7 MGD. There appears to be some wear and deterioration on exposed surfaces of the low lift pump station and may require painting and water proof coating.

In general, all units in the headworks appear to be in poor conditions. Some of the units like bar screen and parshall flume do not meet current design criteria. The plant headworks may require either major rehabilitation or replacement to meet the proposed flows in future.

South Plant

Primary treatment and secondary treatment at the South plant consists of two primary sedimentation tanks, two aeration tanks, two secondary sedimentation tanks and other associated appurtenances such as air diffusers, blowers, sludge pumps, etc.

The primary sedimentation tanks are rectangular tanks of size 72 feet long by 27 feet wide and 11 feet side water depth (SWD) each and are equipped with traveling bridge mechanism for collection of sludge. There are no specific criteria in the ODEQ construction standards for primary sedimentation tanks. However, as per typical design criteria recommended in Metcalf & Eddy, the primary sedimentation tanks can handle an average design flow of 3.5 mgd. At the average design flow of 3.5 mgd, the overflow rate and detention time of each tank is 900 g/ft²/d and 2.2 hour, respectively which are within acceptable design ranges (Metcalf & Eddy).

The aeration basins are rectangular tanks of size 150 feet long, 29 feet wide and 15.5 feet SWD and are equipped with diffusers for oxygen distribution in to the basin. At the average design flow of 3.5 mgd, the organic loading rate, detention time and F/M ratio for each tank are 43 lbs of BOD₅/1000 ft³/d, 6.90 hours and 0.27, respectively. As per ODEQ design criteria, the allowable organic loading rate range for a conventional activated sludge process is 30 to 40 lbs of BOD₅/1000 ft³/d which restricts the treatment capacity of the aeration basins to an average flow of 3.23 mgd.

The secondary sedimentation tanks are rectangular tanks of size 97 feet long, 30 feet wide and 7.5 feet SWD each. The tanks are equipped with traveling bridge mechanism for collection of sludge. Based on the overflow rate recommended by the ODEQ design criteria of 600 g/ft²/d, the average flow that can be

handled by these tanks is 3.5 mgd. However the overflow rate at peak hourly flow shall not exceed 1,200 g/ft²/d which restrict the peak flow to the tanks to 7.0 mgd.

Based on the above evaluation, the average flow that the South Plant can handle based on current ODEQ standards is **3.23 mgd** due to the overloading of the organic load on the aeration basins. The overflow rate on the secondary sedimentation tanks will be a limiting factor on handling the peak hourly flow. Peak flows exceeding 7.0 mgd will overload the secondary sedimentation tanks on the South Plant and deteriorate the effluent quality. **Table TM 1-12** summarizes the capacity of each treatment unit as per current ODEQ design criteria. **Table TM 1-12** also summarizes current condition rating. A template of the facility condition rating protocol can be seen in **Appendix TM 1-4**.

In regards to the condition of the South Plant, this facility was built in 1954 and has been in operation for nearly 50 years before it was taken out of service few years ago. The plant has operated well beyond its life expectancy without any significant maintenance and improvements performed to its treatment units and equipment. The concrete walkways and gratings have also deteriorated to the point that staff safety around these structures could be compromised. Therefore, major improvements will be required to bring the South Plant back in to operation. This will include, but not limited to the installation of new pumps, valves, slide and sluice gates, pipe sections, replacing tracks at the primary and secondary clarifiers and other items. The work will also require the rewiring at the existing MCC's inside the building, including labels, alarm indicators and other miscellaneous items required to get the equipment running and provide the proper alarming and SCADA to the main Control Panel. The other item, which is of more concern, is the safety of plant personnel around these structures. As previously indicated, several walkways are in need of hand railing, most of the gratings are corroded and need replacing, specially the wooded grates around the aeration basins. The wood appeared to be deteriorated through the years and will need to be replaced to handle the proper load. The south gallery where most of the electrical controls and pumps are housed is also, in need of maintenance, including the replacement of flow meters and gauges. The piping inside the gallery appeared to be corroded and the original painting for the most part is flaking off and will need to be repainted. The ventilation system appeared to be working. However, it will need to be verified that it is designed to provide the proper ventilation or number of air changes per minute required under confined spaces to satisfy ODEQ standards. The concrete walkways are cracked and for the most deteriorated to the point that the gravel is exposed and peeling off from the concrete slab. These areas will require resurfacing with concrete products to re establish its original integrity.

The Plant has operated well beyond its life expectancy without significant maintenance and improvements performed to its treatment units and equipment. The current improvements to the South Plant undertaken by the City of Enid are very critical to handle the current flow as well as industrial growth expected in near future and will extend the life of this plant for some more years before it is replaced.

North Plant

Primary treatment and secondary treatment at the North Plant consists of two primary clarifiers, two aeration tanks, two secondary clarifiers and other associated appurtenances such as air diffusers, blowers, sludge pumps, etc. The North Plant was constructed in 1970. Most of the equipment/mechanical parts are in good condition due to regular maintenance. However, concrete structures for the primary clarifiers are showing hairline cracks that will need to be repaired to preserve their structural integrity.

Primary treatment in the North Plant is accomplished through two primary clarifiers of size 65 feet diameter and 8.5 feet SWD each. The primary clarifiers are equipped with circular clarifier mechanisms for scum and sludge removal. The concrete structures are water tight although the walls reflect hair line cracks primarily in the area where the effluent launders are connected. At an average design flow of 5.0 mgd, the overflow rate and detention time of each tank is 753 g/ft²/d and 2.0 hours, respectively which are within acceptable design ranges (Metcalf & Eddy).

Secondary treatment is provided in the aeration basins and secondary clarifiers. The aeration basins are rectangular tanks of size 360 feet long by 18 feet wide with 15 feet SWD. At the average design flow of 5.0 mgd, the organic loading rate, detention time and F/M ratio for each basin are 43 lbs of BOD₅/1000 ft³/d, 7.0 hours and 0.28, respectively. Based on ODEQ design criteria, the allowable organic loading rate range for a conventional activated sludge process is 30 to 40 lbs of BOD₅/1000 ft³/d, which restricts the treatment capacity of the aeration basins to an average flow of about 4.66 mgd.

The secondary clarifiers are circular tanks of diameter 70 feet and 10.5 feet SWD each. The average flow that can be handled by these tanks at the overflow rate recommended by the ODEQ design criteria of 600 g/ft²/d is **4.62 mgd**. The peak hourly flow that can be handled by the clarifiers at the overflow rate of 1,200 g/ft²/d recommended by ODEQ is 9.23 mgd.

Based on the above evaluation, the average flow that the North Plant can handle based on current ODEQ standards is **4.62 mgd** due the overloading of the secondary clarifiers. The overflow rate on the secondary clarifier is the limiting factor on handling the average and peak hourly flows. Flows exceeding 4.62 mgd (average) and 9.24 mgd (peak) will result in increased hydraulic loading on the secondary clarifiers and minimize the solids removal efficiency. **Table TM 1-12** summarizes the treatment capacity of each treatment units as per current ODEQ design criteria and current condition rating.

In regard to the condition of the North Plant, this facility was constructed in 1970 and has been in operation for over 30 years. The plant is currently operating well even though it is running well over its rated capacity (4.62 mgd). With some structural repairs to the walls of the primary clarifiers and the ongoing maintenance program for replacing worn out parts. The North Plant could have a useful life of another 10 to 15 years without major significant improvements.

Table TM 1-12 Summary of treatment capacity and condition of major liquid process treatment units

Unit process	No. of units	Design capacity		Treatment capacity, per ODEQ criteria		Condition rating
		Ave. MGD	Peak MGD	Ave. MGD	Peak MGD	Peak MGD
Headworks						
Grit chamber	2	-	21.0	-	21.0	Poor
Bar screen	2	-	21.0	-	17.0	Poor
Parshall flume	1	-	21.0	-	15.9	Poor
Lift station (two 75 HP & two 100 HP)	-	-	21.0	-	21.0	Poor
North Plant						
Primary clarifiers	2	5.0	-	5.0	-	Fair
Aeration basins	2	5.0	-	4.66	-	Fair
Final clarifiers	2	5.0	-	4.62	9.24	Fair
South Plant						
Primary sedimentation tank	2	3.5	-	3.5	-	Fair
Aeration basins	2	3.5	-	3.23	-	Fair
Secondary sedimentation tank	2	3.5	-	3.5	7.0	Fair
Nitrification Plant						
Nitrification basins	1	8.5	-	8.5	-	Good
Nitrification clarifiers	4	8.5	-	8.5	-	Good

Nitrification Plant (Biological Nutrient Removal – BNR)

The nitrification plant was built in 1991 and was designed to treat 8.5 MGD of secondary treated effluent from North and South Plants for the removal of ammonia nitrogen. The nitrification plant consist of a nitrification basin, four rectangular clarifiers and other associated appurtenances such as lime feeders, disc aerators, sludge pumping etc. The concrete structures appeared to be in good condition. However, there are some mechanical problems with some of the equipment which are explained later in this section.

The nitrification basin is an oxidation ditch type facility with three concentric channels equipped with disc aerators. Each channel is 20 feet wide with 12 feet SWD. The volume of outer, middle and inner channels is 122,440 ft³, 92,280 ft³ and 62,120 ft³, respectively. The total detention time in the nitrification basin at an average design flow of 8.5 mgd is 5.85 hours. ODEQ does not have specific design criteria for nitrification plants.

The nitrification clarifiers are rectangular type with basin dimensions of 120 feet long, 30 feet wide and 12 feet SWD each. The clarifiers are equipped with a traveling bridge used for collection of sludge settled at the basin bottom. At an average design flow of 8.5 mgd, the hydraulic overflow rate from each of the clarifier is 590 g/ft²/d which is within acceptable ranges (Metcalf & Eddy).

Based on the above evaluation, the nitrification plant can handle the average daily flow of 8.5 mgd as designed. However, conversations with plant personnel have revealed that solids carry over occurs when the plant flow exceeds 7 mgd. They also have experienced problems with the operation of the traveling bridge on the nitrification clarifiers, especially during snow and ice periods. This operational issue has been separately addressed in a memorandum circulated to the City of Enid staff (See **Appendix TM 1-5**). The Nitrification plant, in overall, needs some improvements to correct all operational problems.

Existing Liquid Treatment Plant Capacity

Based on the above analysis of the existing treatment units, the total treatment capacity of the existing Water Pollution Control Facility including the North and South treatment facilities is **7.85 MGD**. The capacities of each plant are summarized in **Table TM 1-13** below. However, it should be noted that the South Plant has not been in operation for the last few years due to the major rehabilitation required for its equipments and other appurtenances. As a result, the total design capacity of the existing facility is rated as only 4.62 MGD.

The influent wastewater to the existing WPCF currently averages 6.12 MGD. Since the South Plant is not in use, the North Plant and Nitrification Plant are operated well above its design capacity to make up for the loss of the South Plant, and have no redundancy in case of an emergency.

TABLE TM 1-13: City of Enid Pollution Control Facility Treatment Capacity Summary	
	Average Daily Flow, MGD
North Treatment Plant	4.62
South Treatment Plant	3.23
Nitrification Plant	8.50
Total Capacity	7.85

SOLIDS HANDLING UNITS

Due to the age and deterioration of the existing solids process units, the bio-solids treatment system at the treatment facility is in jeopardy of becoming non-complaint. Therefore, in 2004, the City of Enid retained the services of Dewberry to evaluate its solids operation and prepare a bio-solids facility plan. This facility plan evaluated various alternatives for producing CLASS B bio-solids with the option of land filling for final disposal. The most cost-effective and preferred alternative recommended in the bio-solids facility plan was to use the existing digesters for aerobic digestion and belt filter press for dewatering the digested sludge. The process schematic depicting the proposed improvements is shown in **Figure TM 1-8**.




FIGURE TM 1-8: PROPOSED IMPROVEMENTS TO SOLIDS HANDLING FACILITY

The proposed improvements to the bio-solids treatment system consists of the following: selective demolition and improvements to the existing aerobic digesters and equipment, selective demolition and converting the existing anaerobic digesters to aerobic digesters and equipment, new blower facility, modification to the existing blower facility, a new 2m belt filter press and dewatered sludge conveyors, improvements to the filter press feed pump system, polymer dosing system, flow measurement equipments, controls, yard piping, electrical and instrumentation work, and other appurtenances to produce Class B bio-solids.

The proposed improvements are expected to be completed at the end of the year 2006. With the completion of the above proposed improvements, the solids handling capacity of the treatment facility will increase to about 15,490 pounds/ day on dry solids basis which is equivalent to solids produced from treating wastewater flows of about 10 MGD at the exiting liquid process treatment units.

APPENDICES

APPENDIX TM 1-1

RAW DATA FROM PLANT RECORDS

Historical Flow Peaking Data

Year	Average Annual Flow (mgd)	Maximum Month Flow (mgd)	Maximum Day Flow (mgd)	Maximum Month Factor	Maximum Day Factor
1996	6.264	7.064	11.922	1.13	1.90
1997	7.396	7.866	8.846	1.06	1.20
1998	7.937	9.637	14.724	1.21	1.86
1999	9.439	12.780	15.407	1.35	1.63
2000	6.804	8.207	11.387	1.21	1.67
2001	6.384	7.250	8.362	1.14	1.31
2002	6.015	6.358	8.887	1.06	1.48
2003	5.912	6.401	7.380	1.08	1.25
2004	6.121	6.400	7.800	1.05	1.27
Average	6.919			1.14	1.51

Influent Wastewater Characteristics

Year	Influent BOD₅ (mg/l)	Influent TSS (mg/l)	Influent NH₃ (mg/l)	Influent DO (mg/l)	Influent Alkalinity (mg/l)
1996	333	274	15.80	2.30	368
1997	245	257	14.60	1.20	359
1998	222	261	12.80	1.10	356
1999	196	227	11.10	1.00	354
2000	206	222	15.90	1.10	357
2001	268	283	16.67	-	-
2002	230	254	17.36	-	-
2003	220	248	18.30	-	-
2004	271	234	17.48	1.26	356
Mean	243	251	15.56	1.34	359
Std. Dev.	42	21	2.4	0.54	5

Per capita wastewater generation rate

Year	Total Service population	Average Annual Flow (mgd)	Percapita rate gpcd
1996	45,320	6.264	138
1997	45,190	7.396	164
1998	45,250	7.937	175
1999	45,200	9.439	209
2000	47,045	6.804	145
2001	46,590	6.384	137
2002	46,530	6.015	129
2003	46,480	5.912	127
2004	46,630	6.121	131

Sludge Production Records at the Existing Facility

SHEET	MONTH	TOTAL SLUDGE	TOTAL SLUDGE	TOTAL SLUDGE
	/ YR	GALLONS	CF PER MONTH	CF PER DAY
1	Jan-95	2590575	346334	11172
2	Feb-95	2790340	373040	13323
3	Mar-95	3041700	406644	13118
4	Apr-95	2887300	386003	12867
5	May-95	1794900	239960	7741
6	Jun-95	594000	79412	2647
7	Jul-95	1273545	170260	5492
8	Aug-95			
9	Sep-95			
10	Oct-95	1659812	221900	7158
11	Nov-95	1210972	161895	5396
12	Dec-95	1488050	198937	6417
13	Jan-96	1378331	184269	5944
14	Feb-96	1153731	154242	5509
15	Mar-96	1308950	174993	6734
16	Apr-96	1054483	140974	4699
17	May-96	1561451	208750	6734
18	Jun-96	1562531	208895	6963
19	Jul-96	1687081	225546	7276
20	Aug-96	13294371	1777322	57333
21	Sep-96	2175010	290777	9693
22	Oct-96	2191146	292934	9449
23	Nov-96	2706903	361885	12063
24	Dec-96	4016038	536903	17319
25	Jan-97	3080936	411890	13287
26	Feb-97	1947000	260294	9296
27	Mar-97	2112000	282353	9108
28	Apr-97	1503000	200936	6698
29	May-97	1321000	176604	5697
30	Jun-97	973000	130080	4336
31	Jul-97	971000	129813	4188
32	Aug-97	1009000	134893	4351
33	Sep-97	1017000	135963	4532
34	Oct-97	945000	126337	4075
35	Nov-97	872000	116578	3886
36	Dec-97	1157000	154679	4990
37	Jan-98	892000	119251	3847
38	Feb-98	660000	88235	3151
39	Mar-98	1196861	160008	5162
40	Apr-98	1903000	254412	8480
41	May-98	1226000	163904	5287
42	Jun-98	1228000	164171	5472
43	Jul-98	949000	126872	4093
44	Aug-98	1003500	134158	4328
45	Sep-98	714000	95455	3182
46	Oct-98	630000	84225	2717
47	Nov-98	512347	68496	2283
48	Dec-98	512347	68496	2210
49	Jan-99	921000	123128	3972
50	Feb-99	989495	132285	4724

51	Mar-99	582500	77874	2512
52	Apr-99	416384	55666	1856
53	May-99	416384	55666	1796
54	Jun-99	416384	55666	1856
55	Jul-99	571262	76372	2464
56	Aug-99	112452	15034	485
57	Sep-99	100381	13420	447
58	Oct-99	152188	20346	656
59	Nov-99			
60	Dec-99	349400	46711	1507
61	Jan-00	362932	48520	1565
62	Feb-00	326268	43619	1558
63	Mar-00	1172410	156739	5056
64	Apr-00	500448	66905	2230
65	May-00	500448	66905	2158
66	Jun-00	1480739	197960	6599
67	Jul-00	1280750	171223	5523
68	Aug-00	716337	95767	3089
69	Sep-00	775500	103676	3456
70	Oct-00	985500	131751	4250
71	Nov-00	945500	126404	4213
72	Dec-00	962000	128610	4149
73	Jan-01			
74	Feb-01	638865	85410	3050
75	Mar-01	989544	132292	4267
76	Apr-01	524446	70113	2337
77	May-01	664603	88851	2866
78	Jun-01	455591	60908	2030
	AVG.	1,352,242	180,781	5,951

Quantity of Solids Landfilled		
Year	ton/year	lb/d
1996	1513	8290
1997	1679	9200
1998	1062	5819
1999	-	-
2000	1164	6378
2001	1284	7036
2002	1067	5847
2003	1188	6510
Average	1280	7011

APPENDIX TM 1-2
INFORMATION ABOUT INDUSTRIES

FLOWS, BOD5, TSS AT SIGNIFICANT INDUSTRIAL USERS 2004 AVERAGE						
NO.	INDUSTRIAL USER	AVG DAILY FLOW (MGD)	AVG BOD5 LBS	BOD5 LBS	AVG TSS	TSS LBS
1	INTEGRIS HOSPITAL	0.052	294	127.5	99	42.9
2	LANDFILL LEACHATE	0.028	59	13.8	315	73.6
3	CHEM-CAN	0.01	5040	420.3	159	13.3
4	BROADWAY TEXACO	0.004	10	0.3	8	0.3
5	ADVANCE-E WILLOW	0.03	661	165.4	144	36.0
6	ADVANCE-RALEIGH RD	0.274	838	1915.0	499	1140.3
7	ADVANCE-PINE ST	0.079	1172	772.2	1047	689.8
8	ST MARY'S HOSPITAL	0.069	373	214.6	226	130.1
9	VANCE AFB	0.171	173	246.7	151	215.3
10	SEABOARD FARMS	0.005	642	26.8	254	10.6
11	RED CARPET LANDFILL	0.004	77	2.6	20	0.7
	TOTAL	0.726	9339	3905.2	2922	2352.8
	AVERAGE	0.066	849	355.0	266	213.9
	2004 AVG FLOW AT POTW	6.12	271		234	
	SIU PERCENT OF TOTAL FLOW	11.86				

September 13, 2005

Mr. Robert Hitt, P.E.
Director of Development Services
City of Enid
P.O. Box 1768
Enid, Oklahoma 73702

Re: City of Enid
Sanitary Sewer Master Plan Agreement
"Additional Organic Loading from Advance Foods and New Ethanol Plant"

Dear Mr. Hitt,

On Monday September 12, 2005, we were notified by your staff on the anticipated discharge from the proposed ethanol plant. As a result of this anticipated discharge and in addition to Advance Foods, we felt that it would be necessary to reevaluate the treatment capacity of the existing Water Pollution Control Facility.

Currently, the Influent flow and its BOD5 and TSS concentrations to the existing Water Pollution Control Facility average at 6.24 mgd, 280 mg/l and 226 mg/l, respectively. As you know both the North and South treatment plants were designed for an average BOD and TSS concentrations of 300 mg/l and 250 mg/l, respectively. In addition, our current evaluation of these two plants based on current ODEQ design standards has revealed that the North and South treatment plant are rated at 4.62 mgd and 3.23 mgd, respectively. Based on this information the total combined design capacity of the existing Water Pollution Control Facility for the City of Enid is about 19,641 pounds per day for BOD5 and 16,367 pounds per day for TSS.

With the anticipated discharge limits proposed by Advance Foods of 0.5 mgd, 664 mg/l BOD and 382 mg/l TSS and the new ethanol plant flow of 0.12 mgd, 1000 mg/l BOD and 350 mg/l TSS, we have estimated that the influent flow and raw wastewater characteristics for BOD and TSS to the existing facility will increase to 6.853 mgd, 320 mg/l and 240 TSS, respectively. Under these conditions the projected loading to the existing Water Pollution Control Facility will be approximately 18,313 pounds per day for BOD and 13,689 pounds per day for TSS.

From the information shown above it appears that the existing facility has the capacity to handle the additional loading, since the projected loading is slightly lesser. However, the BOD5 concentration of the projected influent flow (320 mg/l) is greater than the designed BOD5 concentration (300 mg/l) for the existing facility. Operating under these conditions could impact the effluent quality of the treatment plant and possibly exceed the current NPDES permit.

In order to maintain the influent BOD5 and TSS concentrations to the existing facility within the original design parameters, the BOD5 and TSS discharge concentration from these two industries will have to set at 500 mg/l, each. However, Conversations with your staff have also, revealed that Advance Foods is anticipating doubling production in the next two years that will add an additional flow of 0.5 mgd to the existing facility which will worsen conditions and exceed the BOD5 design parameter and possibly impact the effluent quality of the existing facility. With and anticipated additional flow of 1.0 mgd from Advance Foods and 0.12 mgd from the new ethanol plant, the ultimate combined flow to the existing plant will average at 7.4 mgd. Under this scenario the existing facility will be operating at about 94% capacity of its current rated capacity.

Based on the anticipated additional loadings described above and the operation of the existing Water Pollution Control Facility with both the North and South plants and the use of the Biological nutrient removal train as an effluent polishing process, we recommend that the City's pretreatment program shall ensure that any future pretreatment discharge limit for BOD5 does not exceed 300 mg/l until further expansion to the treatment plant is evaluated and designed.

Should you have any questions, please feel free to contact me.

Very truly yours,

Dewberry Design Group Incorporated

Jose A. Pereira, P.E.
Associate

Cc: James McClain, Public Service Director City of Enid
Muralikumar Katta-Muddanna, Project Engineer City of Enid
Barry Brummit, Pretreatment Director City of Enid
Joyce Hight, Superintendent City of Enid
Vel Subramanian, Dewberry

APPENDIX TM 1-3

CITY OF ENID OPDES PERMIT

**AUTHORIZATION TO DISCHARGE UNDER THE
OKLAHOMA POLLUTANT DISCHARGE ELIMINATION SYSTEM**

PART I.

In compliance with the Oklahoma Pollutant Discharge Elimination System Act (OPDES Act), Title 27A O.S., § 2-6-201 *et seq.* and the rules of the State of Oklahoma Department of Environmental Quality (DEQ) adopted there under (See OAC 252:605); the Federal Clean Water Act, Public Law 95-217 (33 U.S.C. 1251 *et seq.*), Section 402; and NPDES Regulations (40 CFR Parts 122, 124 and 403),

City of Enid
(State ID No. S-20931)
P.O. Box 1768
Enid, Oklahoma 73702

is hereby authorized to discharge treated wastewater from a facility located at approximately

NE¼ of SW¼ of NW¼ of Section 14
Township 22 North, Range 6 West, I.M.
Garfield County, State of Oklahoma

to receiving water: Boggy Creek, tributary to Skeleton Creek, tributary to the Cimarron River at a point located approximately

Outfall 001 Outfall 002

Latitude:	36° 23' 11.904" N	36° 23' 11.148" N	(GPS: NAD-27 CONUS)
Longitude:	97° 48' 58.968" W	97° 48' 49.787" W	(GPS: NAD-27 CONUS)
Planning Segment No. 620910 (Water body ID # 620910030250)			

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I, II, III and IV hereof.


This permit replaces and/or supersedes the previous permit modification issued on March 1, 2001


The issuance date of this permit is July 31, 2003

This permit shall become effective August 1, 2003

This permit and authorization to discharge shall expire at midnight, July 31, 3008

For the Oklahoma Department of Environmental Quality:


Edward Dührberg, P.E., Manager
Municipal Permits Section
Water Quality Division


for Jon L. Craig, Director
Water Quality Division

A. Effluent Limitations

During the period beginning the effective date and lasting through date of expiration the permittee is authorized to discharge treated wastewater in accordance with the following limitations:

1. Conventional and Non-Conventional Pollutants

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/d)	Concentration (mg/l)		Measure-ment Frequency	Sample Type
	30-day Average	30-day Average	7-day Average		
Spring (April - May): Outfall 002 only					
Carbonaceous Biochemical Oxygen Demand - 5 Day (CBOD ₅) [80082]	1417.8	20.0	30.0	3/week	12-hour composite
Total Suspended Solids (TSS) [00530]	2126.7	30.0	45.0	2/week	
Ammonia (NH ₃ -N) [00610]	141.8	2.0	3.0	1/week	
Dissolved Oxygen (DO) [00300] ^b Minimum 6 mg/l				3/week	Grab
Summer (June - October): Outfall 002 only					
Carbonaceous Biochemical Oxygen Demand - 5 Day (CBOD ₅) [80082]	1063.4	15.0	22.5	3/week	12-hour composite
Total Suspended Solids (TSS) [00530]	2126.7	30.0	45.0	2/week	
Ammonia (NH ₃ -N) [00610]	141.8	2.0	3.0	1/week	
Dissolved Oxygen (DO) [00300] ^b Minimum 5 mg/l				3/week	Grab
Winter (November - March): Outfall 001 and/or Outfall 002					
Biochemical Oxygen Demand - 5 Day (BOD ₅) [00310]	1417.8 ^a	20.0	30.0	3/week	12-hour composite
Total Suspended Solids (TSS) [00530]	2126.7 ^a	30.0	45.0	2/week	
Ammonia (NH ₃ -N) [00610]	290.6 ^a	4.1	9.9 [Daily max]	3/week ^c	
Dissolved Oxygen (DO) [00300] ^b Minimum 5 mg/l				3/week	Grab

^a The combined mass loading from each outfall may not exceed this value if both outfalls are used simultaneously.

^b If simultaneously discharging from outfalls 001 and 002, grab samples will be taken from both outfalls, and the lower of the two dissolved oxygen values reported.

^c If the highest daily maximum ammonia level reported during this season for the first year after the effective date of these limits is less than or equal to 1.5 times the monthly average limit (i.e., 1.5 × 4.1 = 6.15 mg/l), the monitoring frequency may be reduced to 1/week for that season. Otherwise, the monitoring frequency continues at 3/week for that season for the remaining term of the permit.

There shall be no discharge of floating solids or visible foam in other than trace amounts.

The pH shall not be less than 6.5 standard units nor greater than 9.0 standard units at any time, it shall be monitored by grab samples collected 3/week.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit.

Flow (measured in million gallons per day) shall be monitored daily by totalized measurement and reported as a 30-day average and a daily maximum.

2. Whole Effluent Toxicity Reporting and Monitoring Requirements (Outfalls TX1, TX2).

During the period beginning the effective date of the permit and lasting through the expiration date, the permittee is authorized to discharge from Outfall TX1 and Outfall TX2 (functionally identical to Outfall 001 and Outfall 002). The discharge consists of biologically treated sanitary wastewater. Such discharges shall be limited and monitored by the permittee as specified below:

Whole Effluent Toxicity Reporting and Monitoring Requirements (Outfalls TX1 and TX2)

Effluent Characteristic			Reporting Requirements ^a		Monitoring Requirements	
Test	Critical Dilution	Parameter	30-day Avg Min	7-day Min	Testing Frequency ^b	Sample Type
Routine Testing <i>Ceriodaphnia dubia</i> , 7-day chronic NOEC static renewal, freshwater	100%	Pass/Fail Survival [TLP3B]	---	Report	2/season for TX1 ^c , and 1/quarter ^f for TX2	24-hr comp
		NOEC _s Survival [TOP3B]	Report	Report		
		% Mortality at Critical Dilution [TJP3B]	Report	Report		
		Pass/Fail Reproduction [TGP3B]	---	Report		
		NOEC _s Reproduction [TPP3B]	Report	Report		
		% Coeff of Variation [TQP3B]	Report	Report		
Routine Testing <i>Pimephales promelas</i> (Fathead minnow), 7-day chronic NOEC static renewal, freshwater	100%	Pass/Fail Survival [TLP6C]	---	Report	2/season for TX1 ^c , and 1/quarter ^f for TX2	24-hr comp
		NOEC _s Survival [TOP6C]	Report	Report		
		% Mortality at Critical Dilution [TJP6C]	Report	Report		
		Pass/Fail Growth [TGP6C]	---	Report		
		NOEC _s Growth [TPP6C]	Report	Report		
		% Coeff of Variation [TQP6C]	Report	Report		
Retesting	Retest #1 [22415] ^e		---	Report	As required ^d	24-hr comp
	Retest #2 [22416] ^e		---	Report		

- ^a See Part II, Section A, Whole Effluent Toxicity Testing, for additional monitoring and reporting conditions.
- ^b Reporting periods commence with the effective date of the permit. A valid WET test shall be reported for each species for each reporting period. Results of retests conducted pursuant to prior test failure shall not be submitted on DMRs in lieu of routine test results (see Part II, Section A, Item 2.a).
- ^c Applies to either or both test species, according to results of test failure triggering monthly retests.
- ^d Monthly retesting required only if the routine test for reporting period (for either species) fails.
- ^e When discharging, no frequency reduction will be applied to TX1 for biomonitoring (November - March).
- ^f The frequency of testing may be reduced to twice per year for TX2, if requested and if there are no lethal or sublethal failures in WET testing during the first two years of the permit. See the provision for WET testing monitoring frequency reduction after the first two years (Part II, Section A, Item 5).

Whole effluent toxicity reporting and monitoring requirements apply beginning the effective date of the permit.

WET testing summary reports: Reports of all WET testing initiated, regardless of whether such tests are carried to completion, shall follow the requirements of Part II, Section A, Item 4.

Whole effluent toxicity concurrent testing provision: Concurrent analysis of total ammonia and pH is required on all effluent samples, including static renewals, collected for Fathead minnow WET testing or retesting. Reporting of results shall be in accordance with the following requirements.

Concurrent Effluent Testing - Reporting Requirements

Effluent Characteristic	Concentration ^a			Monitoring Requirements	
	Daily Min	Monthly Avg	Daily Max	Monitoring Frequency	Sample Type
Ammonia, total [STORET 00610]	Report ^b	Report ^b	Report ^b	2/season for TX1 ^c , and 1/quarter ^d for TX2	24 hr composite
pH (std units) [STORET 00400]	Report ^b	---	Report ^b		Note ^e

- ^a Concentration units are mg/l unless otherwise specified.
- ^b Report only those effluent samples collected for Fathead minnow WET testing.
- ^c Measured in each composite effluent sample, including static renewals, just prior to first use.
- ^d The frequency of testing can be reduced to twice per year for TX2, if requested and if there are no lethal or sublethal failures in WET testing during the first two years of the permit.
- ^e When discharging (November - March).

3. Priority Pollutants

a. Monitoring Requirements for Copper for Outfall 002 (period effective beginning eighteen months before the expiration date of the permit and to last one year).

During the period stated above, the permittee shall monitor for one year the effluent for copper and report the results as follows:

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day)	Concentration(ug/l)		Measurement Frequency	Sample Type
	Monthly Avg.	Monthly Avg.	Daily Maximum		
Copper, Total	Report	Report	Report	1/month	24-hr composite

If any individual test result is less than the minimum quantification level (MQL) of 10 ug/l for copper (monthly and/or daily maximum), a value of zero (0) may be used for the discharge monitoring report (DMR) calculations and reporting requirements.

b. Monitoring Requirements for Hardness (Outfall 999)

During the period beginning eighteen months before the expiration of the permit, the permittee shall monitor the upstream hardness for one year, and report the results as follows:

Upstream Characteristics	Upstream Monitoring			Monitoring Requirements	
	Mass (lbs/day)	Concentration(mg/l)		Measurement Frequency	Sample Type
	Monthly Avg.	Monthly Avg.	Daily Maximum		
Hardness	NA	NA	Report	1/month	Grab

B. Sanitary Sewer Overflows

Any bypass in the collection system [sanitary sewer overflow (SSO)] shall be reported in accordance with Part III.B.6. of this permit.

In addition, all reports shall be summarized and reported in tabular format with the Discharge Monitoring report (DMR) for the month in which the bypasses occurred.

PART II. OTHER PERMIT REQUIREMENTS

**A. WHOLE EFFLUENT TOXICITY TESTING
(7-DAY CHRONIC NOEC, STATIC RENEWAL, FRESHWATER)**

1. SCOPE AND METHODOLOGY

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section. Applicability to multiple outfalls is described in Item 3.d.5 of this section. The permittee shall biomonitor for *Ceriodaphnia dubia* and *Pimephales promelas* in accordance with the WET testing frequencies prescribed in Part I. Intervals between test initiation dates shall be a function of the required testing frequency, as follows:

- Monthly retests: No less than 20 days and no more than 40 days.
- Quarterly: No less than 2 months and no more than 4 months.
- Semi-annually: No less than 4 months and no more than 8 months.

APPLICABLE TO OUTFALL(S):	001 and 002
REPORTED ON DMR AS OUTFALL(S):	TX1 and TX2
CRITICAL DILUTION:	100%
EFFLUENT DILUTION SERIES (ALL TESTS):	32%, 42%, 56%, 75%, and 100%
COMPOSITE SAMPLE TYPE:	Defined at Part I
TEST SPECIES/METHODS:	40 CFR 136

Ceriodaphnia dubia chronic static renewal 7-day survival and reproduction test, Method 1002.0, EPA/600/4-91/002 or the most recent update thereof. A minimum of ten (10) replicates consisting of one (1) organism each must be used in the control and in each effluent dilution of this test. This test should be terminated when 60% of the surviving females in the control produce three broods or at the end of eight days, whichever comes first. If these criteria are not met at the end of 8 days, the test must be repeated.

Pimephales promelas (Fathead minnow) chronic static renewal 7-day larval survival and growth test, Method 1000.0, EPA/600/4-91/002, or the most recent update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

b. CHRONIC LETHAL EFFECT TEST FAILURE

The NOEC_L (No Observed Lethal Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic lethal test failure (chronic

NOEC_l test) is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.

c. CHRONIC SUBLETHAL EFFECT TEST FAILURE

The NOEC_s (No Observed Sublethal Effect Concentration) is defined as the greatest effluent dilution at and below which sublethality (inhibited reproduction in the *Ceriodaphnia dubia* test or inhibited growth in the Fathead minnow test) that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic sublethal test failure (chronic NOEC_s test) is defined as a demonstration of a statistically significant sublethal effect at test completion to a test species at or below the critical dilution.

d. REOPENER CLAUSE

This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.

2. TESTING REQUIREMENTS DUE TO CHRONIC TEST FAILURE

Upon becoming aware of the failure of any test, the permittee shall notify the DEQ Water Quality Division Toxics Coordinator immediately, and in writing within 5 working days of the test failure, with a summary of the results of and any other pertinent circumstances associated with the failed test.

a. Whenever there is a lethal effect test failure for either species during routine testing, the frequency of testing for the affected species shall automatically increase to, or continue at, as appropriate, the WET testing frequency prescribed in Part I for the remaining life of the permit. In addition, two (2) additional monthly tests (retests) of the affected species are required. The two additional tests shall be conducted monthly during the next two consecutive months. The permittee shall not substitute either of the two additional tests for routine toxicity testing. Additional tests are not required for a sublethal effect test failure. A full laboratory report for the failed routine test and both additional tests, if required, shall be prepared and submitted to the DEQ in accordance with procedures outlined in Item 4 of this section.

b. PERSISTENT LETHALITY

- (1) If either of the two additional tests result in an NOEC_l value less than the critical dilution, persistent lethality is exhibited, and the permittee shall initiate a Toxicity Reduction Evaluation (TRE) as specified in Item 5 of this section. The TRE initiation date will be the test completion date of the first failed retest.
- (2) The retesting requirements in Item 2.a are suspended upon submittal of the TRE Action Plan.

c. INTERMITTENT LETHALITY

If both additional tests result in an NOEC_l value greater than or equal to the critical dilution, persistent lethality is not exhibited. However, if any routine test lethal effect failure occurs within 18 months of a prior lethal effect test failure, intermittent lethality is

exhibited, and the permittee may be required by the DEQ to initiate a TRE, as described in Item 5 of this section, based on the severity and pattern of such lethal effect over time.

d. PERSISTENT SUBLETHALITY

Barring persistent lethality, if two consecutive routine tests result in a sublethal effect failure for a species, persistent sublethality is exhibited, and the permittee:

- (1) Shall increase the frequency of testing for the affected species to, or continue at, as appropriate, the WET testing frequency prescribed in Part I for the remaining life of the permit; and
- (2) May be required by the DEQ to initiate a TRE, as specified in Item 5 of this section, based on the severity and pattern of such sublethal effect over time.

3. REQUIRED TOXICITY TESTING CONDITIONS

a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- (1) The toxicity test control (0% effluent) must have survival equal to or greater than 80%.
- (2) The mean number of *Ceriodaphnia dubia* neonates produced per surviving female in the control (0% effluent) must be 15 or more.
- (3) Sixty (60) percent of the surviving *Ceriodaphnia dubia* control females must produce three broods.
- (4) The mean dry weight of surviving Fathead minnow larvae at the end of the 7 days in the control (0% effluent) must be 0.25 mg per larva or greater.
- (5) The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for the young of surviving females in the *Ceriodaphnia dubia* reproduction test and for the growth and survival endpoints of the Fathead minnow test.
- (6) The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal or sublethal effects are exhibited for the young of surviving females in the *Ceriodaphnia dubia* reproduction test and for the growth and survival endpoints of the Fathead minnow test.
- (7) As documented at test termination, no more than forty (40) percent of the *Ceriodaphnia dubia* test organisms in the control (0% effluent) or any effluent dilution shall be male.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40% in the critical dilution. A repeat test shall be conducted within the reporting period of any test determined to be invalid.

b. Statistical Interpretation

- (1) For the *Ceriodaphnia dubia* survival test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be Fisher's Exact Test as described in EPA/600/4-91/002, or the most recent update thereof.
- (2) For the *Ceriodaphnia dubia* reproduction test and the Fathead minnow larval survival and growth test the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA/600/4-91/002, or the most recent update thereof.
- (3) If the conditions of test acceptability are met in Item 3.a above and the percent survival of the test organism is equal to or greater than 80% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report an NOEC_i of not less than the critical dilution for the DMR reporting requirements found in Item 4 below.

c. Dilution Water

- (1) Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness and alkalinity to the closest downstream perennial water where the toxicity test is conducted on an effluent discharge to a receiving stream classified as intermittent or to a receiving stream with no flow due to zero flow conditions.
- (2) If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 3.a.), the permittee must submit the test results exhibiting receiving water toxicity with the full test report required in Item 4 below and may thereafter substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
 - (a) A synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a. was run concurrently with the receiving water control;
 - (b) The test indicating receiving water toxicity was carried out to completion; and
 - (c) The synthetic dilution water had a pH, hardness and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- (1) The permittee shall collect three flow-weighted 24-hour composite samples representative of the flows during normal operation from the outfall(s) listed at Item 1.a above. Unless otherwise specified in Part I of the permit, a 24-hour composite sample consists of a minimum of 12 effluent portions collected at equal time intervals

representative of a 24-hour operating day and combined proportional to flow or a sample continuously collected proportional to flow over a 24-hour operating day.

- (2) The first composite effluent sample shall be used to initiate each test and must be collected so that its holding time (between collection of the last portion of the sample and test initiation) does not exceed 36 hours. Collection of the second and third composite effluent samples must be timed so as to permit an approximately equal use distribution of the three composite samples for daily static renewals. In no case shall the holding time of the second and third composite samples (between collection of the last portion of the sample and its first use) exceed 72 hours. All samples shall be chilled to 4 °C during collection, shipping and/or storage.
- (3) The permittee shall collect the 24-hour composite samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
- (4) If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full test report required in Item 4 of this section.
- (5) MULTIPLE OUTFALLS: If the provisions of this section are applicable to multiple outfalls, as specified in Part I of the permit, the permittee shall combine the composite effluent samples in proportion to the average flow from the outfalls listed in Item 1.a of this section for the day the sample was collected. The permittee shall perform the toxicity test on the flow-weighted composite of the outfall samples.

4. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this section in accordance with the Report Preparation Section of EPA/600/4-91/002, or the most current publication, for every valid or invalid toxicity test initiated, whether carried to completion or not. The permittee shall retain each full report pursuant to the records retention provisions of Part III of this permit. The permittee shall submit full test reports for all tests initiated, regardless of whether the tests are carried to completion, to the DEQ no later than the 15th day of the month following completion of the test, including any test which is considered invalid, is terminated early for any reason, or which indicates receiving water toxicity.
- b. A valid test for each species (excluding retests) must be reported on the DMR for each reporting period specified in Part I of this permit unless the permittee is performing a TRE, which may increase the frequency of testing and reporting. A DMR must be submitted by the 15th day of the month following completion of any valid test. The full report for the test (see Item 4.a above) shall be submitted along with the DMR. If a survival test failure is experienced for either test species, two copies of the blank DMR for the applicable

reporting period shall be made in advance of completing and submitting the DMR so that the DMR copies may be used to report results of the required retests. If more than one valid test (excluding retests) is performed on a species during a reporting period, the permittee shall report the lowest survival test results as the 7-day minimum for each species tested, and the arithmetic average of the results of the survival tests shall be reported as the 30-day average minimum. The sublethal test results reported for each species on the DMR are determined in the same manner. If the permittee performs only one valid test (excluding retests) on a species during the reporting period, then the results of that test shall be reported as both the 7-day minimum and the 30-day average minimum on the DMR. The 30-day average minimum does not apply to the pass/fail parameters (TLP3B, TGP3B, TLP6C and TGP6C) in Item 4.c below.

If any test results in anomalous-NOEC_L or NOEC_S findings (i.e., it indicates an interrupted dose response across the dilution series), the DEQ recommends that the permittee contact its DEQ toxicity coordinator for a technical review of the test results prior to submitting the full test report and DMR. A summary of all tests initiated during the reporting period, including invalid tests, repeat tests and retests, shall be attached to the reporting period DMR for DEQ review. A test is a REPEAT test if it is performed as a result of a previously invalid test. A test is a RETEST if it is performed as a result of a previously failed test. Each time a DMR is submitted, put the new submittal date in the lower right-hand corner of the DMR.

- (1) The reporting period test summary attached to the DMR shall be organized as follows:
 - (a) Invalid tests (basis for test invalidity must be described)
 - (b) Valid tests (other than retests) initiated during current reporting period
 - (c) Valid retests for tests failed during previous reporting period (if not submitted in the previous reporting period test summary)
 - (d) Valid retests for tests failed during current reporting period
- (2) The following information shall be listed in the reporting period test summary for each valid test in categories (b) through (d) in Item 4.b(1) above:
 - (a) Test species
 - (b) Date of test initiation at laboratory
 - (c) Results of all concurrent effluent analyses specified in Part I of this permit
 - (d) All test result parameters for the test species specified in Item 4.c below.
- c. The permittee shall report the following results for all VALID toxicity tests (excluding retests) on the DMR(s) for that reporting period in accordance with Item 4.b above and Part III of this permit.
 - (1) *Ceriodaphnia dubia*

- (a) Parameter TLP3B: If the *Ceriodaphnia dubia* NOEC_L for survival is less than the critical dilution, report a "1"; otherwise, report a "0".
 - (b) Parameter TOP3B: Report the *Ceriodaphnia dubia* NOEC_L value for survival.
 - (c) Parameter TJP3B: Report the *Ceriodaphnia dubia* percent mortality in the critical dilution at test completion.
 - (d) Parameter TGP3B: If the *Ceriodaphnia dubia* NOEC_S for reproduction is less than the critical dilution, report a "1"; otherwise, report a "0".
 - (e) Parameter TPP3B: Report the *Ceriodaphnia dubia* NOEC_S value for reproduction.
 - (f) Parameter TQP3B: Report the highest coefficient of variation (critical dilution or control) for *Ceriodaphnia dubia* reproduction.
- (2) *Pimephales promelas* (Fathead minnow)
- (a) Parameter TLP6C: If the Fathead minnow NOEC_L for survival is less than the critical dilution, report a "1"; otherwise, report a "0".
 - (b) Parameter TOP6C: Report the Fathead minnow NOEC_L value for survival.
 - (c) Parameter TJP6C: Report the Fathead minnow percent mortality in the critical dilution at test completion.
 - (d) Parameter TGP6C: If the Fathead minnow NOEC_S for growth is less than the critical dilution, report a "1"; otherwise, report a "0".
 - (e) Parameter TPP6C: Report the Fathead minnow NOEC_S value for growth.
 - (f) Parameter TQP6C: Report the highest coefficient of variation (critical dilution or control) for Fathead minnow survival and growth.
- d. The permittee shall report the following results for all VALID toxicity retests on the DMR(s) for that reporting period.
- (1) Retest #1 (STORET 22415): If the first monthly retest following failure of a routine test for either test species results in an NOEC_L for survival less than the critical dilution, report a "1"; otherwise, report a "0".
 - (2) Retest #2 (STORET 22416): If the second monthly retest following failure of a routine test for either test species results in an NOEC_L for survival less than the critical dilution, report a "1"; otherwise, report a "0".

Results of all retests shall be reported on a copy of the DMR for the reporting period (see Item 4.b above) in which the triggering routine test failure is experienced by no later than the 15th day of the month following completion of the retest. The full report for the retest (see Item 4.a above) shall be submitted along with the retest DMR. Even if a retest cannot be conducted before the end of the reporting period for which it is required (due to test initiation interval requirements), the retest results shall still be reported for the reporting

period in which the triggering test failure is experienced. In this manner, both retests are reported for the same reporting period as the failed routine test. Each time a DMR is submitted, put the new submittal date in the lower right-hand corner of the DMR. If retesting is not required during a given reporting period, the permittee shall leave these DMR fields blank.

5. MONITORING FREQUENCY REDUCTION

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first two years of testing for one or both test species with no lethal or sublethal effects demonstrated at or below the critical dilution. Certification in accordance with Item 5.b of this section shall be submitted at the time of such application for monitoring frequency reduction. If granted, the monitoring frequency may be reduced to not less than once per 6 months (once each during the periods June 1 through September 30 and December 1 through March 31) for either test species.
- b. **CERTIFICATION:** The permittee must certify in writing that no lethal or sublethal test failures have occurred for the species for which the monitoring frequency reduction is being requested and that all tests meet all test acceptability criteria in Item 3.a. above. In addition, the permittee must provide a summary of all tests initiated during the period of certification including test initiation dates, species, test acceptability parameters, NOEC_t values, percent mortality at the critical dilution, NOEC_s values, and coefficients of variation for the controls and critical dilutions. If the certification is approvable, the DEQ will issue a letter of confirmation of the monitoring frequency reduction. A copy of the confirmation letter will be forwarded to the DEQ's Permit Compliance System unit to update the permit reporting requirements. The DEQ may deny the certification if it determines that, during the period for which the certification is submitted, there were errors in meeting test acceptability requirements, errors in statistical interpretation affecting test results reported on DMRs, late submissions of test reports or submissions of substantively incomplete test reports. If the certification is denied, the permittee shall continue biomonitoring of the affected test species at a frequency of once per quarter until the permit is reissued.
- c. **SUBLETHAL FAILURES DURING FIRST YEAR OF TESTING:** If, during the first year of testing, only a sublethal effect is demonstrated to a test species, continued routine testing for that species is required for the remainder of the first year and, as necessary, into the following year(s) at the frequency prescribed in Part I until the effluent passes four consecutive routine tests for both lethal and sublethal test endpoints, at which time the permittee may apply for a monitoring frequency reduction in a manner consistent with Item 5.a above. Certification in accordance with Item 5.b of this section shall be submitted at the time of such application for monitoring frequency reduction. If granted, the monitoring frequency may be reduced in accordance with Item 5.a.
- d. **SURVIVAL FAILURES AFTER A MONITORING FREQUENCY REDUCTION:** If any test fails the survival endpoint at any time after the granting of a monitoring frequency reduction, two monthly retests are required in accordance with Item 2 of this section (unless the permittee is performing a TRE) and the monitoring frequency for the affected test species shall be increased to the WET testing frequency prescribed in Part I until the permit is reissued.

- c. This monitoring frequency reduction applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to the WET testing frequency prescribed in Part I until the permit is reissued.

6. TOXICITY REDUCTION EVALUATION (TRE)

- a. Within ninety (90) days of confirming lethality in the retests for a test species, the permittee shall submit to the DEQ a Toxicity Reduction Evaluation (TRE) Action Plan and Schedule for conducting a TRE. The TRE Action Plan shall specify the approach and methodology to be used in performing the TRE. A Toxicity Reduction Evaluation is an investigation intended to determine those actions necessary to achieve compliance with water quality-based effluent limits by reducing an effluent's toxicity to an acceptable level. A TRE is defined as a step-wise process which combines toxicity testing and analyses of the physical and chemical characteristics of a toxic effluent to identify the constituents causing effluent toxicity and/or treatment methods which will reduce the effluent toxicity. The TRE Action Plan shall lead to the successful elimination of effluent toxicity at the critical dilution and include the following:

- (1) Specific Activities. The plan shall detail the specific approach the permittee intends to utilize in conducting the TRE. The approach may include toxicity characterizations, identifications and confirmation activities, source evaluation, treatability studies, or alternative approaches. When the permittee conducts Toxicity Characterization Procedures the permittee shall perform multiple characterizations and follow the procedures specified in the documents "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA-600/6-91/003) and "Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I" (EPA-600/6-91/005F), or alternate procedures. When the permittee conducts Toxicity Identification Evaluations and Confirmations, the permittee shall perform multiple identifications and follow the methods specified in the documents "Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081), as appropriate.

The documents referenced above may be obtained through the National Technical Information Service (NTIS) by phone at (703) 487-4650, or by writing:

U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161

- (2) Sampling Plan (e.g., locations, methods, holding times, chain of custody, preservation, etc.). The effluent sample volume collected for all tests shall be adequate to perform the toxicity test, toxicity characterization, identification and confirmation procedures, and conduct chemical specific analyses when a probable toxicant has been identified. Where the permittee has identified or suspects specific pollutant(s) and/or source(s) of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical specific analyses for the identified and/or suspected pollutant(s) and/or source(s) of

effluent toxicity. Where lethality was demonstrated within 48 hours of test initiation, each composite sample shall be analyzed independently. Otherwise, the permittee may substitute a composite sample, comprised of equal portions of the individual composite samples, for the chemical specific analysis.

- (3) Quality Assurance Plan (e.g., QA/QC implementation, corrective actions, etc.).
 - (4) Project Organization (e.g., project staff, project manager, consulting services, etc.).
- b. The permittee shall initiate the TRE Action Plan within thirty (30) days of plan and schedule submittal. The permittee shall assume all risks for failure to achieve the required toxicity reduction.
 - c. The permittee shall submit to the DEQ a quarterly TRE Activities Report with the Discharge Monitoring Report in the months of (to be specified), containing information on toxicity reduction evaluation activities including:
 - (1) any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;
 - (2) any studies/evaluations and results on the treatability of the facility's effluent toxicity; and
 - (3) any data which identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant lethality at the critical dilution.
 - d. The permittee shall submit to the DEQ a Final Report on Toxicity Reduction Evaluation Activities no later than twenty-eight (28) months from confirming lethality in the retests, which provides information pertaining to the specific control mechanism selected that will, when implemented, result in reduction of effluent toxicity to no significant lethality at the critical dilution. The report will also provide a specific corrective action schedule for implementing the selected control mechanism.
 - e. Quarterly testing during the TRE is a minimum monitoring requirement. The DEQ recommends that permittees required to perform a TRE not rely on quarterly testing alone to ensure success in the TRE, and that additional tests be performed to capture toxic samples for identification of toxicants. Failure to identify the specific chemical compound causing toxicity test failure will normally result in a permit limit for whole effluent toxicity per federal regulations at 40 CFR 122.44(d)(1)(v).

B. SEWAGE SLUDGE REQUIREMENTS

The sludge produced at the facility is presently sent to the Enid Municipal Landfill located in the NE of Sections 29, Township 22-N, Range 6 W. I.M., Garfield County, Oklahoma..

Sewage sludge disposal practices shall comply with the federal regulations for landfills, sludge, and solid waste disposal established at 40 CFR Part 257, 503 and the DEQ rules governing Sludge Management (OAC 252:648) as applicable.

The permittee shall give 120 days prior notice to DEQ of any change planned in the sewage sludge disposal practice.

In addition, the permittee shall comply with other sludge requirements specified in Part IV of this permit.

The permittee is required to maintain all records relevant to sewage sludge disposal for the life of the permit. These records shall be made available to DEQ upon request.

C. POLLUTION PREVENTION REQUIREMENTS

1. The permittee shall institute a program within 12 months of the effective date of the permit (or continue on existing one) directed towards optimizing the efficiency and extending the useful life of the facility. The permittee shall consider the following items in the program:
 - a. The influent loadings, flow and design capacity;
 - b. The effluent quality and plant performance;
 - c. The age and expected life of the wastewater treatment facility's equipment;
 - d. Bypasses and overflows of the tributary sewerage system and treatment works;
 - e. New developments at the facility;
 - f. Operator certification and training plans and status;
 - g. The financial status of the facility;
 - h. Preventative maintenance programs and equipment conditions and;
 - i. An overall evaluation of conditions at the facility.

2. The permittee shall prepare the following information on the sewage sludge generated by the facility.
 - a. An annual quantitative tabulation of the ultimate disposition of all sewage sludge (including, but not limited to, the amount beneficially reused, landfilled, surface disposed, and incinerated).
 - b. An assessment of technological processes and an economic analysis evaluating the potential for beneficial reuse of all sewage sludge not currently beneficially reused including a listing of any steps which would be required to achieve the sludge quality necessary to beneficially reuse the sludge.
 - c. A description of, including the expected results and the anticipated timing for, all projects in process, in planning and/or being considered which are directed towards additional beneficial reuse of sewage sludge.
 - d. An analysis of one composite sample of the sludge collected prior to ultimate re-use or disposal shall be performed for the pollutants listed in Part IV, Element 1, Section III, Table 3 of the permit.
 - e. A listing of the specific steps (controls/changes) which would be necessary to achieve and sustain the quality of the sludge so that the pollutant concentrations in the sludge fall below the pollutant concentration criteria listed in Part IV, Element I, Section III, Table 3 of the permit.
 - f. A listing of, and the anticipated timing for, all projects in process, in planning, and/or being considered which are directed towards meeting the sludge quality referenced in (c) above.

The permittee shall certify in writing, within three years of the effective date of the permit, that all pertinent information is available. This certification shall be submitted to:

Oklahoma Department of Environmental Quality
Water Quality Division
Wastewater Discharge Permit Section
P. O. Box 1677;
707 North Robinson Street
Oklahoma City, Oklahoma 73101-1677

D. CONTRIBUTING INDUSTRIES AND PRETREATMENT REQUIREMENTS

1. The permittee shall operate an industrial pretreatment program in accordance with Section 402(b)(8) of the Clean Water Act, the General Pretreatment Regulations (40 CFR Part 403) and the approved POTW pretreatment program submitted by the permittee. The pretreatment program was approved on October 15, 1984 and modified on July 15, 1994 and March 1, 2001. A Publicly Owned Treatment Works (POTW) facility is defined in 40 CFR 403.3(o) "as any devices and systems used in storage, treatment, recycling and reclamation of municipal sewage and industrial wastes of a liquid nature. It also includes sewers, pipes and other conveyances only if they convey wastewater to a POTW Treatment Plant. The term also means the municipality as defined in section 502(4) of the Act, which has jurisdiction over the Indirect Discharges to and from such treatment works." The POTW pretreatment program is hereby incorporated by reference and shall be implemented in a manner consistent with the following requirements:
 - a. Industrial user information shall be updated at a frequency adequate to ensure that all IUs are properly characterized at all times;
 - b. The frequency and nature of industrial user compliance monitoring activities by the permittee shall be commensurate with the character, consistency and volume of waste. However, in keeping with the requirements of 40 CFR 403.8 (f)(2)(v), the permittee must inspect and sample the effluent from each Significant Industrial User at least once a year. This is in addition to any industrial self-monitoring activities;
 - c. The permittee shall enforce and obtain remedies for noncompliance by any industrial users with applicable pretreatment standards and requirements;
 - d. The permittee shall control through permit, order, or similar means, the contribution to the POTW by each Industrial User to ensure compliance with applicable Pretreatment Standards and requirements. In the case of Industrial Users identified as significant under 40 CFR 403.3(i), this control shall be achieved through permits or equivalent individual control mechanisms issued to each such user. Such control mechanisms must be enforceable and contain, at a minimum, the following conditions:
 - (1). Statement of duration (in no case more than five years);
 - (2). Statement of non-transferability without, at a minimum, prior notification to the POTW and provision of a copy of the existing control mechanism to the new owner or operator;
 - (3). Effluent limits based on applicable general pretreatment standards, categorical pretreatment standards, local limits, and State and local law;

- (4). Self-monitoring, sampling, reporting, notification and record keeping requirements, including an identification of the pollutants to be monitored, sampling location, sampling frequency, and sample type, based on the applicable general pretreatment standards in 40 CFR 403, categorical pretreatment standards, local limits, and State and local law; and
 - (5). Statement of applicable civil and criminal penalties for violation of pretreatment standards and requirements and any applicable compliance schedule. Such schedules may not extend the compliance date beyond federal deadlines.
- e. The permittee shall evaluate, at least once every two years, whether each Significant Industrial User needs a plan to control slug discharges. If the POTW decides that a slug control plan is needed, the plan shall contain at least the minimum elements required in 40 CFR 403.8 (f)(2)(v);
 - f. The permittee shall provide adequate staff, equipment, and support capabilities to carry out all elements of the pretreatment program; and,
 - g. The approved program shall not be modified by the permittee without the prior approval of the DEQ.
2. The permittee shall establish and enforce specific limits to implement the provisions of 40 CFR Parts 403.5(a) and (b), as required by 40 CFR Part 403.5(c). Each POTW with an approved pretreatment program shall continue to develop these limits as necessary and effectively enforce such limits.

The permittee shall, within sixty days of the effective date of this permit, (1) submit a WRITTEN CERTIFICATION that a technical evaluation has been performed demonstrating that the existing technically based local limits (TBLL) are based on the current state water quality standards and are adequate to prevent pass through of pollutants, inhibition of or interference with the treatment facility, worker health and safety problems, and sludge contamination, OR (2) submit a WRITTEN NOTIFICATION that a technical evaluation revising the current TBLL and a draft sewer use ordinance which incorporates such revisions will be submitted within 12 months of the effective date of this permit.

All specific prohibitions or limits developed under this requirement are deemed to be conditions of this permit. The specific prohibitions set out in 40 CFR Part 403.5(b) shall be enforced by the permittee unless modified under this provision.

3. The permittee shall analyze the treatment facility influent and effluent for the presence of the toxic pollutants listed in 40 CFR 122 Appendix D (NPDES Application Testing Requirements) Table II at once per year and the toxic pollutants in Table III at least once every six months. If, based upon information available to the permittee there is reason to suspect the presence of any toxic or hazardous pollutant listed in Table V, or any other pollutant, known or suspected to adversely affect treatment plant operation, receiving water quality, or solids disposal procedures, analysis for those pollutants shall be performed at least once every six months on both the influent and the effluent.

The influent and effluent samples collected shall be composite samples consisting of at least 12 aliquots collected at approximately equal intervals over a representative 24 hour period and

composited according to flow. Sampling and analytical procedures shall be in accordance with guidelines established in 40 CFR 136. The effluent samples shall be analyzed to a level as required in item 6 below. Where composite samples are inappropriate, due to sampling, holding time, or analytical constraints, at least 4 grab samples, taken at equal intervals over a representative 24 hour period, shall be taken.

4. The permittee shall prepare annually a list of Industrial Users which during the preceding twelve months were in significant noncompliance with applicable pretreatment requirements. For the purposes of this Part, significant noncompliance shall be determined based upon the more stringent of either criteria established at 40 CFR Part 403.8(f)(2)(vii) [rev. 7/24/90] or criteria established in the approved POTW pretreatment program. This list is to be published annually in the largest daily newspaper in the municipality during the month of December.

In addition, during the month of December the permittee shall submit an updated status report to DEQ containing the following information:

- a. An updated list of all significant industrial users. For each industrial user listed the following information shall be included (Note: A sample table, which includes the requested information has been provided on Page 20 for your convenience):
 - (1). Standard Industrial Classification (SIC) code and categorical determination;
 - (2). Control document status. Whether the user has an effective control document, and the date such document was last issued, reissued, or modified, (indicate which industrial users were added to the system (or newly identified) within the previous 12 months);
 - (3). A summary of all monitoring activities performed within the previous 12 months. The following information shall be reported:
 - total number of inspections performed;
 - total number of sampling visits made;
 - (4). Status of compliance with both effluent limitations and reporting requirements. Compliance status shall be defined as follows:
 - Compliant (C) - no violations during the previous 12 month period;
 - Non-compliant (NC) - one or more violations during the previous 12 months but does not meet the criteria for significantly non-compliant industrial users;
 - Significant Noncompliance (SN) - in accordance with requirements described in d. above; and
 - (5). For significantly noncompliant industrial users, indicate the nature of the violations, the type and number of actions taken (notice of violation, administrative order, criminal or civil suit, fines or penalties collected, etc.) and current compliance status. If ANY industrial user was on a schedule to attain compliance with effluent limits, indicate the date the schedule was issued and the date compliance is to be attained (Note: A sample table, which includes the requested information has been provided on Page 19 for your convenience);

- b. A list of all significant industrial users whose authorization to discharge was terminated or revoked during the preceding 12 month period and the reason for termination;
 - c. A report on any interference, pass through, upset or POTW permit violations known or suspected to be caused by industrial contributors and actions taken by the permittee in response;
 - d. The results of all influent and effluent analyses performed pursuant to "item 3 above". These results and comparisons to the appropriate technically based local limit allowances and effluent water quality standards may be presented in tabular form as per the sample table provided on Page 18 for your convenience;
 - e. A copy of the newspaper publication of the significantly non-compliant industrial users giving the name of the newspaper and the date published;
5. The permittee shall provide adequate notice of the following:
- a. Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the CWA and/or Sections 40 CFR 405-499 if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Adequate notice shall include information on (i) the quality and quantity of effluent to be introduced into the treatment works, and (ii) any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

6. All effluent monitoring conducted in accordance with "item 3 above" shall meet the Minimum Quantification Levels (MQLs) shown in the attached tables.

MINIMUM QUANTIFICATION LEVELS (MQLs)

<u>METALS AND CYANIDE</u>	(ug/L)	EPA METHOD	<u>VOLATILE COMPOUNDS</u>	(ug/L)	EPA METHOD
Antimony (Total) ¹	60	200.7	1,1,2,2-Tetrachloroethane ⁵	10	624
Arsenic (Total) ¹	10	206.2	Tetrachloroethylene ⁵	10	624
Beryllium (Total) ¹	5	200.7	Toluene ⁵	10	624
Cadmium (Total) ²	1	213.2	1,2-trans-Dichloroethylene ⁵	10	624
Chromium (Total) ¹	10	200.7	1,1,1-Trichloroethane ⁵	10	624
Chromium (3+) ¹	10	200.7	1,1,2-Trichloroethane ⁵	10	624
Chromium (6+) ¹	10	200.7	Trichloroethylene ⁵	10	624
Copper (Total) ²	10	220.2	Vinyl Chloride ⁵	10	624
Lead (Total) ²	5	239.2	<u>ACID COMPOUNDS</u>		
Mercury (Total) ¹	0.2	245.1	2-Chlorophenol ⁵	10	625
Nickel (Total) ¹ [Freshwater]	40	200.7	2,4-Dichlorophenol ⁵	10	625
Nickel (Total) ² [Marine]	5	249.2	2,4-Dimethylphenol ⁷	10	625
Selenium (Total) ¹	5	270.2	4,6-Dinitro-o-Cresol		
Silver (Total) ²	2	272.2	1,2 methyl 4,6-dinitrophenol ⁵	50	625
Thallium (Total) ¹	10	279.2	2,4-Dinitrophenol ⁵	50	625
Zinc (Total) ¹	20	200.7	2-Nitrophenol ⁵	20	625
Cyanide (Total) ¹	10	335.2	4-Nitrophenol ⁵	50	625
<u>DIOXIN</u>			p-Chloro-m-Cresol		
1,7,8-Tetrachloro-dibenzo- p-dioxin (TCDD) ⁵	.00001	1613	[4 chloro-3-methylphenol] ⁶	10	625
<u>VOLATILE COMPOUNDS</u>			Pentachlorophenol ⁵	50	625
Acrolein ⁴	50	624	Phenol ⁵	10	625
Acrylonitrile ⁴	50	624	2,4,6-Trichlorophenol ⁵	10	625
Benzene ⁴	10	624	<u>BASE/NEUTRAL COMPOUNDS</u>		
Bromoform ⁵	10	624	Acenaphthene ⁵	10	625
Carbon Tetrachloride ⁴	10	624	Acenaphthylene ⁵	10	625
Chlorobenzene ⁵	10	624	Anthracene ⁵	10	625
Chlorodibromomethane ⁵	10	624	Benzidine ⁴	50	625
Chloroethane ⁴	50	624	Benzo(a)anthracenes ⁵	10	625
2-Chloroethyl vinyl ether ⁴	10	624	Benzo(a)pyrene ⁵	10	625
Chloroform ⁵	10	624	3,4-Benzofluoranthene ⁵	10	625
Dichlorobromomethane ⁵	10	624	Benzo(ghi)perylene ⁶	20	625
1,1-Dichloroethane ⁵	10	624	Benzo(k)fluoranthene ⁵	10	625
1,2-Dichloroethane ⁵	10	624	Bis(2-chloroethoxy) methane ⁵	10	625
1,1-Dichloroethylene ⁵	10	624	Bis(2-chloroethyl) ether ⁵	10	625
1,2-Dichloropropane ⁵	10	624	Bis(2-chloroisopropyl) ether ⁵	10	625
1,3-Dichloropropylene ⁴	10	624	Bis(2-ethylhexyl) phthalate ⁵	10	625
Ethylbenzene ⁵	10	624	4-Bromophenyl phenyl ether ⁵	10	625
Methyl Bromide [Bromomethane] ⁶	50	624	Butyl benzyl phthalate ⁵	10	625
Methyl Chloride [Chloromethane] ⁶	50	624	2-Chloronaphthalene ⁵	10	625
Methylene Chloride ⁵	20	624	4-Chlorophenyl phenyl ethers ⁵	10	625
			Chrysene ⁵	10	625

MINIMUM QUANTIFICATION LEVELS (MQLs)

<u>BASE/NEUTRAL COMPOUNDS</u>	(ug/L)	EPA METHOD	<u>PESTICIDES</u>	(ug/L)	EPA METHOD
Dibenzo (a,h) anthracene ⁶	20	625	Endrin ⁷	.1	609
1,2-Dichlorobenzene ⁵	10	625	Endrin aldehyde ⁷	.1	609
1,3-Dichlorobenzene ⁵	10	625	Heptachlor ⁷	.05	608
1,4-Dichlorobenzene ⁵	10	625	Heptachlor epoxide ⁷	.05	608
3,3'-Dichlorobenzidine ⁶	50	625	(BHC-hexachlorocyclohexane)		
Diethyl Phthalate ⁵	10	625	PCB-1242 ⁷	1.0	608
Dimethyl Phthalate ⁵	10	625	PCB-1254	1.0	608
Di-n-Butyl Phthalate ⁵	10	625	PCB-1221	1.0	608
2,4-Dinitrotoluene ⁵	10	625	PCB-1232	1.0	608
2,6-Dinitrotoluene ⁵	10	625	PCB-1248	1.0	608
Di-n-octyl Phthalate ⁵	10	625	PCB-1260	1.0	609
1,2-Diphenylhydrazine ⁴	20	625	PCB-1016	1.0	608
Fluoranthene ⁵	10	625	Toxaphene ⁷	5.0	608
Fluorene ⁵	10	625			
Hexachlorobenzene ⁵	10	625			
Hexachlorobutadiene ⁵	10	625			
Hexachlorocyclopentadiene ⁵	10	625			
Hexachloroethane ⁶	20	625			
Indeno (1,2,3-cd) pyrene ⁶	20	625			
(2,3-o-phenylene pyrene)					
Isophorone ⁵	10	625			
Naphthalene ⁵	10	625			
Nitrobenzene ⁵	10	625			
N-nitrosodimethylamine ⁶	50	625			
N-nitrosodi-n-propylamine ⁶	20	625			
N-nitrosodiphenylamine ⁶	20	625			
Phenanthrene ⁵	10	625			
Pyrene ⁵	10	625			
1,2,4-Trichlorobenzene ⁵	10	625			
<u>PESTICIDES</u>					
Aldrin ⁷	0.05	608			
Alpha-BHC ⁷	0.05	608			
Beta-BHC ⁷	0.05	609			
Gamma-BHC (Lindane) ⁷	0.05	608			
Delta-BHC ⁷	0.05	608			
Chlordane ⁷	0.2	608			
4,4'-DDT ⁷	0.1	608			
4,4'-DDE (p,p-DDX) ⁷	0.1	608			
4,4'-DDD (p,p-TDE) ⁷	0.1	608			
Dieldrin ⁷	0.1	608			
Alpha-endosulfan ⁷	0.1	608			
Beta-endosulfan ⁷	0.1	608			
Endosulfan sulfate ⁷	0.1	608			

¹Based on Contract Required Detection level (CRDL) developed pursuant to 40 CFR Part 300.430(h)(8)

²Method 213.2, 239.2, 220.2, 272.2

³Dioxin National Strategy

⁴No CRQL (Contract required Quantification Level) developed pursuant to 40 CFR Part 300.430(h)(8) established

⁵CRQL basis, equivalent to ML

⁶ML basis, higher than CRQL

⁷CRQL basis, no ML established

⁸CRQL basis, higher than ML

**OKLAHOMA DEQ SAMPLE
POTW MONITORING RESULTS SUMMARY TABLE
FOR THE (CA NAME) ANNUAL PRETREATMENT REPORT, (MONTH & YEAR)**

POLLUTANT	Minimum Quantification Level (MQL)	Detection Level (DL) Concentration Used (mg/l or ug/l)	POTW Monitoring Results (Concentrations in mg/l unless otherwise noted)					Comparative Standards (Loadings in lbs/day; concentration in mg/l unless otherwise noted)		
			Average Influent Concentration	POTW Average Flow (MGD)	Calculated Headworks Loading (lbs/d)	Maximum Effluent Concentration	Average Effluent Concentration	Maximum Allowable Headworks Loading or Concentration	Permit or OK Limits Concentrations	
	Daily Maximum								Daily Maximum	
Arsenic (Total)										
Cadmium (Total)										
Chromium (Total)										
Copper (Total)										
Lead (Total)										
Mercury (Total)										
Nickel (Total)										
Silver (Total)										
Zinc (Total)										
Cyanide (Total)										
Other pollutants detected:										

It is advised that the influent and effluent samples are collected considering flow detention time through each plant. Analytical MQLs should be used so that the data can also be used for Local Limits assessment and NPDES application purposes.

PART III. STANDARD CONDITIONS FOR OPDES MUNICIPAL/DOMESTIC PERMIT

SECTION A. Definitions

In addition to the definitions included in the Oklahoma Pollutant Discharge Elimination System Act (OPDES Act), Title 27 O.S. Supp. 1996, Section 2-6-201 et seq., and the rules of the State of Oklahoma Department of Environmental Quality (DEQ) adopted thereunder (See OAC 252:605); the following definitions shall apply to this permit:

1. "Act" means the OPDES Act as amended.
2. "Applicable effluent standards and limitations" means all state and federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards of performance, toxic effluent standards and prohibitions, and pretreatment standards.
3. "Applicable water quality standards" means all water quality standards to which a discharge is subject under the Act.
4. "Average limitations"
 - a. "7-day average" (or weekly average), other than for coliform bacteria, is the arithmetic mean of the daily values for all effluent samples collected during a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week. The "7-day average" for coliform bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
 - b. "30-day average" (or monthly average), other than for coliform bacteria, is the arithmetic mean of the daily values for all effluent samples collected during a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. The "30-day average" for coliform bacteria is the geometric mean of the values for all effluent samples collected during a calendar month.
5. "Bypass" means the diversion, whether intentional or unintentional, of waste streams from any portion of the collection system or treatment facility.
6. "Daily discharge" means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the sampling day. "Daily discharge" determination of concentrations made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the "daily discharge" determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that sampling day.
7. "Daily maximum" discharge limitation means the highest allowable "daily discharge" during the calendar month.
8. "Environmental Protection Agency" (EPA) means the U.S. Environmental Protection Agency.
9. "Executive Director" means the Executive Director of the State of Oklahoma Department of Environmental Quality (DEQ) or his/her authorized representative(s).
11. "Industrial user" means a nondomestic discharger, as identified in 40 CFR Part 403, introducing pollutants to a publicly owned treatment works.
12. "Oklahoma Pollutant Discharge Elimination System" (OPDES) means the state program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under the Act.
13. "Oklahoma Department of Environmental Quality" also known as (DEQ), means the State of Oklahoma Department of Environmental Quality.
14. "OPDES Act" means the Oklahoma Pollutant Discharge Elimination System Act, Title 27 O.S. Supp. 1996, Section 2-6-201 et seq.
15. "Samples"
 - a. For coliform bacteria, a sample consists of one effluent grab portion collected during a 24-hour period at peak loads.
 - b. "Grab sample" means an individual sample collected in less than 15 minutes.
 - c. "SBR (sequential batch reactor) sample and the various composite samples" are as defined in the OPDES Act, the Oklahoma Environmental Quality Code, rules transferred to or promulgated thereunder by DEQ.

SBR Composite Sample:

SBR Sample

A minimum of three aliquots collected from the discharge of a reactor. The first aliquot must be collected no later than $\frac{1}{4}$ time, the second approximately $\frac{1}{2}$ time, and the third no earlier than $\frac{3}{4}$ time from the initiation of a discharge cycle to the stoppage of the discharge cycle. The three aliquots shall consist of equal portions unless the rate of discharge from the reactor varies significantly during the cycle, in which case the measurement of the flow occurring at the time of their collection

Single Composite SBR Sample

One SBR sample collected from each reactor during one discharge cycle and composited proportional to the volume discharged from each of the reactors. The sample from at least one of the reactors shall represent the expected period of peak influent organic loading.

Two-Cycle Composite SBR Sample

One SBR sample collected from two consecutive discharge cycles of each reactor and composited proportional to the volume discharged during each cycle of each reactor. The sample from at least one cycle shall represent the expected period of peak influent organic loading.

Three-Cycle Composite SBR Sample

One SBR sample collected from three consecutive discharge cycles of each reactor and composited proportional to the volume discharged during each cycle of each reactor. The sample from at least one cycle shall represent the expected period of peak influent organic loading.

- d. "24-hour composite sample" consists of a minimum of 12 effluent portions collected at equal time intervals over the 24-hour period and combined proportional to flow or a sample collected at frequent intervals proportional to flow over the 24-hour period.
 - e. "12-hour composite sample" consists of 12 effluent portions collected no closer together than one hour and composited according to flow. The daily sampling intervals shall include the highest flow periods.
 - f. "6-hour composite sample" consists of six effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.
 - g. "3-hour composite sample" consists of three effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.
16. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 17. "Sewage sludge" means the solids, residues and precipitates separated from or created in sewage by the unit processes of a publicly owned treatment works. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and storm water runoff, that are discharged to or otherwise enter a publicly owned treatment works.
 18. "Treatment works" means any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage and industrial wastes of a liquid nature to implement the Act, or necessary to recycle or reuse water at the most economical cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and their appurtenances, extension, improvement, remodeling, additions, and alterations thereof.
 19. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
 20. "MGD" means million gallons per day.
 21. "mg/l" means milligrams per liter or parts per million (ppm).
 22. "µg/l" means micrograms per liter or parts per billion (ppb).

SECTION B. Monitoring, Record Keeping, Reporting and Liabilities**1. Monitoring****a. Site and Frequency**

All monitoring undertaken in compliance with the terms of this permit shall be conducted at the frequency and sample site specified in Part I, Section A of this permit and in accordance with the OPDES Act and the Oklahoma Environmental Quality Code. Grab or composite in Part III, Section B.5 below.

b. Representative Samples

Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.

c. Averaging of Measurements

Calculations of all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Executive Director in the permit.

d. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the Discharge Monitoring Report (DMR). Such increased monitoring frequency shall also be indicated on the DMR.

2. Testing Requirements

a. Methods

All sampling and analytical methods used to meet monitoring requirements specified above shall conform to the Act, 40 CFR Part 136, and DEQ rules and regulations.

b. Maintenance and Calibration

The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instruments at intervals frequent enough to ensure accuracy of measurements and shall maintain appropriate records of such activities.

c. Quality Control

An adequate analytical quality control program, including the analyses of sufficient standards, spikes, and duplicate samples to insure the accuracy to all required analytical results shall be maintained by the permittee or designated commercial laboratory.

3. Flow Measurements

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure that the accuracy of the measurements is consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than 10% from true discharge rates throughout the range of expected discharge rates.

4. Records

a. Contents

Records of monitoring information shall include:

- (1) The date, exact place, and time of sampling or measurements;
- (2) The individual(s) who performed the sampling or measurements;
- (3) The date(s) and time(s) analyses were performed;
- (4) The individual(s) who performed the analyses;
- (5) The analytical techniques or methods used; and
- (6) The results of such analyses.

b. Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least three (3) years from the date of the sample, measurement, report, or application. This period may be extended by request of the Executive Director at any time.

5. Discharge Monitoring Reports (DMRs)

All monitoring information required in Part I, Section A of this permit shall be included on DMRs (EPA form 3320-1). Reporting periods shall end on the last day of the month. The reports shall be prepared monthly. The original and one copy shall be submitted to the Oklahoma Department of Environmental Quality at the address shown below no later than the tenth (10th) day of the following month. A copy shall also be submitted simultaneously to the appropriate local DEQ office. All operating records and reports shall comply with the OPDES Act, the Oklahoma Environmental Quality Code, and the requirements of 40 CFR 122.41(j).

Water Quality Division
Oklahoma Department of Environmental Quality
P.O. Box 1677
Oklahoma City, OK 73101-1677

6. Noncompliance Reports

a. Twenty-Four Hour Reporting

(1) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. The DEQ shall be notified by calling 1-800-256-2365 or 702-8290 (Oklahoma City Metropolitan Area). A written submission shall be provided within five (5) days of the time the permittee becomes aware of the circumstances. The report shall contain the following information:

- (a) A description of the noncompliance and its cause;
- (b) The period of noncompliance including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and,
- (c) Steps being taken to reduce, eliminate, and prevent recurrence of the noncomplying discharge.

(2) The following shall be included as information which must be reported within 24 hours:

- (a) Any unanticipated bypass which exceeds any effluent limitation in the permit;
- (b) Any upset which exceeds any effluent limitation in the permit;
- (c) Any violation of a maximum daily discharge limit for any of the pollutants listed by the Executive Director in Part I, Section A; and,
- (d) Any bypass in the collection system [sanitary sewer overflow (SSO)].

(3) The Executive Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

b. Other Noncompliance

The permittee shall report all instances of noncompliance not reported under Part III, Sections B.5 and B.6.a or the reporting requirements of any Schedule of Compliance included in Part I, Section B at the time monitoring reports are submitted. The reports shall contain the information listed at Part III, Section B.6.a.

7. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under the Act.

8. Federal Penalties for Violations of Permit Conditions

Nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of the permit, the Act, or applicable regulations, which avoids or effectively defeats the regulatory purpose of the permit may subject the Permittee to criminal enforcement pursuant to 18 U.S.C. Section 1001.

a. Criminal

(1) Negligent Violations

The Act provides that any person who negligently violates permit conditions implementing the Act is subject to a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one (1) year, or both.

(2) Knowing Violations

The Act provides that any person who knowingly violates permit conditions implementing the Act is subject to a fine of not less than \$5,000 nor more than \$50,000 per day of violation, or by imprisonment for not more than three (3) years, or both.

(3) Knowing Endangerment

The Act provides that any person who knowingly violates permit conditions implementing the Act and who knows at that time that he is placing another person in imminent danger of death or serious bodily injury is subject to a fine of not more than \$250,000, or by imprisonment for not more than fifteen (15) years, or both.

(4) False Statements

The Act provides that any person who knowingly makes any false material statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under the Act or who knowingly falsifies, tampers with, or renders inaccurate, any monitoring device or method required to be maintained under the Act, shall upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two (2) years, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment shall be by a fine of not more than \$20,000 per day of violation, or by imprisonment for not more than four (4) years, or by both. (See Section 2-6-206 of the Act).

b. Civil Penalties

The Act provides that any person who violates a permit condition implementing the Act is subject to a civil penalty not to exceed \$27,500 per day for each violation.

c. Administrative Penalties

The Act provides that any person who violates a permit condition implementing the Act is subject to an administrative penalty, as follows:

(1) Class I Penalty

Not to exceed \$11,000 per violation nor shall the maximum amount exceed \$27,500.

(2) Class II Penalty

Not to exceed \$11,000 per day for each day during which the violation continues nor shall the maximum amount exceed \$137,500.

9. State Penalties

a. Civil and Administrative

For any violation of the limitations and/or conditions of this permit, the State may assess a fine of up to \$10,000 per day per violation.

b. Criminal

Violations of the terms of this permit constitute a misdemeanor under Oklahoma Statutes with various provisions for fines and jail terms.

SECTION C. Other Conditions

1. Permit Application

a. Timely Application

Upon timely application for a permit, any prior permit remains in effect until a new one is issued.

b. Date of Application

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The application shall be submitted at least 180 days before the expiration date of this permit unless otherwise authorized by the Executive Director. He or she may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated at 40 CFR 122.6 and any subsequent amendments.

c. Relevant Facts

When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Executive Director, it shall promptly submit such facts or information.

2. Changes

a. Change in discharge

(1) Anticipated Noncompliance

The permittee shall give advance notice of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

(2) Municipal Permits

Any change in the facility discharge (including the introduction of any new source or significant discharge or significant changes in the quantity or quality of existing discharges to the treatment system that may result in new or increased discharges of pollutants) must be reported to the permitting authorities. In no case are any new connections, increased flows, or significant changes in influent quality permitted that will cause violations or add to existing violations of the effluent limitations specified herein.

(3) Other Permits

The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:

- (a) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or,
- (b) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to all pollutants whether or not they are subject to effluent limitations in the permit.

h. Transfer of ownership or control

This permit is not transferable to any person except after notice to the Executive Director. The Executive Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as necessary under the Act.

3. Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege.

4. Duty to Comply

- a. All authorized discharges shall comply with the rules of the DEQ, which are hereby incorporated by reference: the Act and CDDDES Regulations, and all provisions, conditions, and requirements included in this permit.
- b. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of applicable state and federal laws and the Act, the Oklahoma Environmental Quality Code and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- c. The permittee shall comply with effluent standards or prohibitions established under the Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Duty to mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

6. Duty to halt or reduce activity

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

7. Duty to provide information

The permittee shall furnish within a reasonable time, any information which the Executive Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish, upon request, copies of records required to be kept by this permit.

8. Permit modification, suspension and revocation

After notice and opportunity for a hearing, as is required by law, this permit may be modified, suspended, revoked and reissued, or terminated during its term in accordance with 40 CFR 122.62 and 122.64; and Title 27 O.S. Supp. 1996, Section 2-6-201 et seq., and the rules of the State of Oklahoma Department of Environmental Quality (DEQ) adopted thereunder [See OAC 252:605]. The filing of a request for a permit modification or reissuance, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

9. Proper operation and maintenance

- a. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by permittee as efficiently as possible and in a manner which will minimize upsets and discharges of excessive pollutants and will achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of this permit.
- b. The permittee shall provide an adequate operating staff which is duly qualified to carry out operation, maintenance and testing functions required to insure compliance with the conditions of this permit.
- c. Collected screenings, slurries, sludges and other solids shall be disposed of in accordance with the Oklahoma Solid Waste Management Act and in such a manner as to prevent entry of those wastes (or runoff from the wastes) into waters of the state and in compliance with applicable rules of the DEQ.

10. Power Failure

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures either by means of alternative power sources, standby generators, or retention of inadequately treated effluent.

11. Upsets and Bypasses

a. Upsets

- (1) An upset constitutes an affirmative defense to an enforcement action brought for noncompliance with technology-based permit effluent limitations if the following requirements are met. A permittee who wishes to establish the affirmative defense of upset shall demonstrate through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (a) An upset occurred and that the permittee can identify the specific cause(s) of the upset;
 - (b) The permitted facility was at the time being properly operated;
 - (c) The permittee submitted notice of the upset as required in Part III, Section B.6 of this permit;
 - (d) The permittee complied with any remedial measures under Part III, Section C.5.
- (2) Burden of Proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

b. Bypasses

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
 - (a) Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the reporting requirements of Part III, Sections C.11.b(1) and (2).
 - (b) Bypass exceeding limitations is prohibited, and the Executive Director may take enforcement action against a permittee for bypass, unless:
 - i. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - ii. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgement to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and,
 - iii. The permittee submitted notices required by Part III, Section B.6.
 - (c) The Executive Director may allow an anticipated bypass that exceeds limitations after considering its adverse effects, if he/she determines that it will meet the three conditions listed at Part III, Section C.11.b.(1)(b).
- (2) Unanticipated bypass. The permittee shall, within 24 hours, submit notice of an unanticipated bypass as required in Part III, Section B.6.

12. Percent Removal

For publicly owned treatment works, the 30-day average (or monthly average) percent removal for Biochemical Oxygen Demand (BOD) and Total Suspended Solids (TSS) shall not be less than 85 percent unless otherwise authorized by the permitting authority in accordance with 40 CFR 133.103. This requirement may be waived in permits containing mass loading limits for BOD and TSS.

13. Right of entry

The permittee shall allow the Executive Director, and/or his/her authorized representative(s), upon presentation of credentials and such other documents as may be required by the law to:

- a. Enter upon the permittee's premises or other premises under the control of the permittee, where an effluent source is located or may be located or in which any records are required to be kept under the terms and conditions of this permit;
- b. Have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit, or the Act or DEQ rules;

- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), maintenance, practices or operations regulated or required under this permit; and
- d. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the Act, any substances or parameters at any location.

14. Toxic Effluent Standards

Notwithstanding Section III.C.8 of this permit, if any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under the Act for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or prohibition.

15. Signatory Requirements

All applications, reports, or information submitted to the Executive Director shall be signed and certified.

- a. All permit applications shall be signed as follows:

- (1) For a corporation - by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:

- (a) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation; or,
- (b) The manager of one or more manufacturing, production, or operating facilities employing more than 250 persons or having gross annual sales or expenditures exceeding \$25 million (in second-quarter 1980 dollars), if authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

- (2) For a partnership or sole proprietorship - by a general partner or the proprietor, respectively.

- (3) For a municipality, state, federal, or other public agency - by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a federal agency includes:

- (a) The chief executive officer of the agency, or
- (b) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.

- b. All reports required by the permit and other information requested by the Executive Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- (1) The authorization is made in writing by a person described above;

- (2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. A duly authorized representative may thus be either a named individual or an individual occupying a named position; and,

- (3) The written authorization is submitted to the Executive Director.

- c. Certification. Any person signing a document under this section shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

16. Confidentiality

Except for applications, effluent data, permits, and other data specified in 40 CFR 122.7, any information submitted pursuant to this permit may be claimed as confidential by the submitter. The Executive Director will rule upon such claim in accordance with the Act. If no claim is made at the time of submission, information may be made available to the public without further notice.

Part IV
SEWAGE SLUDGE REQUIREMENTS
PERMIT
INSTRUCTIONS TO PERMITTEES

Select only those Elements and Sections which apply to your sludge reuse or disposal practice.

If your facility utilizes more than one type of disposal or reuse method (for example, Element 1 and Element 2 apply) or the quality of your sludge varies (for example, Section II and Section III of Element 1 apply) use a separate Discharge Monitoring Report (DMR) for each Section that is applicable.

The sludge DMRs shall be due by February 19th of each year and shall cover the previous January through December time period.

The sludge conditions do not apply to wastewater treatment lagoons where sludge is not wasted for final reuse/disposal. If the sludge is not removed, the permittee shall indicate on the DMR "No Discharge."

ELEMENT 1 - LAND APPLICATION

- SECTION I: Page 1 - Requirements Applying to All Sewage Sludge Land Application
- SECTION II: Page 4 - Requirements Specific to Bulk Sewage Sludge for Application to the Land Meeting Class A or B Pathogen Reduction and the Cumulative Loading Rates in Table 2, or Class B Pathogen Reduction and the Pollutant Concentrations in Table 3
- SECTION III: Page 7 - Requirements Specific to Bulk Sewage Sludge Meeting Pollutant Concentrations in Table 3 and Class A Pathogen Reduction Requirements
- SECTION IV: Page 8 - Requirements Specific to Sludge Sold or Given Away in a Bag or Other Container for Application to the Land that does not Meet the Pollutant Concentrations in Table 3

ELEMENT 2 - MUNICIPAL SOLID WASTE LANDFILL DISPOSAL

- SECTION I: Page 10 - Requirements Applying to All Municipal Solid Waste Landfill Disposal Activities

ELEMENT 1 - LAND APPLICATION

SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE LAND APPLICATION

A. General Requirements

1. The permittee shall handle and dispose of sewage sludge in accordance with the Oklahoma Pollutant Discharge Elimination System (OPDES) Act (hereafter "the Act") and all other applicable federal and state regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants which may be present in the sludge.
2. If requirements for sludge management practices or pollutant criteria become more stringent than the sludge pollutant limits or acceptable management practices in this permit, or control a pollutant not listed in this permit, this permit may be modified or revoked and reissued to conform to the requirements promulgated under the Act. If new limits for molybdenum are promulgated prior to permit expiration, then those limits shall become directly enforceable.
3. In all cases, if the person (permit holder) who prepares the sewage sludge supplies the sewage sludge to another person for land application use or to the owner or lease holder of the land, the permit holder shall provide necessary information to the parties who receive the sludge to assure compliance with these regulations.
4. The permittee shall give prior notice to the Director, Water Quality Division, State of Oklahoma, Department of Environmental Quality (DEQ), 707 North Robinson, Oklahoma City, Oklahoma 73101-1677 of any planned changes in the sewage sludge disposal practice, in accordance with 40 CFR 122.41(l)(1)(iii). These changes may justify the application of permit conditions that are different from or absent in the existing permit. Change in the sludge use or disposal practice may be cause for modification of the permit in accordance with 40 CFR 122.62(a)(1).

B.

Testing Requirements

1. Sewage sludge shall be tested once during the life of the permit within one year from the effective date of the permit in accordance with the method specified at 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other approved methods. Sludge shall be tested after final treatment prior to leaving the publicly owned treatment works (POTW) site. Sewage sludge determined to be a hazardous waste in accordance with 40 CFR Part 261, shall be handled according to Resource Conservation and Recovery Act (RCRA) standards for the disposal of hazardous waste in accordance with 40 CFR Part 262. The disposal of sewage sludge determined to be a hazardous waste, in other than a certified hazardous waste disposal facility shall be prohibited. The DEQ, Waste Management Division at 405-702-5100, shall be notified of test failure within 24 hours. A written report shall be provided to this division within 7 days after failing the TCLP. The report will contain test results, certification that unauthorized disposal has not occurred and a summary of alternative disposal plans that comply with RCRA standards for the disposal of hazardous waste. The report shall be addressed to the Director, Waste Management Division, DEQ, 707 N. Robinson, Oklahoma City, Oklahoma 73101-1677 and a copy sent to the Director, Water Quality Division, DEQ, at the same address.
2. Sewage sludge shall not be applied to the land if the concentration of the pollutants exceeds the pollutant concentration criteria in Table 1. The frequency of testing for pollutants in Table 1 is found in Element I, Section I.C.

TABLE 1

<u>Pollutant</u>	<u>Ceiling Concentration (milligrams per kilogram)*</u>
Arsenic	75
Cadmium	85
Copper	4300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
PCBs	49
Selenium	100
Zinc	7500

* Dry weight basis

3. Pathogen Control

All sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by either the Class A or Class B pathogen requirements. Sewage sludge that is applied to a lawn or home garden shall be treated by the Class A pathogen requirements. Sewage sludge that is sold or given away in a bag shall be treated by the Class A pathogen requirements.

Class A Sludge Requirements:

- a. Six alternatives are available to demonstrate compliance with Class A sewage sludge. All 6 options require either the density of fecal coliform in the sewage sludge be less than 1000 Most Probable Number (MPN) per gram of total solids (dry weight basis), or the density of *Salmonella sp.* bacteria in the sewage sludge be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed; at the time the sewage sludge is prepared for sale or given away in a bag or other container for application to the land. Below are the additional requirements necessary to meet the definition of a Class A sludge.

Alternative 1 - The temperature of the sewage sludge that is used or disposed shall be maintained at a specific value for a period of time. See 40 CFR 503.32(a)(3)(ii) and OAC 252:648 for specific information.

Alternative 2 - The pH of the sewage sludge that is used or disposed shall be raised to above 12 and shall remain above 12 for 72 hours.

The temperature of the sewage sludge shall be above 52 degrees Celsius for 12 hours or longer during the period that the pH of the sewage sludge is above 12.

At the end of the 72 hour period during which the pH of the sewage sludge is above 12, the sewage sludge shall be air dried to achieve a percent solids in the sewage sludge greater than 50 percent.

Alternative 3 - The sewage sludge shall be analyzed for enteric viruses prior to pathogen treatment. The limit for enteric viruses is one Plaque-forming Unit per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 40 CFR 503.32(a)(5)(ii) for specific information. The sewage sludge shall be analyzed for viable helminth ova prior to pathogen treatment. The limit for viable helminth ova is less than one per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 40 CFR 503.32(a)(5)(iii) and OAC 252:648 for specific information.

Alternative 4 - The density of enteric viruses in the sewage sludge shall be less than one Plaque-forming Unit per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed or at the time the sludge is prepared for sale or given away in a bag or other container for application to the land.

The density of viable helminth ova in the sewage sludge shall be less than one per four grams of total solids (dry weight

basis) at the time the sewage sludge is used or disposed or at the time the sewage sludge is prepared for sale or given away in a bag or other container for application to the land.

Alternative 5 - Sewage sludge shall be treated by one of the Processes to Further Reduce Pathogens (PFRP) described in 40 CFR 503 Appendix B. PFRPs include composting, heat drying, heat treatment, and thermophilic aerobic digestion.

Alternative 6 - Sewage sludge shall be treated by a process that is equivalent to a PFRP, if individually approved by the Pathogen Equivalency Committee representing the DEQ.

Class B Sludge Requirements:

b. Three alternatives are available to demonstrate compliance with Class B sewage sludge.

Alternative 1 - (i) Seven separate random samples representative of the sewage sludge shall be collected for one monitoring episode at the time the sewage sludge is used or disposed.

(ii) The geometric mean of the density of fecal coliform in the samples collected shall be less than either 2,000,000 MPN per gram of total solids (dry weight basis) or 2,000,000 Colony Forming Units per gram of total solids (dry weight basis).

Alternative 2 - Sewage sludge shall be treated in one of the Processes to Significantly Reduce Pathogens (PSRP) described in 40 CFR 503 Appendix B.

Alternative 3 - Sewage sludge shall be treated in a process that is equivalent to a PSRP, if individually approved by the Pathogen Equivalency Committee representing the DEQ.

In addition, the following site restrictions must be met if Class B sludge is land applied:

- i. Food crops with harvested parts that touch the sewage sludge/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of sewage sludge.
- ii. Food crops with harvested parts below the surface of the land shall not be harvested for 20 months after application of sewage sludge when the sewage sludge remains on the land surface for 4 months or longer prior to incorporation into the soil.
- iii. Food crops with harvested parts below the surface of the land shall not be harvested for 38 months after application of sewage sludge when the sewage sludge remains on the land surface for less than 4 months prior to incorporation into the soil.
- iv. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of sewage sludge.
- v. Animals shall not be allowed to graze on the land for 30 days after application of sewage sludge.
- vi. Turf grown on land where sewage sludge is applied shall not be harvested for 1 year after application of the sewage sludge when the harvested turf is placed on either land with a high potential for public exposure or a lawn, unless otherwise specified by the permitting authority.
- vii. Public access to land with a high potential for public exposure shall be restricted for 1 year after application of sewage sludge.
- viii. Public access to land with a low potential for public exposure shall be restricted for 30 days after application of sewage sludge.

4. Vector Attraction Reduction Requirements

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by one of the following alternatives 1 through 10 for Vector Attraction Reduction. If bulk sewage sludge is applied to a home garden, or bagged sewage sludge is applied to the land, only Alternatives 1 through 8 shall be used.

Alternative 1 - The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38 percent.

Alternative 2 - If Alternative 1 cannot be met for an anaerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge anaerobically in the laboratory in a bench-scale unit for 40 additional days at a temperature between 30 and 37 degrees Celsius. Volatile solids must be reduced by less than 17 percent to demonstrate compliance.

Alternative 3 - If Alternative 1 cannot be met for an aerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge with a percent solids of two percent or less aerobically in the laboratory in a bench-scale unit for 30 additional days at 20 degrees Celsius. Volatile solids must be reduced by less than 15 percent to demonstrate compliance.

Alternative 4 - The specific oxygen uptake rate (SOUR) for sewage sludge treated in an aerobic process shall be equal to or less than 1.5 milligrams of oxygen per hour per gram of total solids (dry weight basis) at a temperature of 20 degrees Celsius.

Alternative 5 - Sewage sludge shall be treated in an aerobic process for 14 days or longer. During that time, the temperature of the

sewage sludge shall be higher than 40 degrees Celsius and the average temperature of the sewage sludge shall be higher than 45 degrees Celsius.

Alternative 6 - The pH of sewage sludge shall be raised to 12 or higher by alkali addition and, without the addition of more alkali, shall remain at 12 or higher for two hours and then at 11.5 or higher for an additional 22 hours.

Alternative 7 - The percent solids of sewage sludge that does not contain unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 75 percent based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

Alternative 8 - The percent solids of sewage sludge that contains unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 90 percent based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

- Alternative 9 -
- (i) Sewage sludge shall be injected below the surface of the land.
 - (ii) No significant amount of the sewage sludge shall be present on the land surface within one hour after the sewage sludge is injected.
 - (iii) When sewage sludge that is injected below the surface of the land is Class A with respect to pathogens, the sewage sludge shall be injected below the land surface within eight hours after being discharged from the pathogen treatment process.
- Alternative 10 -
- (i) Sewage sludge applied to the land surface or placed on a surface disposal site shall be incorporated into the soil within six hours after application to or placement on the land.
 - (ii) When sewage sludge that is incorporated into the soil is Class A with respect to pathogens, the sewage sludge shall be applied to or placed on the land within eight hours after being discharged from the pathogen treatment process.

C. Monitoring Requirements

- | | |
|--|------------------|
| 1. Toxicity Characteristic Leaching Procedure (TCLP) Test performed within one year from the effective date of the permit. | Once/Permit Life |
| 2. PCBs | Once/Year |
| 3. All other pollutants shall be monitored at the frequency shown below: | |
| Amount of sewage sludge*
(metric tons per 365 day period) | Frequency |
| 0 ≤ Sludge < 290 | Once/Year |
| 290 ≤ Sludge < 1,500 | Once/Quarter |
| 1,500 ≤ Sludge < 15,000 | Once/Two Months |
| 15,000 ≤ Sludge | Once/Month |

*Either the amount of bulk sewage sludge applied to the land or the amount of sewage sludge received by a person who prepares sewage sludge that is sold or given away in a bag or other container for application to the land (dry weight basis).

Representative samples of sewage sludge shall be collected and analyzed in accordance with the methods referenced in 40 CFR 503.8(h) and OAC 252:648.

SECTION II. REQUIREMENTS SPECIFIC TO BULK SEWAGE SLUDGE FOR APPLICATION TO THE LAND MEETING CLASS A OR B PATHOGEN REDUCTION AND THE CUMULATIVE LOADING RATES IN TABLE 2, OR CLASS B PATHOGEN REDUCTION AND THE POLLUTANT CONCENTRATIONS IN TABLE 3

For those permittees meeting Class A or B pathogen reduction requirements and that meet the cumulative loading rates in Table 2 below, or the Class B pathogen reduction requirements and contain concentrations of pollutants below those listed in Table 3 found in Element 1, Section III, the following conditions apply:

TABLE 2

Pollutant	Cumulative Pollutant Loading Rate (kilograms per hectare)
Arsenic	41
Cadmium	39
Copper	1500
Lead	300
Mercury	17
Molybdenum	Report
Nickel	420
Selenium	100
Zinc	2800

2. Pathogen Control

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, or lawn or home garden shall be treated by either Class A or Class B pathogen reduction requirements as defined above in Element 1, Section 1.B.3.

3. Management Practices

- a. Bulk sewage sludge shall not be applied to agricultural land, forest, a public contact site, or a reclamation site that is flooded, frozen, or snow-covered so that the bulk sewage sludge enters a wetland or other waters of the state, as defined in 40 CFR 122.2, except as provided in a permit issued pursuant to the Act.
- b. Bulk sewage sludge shall not be applied within 100 feet of a water of the state.
- c. Bulk sewage sludge shall be applied at or below the agronomic rate in accordance with recommendations from the following references:
 - i. STANDARDS 1992, Standards, Engineering Practices and Data, 39th Edition (1992) American Society of Agricultural Engineers, 2950 Niles Road, St. Joseph, MI 49085-9659.
 - ii. National Engineering Handbook Part 651, Agricultural Waste Management Field Handbook (1992), P.O. Box 2890, Washington, D.C. 20013.
 - iii. Recommendations of local extension services or Soil Conservation Services.
 - iv. Recommendations of a major university's Agronomic Department.
- d. An information sheet shall be provided to the person who receives bulk sewage sludge that is sold or given away. The information sheet shall contain the following information:
 - i. The name and address of the person who prepared the sewage sludge that is sold or given away in a bag or other container for application to the land.
 - ii. A statement that application of the sewage sludge to the land is prohibited except in accordance with the instructions on the label or information sheet.
 - iii. The annual whole sludge application rate for the sewage sludge that does not cause any of the cumulative pollutant loading rates in Table 2 above to be exceeded, unless the pollutant concentrations in Table 3 found in Element 1, Section III below are met.

4. Notification requirements

- a. If bulk sewage sludge is applied to land in a state other than the state in which the sludge is prepared, written notice shall be provided prior to the initial land application to the permitting authority for the state in which the bulk sewage sludge is proposed to be applied. The notice shall include:
 - i. The location, by either street address or latitude and longitude, of each land application site.
 - ii. The approximate time period bulk sewage sludge will be applied to the site.
 - iii. The name, address, telephone number, and Oklahoma Pollutant Discharge Elimination System or National Pollutant Discharge Elimination System, whichever is applicable, permit number (if appropriate) for the person who prepares the bulk sewage sludge.
 - iv. The name, address, telephone number, and Oklahoma Pollutant Discharge Elimination System or National Pollutant Discharge Elimination System, whichever is applicable, permit number (if appropriate) for the person who will apply the bulk sewage sludge.

- b. The permittee shall give 60 days prior notice to the DEQ of any change planned in the sewage sludge practice. Any change shall include any planned physical alterations or additions to the permitted treatment works, changes in the permittee's sludge use or disposal practice, and also alterations, additions, or deletions of disposal sites. These changes may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional disposal sites not reported during the permit application process or absent in the existing permit. Change in the sludge use or disposal practice may be cause for modification of the permit in accordance with 40 CFR 122.62(a)(1).
- c. The permittee shall provide the location of all existing sludge disposal/use sites to the State Historical Commission within 90 days of the effective date of this permit. In addition, the permittee shall provide the location of any new disposal/use site to the State Historical Commission prior to use of the site.

The permittee shall within 30 days after notification by the State Historical Commission that a specific sludge disposal/use area will adversely effect a National Historic Site, cease use of such area.

5. Recordkeeping Requirements - The sludge documents will be retained on site at the same location as other OPDES records.

The person who prepares bulk sewage sludge or a sewage sludge material shall develop the following information and shall retain the information for five years. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for recordkeeping found in 40 CFR 503.17 and OAC 252:648 for persons who land apply.

- a. The concentration (mg/Kg) in the sludge of each pollutant listed in Table 3 found in Element 1, Section III and the applicable pollutant concentration criteria (mg/Kg), or the applicable cumulative pollutant loading rate and the applicable cumulative pollutant loading rate limit (kg/ha) listed in Table 2 above.
- b. A description of how the pathogen reduction requirements are met (including site restrictions for Class B sludges, if applicable).
- c. A description of how the vector attraction reduction requirements are met.
- d. A description of how the management practices listed above in Section II.3 are being met.
- e. The recommended agronomic loading rate from the references listed in Section II.3.c above, as well as the actual agronomic loading rate shall be retained.
- f. A description of how the site restrictions in 40 CFR 503.32(b)(5) and OAC 252:648 are met for each site on which Class B bulk sewage sludge is applied.
- g. The following certification statement:
- "I certify, under penalty of law, that the management practices in 40 CFR 503.14 have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."
- h. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 40 CFR 503.17(a)(4)(i)(B) or 40 CFR 503.17(a)(5)(i)(B) as applicable to the permittees sludge treatment activities.
- i. The permittee shall maintain information that describes future geographical areas where sludge may be land applied.
- j. The permittee shall maintain information identifying site selection criteria regarding land application sites not identified at the time of permit application submission.
- k. The permittee shall maintain information regarding how future land application sites will be managed

The person who prepares bulk sewage sludge or a sewage sludge material shall develop the following information and shall retain the information indefinitely. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for recordkeeping found in 40 CFR 503.17 and OAC 252:648 for persons who land apply.

- i. The location, by either street address or latitude and longitude, of each site on which sludge is applied.
- ii. The number of hectares in each site on which bulk sludge is applied.
- iii. The date and time sludge is applied to each site.
- iv. The cumulative amount of each pollutant in kilograms/hectare listed in Table 2 applied to each site.
- v. The total amount of sludge applied to each site in metric tons.
- vi. The following certification statement:

"I certify, under penalty of law, that the requirements to obtain information in 40 CFR 503.17(e)(2) have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision

in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the requirements to obtain information have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."

vii. A description of how the requirements to obtain information in 40 CFR 503.12(c)(2) and OAC 252:648 are met.

6. Reporting Requirements - The permittee shall report annually on the DMR the following information:

- a. Pollutant Table (2 or 3) appropriate for permittee's land application practices.
- b. The frequency of monitoring listed in Element 1, Section I.C which applies to the permittee.
- c. Toxicity Characteristic Leaching Procedure (TCLP) results (Pass/Fail).
- d. The concentration (mg/Kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) as well as the applicable pollutant concentration criteria (mg/Kg) listed in Table 3 found in Element 1, Section III, or the applicable pollutant loading rate limit (kg/ha) listed in Table 2 above if it exceeds 90% of the limit.
- e. Level of pathogen reduction achieved (Class A or Class B).
- f. Alternative used as listed in Section I.B.3.(a. or b.). Alternatives describe how the pathogen reduction requirements are met. If Class B sludge, include information on how site restrictions were met in the DMR comment section or attach a separate sheet to the DMR.
- g. Vector attraction reduction alternative used as listed in Section I.B.4.
- h. Annual sludge production in dry metric tons/year.
- i. Amount of sludge land applied in dry metric tons/year.
- j. Amount of sludge transported interstate in dry metric tons/year.
- k. The certification statement listed in 40 CFR 503.17(a)(4)(i)(B) or 40 CFR 503.17(a)(5)(i)(B) whichever applies to the permittees sludge treatment activities shall be attached to the DMR.
- l. When the amount of any pollutant applied to the land exceeds 90% of the cumulative pollutant loading rate for that pollutant, as described in Table 2, the permittee shall report the following information as an attachment to the DMR.
 - i. The location, by either street address or latitude and longitude.
 - ii. The number of hectares in each site on which bulk sewage sludge is applied.
 - iii. The date and time bulk sewage sludge is applied to each site.
 - iv. The cumulative amount of each pollutant (i.e., kilograms/hectare) listed in Table 2 in the bulk sewage sludge applied to each site.
 - v. The amount of sewage sludge (i.e., metric tons) applied to each site.
 - vi. The following certification statement:

"I certify, under penalty of law, that the requirements to obtain information in 40 CFR 503.12(c)(2) have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the requirements to obtain information have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."
- vii. A description of how the requirements to obtain information in 40 CFR 503.12(c)(2) and OAC 252:648 are met.

SECTION III. REQUIREMENTS SPECIFIC TO BULK OR BAGGED SEWAGE SLUDGE MEETING POLLUTANT CONCENTRATIONS IN TABLE 3 AND CLASS A PATHOGEN REDUCTION REQUIREMENTS

For those permittees with sludge that contains concentrations of pollutants below those pollutant limits listed in Table 3 for bulk or bagged (containerized) sewage sludge and also meet the Class A pathogen reduction requirements, the following conditions apply (Note: All bagged sewage sludge must be treated by Class A pathogen reduction requirements.):

- I. Pollutant limits - The concentration of the pollutants in the municipal sewage sludge is at or below the values listed.

TABLE 3

pollutant

Monthly Average Concentration
(milligrams per kilogram)*

Arsenic	41
Cadmium	39
Copper	1500
Lead	300
Mercury	17
Molybdenum	Report
Nickel	420
Selenium	36
Zinc	2800

* Dry weight basis

2. Pathogen Control

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, or lawn or home garden shall be treated by the Class A pathogen reduction requirements as defined above in Element 1, Section 1.B.3. All bagged sewage sludge must be treated by Class A pathogen reduction requirements.

3. Management Practices - None.

4. Notification Requirements - None.

5. Recordkeeping Requirements - The permittee shall develop the following information and shall retain the information for five years. The sludge documents will be retained on site at the same location as other OPDES records.

- a. The concentration (mg/Kg) in the sludge of each pollutant listed in Table 3 and the applicable pollutant concentration criteria listed in Table 3.
- b. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 40 CFR 503.17(a)(1)(ii) or 40 CFR 503.17(a)(3)(i)(B), and OAC 252:648 whichever applies to the permittees sludge treatment activities.
- c. A description of how the Class A pathogen reduction requirements are met.
- d. A description of how the vector attraction reduction requirements are met.

6. Reporting Requirements - The permittee shall report annually on the DMR the following information:

- a. Pollutant Table 3 appropriate for permittee's land application practices.
- b. The frequency of monitoring listed in Element 1, Section 1.C which applies to the permittee.
- c. Toxicity Characteristic Leaching Procedure (TCLP) results. (Pass/Fail).
- d. The concentration (mg/Kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) found in Element 1, Section 1. In addition, the applicable pollutant concentration criteria listed in Table 3 should be included on the DMR.
- e. Pathogen reduction Alternative used for Class A bagged or bulk sludge as listed in Section 1.B.3.a.
- f. Vector attraction reduction Alternative used as listed in Section 1.B.4.
- g. Annual sludge production in dry metric tons/year.
- h. Amount of sludge land applied in dry metric tons/year.
- i. Amount of sludge transported interstate in dry metric tons/year.
- j. The certification statement listed in 40 CFR 503.17(a)(1)(ii) or 40 CFR 503.17(a)(3)(i)(B), and OAC 252:648 whichever applies to the permittees sludge treatment activities, shall be attached to the DMR.

SECTION IV.

REQUIREMENTS SPECIFIC TO SLUDGE SOLD OR GIVEN AWAY IN A BAG OR OTHER CONTAINER FOR APPLICATION TO THE LAND THAT DOES NOT MEET THE POLLUTANT CONCENTRATIONS in Table 3

1. Pollutant Limits

TABLE 4

Pollutant	Annual Pollutant Loading Rate (kilograms per hectare per 365 day period)
-----------	---

Arsenic	2.0
Cadmium	1.9
Copper	75.0
Lead	15.0
Mercury	0.85
Molybdenum	Report
Nickel	21.0
Selenium	5.0
Zinc	140.0

2. Pathogen Control

All sewage sludge that is sold or given away in a bag or other container for application to the land shall be treated by the Class A pathogen requirements as defined in Section 1.B.3.a.

3. Management Practices

Either a label shall be affixed to the bag or other container in which sewage sludge that is sold or given away for application to the land, or an information sheet shall be provided to the person who receives sewage sludge sold or given away in another container for application to the land. The label or information sheet shall contain the following information:

- The name and address of the person who prepared the sewage sludge that is sold or given away in a bag or other container for application to the land.
- A statement that application of the sewage sludge to the land is prohibited except in accordance with the instructions on the label or information sheet.
- The annual whole sludge application rate for the sewage sludge that will not cause any of the annual pollutant loading rates in Table 4 above to be exceeded.

4. Notification Requirements - None.

5. Recordkeeping Requirements - The sludge documents will be retained on site at the same location as other OPIDES records.

The person who prepares sewage sludge or a sewage sludge material shall develop the following information and shall retain the information for five years.

- The concentration in the sludge of each pollutant listed above in found in Element 1, Section 1, Table 1.
- The following certification statement found in 40 CFR 503.17(a)(6)(iii).

"I certify, under penalty of law, that the management practices in 40 CFR 503.14(c), the Class A pathogen requirement in 40 CFR 503.32(a), and the vector attraction reduction requirement in (insert vector attraction reduction option) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices, pathogen requirements, and vector attraction reduction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment".

- A description of how the Class A pathogen reduction requirements are met.
- A description of how the vector attraction reduction requirements are met.
- The annual whole sludge application rate for the sewage sludge that does not cause the annual pollutant loading rates in Table 4 to be exceeded. See Appendix A to 40 CFR Part 503 - Procedure to Determine the Annual Whole Sludge Application Rate for a Sewage Sludge.

6. Reporting Requirements - The permittee shall report annually on the DMR the following information:

- Pollutant listed in Table 4 as appropriate for permittee's land application practices.
- The frequency of monitoring listed in Element 1, Section 1.C which applies to the permittee.
- Toxicity Characteristic Leaching Procedure (TCLP) results (Pass/Fail).
- The concentration (mg/Kg) in the sludge of each pollutant listed above in Table 1 (defined as a monthly average) found in Element 1, Section 1.
- Class A pathogen reduction Alternative used as listed in Section 1.B.3.a. Alternatives describe how the pathogen reduction requirements are met.
- Vector attraction reduction Alternative used as listed in Section 1.B.4.
- Annual sludge production in dry metric tons/year.

- h. Amount of sludge land applied in dry metric tons/year.
- i. Amount of sludge transported interstate in dry metric tons/year.
- j. The following certification statement found in 40 CFR 503.17(a)(6)(iii) shall be attached in the DMR.

"I certify, under penalty of law, that the management practice in 40 CFR 503.14(e), the Class A pathogen requirement in 40 CFR 503.32(a), and the vector attraction reduction requirement (insert appropriate option) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel gather and evaluate the information used to determine that the management practice, pathogen requirements, and vector attraction reduction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment."

ELEMENT 2 - MUNICIPAL SOLID WASTE LANDFILL DISPOSAL

SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE DISPOSED IN A MUNICIPAL SOLID WASTE LANDFILL

1. The permittee shall handle and dispose of sewage sludge in accordance with the Act and all other applicable federal and state regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present. The permittee shall ensure that the sewage sludge meets the requirements in 40 CFR Part 258 concerning the quality of the sludge disposed in the municipal solid waste landfill (MSWLF) unit.
2. If requirements for sludge management practices or pollutant criteria become more stringent than the sludge pollutant limits or acceptable management practices in this permit, or control a pollutant not listed in this permit, this permit may be modified or revoked and reissued to conform to the requirements promulgated under the Act.
3. If the permittee generates sewage sludge and supplies that sewage sludge to the owner or operator of a MSWLF for disposal, the permittee shall provide to the owner or operator of the MSWLF appropriate information needed to be in compliance with the provisions of this permit.
4. The permittee shall give prior notice to the Director, Water Quality Division, DEQ, 707 N. Robinson, Oklahoma City, Oklahoma 73101-1677, of any planned changes in the sewage sludge disposal practice, in accordance with 40 CFR 122.41(d)(1)(iii). These changes may justify the application of permit conditions that are different from or absent in the existing permit. Change in the sludge use or disposal practice may be cause for modification of the permit in accordance with 40 CFR 122.62(a)(1).
5. The permittee shall provide the location of all existing sludge disposal/use sites to the State Historical Commission within 90 days of the effective date of this permit. In addition, the permittee shall provide the location of any new disposal/use site to the State Historical Commission prior to use of the site.

The permittee shall within 30 days after notification by the State Historical Commission that a specific sludge disposal/use area will adversely affect a National Historic Site, cease use of such area.
6. Sewage sludge shall be tested once during the life of the permit within one year from the effective date of the permit in accordance with the method specified at 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other approved methods. Sludge shall be tested after final treatment prior to leaving the POTW site. Sewage sludge determined to be a hazardous waste in accordance with 40 CFR Part 261, shall be handled according to RCRA standards for the disposal of hazardous waste in accordance with 40 CFR Part 262. The disposal of sewage sludge determined to be a hazardous waste, in other than a certified hazardous waste disposal facility shall be prohibited. The DEQ, Waste Management Division at (405) 271-5338, shall be notified of test failure within 24 hours. A written report shall be provided to this office within 7 days after failing the TCLP. The report will contain test results, certification that unauthorized disposal has not occurred and a summary of alternative disposal plans that comply with RCRA standards for the disposal of hazardous waste. The report shall be addressed to the Director, Waste Management Division, DEQ, 707 N. Robinson, Oklahoma City, Oklahoma 73101-1677, and a copy sent to the Director, Water Quality Division, DEQ, at the same address.
7. Sewage sludge shall be tested as needed, or at a minimum, once/year in accordance with the method 9095 (Paint Filter Liquids Test) as described in "Test Methods for Evaluating Solid Wastes, Physical/Chemical Methods" (EPA Pub. No. SW-846).
8. Recordkeeping requirements - The permittee shall develop the following information and shall retain the information for five years.
 - a. The description, including procedures followed, and results of the Paint Filter Tests performed.
 - b. The description, including procedures followed, and results of the TCLP Test.
9. Reporting requirements - The permittee shall report annually on the Discharge Monitoring Report the following information:
 - a. Results of the Toxicity Characteristic Leaching Procedure Test conducted on the sludge to be disposed (Pass/Fail).
 - b. Annual sludge production in dry metric tons/year.
 - c. Amount of sludge disposed in a municipal solid waste landfill in dry metric tons/year.
 - d. Amount of sludge transported interstate in dry metric tons/year.
 - e. A certification that sewage sludge meets the requirements in 40 CFR Part 258 concerning the quality of the sludge disposed in a





municipal solid waste landfill unit shall be attached to the DMR.



F:\standard municipal permit documents\part iv.doc
updated 8/21/98

APPENDIX TM 1-4
TEMPLATE FOR CONDITION RATING

FACILITY INSPECTIONS

Condition Assessment Ratings

Condition Rating	Percent of Useful Life Remaining	General Description of Condition	Photo Examples
New	100-90	<ul style="list-style-type: none"> ✓ Newly built to recently built ✓ No wear ✓ Operates as designed ✓ No maintenance needed 	
Excellent	90-75	<ul style="list-style-type: none"> ✓ Recently built ✓ Little to no appreciable wear ✓ Operates as designed ✓ Normal maintenance 	
Good	75-55	<ul style="list-style-type: none"> ✓ Within first half of useful life ✓ Slight wear ✓ Operates as designed ✓ Normal to slight maintenance needed 	
Fair	55-35	<ul style="list-style-type: none"> ✓ At or beyond first half of useful life ✓ Slight to significant wear ✓ Normally operates as designed ✓ Slight to supplementary maintenance needed 	

Condition Rating	Percent of Useful Life Remaining	General Description of Condition	Photo Examples
Poor	35-15	<ul style="list-style-type: none"> ✓ Beyond first half of useful life to at the end of useful life ✓ Significant to major wear ✓ Operates as designed with additional to significant maintenance ✓ Significant to burdensome maintenance necessary 	
Replace	15-0	<ul style="list-style-type: none"> ✓ Beyond useful life in need of replacement ✓ Major wear ✓ Will not operate as designed without significant and constant maintenance, is inoperable or abandoned ✓ Significant to burdensome constant maintenance necessary 	

APPENDIX TM 1-5

NITRIFICATION CLARIFIER OPERATIONAL ISSUES

Memorandum

To: Robert Hitt; Jim McClain, Muralikumar, Joyce Hight,

From: Jose Pereira

Date: September 19, 2005

Re: Nitrification Clarifiers – Handling capacity & operational issues - S-0505A

During a site visit on 08/31/05 to the City of Enid Water Pollution Control Facility, the facility staff indicated that when flows exceed 7 mgd there is high solids carryover in the final effluent, although the design capacity of the final clarifiers in the nitrification plant were designed to handle 8.5 mgd. This technical memorandum offers our comments/recommendation on the operation of the nitrification plant following our inspection of the nitrification plant and review of as-built plans.

As you know, the nitrification plant was originally designed to handle average and peak flows of 8.5 mgd and 21 mgd, respectively at an average BOD₅ of 30 mg/l and TSS of 20 mg/l. The nitrification plant is equipped with four rectangular clarifiers, each 30' wide by 120' long by 12' SWD. These rectangular clarifiers are equipped with traveling bridge mechanisms for the collection and removal of settled sludge and effluent troughs with V- notch weirs to distribute the flow uniformly and improve the effluent quality. Our calculations show that the surface overflow rates at average and peak flows are 590gpd/ft² and 1,458gpd/ft² respectively. The weir loading rates at average and peak flows are estimated to be 5,902 gpd/ft and 14,583 gpd/ft respectively, which are within recommended design criteria (10,000 gpd/ft at average flow and 15,000 gpd/ft at peak flow). However, during our visual inspection of the traveling bridge clarifiers, we noticed few operational issues that could possibly impair the effluent quality, particularly during high flow conditions. These Observations are as follow:

- a. The nitrification plant rectangular clarifier effluent troughs are not leveled, which affects the V-notch weirs elevation. The elevation of the V-notch weirs at the east end of the clarifiers is lower than the west end. As a result, there is no overflow on the V- notch weirs located at the west end of the clarifier troughs and most of the flow occurs through the east end creating more undercurrent and turbulence. This is confirmed by the operators when the flow exceeds 7 mgd the v-notch weirs at the east end of the clarifier troughs become submerged. The V-notch weir submergence does not reflect under designed of the weirs but instead overcharge due to the unlevelled surface.
- b. The traveling bridge mechanism used for sludge collection has a supporting truss extending all the way down in to the clarifier bottom. The traveling bridge also has too many moving parts for its operation and the movement of the bridge on the rail is not smooth and at times, creating a jerk sudden movement possibly due to wear and tear on the traveling parts as result of the equipment age. The truss/other parts on the traveling bridge, and agitation due to the sudden jerk movement could possibly create an under current wave that could stir the settled/settling solids in the clarifier through out the basin and impact the effluent quality, particularly during the high flow conditions.

In summary, it is our opinion that if the plant is operated within the design range and if the above operational deficiencies are corrected, as well as other manufacturer recommendations to fine tune its operation, we anticipate that the final clarifiers could see a major improvement and handle the flow as originally designed. However, additional information and evaluation will be required before final conclusions are recommended.

1. INTRODUCTION

Dewberry was retained by the City of Enid to prepare a Sanitary Sewer Master Plan. In turn, ENVIROTECH ENGINEERING & CONSULTING, INC., was retained by Dewberry Engineering to provide an evaluation of the existing sanitary sewer collection system and provide recommendations for sewer improvements, based on current and future. The ENVIROTECH study assessed the current sanitary sewer system to include sanitary sewer mains, pump stations, wet weather holding facilities, and run-off basins. In addition, a sanitary sewer monitoring program recorded flow data from strategic points throughout the sanitary sewer system. Estimated sanitary sewer usage rates were calculated for dry flow conditions and all of the data was entered into a computer model and calibrated against the sanitary sewer monitoring program.

During rainfall events, the stormwater runoff entering the sanitary sewer collection system is defined as Inflow and Infiltration (I/I). This runoff can potentially overwhelm the sanitary sewer system's capacity and result in discharges to local waterways. ENVIROTECH utilized the sanitary sewer monitoring program to determine stormwater I/I flows. The storm event was increased to a 100-year event, and these flows were compared to EPA's maximum allowable I/I flows to determine the extent of I/I that the collection system was experiencing. The computer model was used to diagnose the inadequacies in the sanitary sewer collection system and determine the improvements needed.


2. EXISTING COLLECTION SYSTEM

- 2.1 Sanitary Sewer Drainage Basins.** The City of Enid's engineering department assisted during the sanitary sewer computer model development by providing manhole inspection reports, an AutoCAD sanitary sewer model, and pumping and sanitary sewer storage data. This information can be reviewed at the City of Enid's administrative offices located at 401 West Owen K. Garriott Road.

ENVIROTECH continued with the City of Enid's previously-implemented manhole labeling system during development of the sanitary sewer model. The City is divided into two (2) major sanitary sewer pipelines encompassing 16 basins (A-P) and 11 basins (A-K), respectively. Each sanitary sewer system basin was divided into sub-basins for a total of 125 sub-basins. The sanitary sewer system sub-basins are graphically depicted on *Figure 1*.

Although this report is limited to the study area provided by the City of Enid, sanitary sewer lines extend beyond the area mapped by the City of Enid. This mainly includes lines in the 1-N basin in the vicinity of Northwestern University on 30TH Street and Purdue Road as well the 2-D basin that services Vance Air Force Base. A trunk line fed by a pump station services the Base, but remains outside the City of Enid's mapped limits.

- 2.2 Pump Stations and Force Mains.** A total of eleven (11) pump stations and force mains are located on the City of Enid's sanitary sewer pipeline. Of the eleven (11) pump stations, only the pump station located at 541 South 54TH Street appears on the model. The remaining



Date: August 2008
 Scale: 1" = 1250'
 Designed by: J. Voss
 Drawn by: J. Voss
 Checked By: J. Stallings
 Project No. 05.123

ENVIROTECH
 ENGINEERING & CONSULTING, INC.
 2500 North 11th Street - Enid, Oklahoma 73701
 Phone (580) 234-8780, Fax (580) 237-4302
 C.A. #1960 - Expiration Date: 6-30-2008
 www.envirotechconsulting.com

Figure 1 - Sanitary Sewer Basins
 Enid Sanitary Sewer Monitoring
 City of Enid

Dewberry®

pump stations either exist outside the mapped parameters of the City of Enid's sanitary sewer basins or are located far upstream and utilized for isolated residential districts and therefore, these pump stations are inconsequential to the system. Pump station details, locations, and reasons for not including them in the model are summarized in *Table 1*.

TABLE 1.

SUMMARY OF STATIONS NOT INCLUDED IN THE MODEL COMPARISON

STATION	LOCATION	PUMP RATING (gpm)	INCLUDED	BASIN	COMMENTS
Chisholm Creek	4607 Chisholm Creek	N/A	No	1N4	Feeds from Basin 1N4 (North Enid)
Fairgrounds	225 W. Purdue	10	No	1N4	Outside existing model
54 TH Street	541 S. 54 TH Street	1,520	Yes	1P	Lifts all from the 1-P Basins
Phillips	2429 1/2 N. 30 TH	100	No	1N7	Small and outside existing model
S. Hayes	1600 S. Hayes	160	No	2D2	Serves a small portion of the 2D2 Basin
Neilson	3105 W. Maine	385	No	2J5	Serves a small portion of the 2J5 Basin
Scooters	N. Van Buren	125	No	1O5	Outside existing model (from Scooters)
Union	2811 N. 6 TH Street	75	No	1N6	Serves a small portion of the 1N6 Basin
Willow Underpass	833 E. Willow	385	No	1N6	Serves a small portion of the 1N6 Basin
Airport	66 TH St. and Airport	80	No	1P3	Pumps directly to the 54 TH Street Lift Station
Vance AFB	Vance AFB	N/A	No	2D3	Outside existing model

2.3 Wet Weather Holding Facilities. A total of three (3) modeled wet weather peak holding facilities are located in the City of Enid. The first holding facility is located at 658 West Willow on the 1-O line and a second facility is located at 1901 East Randolph on the 1-C line. Both facilities were modeled as a 500,000-gal. facilities with appropriate control structures.

The third holding facility is located at the City of Enid's sanitary sewer treatment plant for wet weather overflow. The sanitary sewer department estimates the volume of this holding basin to be approximately 280-ac-ft.

3. FLOW METERING AND ANALYSIS

During storm events, a dramatic increase in the inflow into the City of Enid's sanitary sewer treatment plants occurs and in some instances, overflow storage is utilized to prevent the increased flows from exceeding the plant's capacity. Excessive wastewater treatment due to stormwater run-off has

historically been a problem for the City of Enid. These increased stormwater flows originate from inflow and infiltration.

Inflow is defined as additional stormwater flowing into the wastewater stream from *aboveground sources* to include downspouts, foundation drains, leaking manhole covers, and cracked pipelines in stormwater channels. **Infiltration** is defined as additional stormwater entering the wastewater stream from the *surrounding soil* resulting from cracked pipelines and service laterals, separated joints, and leaking manholes.

Several investigative methods are utilized during sanitary sewer system evaluations to determine the most effective method of decreasing inflow and infiltration to include the following:

- Inflow and Infiltration (I/I) Studies.** Inflow and Infiltration (I/I) studies are useful for determining where the increased flows are originating in order to establish solutions for the increased sanitary sewer flows. The results of these studies mainly determine the approximate locations for conducting more rigorous sanitary sewer investigations. Sanitary sewer flow monitoring is used in conjunction with the Inflow and Infiltration (I/I) study to calibrate and evaluate the generated computer model.
- Dye Testing.** Dye testing is a large-scale analysis that involves introducing dyes in upstream catch basins. The quantity of dye recovered in the sanitary sewer treatment plant is used as an indicator of inflow in a particular basin. However, these test results can be misleading and are often difficult to accurately calibrate due to the inflow sources.
- Smoke Testing.** Smoke testing is accomplished by introducing (i.e., pumping) non-toxic smoke into the sanitary sewer system while simultaneously observing and documenting the location of the exiting smoke. Smoke testing activities will reveal pipeline cracks, connected roof drains, unsealed manholes, yard drains, and other sources associated with damaged pipelines and/or associated connections. It should be noted that smoke testing is a location-specific procedure and therefore, it is not recommended for extensive areas.
- TV Inspection.** TV inspection is a testing procedure limited to a single pipe per test inspection. However, this test will reveal cracked or broken pipelines in addition to eroded piping that results in groundwater infiltration or root intrusion that is not revealed by smoke testing activities.
- Door-to-Door Surveys.** Door-to-door surveys can assist in locating downspouts, gutter drains, sump pumps, and other stormwater inflow into the sanitary sewer system. Homeowners are often knowledgeable about sanitary sewer connections and can assist during smoke testing operations.

3.1 **Flow Metering Program.** In conjunction with Dewberry, ENVIROTECH conducted flow-monitoring services for the inflow and infiltration study. *Flo Tote* sanitary sewer monitoring

devices were utilized at strategic locations throughout the City of Enid for both dry and wet conditions. The meters were initially placed on trunk and secondary trunk lines. As flow information was assimilated, the meters were relocated to tertiary lines that were suspected sources of inflow and infiltration.

The flow-monitoring program provided both dry and wet weather flows. Each meter remained in-place until the line experienced a significant wet weather flow before being relocated to isolate the suspected sources of inflow and infiltration. This data was utilized in conjunction with a hydraulic model to predict sanitary sewer flows throughout the City of Enid and is included in *TM-2-1*.

In addition, the City of Enid provided Envirotech with daily sanitary sewer treatment rates (i.e., amount of treated sewage from all sources) which is on file at the City of Enid's 54TH Street treatment facility. For the project's duration, the facility treated an average of 6.8-MGD of sanitary sewage.

3.2 Determination of Dry Flows and Model Development. Typical sanitary sewer usage flow rate values, published by the *Oklahoma Department of Environmental Quality (ODEQ), Title 252, Chapters 656 and 641*, were utilized to determine the flows from each basin. The developed flows were then calculated on a typical daily sanitary sewer usage curve and input into the SWMM sanitary sewer model. The usage calculations are included in *TM-2-2*.

3.3 Description of Hydraulic Model. The City of Enid's sanitary sewer system was modeled utilizing the *United States Environmental Protection Agency Sanitary Water Management Model (USEPA SWMM)* (version 5.0.011), based on sanitary sewer collection system data and calculated dry flow usage rates provided by the City of Enid. This model was utilized to evaluate the following scenarios:

- Pipelines that have reached or exceeded their full capacity during normal everyday flow events that require upgrading or replacement.
- Pipelines that have reached or exceeded full capacity during a storm event that require construction of an additional in-system storage facility to alleviate impacts to the system.
- Problematic areas in the sanitary sewer system for future study. These areas may include cracked or eroded pipes, unsealed manholes, or stormwater drains connected to the sanitary sewer system.

Following completion of the SWMM model, the model was calibrated utilizing flow documentation recorded by the *Flo Tote* sanitary sewer monitoring devices. The relationship between the modeled values and actual recorded values for dry flow conditions is summarized in *Table 2*.

TABLE 2.
COMPARISON OF MODELED VALUES VS. ACTUAL RECORDED VALUES FOR
DRY FLOW CONDITIONS

Name	Basin	Location	Metered Flow		Model Flow	
			Base Flow (gpm)	Peak Flow (gpm)	Base Flow (gpm)	Peak Flow (gpm)
North Main	1-A	West 16 TH	550	1700	1352	3495
NOC	1-B	NOC	280	930	350	875
	1-C	19 TH & Randolph	15	65	30	71
30 TH Street	1-D	30 TH & Garriott	65	140	56	135
Downtown	1-F Fed by 1-G and 1-H	2 ND & Randolph	2	14	7	16
		Pasttimes	31	78	32	77
		3 RD & Main	40	110	53	130
	1G2	5 TH & Randolph	60	225	50	220
	1-I Fed by 1-J and 1-K	Ind. & Oklahoma	150	300	167	280
Integriss Pavilion		363	775	330	744	
North Enid	1-N	4 TH & Beech	70	275	123	295
		3 RD & Beech	85	300	166	320
N. Van Buren	1-O	N. Van Buren	NA	330	148	356
54 TH Street	1-P	54 TH Street Lift	274	1200	504	1210
Brookside	2-B	BS Trunk Line	500	1750	1377	2470
		BS Res.	2	20	NA	NA
South Main	2-C	East 16 TH Street	440	1650	390	1450
		West 16 TH Street	550	1700	1258	2373
S. Van Buren	2-D	S. Van Buren	40	240	101	245
Frantz Main	2-E	Jeff & Frantz	650	1850	1050	2200
Oakwood Mall	2-G	Mall	330	920	278	890
		Indian Oaks	200	650	300	758
Cleveland	2-H	Rand & Mck.	100	500	219	512
	2-I	Lisa Lane	35	143	53	130
	2-K	Cleveland & Chestnut	120	240	111	270

3.4 **Determination of Wet Weather Flows and Inflow and Infiltration.** In order to determine the wet weather events, the amount of rainfall each sanitary sewer basin receives must be

known. Initially, the catch basins were modeled in accordance with the *United States Department of Agriculture (USDA) TR-55 Urban Hydrology for Small Watersheds*. A modified version of the Soil Conservation Service (SCS) runoff curve method was utilized to determine infiltration. Although the run-off curve factor was calculated pursuant to the above-referenced USDA TR-55 document, the soil conductivity and basin width factors were substituted for time-of-concentration (as per the USEPA SWMM 5.0 Help Files.) Utilizing this data, unit hydrographs were produced for each basin and input into the model. In addition, the diameter and length of the pipe in each sub-basin was determined. The USCS calculations and piping information are included herein as *TM-2-3*.

For calibration purposes, rainfall was based on data obtained from the City of Enid's rainfall gauges and patterned on the rainfall distribution on the website weatherunderground.com for the Enid area, each rainfall event was modeled as an intensity hydrograph. The events were input into the model in order to calculate the inflow/infiltration for the associated storm event and compared to monitored storm events. For final modeling purposes, an SCS 8-in. Type II rainfall event was incorporated in the model as the 100-year design event. The patterned rain events are included herein as *TM-2-4*.

The limiting factor for infiltration is the storm event. A value of 200-gal./pipe dia./mi./day was assumed to occur during a 100-year storm event. Therefore, 200-gal. of infiltration/pipe dia./mi. was introduced into the sanitary sewer model with subsequent smaller storms events derived from the 100-year event. The SWMM engine calculated the smaller storm events and infiltration values from the SWMM Model were compared to the metered events recorded by the Flo Tote monitoring equipment. Actual infiltration values for gal./pipe dia./mi./day were derived for each monitoring point, as summarized in *Table 3*. A more detailed explanation of inflow/infiltration model development is included in *TM-2-5* and the final SWMM model output data is included in *TM-2-6*. In addition, an electronic copy of this model is included herewith and made a part of this report.

3.5 Model Limitations. While the SWMM model is extensive, the model limitations include the following:

- The model includes all 10-in. pipes and above, but ignores all 8-in. pipes and below.
- The model is also only as good as the input data provided. Much of the manhole and pipe data was old and contained only approximate manhole depths without invert elevations.
- New pipelines along Purdue Street and older pipeline at Vance Air Force Base were not available for inclusion in the model.
- Calibration data for dry and wet weather flows was incomplete. Although a large area was monitored, some flows remained uncalibrated and extrapolated from known flows for similar land uses.

TABLE 3.

SUMMARY OF MONITORING POINT INFILTRATION VALUES

Name	Basin	Location	100-Year Model Infiltration (gpm)	Storm Event	Date	Metered Flow gpm	Storm Event Infiltration gpm	Stormwater Infiltration gal./d/in./mil.
North Main	1-A	West 16 TH	4542	1.54	6/23/06	4654	4156	221
NOC	1-B 1-C	NOC	1291	2.7	4/28/06	1220	1220	200
		19 TH & Randolph	185	1.32	6/23/06	107	143	133
30 TH Street	1-D	30 TH & Garriott	296	2.7	4/28/06	167	201	159
Downtown	1-F Fed by 1-G and 1-H	2 ND & Randolph	41	1.32	6/23/06	49	32	269
		Pasttimes	115	NA	NA	NA	NA	NA
		3 RD & Main	190	2.36	4/28/06	420	185	312
	1-I Fed by 1-J and 1-K	Ind. & Oklahoma	370	Any	Any	680	370	291
		Integris Pavilion	838	1.32	6/23/06	2237	745	333
North Enid	1-N	3 RD & Rock Island	386	2.36	4/28/06	1036	354	332
		4 TH & Beech	374	1.01	5/24/07	331	406	155
		3 RD & Beech	370	1.32	6/23/06	NA	316	NA
N. Van Buren	1-O	N. Van Buren	518	1.01	5/24/07	766	418	291
54 TH Street	1-P	54 TH Street Lift	1229	Any	Any	NA	1229	NA
Brookside	2-B	B5 Trunk Line	5897	1.73	4/13/07	3748	3443	216
South Main	2-C	East 16 TH Street	5617	1.3	8/20/06	2033	5030	-95
S. Van Buren	2-D	S. Van Buren	601	1.11	3/30/07	482	499	193
Oakwood Mall	2-G	Mall	1999	1.32	6/23/06	1901	1203	273
		Indian Oaks	986	NA	NA	NA	NA	NA
Cleveland	2-H	Rand. & Mck.	1473	0.8	5/30/07	840	888	189
	2-I	Lisa Lane	441	2.36	4/28/06	805	280	330
	2-K	Cleveland & Chestnut	811	1.32	6/23/06	574	520	219

Note: Modeled infiltration values based on 200-gal./day/in./dia./mi.

4. ADEQUACY OF EXISTING SYSTEM

4.1 **Current Design Conditions.** An analysis of the SWMM model pipeline was conducted to identify problem areas during both dry and wet weather flow conditions. Pipe capacity is

often referred to as the fundamental factor in determining the volume of flow a sanitary sewer system can convey in a specific location. Pipe capacity is defined as the volume of flow a pipe at 3/4-full capacity can convey and is based on the minimum slope and actual diameter of the pipe. The steeper the slope or larger the pipe's diameter, the greater the pipe's capacity to convey increased flow volumes.

4.2 Existing System Evaluation. Although the current system is old, it is in a fairly well-preserved condition. Much of the system continues to receive less than 200-gal./pipe dia./mi./day of infiltration. With the exception of a few isolated lines, infiltration exceeds 200-gal./pipe dia./mi./day by relatively small amounts. Additional sanitary sewer investigations will assist in decreasing the amount of inflow and infiltration into the system. However, some upgrades are necessary in the immediate future to accommodate wet flows and new industrial flows as Enid develops.

4.2.1 Dry Flow Condition Analysis. During periods of no precipitation, the Line 1 Basin A (1A) and Line 1 Basin P (1P) pipes appear to be flowing at or near capacity and therefore, the City of Enid intends to construct an additional pipeline adjacent to the current 1P pipe for increased flow capacity. Although the 1A pipeline performs at or above capacity during dry flow conditions, plans should be implemented to increase this pipeline's capacity as well.

There is some confusion regarding the 1N pipeline that extends toward North Enid. Two (2) lines converge in the vicinity of the 1N008 manhole, but neither City of Enid or ENVIROTECH engineers could determine the exact path of the sanitary sewer manholes. In the current model set-up, the manhole connecting the two (2) branches of the 1N pipeline surcharges during dry flow conditions.

The 1N pipeline in the vicinity of North Van Buren receives inordinately high flow rates for the businesses and residents served in the area. This pipeline was recently upgraded to accommodate these higher flow rates. Although an additional investigation may help identify the source of these flows, the new pipeline can adequately manage these higher flow rates.

The 1-J pipeline trunk line flows above capacity during dry periods. Both the 1-J and 1-K Basins feed this pipeline. Plans should be made to increase the capacity of this pipeline.

4.2.2 Wet Flow Condition Analysis. During precipitation events, flows in the sanitary sewer pipelines greatly increase due to Inflow and Infiltration (I/I). According to the wet condition model, the capacity of most pipelines is sufficient to accommodate the increased flow rates. However, flow back-ups occur in the 1A and 2A pipelines due to sanitary sewer treatment plant and pipeline capacity limitations associated with the

additional flows. Due to the increased flows, additional back-ups will also occur in lower portions of the 1B, 1D, and 2B pipelines.

The 1N pipeline appears to experience additional surcharging during storm events in addition to the surcharging experienced during dry events. In addition, the 1-J pipeline remains surcharged for extended periods during wet events due to increased flow.

4.3 Inadequacies in the Existing System. Currently, the City of Enid's sanitary sewer collection system experiences an annual peak dry flow of approximately 7-mgd. Several collection basins exhibit the need for investigation, rehabilitation, or increased capacity. The basins requiring improvement and the degree of urgency are graphically depicted on *Figure 2*. A description of the affected basins and associated improvement recommendations are summarized in the following paragraphs.


4.3.1 Basin 1P Expansion Recommendations. Currently, the 12-in. trunk line serving the 1P Basin is operating at capacity and therefore, system expansion should be considered to allow for continued growth in east Enid. ENVIROTECH recommends construction of a second, minimum 24-in.-dia. pipeline adjacent to the existing 12-in.-dia. pipeline. This upgrade will accommodate flows from both the new Advanced Foods facility and Ethanol treatment facilities.

The cost for this upgrade will be approximately \$2.5 million.

4.3.2 Basins 1A and 2A Peak Holding Tank Recommendations. The City of Enid has experienced overflow events in the 1A and 2A pipelines near the sanitary sewer treatment plant at Boggy Creek. Based on both the physical evidence and SWMM modeled flows, this trend will continue to occur and therefore, construction of a peak flow holding tank appears to be the most effective solution. Although additional study and design is necessary, ENVIROTECH recommends utilizing the old sanitary sewer treatment facility as an appropriate site.

The overflow tank's capacity should be approximately 800,000-gal. and the cost is estimated to be \$1.5 million.

4.3.3 Basins 1J and 1K Expansion Recommendations. The 1-J pipeline flows above capacity during dry periods and remains surcharged for long periods during wet events. Therefore, ENVIROTECH recommends that an investigation of the I/I sources utilizing smoke testing, door-to-door surveys, and video monitoring, where appropriate, be conducted. In addition, the pipe capacity needs to be expanded and may include a few small pipe and manhole replacements to the entire pipeline replacement.



Legend

- Critical Priority Investigation
- High Priority Investigation
- Secondary Investigation
- Tertiary Investigation
- Lowest Priority Investigation



Figure 2 - Sewer Investigation
 Enid Sanitary Sewer Monitoring
 City of Enid

ENVIROTECH
 ENGINEERING & CONSULTING, INC.
 2500 North 11th Street, Enid, Oklahoma 73701
 Phone: (580) 234-9700 Fax: (580) 234-3008
 www.envirotechconsulting.com

Date: August 2008
Scale: 1" = 1250'
Designed by: J. Voss
Drawn by: J. Voss
Checked by: J. Stallings
Project No. 05.123

Based on the results of the I/I study, this project will cost between \$100,000 and \$600,000.

- 4.3.4 Basin 2H Investigation.** Basin 2H receives little inflow during small storm events and exceedingly high amounts of inflow during large events. Since the pipeline is located near a stormwater channel, a possibility exists that the line is receiving inflow from the channel. Therefore, ENVIROTECH recommends that a more detailed I/I study be conducted in this basin to include smoke testing and video monitoring, where appropriate.
- 4.3.5 Basin 1N Investigation.** The exact configuration of Basin 1N near the confluence with the 24-in. cross-town main is not known. In addition, the 1N basin receives high amounts of inflow during storm events. Therefore, ENVIROTECH recommends that a more detailed investigation of the 1N basin be conducted to include smoke testing, door-to-door surveys, and video monitoring, where appropriate.
- 4.3.6 Basins 2G and 2K Investigations.** Basins 2G and 2K receive higher than EPA-recommended rates of infiltration. Therefore, ENVIROTECH recommends conducting additional sanitary sewer inflow and infiltration investigations in these basins to include smoke testing and video monitoring, where appropriate.

Total Estimated Cost (7-MGD - 2007) \$4.3 million

5. FUTURE COLLECTION SYSTEM EVALUATION

In order to alleviate manhole surcharging and prepare for expanding the sanitary sewer pipeline network, ENVIROTECH has prepared recommendations for sanitary sewer improvements and additional Inflow and Infiltration (I/I) investigation(s).

- 5.1 Future Design Conditions.** Recent trends in the City of Enid's expansion efforts reflect growth to the east, northwest and west, with each direction of growth representing a different type of development. Industry in east Enid has expanded as a result of construction of the Advanced Foods Processing Plant and the proposed Ethanol production facilities. Residential development is steadily expanding northwest of Enid while a combination of commercial and residential development dominates westward expansion along Owen K. Garriott Road. As a result of this growth, recommendations for expanding the affected sanitary sewer basins are summarized in the following sections of this report.
- 5.2 Hydraulic Capacity Evaluation - Year 2010 (9-MGD).** As the City of Enid develops/expands and the sanitary sewer capacity reaches 8.5- to 9-MGD, several expansions to the sanitary sewer collection system will be necessary.

5.2.1 Basins 2H and 2K Expansion Recommendations. Residential expansion northwest of Enid poses minimal short-term problems regarding the sanitary sewer system's capacity. Although Basins 2H and 2K have not yet reached total flow volume capacity, additional residential growth may require system expansion in the future. Expansion recommendations for Basins 2H and 2K are as follows:

- **BASIN 2H.** Since several collection lines will eventually reach capacity, alternative collection lines may be required to service the expanding community. The 12-in. line that services Sub-basin 2H-2 will most likely reach capacity and subsequently, the 18-, 21-, 24- and 27-in. collection pipelines will also near capacity. In addition, some of these lines may require improvement.

The cost to upgrade the 12-in. pipeline alone is estimated to be \$500,000. Additional upgrades to the 18- and 21-in. collection pipelines will cost approximately \$1.3 million.

Total Estimated Cost..... \$1.8 million

- **BASIN 2K.** The 12-in. collection line that services Basin 2K and flows north-south down Cleveland Road will eventually reach capacity. This will subsequently affect the same 24- and 27-in. collection lines referenced above for Basin 2H, resulting in surcharging and backup in the pipelines. Depending upon peak flow rates, the 30-in. Frantz Street line may also require improvement.

The cost to upgrade the 12-in. pipeline is estimated to be \$1.3 million. Additional upgrades to the 24- and 27-in. pipelines will cost approximately \$1.8 million. The cost to improve the 30-in. Frantz Street pipeline is estimated between \$2 million and \$7 million, depending on the extent of pipeline replacement required.

Total Estimated Cost..... \$7.1 million

5.2.2 Basin 2G Expansion Recommendations. Continued commercial and residential growth westward along Owen K. Garriott Road may be impeded by the existing sanitary sewer system that services this area. Currently, the Basin 2 pipeline that transverses the southern portion of the City has sufficient capacity to easily accommodate expansion both west and northwest of Enid. However, once the pipelines reach Oakwood Road, the sizes decrease to 12- and 8-in.-dia. beyond Bob's Farm residential development. Therefore, it is recommended that the pipeline network capacity be expanded from the Bob's Farm complex westward along Oakwood Road to accommodate additional growth.

This can be accomplished by either expanding the 12-in. pipeline that services Bob's Farm further west, or installing a second 12-in. pipeline westward on the north side of Owen K. Garriott Road. The cost to complete this work is estimated to be \$800,000.

In addition, the 12- and 18-in. collection pipelines that service the Bob's Farm pipeline will require improvement. The cost to upgrade the 12- and 18-in. collection pipelines is estimated to be \$2 million.

Total Estimated Cost..... \$2.8 million

Estimated Cost for Section 5.2 Improvements..... \$11.7 million

Total Estimated Cost (9-MGD - 2010) \$16 million

5.3 Hydraulic Capacity Evaluation - Year 2015 (11-MGD). In the event the City of Enid continues to develop/expand and flows increase to 11-MGD, several of the main lines will begin to back-up and flows will push into residential lines. Most lines above 18-in.-dia., including some select lines below 18-in.-dia., will require upgrading to accommodate the increased flows. Alternatively, additional collection lines paralleling existing lines would be required to alleviate the increased flows.

These upgrades represent improvements that must be made to the system in addition to those already summarized in sections 4.3 and 5.2.

5.3.1 Sanitary Sewer Main Expansion. Several sanitary sewer mains that transverse the City will experience increased flows and therefore, many will need to be replaced and include (a) 1A and 2A main lines south of the City; (b) north-south 36-in. main from 11TH Street to Van Buren and Willow; (c) Frantz Street 30-in. cross-town main; and (d) 2D line servicing Vance Air Force Base (VAFB).

The cost for this expansion is estimated to be in the \$20 million range.

5.3.2 Sanitary Sewer Collection Lines. The secondary collection pipelines that will require improvements in addition to those outlined in Section 5.2 are as follows:

- The Oakwood pipeline will require an additional \$1 million expansion north of Owen K. Garriott Road.
- The north-south 36-in. main will require that a collection pipe be extended to the north along Van Buren. This line will most likely require construction of

an additional pump station and therefore, the expansion will cost approximately \$2.5 million.

- The 1N pipeline will require improvement, both east and north, at an approximate cost of \$2 million.
- The Basin 2D 10-in. pipeline that services southeast Van Buren will require improvement at an approximate cost of \$2 million.
- Although additional flows north of Basin 1C will burden the existing pipelines, they should maintain below full-capacity.

5.3.3 Peak Storage Basins. As a result of high flow rates, the occurrence of stormwater seepage will be significant and therefore, construction of two (2) additional stormwater peak storage basins should be considered. One (1) tank should be located on south Cleveland Road where the Oakwood and Cleveland sanitary sewer systems converge; and the second tank should be located where the 2D and 2A pipelines merge. Each facility should detain approximately 800,000- to 1-million-gal.

Estimated Cost to Construct Both Facilities \$4 million.

Estimated Cost for Section 5.3 Improvements..... \$31 million

Total Estimated Cost (11-MGD - 2015) \$47 million

6. CONCLUSIONS

The sanitary sewer collection model constructed for the City of Enid should be considered a working model that should be continually updated as new information becomes available. This will provide the City of Enid a real-time tool to answer questions concerning current sanitary sewer capacity and future growth.

Overall, the City of Enid's sanitary sewer capacity can adequately accommodate flows of 8-MGD and below. As the City expands, additional sanitary sewer capacity will be required. In addition, as flows increase to 10-MGD, some minor expansion projects will be required to ensure sufficient sanitary sewer capacity. Once flows reach 11-MGD, major expansions to the sanitary sewer system will be required.

The SWMM computer model and the 2007 AutoCAD sanitary sewer system drawing are included in electronic format with this report.

Engineering Calculations (I/I Study)

Engineering Notes:

Problem: Determine amount of I/I in each Sewer Basin

Assumption: The maximum allowable inflow/infiltration for a sewer operating within "normal" limits is 200 gallons/mile/day/in-diameter

- Step 1: TM 2-1 From the flow data gathered from the city sewers, determine average and peak daily flows as well as peak storm water flows. Correlate the storm flows with their individual storm Flow data was divided into yearly quarters and analyzed for peak flows. Flow data was analyzed on a 15 minute basis to determine flow profile and base flow for each monitoring point. Some conditions were taken into account, such as line back ups, surcharging, and seasonal flows.
- Step 2: TM 2-2 Calculate the Municipal sewer inflows
Utilizing typical inflows from municipal sources, inflows in the various sub-basins were calculated throughout the city.
- Step 3: TM 2-3 Determine the US SCS curve numbers, % impervious, and conductivity for each sub-basin.
Calculated utilizing TR-55 techniques through observation
- Step 4: TM 2-3 Determine the length*in-diameter of the sewer pipe and area of each sub-basin.
Calculated by observation.
- Step 5: TM 2-4 Determine the rainfall for the 100-year storm and the individual storms in Enid
Data obtained from TR-55 and weatherunderground.com in combination with the City of Enid raingauges
- Step 6: TM 2-5 Determine the hydrograph of the infiltration/inflow
The SWMM model is divides the I/I hydrograph into Start Tern Response (ST), Median Term Response (MT), and Long Term Reponses (LT). Within each hydrograph is a ratio of the flow (R) Proportional to the Response Term, a Time to the Peak (T), and (K) the
Step 4a Find Proportionality between each response
From the CN values, a Proportionality curve was generated for each response time
Step 2b Determine the T and K factors
The conductivity of the soil divided by the depth of soil/manhole was used to calculate the T factor. In general the K factor is approximately 2:1 for a typical curve (Twice the lag time to initial concentration)
- Step 7: TM 2-5 Determine the sewer area necessary to provide a 200 gal/mil/day/in-dia flow.
Step 5a: Find the amount of inflow required to provide the 200 g/m/d/in for the sub-basin. The 200 g/m/d/in term was multiplied by the observed length*dia term in Step 3.
Step 5b: Find the relationship between sewer inflow area and required inflow
The relationship between inflow and the sewer basin inflow area term is liner with a 0 y-intercept for a given CN value and MH depth.
Step 5c: Find the relationship between CN and sewer inflow
Since the inflow relationship is liner with a y-intercept = 0, the slopes of the CN values for each manhole depth were fit to a inflow*area vs. CN graph.
Step 5d: Determine the sewer inflow area.
The CN value was inputted into the graphical relationship in 5c and an area*inflow value was found. The factor was divided by the necessary inflow rate determined in Step 5a, and an area value was determined on a 5-ft depth basis (5, 10, 15, 20, and 25-ft deep sewers). The values were interpolated against the actual sewer depth and the inflow area term was determined for an infiltration value of 200 gallon/mile/in-diameter/day.
- Step 8: TM 2-6 SWMM Model and Output
The SWMM model was developed from the above data. The input/final output report appear in Appendix F.

WATEWER TREATMENT SYSTEM ALTERNATIVES

DEVELOPMENT NEEDS

The following needs were identified during the analysis and evaluation of previous reports and facility plans, the inspection and evaluation of the existing units and facilities at the Water Pollution Control Facility, and interviews/meetings with City personnel. The needs presented below cover the liquid process as well as bio-solids process.

The Oklahoma Department of Environmental Quality's Design Criteria for Sewerage Systems was used to benchmark unit conditions and establish permissible guidelines for future unit designs. Onsite evaluation of facilities, current and future flow analysis, interviews with operations staff, and an analysis of existing site conditions were all incorporated in the projection of system needs. Finally, each unit and process was evaluated with respect to the following areas of concern:

- Health & Safety,
- System Operations and Maintenance, and
- Future Growth.

The system needs that were determined are as follows:

Health & Safety

- Additional and sufficient capacity to prevent overflows or discharge of untreated wastewaters.
- Less disruption to current operations.

System O&M

- Redundancy in unit operations.
- Easy operation and maintenance
- Easy access of mechanical and electrical mechanisms.
- Corrosion resistant structures and equipment.
- Flexible plant piping with ability to take any unit out of service for maintenance.

Growth

- Sufficient capacity to meet needs during the 25 year planning horizon including sufficient capacity and flexibility to promote growth in annexed areas,
- Ability to mitigate fluctuations in plant flow and effluent quality due to influx of storm water and industrial flows

DESCRIPTION OF ALTERNATIVES

The following section summarizes each alternative that was considered in the planning phase of this project. The alternatives are developed with the objective of meeting the projected design capacity of the WPCF for the year 2030 is 14 MGD. The projected design capacity for the years 2010, 2015 and 2020 will be 9.00 MGD and 10.50 MGD and 12.00 MGD, respectively. The above projection include domestic flows from projected population, future flows from the expansion of Advance Foods, two new Ethanol Plants and other industries which are unknown at this time. The options for Plant expansions will be phased in stages that provide flexibility during expansion. The alternatives were developed based on the premise that the existing WPCF with the exception of bio-solids processing facility will be decommissioned either in 2010 or in 2020 after utilizing its useful life. The existing renovated sludge

processing facility capable of processing the sludge generated from a 10 MGD wastewater treatment facility will be expanded to 14 MGD as and when necessary based on the plant capacity of the given alternative. These alternatives will be presented with the major advantages and disadvantages listed for each.

Option 1: New 14 MGD treatment facility

This Option consists of building a new 14 MGD treatment plant by in the year 2010 that would cater to the projected ultimate flow for 2030. The bio-solids processing facility would be expanded from the current capacity of 10 MGD to 14 MGD in the year 2020. The advantages of this Option would be the total replacement of the existing wastewater treatment facility, a reliable treatment process, good growth capacity, general aesthetic improvements, ease of operation and maintenance, and no disruption to current plant operations. The disadvantages of this option would be a high capital construction cost, high land use, and high operation and maintenance cost.

Option 2: New 14 MGD treatment facility with an ability to treat industrial wastes directly without pretreatment

This Option consists of building a new 14 MGD treatment plant to treat wastewater with a high organic loading. This Option was developed with the purpose of receiving the industrial wastes within the City without significant pretreatment. Option 2 is identical to Option 1 with the exception of its design to treat the high strength wastewater. Under this Option, the existing bio-solids processing facility will be upgraded immediately as a result of increased bio-solids production from the high strength wastewater. The advantages of this Option will include the total replacement of the existing wastewater treatment facility, receiving industrial wastes without pretreatment leading to increased revenue to the City, good growth capacity, general aesthetic improvements and no disruption to current plant operations. Consequently the disadvantages of this option will include a higher capital construction cost than Option 1, higher land use, higher operation and maintenance costs, uncertainty in treated effluent quality, no control over the discharges by the industrial users and increased maintenance issues in collection system.

Option 3: New 12 MGD treatment facility with expansion to 14 MGD

This Option consists of building a new 12 MGD treatment plant in the year 2010 and expanding to 14 MGD in the year 2020 to meet the projected ultimate flow. The expansion to 14 MGD and upgrading of the existing bio-solids processing facility will occur in year 2020. The advantages of this Option will include the total replacement of the existing wastewater treatment facility, a reliable treatment process, good growth capacity, general aesthetic improvements, ease of operation and maintenance, and no disruption to current plant operations. The disadvantages of this Option include a high capital construction cost, high land use, and high operation and maintenance cost.

Option 4: Using existing treatment facility and building a new 7 MGD treatment facility with expansion to 14 MGD

This Option consists of building a new treatment plant in two stages, 7 MGD treatment facility in the year 2010 and expanding it to 14 MGD in the year 2020. Building a first stage 7 MGD plant will allow for the replacement of existing headworks and South Plant. The second stage expansion to 14 MGD plant will allow for the replacement of existing North Plant and BNR Plant. The advantages of this Option are less capital construction cost, and high utilization of the existing North and BNR Plants. Consequently the disadvantages of this option would be complexity in operations, possible disruption to current operations, renovations or replacement of certain treatment units in the North Plant, and high operation and maintenance cost.

Option 5: New 9 MGD treatment facility for domestic flows and a separate new 5 MGD treatment facility for industrial flows

This Option consists of building two new treatment plants at two different sites, the first, a new 9 MGD treatment facility in the year 2010 for treating domestic flows and a second a 5 MGD treatment facility in the year 2010 for treating industrial flows. The advantages of this Option include the total replacement of the existing wastewater treatment facility, good growth capacity, general aesthetic improvements, requires no expansion to the existing bio-solids processing facility, and no disruption to current plant operations. Consequently the disadvantages of this Option include high capital construction cost, high land use, high operation and maintenance cost, requirement of two separate collection systems, uncertainty in treated effluent quality, more operational skills, and increased maintenance issues in collection system.

Option 6: New 9 MGD treatment facility for domestic flows and a separate new 2.5 MGD treatment facility for industrial flows with expansion to 5 MGD

This Option is similar to Option 5 except that the 5 MGD treatment facility for industrial flows is expanded in two stages of 2.5 MGD (2.5 MGD each, in the year 2010 and 2020 respectively) treatment capacity each. The benefits and disadvantages of this Option would be same as Option 5 except that it has lower initial capital cost than Option 5.

EVALUATION METHODOLOGY

In general, the evaluation of alternatives is a two-fold process. The first is a qualitative analysis based on the factors listed below, which are considered to be important to the process system and the second is a quantitative analysis of the top few selected Options. The second analysis utilizes Present Worth Cost Analysis, to yield the most cost-effective, preferred alternative to meet the needs.

The factors used in the evaluation of qualitative analysis are listed below:

- Capital Costs
- Operation and Maintenance Costs
- Ease of Operation and Maintenance
- Reliability
- Expansion Potential
- Constructability
- Land Requirements
- Aesthetics

But in this evaluation, as an intermittent step, each of the top few selected Options were analyzed for two different processes namely, conventional activated sludge process, and sequential batch reactor process to determine the most reliable and cost effective alternative to meet the ultimate flow condition.

The Options developed in the previous sections were presented to the City staff consisting of the following members on August 2, 2006.

- 1. Robert Hitt, P.E. - Director of Development Services
- 2. James McClain - Public Utility Director
- 3. Barry Brummit - Pretreatment Director
- 4. Jason Brinley, P.E. - Engineering Administrator
- 5. Murali Katta - Project Engineer
- 6. Joyce Hight - Wastewater Plant Superintendent

After discussions on each of these Options, the City of Enid selected the following three (3) Options to proceed further with detailed analysis.

TABLE TM 3-1 : Top Selected Options for Detailed Analysis.

Option	Description
1	New 14 MGD treatment facility
3	New 12 MGD treatment facility with expansion to 14 MGD
4	Using existing treatment facility and building new 7 MGD treatment facility with expansion to 14 MGD

PROCESS ALTERNATIVES

Each of the selected Options in Table TM 3-1 were further divided in two Options based on the two chosen process types namely, conventional activated sludge process and sequential batch reactor process, and analyzed in detail for capital and operation and maintenance costs. Process selection is very important step in the design of wastewater treatment plant as it provides an opportunity to implement the treatment system that suits local environmental conditions, construction and operation costs, energy considerations, operator’s skills, process flexibility, etc. In this study, a conventional activated sludge process and sequential batch reactor process were considered for the following reasons

Conventional activated sludge process

In a conventional activated sludge process, the primary-treated wastewater and acclimated micro-organisms (activated sludge or biomass) are aerated in a basin or tank. After a sufficient aeration period, the flocculent activated sludge solids are separated from the wastewater in a secondary clarifier. The clarified wastewater flows forward for further treatment or discharge. A portion of the clarifier underflow sludge is returned to the aeration basin for mixing with the primary- treated influent to the basin and the remaining sludge is wasted to the sludge handling portion of the treatment plant.

The City of Enid operational staff is familiar with this process as they have been operating the North and South Plants for many years. The North and South Plants use conventional activated sludge process. The benefits of this process were simple operation, smaller basin size, familiar and more reliable process. The disadvantages of this process will be high energy costs, requires more process treatment units, requires separate treatment units for nitrification, effluent quality is susceptible to variations in influent flow and quality, and high land use.

Sequencing batch reactor (SBR) process

A sequencing batch reactor process is a fill-and-draw activated-sludge treatment system. This process is identical to conventional activated sludge system, but the (SBR) reactor is a self contained system performing equalization, aeration and clarification in a single reactor. Although the reactor size is larger than the conventional activated sludge process reactor, it eliminates the use of primary clarifiers, secondary clarifiers and return sludge recirculation. This process is being increasingly used in recent years.

The major advantages of this process will be improved effluent quality, elimination of primary, secondary clarifiers and return sludge recirculation, elimination of short circuiting, ability to handle shock in hydraulic and organic loading and the ability to remove nutrients within the same basin.

PREFERRED ALTERNATIVES

The Options selected by the City of Enid as shown in **Table TM 3-1** were expanded to six alternatives, each Option using two different processes, conventional activated sludge and sequencing batch reactor processes. These Options are as follows.

Option 1A: *New 14 MGD treatment facility using conventional activated sludge process*



The process schematic for this Option is shown in **Figure TM 3-1**. This process is a two stage treatment process, first stage for BOD removal and the second stage for the removal of ammonia. The Option is designed to handle the projected ultimate design flow of 14 MGD, and replaces the existing WPCF facility in totality with the exception of the biosolids processing facility. The size of individual treatment units, its construction cost, and operation and maintenance cost is shown in **Table 1** and **7** in **Appendix TM 3-1**.

Option 1B: *New 14 MGD treatment facility using sequencing batch reactor process*

The process schematic for this Option is shown in **Figure TM 3-2**. The designed capacity of this plant is the same as Option 1A except it uses SBR process. The BOD and ammonia removal are accomplished in several steps using the same basin/tank. The size of individual treatment units, its construction cost, and operation and maintenance cost is shown in **Table 2** and **7** in **Appendix TM 3-1**.

Option 3A: *New 12 MGD treatment facility using conventional activated sludge process with expansion to 14 MGD*

The process schematic for this Option is shown in **Figure TM 3-3**. This Option uses conventional activated sludge process. The preliminary treatment unit consisting of screen, grit removal, parshall flume and lift station, primary clarifier and UV disinfection system are designed for an ultimate design flow of 14 MGD and the remaining treatment units are designed for 12 MGD with the Option to expand to 14 MGD in the year 2020. This Option also replaces the existing WPCF facility in totality with the exception of bio-solids processing facility. The size of individual treatment units, its construction cost, and operation and maintenance cost for the staged expansion is shown in **Table 3** and **8** in **Appendix TM 3-1**.



NOTE:
FOR THE PURPOSE OF CLARITY,
SOLIDIOS PROCESSING FLOW CHART
IS NOT SHOWN.

REVISION	DATE

SEAL'S


DRAWN: EA
 CHECKED: VS
 APPROVED: JAP
 SCALE: AS SHOWN

PSA Dewberry
 1330 South Boulder - Suite 600
 Tulsa, Oklahoma 74118 - 3218
 918.007.2293 - fax 918.587.0071

PROJECT TITLE
**CITY OF ENID
 WASTEWATER
 FACILITY PLAN**



PROJECT NO. 32158005 | DATE: 8-29-2006
 SHEET TITLE
**OPTION 1A:
 14 MGD CONVENTIONAL ACTIVATED
 SLUDGE TREATMENT SYSTEM**

FIGURE
 TM 3-1



NOTE:
FOR THE PURPOSE OF CLARITY,
BIOLOGICALS PROCESSING FLOW CHART
IS NOT SHOWN.

REVISION	DATE	SEALS	DRAWN: EA CHECKED: VS APPROVED: JAP SCALE: AS SHOWN	PSA Dewberry <small>1350 South Boulder - Suite 600 Tulsa, Oklahoma 74119 - 3210 918.597.7263 - Fax 918.987.0271</small>	PROJECT TITLE CITY OF ENID WASTEWATER FACILITY PLAN	PROJECT NO. 32158005 SHEET TITLE	DATE: 9-29-2006	FIGURE TM 3-2
		OPTION 1B: 14 MGD SEQUENTIAL BATCH REACTOR (SBR) SYSTEM						



REVISION	DATE

SEALS

DRAWN:	EA
CHECKED:	YS
APPROVED:	JAP
SCALE:	AS SHOWN

PSA Dewberry
 1350 South Boulder - Suite 600
 Tulsa, Oklahoma 74119 - 3216
 918.597.7263 - Fax 918.597.0071

PROJECT TITLE
**CITY OF ENID
 WASTEWATER
 FACILITY PLAN**

PROJECT NO. 32158005 | DATE: 9-25-2006
 SHEET TITLE
**OPTION 3A:
 12 MGD CONVENTIONAL ACTIVATED SLUDGE
 TREATMENT SYSTEM EXPANDED TO 14 MGD**

FIGURE
TM 3-3

Option 3B: *New 12 MGD treatment facility using sequencing batch reactor process with expansion to 14 MGD*

The process schematic for this Option is shown in **Figure TM 3-4**. The designed capacities and expansion phasing of this Option is the same as Option 3A except it uses SBR process. The size of individual treatment units, its construction cost, and operation and maintenance cost for the staged expansion is shown in **Table 4** and **8** in **Appendix TM 3-1**.


Option 4A: *Using the existing treatment facility and building a new 7 MGD treatment facility using conventional activated sludge process with expansion to 14 MGD*

This Option uses conventional activated sludge process, and the process schematic for this Option is shown in **Figure TM 3-5**. The preliminary treatment unit consisting of screen, grit removal, parshall flume and lift station, and UV disinfection system are designed for ultimate design flow of 14 MGD and the remaining treatment units are designed for 7 MGD with the Option to expand to them to 14 MGD in the year 2020. This Option will still use the North Plant until 2020. As a result it will require some rehabilitation work to existing primary and secondary clarifiers in the North Plant and construction of new nitrification clarifiers at existing BNR system. The size of individual treatment units, its construction cost, and operation and maintenance cost for the staged expansion of this Option is shown in **Table 5** and **9** in **Appendix TM 3-1**.

Option 4B: *Using the existing treatment facility and building a new 7 MGD treatment facility using sequencing batch reactor process with expansion to 14 MGD*

The process schematic for this Option is shown in **Figure TM 3-6**. The designed capacities and expansion phasing of this Option is the same as Option 3A except it uses SBR process. The size of individual treatment units, its construction cost, and operation and maintenance cost for the staged expansion is shown in **6** and **9** in **Appendix TM 3-1**.

Summary of capital cost and operation and maintenance cost for each of the above six Options is shown in **Table TM 3-2**.



FUTURE EXPANSION
 TO UPGRADE TO 14 MGD

NOTES:
 FOR THE PURPOSE OF CLARITY,
 BIOLOGICAL PROCESSING FLOW CHART
 IS NOT SHOWN.

REVISION	DATE

SEALS

DRAWN: EA
 CHECKED: VS
 APPROVED: JAP
 SCALE: AS SHOWN



PSA Dewberry
 1350 South Boulder - Suite 600
 Tulsa, Oklahoma 74119 - 3210
 918.587.7263 - fax 918.587.0071

PROJECT TITLE
**CITY OF ENID
 WASTEWATER
 FACILITY PLAN**

PROJECT NO. 32158008 / DATE: 8-25-2006
 SHEET TITLE
**OPTION 3B:
 12 MGD SEQUENTIAL BATCH
 REACTOR (SBR) SYSTEM
 W/EXPANSION TO 14 MGD**

FIGURE
 TM 3-4

12/28/2006 0:32:00 PM C:\PROJECTS\ENID\ENID\ENID_03.dwg



--- FUTURE EXPANSION TO UPGRADE TO 14 MGD

NOTE:
FOR THE PURPOSE OF CLARITY,
BIOLOGICAL PROCESSING FLOW CHART
IS NOT SHOWN.

12/28/2006 00:32:58005\CA\CHINA\LT_3A.dgn

REVISION	DATE


SEALS	
DRAWN: EA	
CHECKED: VS	
APPROVED: JAP	
SCALE: AS SHOWN	

PSA Dewberry
 1350 South Boulder - Suite 800
 Tulsa, Oklahoma 74110 - 3210
 918.567.7283 • Fax 918.567.0071

PROJECT TITLE
**CITY OF ENID
 WASTEWATER
 FACILITY PLAN**

PROJECT NO. 32158005 DATE: 9-28-2006
 SHEET TITLE
**OPTION 4A: USING EXISTING TREATMENT
 FACILITY AND BUILDING A NEW 7 MGD
 CONVENTIONAL ACTIVATED SLUDGE
 TREATMENT SYSTEM W/ EXPANSION TO 14 MGD**

FIGURE
 TM 3-5



FUTURE EXPANSION TO 14 MGD

NOTE: FOR THE PURPOSE OF CLARITY, BIOLOGICAL PROCESSING FLOW CHART IS NOT SHOWN.

12/28/2006 Q:\3215R005\CAD\DWG\PLANT 36.dwg

REVISION	DATE

SEALS

DRAWN: EA
 CHECKED: VS
 APPROVED: JAP
 SCALE: AS SHOWN

PSA Dewberry
 1260 South Boulder - Suite 800
 Tulsa, Oklahoma 74119 - 3216
 918.567.7283 - Fax 918.567.0074

PROJECT TITLE
**CITY OF ENID
 WASTEWATER
 FACILITY PLAN**

PROJECT NO. 3215R005 DATE: 9-28-2006
 SHEET TITLE
**OPTION 4B:
 USING EXISTING TREATMENT FACILITY
 AND BUILDING A NEW 7 MGD SEQUENTIAL
 BATCH REACTOR (SBR) SYSTEM
 W/ EXPANSION TO 14 MGD**

**FIGURE
 TM 3-6**

TABLE TM 3-2: Summary of capital and operation and maintenance cost

OPTION	DESCRIPTION	CAPITAL COST		O & M COST	
		2010	2020	2010-2020	2020-2030
1A	14 MGD New Plant Conventional Activated Sludge Process	\$ 48,316,100	\$ 4,935,100	\$ 1,717,680	\$ 1,888,480
1B	14 MGD New Plant SBR Process	\$ 46,580,700	\$ 4,935,100	\$ 1,442,030	\$ 1,612,830
3A	12 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 42,796,500	\$ 11,077,500	\$ 1,514,290	\$ 1,888,480
3B	12 MGD New Plant SBR Process W/ Expansion to 14 MGD	\$ 42,121,600	\$ 9,430,200	\$ 1,289,790	\$ 1,612,830
4A	Using Existing Treatment Facility and building new 7 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 33,039,300	\$ 26,421,000	\$ 1,627,910	\$ 1,888,480
4B	Using Existing Treatment Facility and building new 7 MGD New Plant SBR Process W/Expansion to 14 MGD	\$ 31,930,500	\$ 24,026,400	\$ 1,577,340	\$ 1,612,830

From the capital and operations costs listed in **Table TM 3-2**, the Present Worth Cost for each Option was calculated. A summary of the Present Worth Costs can be seen below in **Table TM 3-3**. The following assumptions were used in the Present Worth Cost Analysis.

1. Present Worth Analysis was performed for the year 2006
2. Evaluation period used is 20 years, between years 2010 and 2030
3. Capital costs were expected to occur in two stages, year 2010 and 2020. Capital cost for the year 2020 includes additional expansion to meet the ultimate condition.
4. Annual operations and maintenance costs were divided in to two time periods, one for the period 2010-2020 and the other for the period 2020-2030 as the expansion at 2020 would increase the operation and maintenance cost.
5. Inflation factor of 4.5% per year was used for Present worth Analysis.

The detailed Present Worth Cost analysis is shown in **Table 10** in **Appendix TM 3-1**.

TABLE TM 3-3: Summary of present worth cost

Option	Description	Present Worth Cost
1 A	14 MGD New Plant Conventional Activated Sludge Process	\$ 62,646,975
1 B	14 MGD New Plant SBR Process	\$ 58,184,959
3 A	12 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 59,985,628
3 B	12 MGD New Plant SBR Process W/ Expansion to 14 MGD	\$ 55,862,804
4 A	Using Existing Treatment Facility and Building a 7 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 60,842,593
4 B	Using Existing Treatment Facility and Building a 7 MGD New Plant SBR Process W/ Expansion to 14 MGD	\$ 57,106,473

Normally the recommended alternative selection is based upon the Present Worth Cost Analysis described and summarized above. The Present Worth Cost information presented in **Table TM 3-3**, worth indicates that Option 3B has the lowest present worth cost among all of the alternatives evaluated. Therefore it is recommended that Option 3B be considered by the City of Enid for implementation. This Option is discussed in more detail in the following section.

RECOMMENDED ALTERNATIVE

The recommendations below are based on an extensive evaluation of the existing treatment units and the introduction of new treatment concepts. During this evaluation, the basis for selection was the cost effectiveness of the system process. Generally, the alternative with the lowest present worth cost was recommended. In this evaluation, *Option 3B* has the lowest present worth cost, and therefore fore it is recommended that *Option 3B* be considered by the City of Enid for implementation.

The proposed improvements under *Option 3B* will provide the City of Enid Water Pollution Control Facility with the following attributes:

- Replaces the existing WPCF facility in totality with the exception of the bio-solids processing facility;
- Less / no disruption to current plant operations while new facility is being built;
- Improved effluent quality;
- Elimination of primary, secondary clarifiers and return sludge recirculation, elimination of short circuiting;

- Ability to handle shock in hydraulic and organic loading;
- Ability to remove nutrients;
- Easy to expand and replicate the additional reactors;
- Less land requirements than other processes.

The improvements recommended under *Option 3B* consist of expanding the plant in two stages as follows:

Improvements at 2010:

- New headworks including screening, grit removal and flow measurement to handle ultimate peak flow of 28 MGD;
- New low lift pump station to handle ultimate peak flow of 28 MGD;
- SBR reactors to treat an average daily flow of 12 MGD;
- New sludge holding basins;
- Disinfection system;
- Effluent flow measurement structure;
- Influent/effluent outfall; site work, piping, electrical, instrumentation & controls;
- Decommissioning of the existing WPCF facility in totality except bio-solids processing facility.

Improvements at 2020:

- One additional SBR reactor to increase the design capacity of the SBR reactors from 12 MGD to 14 MGD of average daily flow;
- Expanding the capacity of the existing bio-solids processing facility from 10 MGD to 14 MGD by building two new aerobic digesters and additional dewatering system consisting of belt press, polymer dosing system, sludge conveyor, etc.;
- Sitework, piping, electrical, instrumentation & controls.

The site plan showing the improvements as recommended in *Option 3B* is shown in **Figure TM 3-7**. This site is located northwest of the North Plant and south of Market Road and was recommended in the previous facility plan as suitable land for expansion. This site appears to be outside the floodway, and will not disrupt the Facility's operation but still close to the existing facility.

TABLE TM 3-4: *Capital construction cost for recommended alternative, Option 3B*

Unit Description	Capital Construction Cost	
	2010	2020
Mobilization	\$ 773,900	\$ 224,800
Sitework	\$ 2,220,600	\$ 680,600
Headworks		
Screening	\$ 510,400	-
Grit Removal	\$ 783,100	-
Parshall Flume	\$ 240,500	-
Low Lift Pump Station	\$ 1,383,900	-
SBR Reactors	\$ 16,590,200	\$ 2,370,100
Sludge Holding Basins	\$ 1,174,100	-
Disinfection System	\$ 1,975,300	-
Aerobic Digesters	-	\$ 1,295,800
Dewatering System	-	\$ 1,200,300
Electrical	\$ 2,251,500	\$ 608,800
Instrumentation & Controls	\$ 1,187,700	\$ 293,600
Piping	\$ 2,560,000	\$ 580,000
Influent / Effluent outfall	\$ 750,000	-
SUB TOTAL	\$ 32,401,200	\$ 7,254,000
Non-Construction Cost (15%)	\$ 4,860,200	\$ 1,088,100
Contingency (15%)	\$ 4,860,200	\$ 1,088,100
TOTAL	\$ 42,121,600	\$ 9,430,200

The approximate capital construction cost to build all recommended improvements has been estimated to be \$42,121,600 and \$9,430,200 for the years 2010 and 2020, respectively. **Table TM 3-4** shows the breakdown of these estimated capital costs for the recommended improvements. The estimated construction costs are based on August 2006, Engineering News Record (ENR) construction cost index (7722).

The annual operation and maintenance cost for the years 2010-2020 and 2020-2030 are \$1,289,790 and \$1,612,830 respectively. A detailed break down of these estimated operation and maintenance cost is shown in **Table 8** in **Appendix TM 3-1**.

APPENDICES

APPENDIX TM 3-1

COST ANALYSIS WORKSHEETS

CITY OF ENID WASTEWATER FACILITY PLAN

CAPITAL COST ESTIMATES

TABLE 1

Sep-06

OPTION 1A: 14 MGD NEW PLANT, CONVENTIONAL ACTIVATED SLUDGE PROCESS

Unit Description	Unit Size/ Design Capacity	Number of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	860,800
Sitework	-	-	2,458,400
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
Primary Clarifiers	90 ft. Dia	2	1,794,600
Aeration Basin	200' L x 50' W x 16.5' D	4	8,115,200
Secondary Clarifiers	100 ft. Dia	3	3,322,900
Nitrification Basin	14 MGD	-	4,643,300
Tertiary clarifiers	100 ft. Dia	3	3,322,900
Disinfection system	28 MGD	-	1,382,000
Electrical	-	-	2,519,600
Instrumentation & Controls	-	-	1,339,400
Piping	-	-	3,739,100
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			37,166,100
Non-Construction Cost (15%)			5,575,000
Contingency (15%)			5,575,000
TOTAL			48,316,100
Improvements at 2020			
Mobilization	-	-	200,000
Sitework	-	-	300,000
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	250,000
Instrumentation & Controls	-	-	150,000
Piping	-	-	400,000
SUB TOTAL			3,796,100
Non-Construction Cost (15%)			569,500
Contingency (15%)			569,500
TOTAL			4,935,100

CITY OF ENID WASTEWATER FACILITY PLAN

CAPITAL COST ESTIMATES

TABLE 2

Sep-06

OPTION 1B: 14 MGD NEW PLANT, SBR (SEQUENTIAL BATCH REACTOR) PROCESS

Unit Description	Unit Size/ Design Capacity	Number of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	860,800
Sitework	-	-	2,458,400
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
SBR Reactors	140' L x 98' W x 22' D	8	18,960,200
Sludge Holding Basins	70' L x 35' W x 12' D	2	1,174,100
Disinfection System	40 MGD	-	1,975,300
Electrical	-	-	2,519,600
Instrumentation & Controls	-	-	1,339,400
Piping	-	-	2,875,600
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			35,831,300
Non-Construction Cost (15%)			5,374,700
Contingency (15%)			5,374,700
TOTAL			46,580,700
Improvements at 2020			
Mobilization	-	-	200,000
Sitework	-	-	300,000
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	250,000
Instrumentation & Controls	-	-	150,000
Piping	-	-	400,000
SUB TOTAL			3,796,100
Non-Construction Cost (15%)			569,500
Contingency (15%)			569,500
TOTAL			4,935,100

CITY OF ENID WASTEWATER FACILITY PLAN

CAPITAL COST ESTIMATES

TABLE 3

Sep-06

OPTION 3A: 12 MGD NEW PLANT, CONVENTIONAL ACTIVATED SLUDGE PROCESS
WITH EXPANSION TO 14 MGD CAPACITY

Unit Description	Unit Size/ Design Capacity	Number of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	773,900
Sitework	-	-	2,220,600
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
Primary Clarifiers	90 ft. Dia	2	1,794,600
Aeration Basin	180' L x 45' W x 17.20' D	4	6,852,200
Secondary Clarifiers	90 ft. Dia	3	2,691,900
Nitrification Basin	12 MGD	-	4,085,500
Tertiary clarifiers	90 ft. Dia	3	2,691,900
Disinfection System	28 MGD	-	1,382,000
Electrical	-	-	2,251,500
Instrumentation & Controls	-	-	1,187,700
Piping	-	-	3,320,600
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			32,920,300
Non-Construction Cost (15%)			4,938,100
Contingency (15%)			4,938,100
TOTAL			42,796,500
Improvements at 2020			
Mobilization	-	-	224,800
Sitework	-	-	680,600
Aeration Basin	180' L x 30' W x 17.20' D	4	1,142,100
Secondary Clarifiers	80 ft. Dia	1	709,000
Nitrification Basin	2 MGD	-	821,400
Tertiary clarifiers	80 ft. Dia	1	709,000
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	608,800
Instrumentation & Controls	-	-	293,600
Piping	-	-	835,700
SUB TOTAL			8,521,100
Non-Construction Cost (15%)			1,278,200
Contingency (15%)			1,278,200
TOTAL			11,077,500

CITY OF ENID WASTEWATER FACILITY PLAN

TABLE 4

CAPITAL COST ESTIMATES

Sep-06

**OPTION 3B: 12 MGD NEW PLANT, SBR (SEQUENTIAL BATCH REACTOR) PROCESS
WITH EXPANSION TO 14 MGD CAPACITY**

Unit Description	Unit Size/ Design Capacity	Number of Units of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	773,900
Sitework	-	-	2,220,600
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
SBR Reactors	140' L x 98' W x 22' D	7	16,590,200
Sludge Holding Basins	70' L x 35' W x 12' D	2	1,174,100
Disinfection System	40 MGD	-	1,975,300
Electrical	-	-	2,251,500
Instrumentation & Controls	-	-	1,187,700
Piping	-	-	2,560,000
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			32,401,200
Non-Construction Cost (15%)			4,860,200
Contingency (15%)			4,860,200
TOTAL			42,121,600
Improvements at 2020			
Mobilization	-	-	224,800
Sitework	-	-	680,600
SBR Reactors	140' L x 98' W x 22' D	1	2,370,100
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	608,800
Instrumentation & Controls	-	-	293,600
Piping	-	-	580,000
SUB TOTAL			7,254,000
Non-Construction Cost (15%)			1,088,100
Contingency (15%)			1,088,100
TOTAL			9,430,200

CITY OF ENID WASTEWATER FACILITY PLAN

TABLE 5
Sep-06

CAPITAL COST ESTIMATES

OPTION 4A: USING EXISTING TREATMENT FACILITY AND BUILDING A 7 MGD NEW PLANT, CONVENTIONAL ACTIVATED SLUDGE PROCESS WITH EXPANSION TO 14 MGD CAPACITY

Unit Description	Unit Size/ Design Capacity	Number of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	533,600
Sitework	-	-	1,555,900
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
Primary Clarifiers	70 ft. Dia	2	1,085,700
Aeration Basin	150' L x 75' W x 15' D	2	4,149,900
Secondary Clarifiers	90 ft. Dia	2	1,794,600
Nitrification Basin	7 MGD	-	2,721,100
Tertiary clarifiers	90 ft. Dia	2	1,794,600
Disinfection System	28 MGD	-	882,000
Improvements to Existing WWTP	-	-	2,737,700
Electrical	-	-	1,519,000
Instrumentation & Controls	-	-	780,000
Piping	-	-	2,192,700
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			25,414,700
Non-Construction Cost (15%)			3,812,300
Contingency (15%)			3,812,300
TOTAL			33,039,300
Improvements at 2020			
Mobilization	-	-	533,600
Sitework	-	-	1,555,900
Primary Clarifiers	70 ft. Dia	2	1,085,700
Aeration Basin	150' L x 75' W x 15' D	2	4,149,900
Secondary Clarifiers	90 ft. Dia	2	1,794,600
Nitrification Basin	7 MGD	-	1,921,700
Tertiary clarifiers	90 ft. Dia	2	1,794,600
Disinfection System	-	-	500,000
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	1,519,000
Instrumentation & Controls	-	-	780,000
Piping	-	-	2,192,700
SUB TOTAL			20,323,800
Non-Construction Cost (15%)			3,048,600
Contingency (15%)			3,048,600
TOTAL			26,421,000

CITY OF ENID WASTEWATER FACILITY PLAN

TABLE 6

CAPITAL COST ESTIMATES

Sep-06

OPTION 4B: USING EXISTING TREATMENT FACILITY AND BUILDING A 7 MGD NEW PLANT, SBR (SEQUENTIAL BATCH REACTOR) PROCESS WITH EXPANSION TO 14 MGD CAPACITY

Unit Description	Unit Size/ Design Capacity	Number of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	533,600
Sitework	-	-	1,555,900
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
SBR Reactors	140' L x 98' W x 22' D	4	9,480,100
Sludge Holding Basins	70' L x 35' W x 12' D	1	587,100
Disinfection System	40 MGD	-	1,975,300
Improvements to Existing WWTP	-	-	2,737,700
Electrical	-	-	1,519,000
Instrumentation & Controls	-	-	780,000
Piping	-	-	1,725,300
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			24,561,900
Non-Construction Cost (15%)			3,684,300
Contingency (15%)			3,684,300
TOTAL			31,930,500
Improvements at 2020			
Mobilization	-	-	553,600
Sitework	-	-	1,555,900
SBR Reactors	140' L x 98' W x 22' D	4	9,480,100
Sludge Holding Basins	70' L x 35' W x 12' D	1	587,100
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	1,519,000
Instrumentation & Controls	-	-	780,000
Piping	-	-	1,510,000
SUB TOTAL			18,481,800
Non-Construction Cost (15%)			2,772,300
Contingency (15%)			2,772,300
TOTAL			24,026,400

CITY OF ENID WASTEWATER FACILITY PLAN

TABLE 7

Operations & Maintenance Costs

September-06

Unit Component	Base Year Labor Rate (\$/hr)	Annual Operations Costs							Total Annual Costs (\$)
		Operations Labor (man-hours)	Operations Labor (\$)	Maintenance Labor (man-hours)	Maintenance Labor (\$)	Additional Energy Costs (\$)	Materials and Supply Costs** (\$)		
Between 2010 - 2020									
OPTION 1A									
Influent Pumping	\$ 11.00	700	\$ 7,700	600	\$ 6,600	\$ 122,400	\$ 12,300	\$ 149,000	
Preliminary treatment	\$ 11.00	2700	\$ 29,700	1300	\$ 14,300	\$ -	\$ 17,100	\$ 61,100	
Primary sedimentation	\$ 11.00	1300	\$ 14,300	700	\$ 7,700	\$ -	\$ 9,800	\$ 31,800	
Activated sludge Process	\$ 11.00	4300	\$ 47,300	2800	\$ 30,800	\$ 424,200	\$ 34,200	\$ 536,500	
Secondary Clarifiers	\$ 11.00	1800	\$ 19,800	1000	\$ 11,000	\$ -	\$ 17,600	\$ 48,400	
Nitrification Basin	\$ 11.00	3500	\$ 38,500	2100	\$ 23,100	\$ 228,500	\$ 34,200	\$ 324,300	
Tertiary clarifiers	\$ 11.00	1800	\$ 19,800	1000	\$ 11,000	\$ -	\$ 17,600	\$ 48,400	
Disinfection	\$ 11.00	140	\$ 1,540	140	\$ 1,540	\$ 68,600	\$ 18,000	\$ 89,680	
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200	
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	\$ -	\$ 165,600	\$ 239,300	
Total:								\$ 1,717,680	
Between 2020 - 2030*									
OPTION 1A									
Digestion	\$ 11.00	1000	\$ 11,000	600	\$ 6,600	\$ 22,900	\$ 12,300	\$ 52,800	
Dewatering	\$ 11.00	3000	\$ 33,000	400	\$ 4,400	\$ -	\$ 80,600	\$ 118,000	
Total:								\$ 1,888,480	
Between 2010 - 2020									
OPTION 1B									
Influent Pumping	\$ 11.00	700	\$ 7,700	600	\$ 6,600	\$ 122,400	\$ 12,300	\$ 149,000	
Preliminary treatment	\$ 11.00	2700	\$ 29,700	1300	\$ 14,300	\$ -	\$ 17,100	\$ 61,100	
Sequential Batch Reactor	\$ 11.00	5500	\$ 60,500	3600	\$ 39,600	\$ 548,200	\$ 34,200	\$ 682,500	
Sludge Holding Basin	\$ 11.00	1000	\$ 11,000	550	\$ 6,050	\$ -	\$ 14,200	\$ 31,250	
Disinfection	\$ 11.00	140	\$ 1,540	140	\$ 1,540	\$ 68,600	\$ 18,000	\$ 89,680	
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200	
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	\$ -	\$ 165,600	\$ 239,300	
Total:								\$ 1,442,030	
Between 2020 - 2030*									
OPTION 1B									
Digestion	\$ 11.00	1000	\$ 11,000	600	\$ 6,600	\$ 22,900	\$ 12,300	\$ 52,800	
Dewatering	\$ 11.00	3000	\$ 33,000	400	\$ 4,400	\$ -	\$ 80,600	\$ 118,000	
Total:								\$ 1,612,830	

* O&M Costs for the period 2020 - 2030 Includes annual O&M costs estimated for the period 2010 - 2020 plus additional O&M costs resulting from expansion in 2020

CITY OF ENID WASTEWATER FACILITY PLAN

TABLE 8

Operations & Maintenance Costs

September-06

Unit Component	Base Year Labor Rate (\$/hr)	Annual Operations Costs						
		Operations Labor* (man-hours)	Operations Labor (\$)	Maintenance Labor* (man-hours)	Maintenance Labor (\$)	Additional Energy Costs (\$)	Materials and Supply Costs** (\$)	Total Annual Costs (\$)
Between 2010 - 2020								
OPTION 3A								
Influent Pumping	\$ 11.00	650	\$ 7,150	550	\$ 6,050	\$ 81,600	\$ 9,300	\$ 104,100
Preliminary treatment	\$ 11.00	2300	\$ 25,300	1100	\$ 12,100	\$ -	\$ 14,700	\$ 52,100
Primary sedimentation	\$ 11.00	1200	\$ 13,200	650	\$ 7,150	\$ -	\$ 10,000	\$ 30,350
Activated sludge Process	\$ 11.00	4000	\$ 44,000	2500	\$ 27,500	\$ 359,000	\$ 29,300	\$ 459,800
Secondary Clarifiers	\$ 11.00	1700	\$ 18,700	850	\$ 9,350	\$ -	\$ 13,200	\$ 41,250
Nitrification Basin	\$ 11.00	3000	\$ 33,000	2000	\$ 22,000	\$ 195,800	\$ 29,300	\$ 280,100
Tertiary clarifiers	\$ 11.00	1700	\$ 18,700	850	\$ 9,350	\$ -	\$ 13,200	\$ 41,250
Desinfection	\$ 11.00	120	\$ 1,320	120	\$ 1,320	\$ 58,800	\$ 15,400	\$ 76,840
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	\$ -	\$ 165,600	\$ 239,300
							Total:	\$ 1,514,290
Between 2020 - 2030*								
OPTION 3A							Total:	\$ 1,888,480
Between 2010 - 2020								
OPTION 3B								
Influent Pumping	\$ 11.00	650	\$ 7,150	550	\$ 6,050	\$ 81,600	\$ 9,300	\$ 104,100
Preliminary treatment	\$ 11.00	2300	\$ 25,300	1100	\$ 12,100	\$ -	\$ 14,700	\$ 52,100
Sequential Batch Reactor	\$ 11.00	5000	\$ 55,000	3000	\$ 33,000	\$ 478,700	\$ 29,300	\$ 597,000
Sludge Holding Basin	\$ 11.00	1000	\$ 11,000	550	\$ 6,050	\$ -	\$ 14,200	\$ 31,250
Desinfection	\$ 11.00	120	\$ 1,320	120	\$ 1,320	\$ 58,800	\$ 15,400	\$ 76,840
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	\$ -	\$ 165,600	\$ 239,300
							Total:	\$ 1,289,790
Between 2020 - 2030*								
OPTION 3B							Total:	\$ 1,612,830

* O&M Costs for the period 2020 - 2030 includes annual O&M costs estimated for the period 2010 - 2020 plus additional O&M costs resulting from expansion in 2020

CITY OF ENID WASTEWATER FACILITY PLAN

TABLE 9

Operations & Maintenance Costs

September-06

Unit Component	Base Year Labor Rate (\$/hr)	Annual Operations Costs							Total Annual Costs (\$)
		Operations Labor* (man-hours)	Operations Labor (\$)	Maintenance Labor* (man-hours)	Maintenance Labor (\$)	Additional Energy Costs (\$)	Materials and Supply Costs** (\$)		
Between 2010 - 2020									
OPTION 4A									
Influent Pumping	\$ 11.00	650	\$ 7,150	550	\$ 6,050	\$ 81,600	\$ 9,300	\$ 104,100	
Preliminary treatment	\$ 11.00	2300	\$ 25,300	1100	\$ 12,100	\$ -	\$ 14,700	\$ 52,100	
Primary sedimentation	\$ 11.00	1100	\$ 12,100	600	\$ 6,600	\$ -	\$ 10,800	\$ 29,500	
Activated sludge Process	\$ 11.00	4500	\$ 49,500	2900	\$ 31,900	\$ 339,400	\$ 44,500	\$ 465,300	
Secondary Clarifiers	\$ 11.00	1850	\$ 20,350	990	\$ 10,890	\$ -	\$ 17,400	\$ 48,640	
Nitrification Basin	\$ 11.00	4100	\$ 45,100	2800	\$ 30,800	\$ 244,800	\$ 44,500	\$ 365,200	
Tertiary clarifiers	\$ 11.00	2250	\$ 24,750	1180	\$ 12,980	\$ -	\$ 20,000	\$ 57,730	
Desinfection	\$ 11.00	120	\$ 1,320	120	\$ 1,320	\$ 58,800	\$ 15,400	\$ 76,840	
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200	
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	\$ -	\$ 165,600	\$ 239,300	
Total:								\$	1,627,910
Between 2020 - 2030*									
OPTION 4A									
Total:								\$	1,888,480
Between 2010 - 2020									
OPTION 4B									
Influent Pumping	\$ 11.00	650	\$ 7,150	550	\$ 6,050	\$ 81,600	\$ 9,300	\$ 104,100	
Preliminary treatment	\$ 11.00	2300	\$ 25,300	1100	\$ 12,100	\$ -	\$ 14,700	\$ 52,100	
Primary sedimentation	\$ 11.00	650	\$ 7,150	350	\$ 3,850	\$ -	\$ 4,400	\$ 15,400	
Activated sludge Process	\$ 11.00	2500	\$ 27,500	1500	\$ 16,500	\$ 195,800	\$ 20,000	\$ 259,800	
Secondary Clarifiers	\$ 11.00	900	\$ 9,900	500	\$ 5,500	\$ -	\$ 7,400	\$ 22,800	
Nitrification Basin	\$ 11.00	2600	\$ 28,600	1700	\$ 18,700	\$ 130,600	\$ 20,000	\$ 197,900	
Tertiary clarifiers	\$ 11.00	1300	\$ 14,300	700	\$ 7,700	\$ -	\$ 10,800	\$ 32,800	
Sequential Batch Reactor	\$ 11.00	3600	\$ 39,600	2100	\$ 23,100	\$ 274,100	\$ 24,500	\$ 361,300	
Sludge Holding Basin	\$ 11.00	750	\$ 8,250	350	\$ 3,850	\$ -	\$ 13,700	\$ 25,800	
Desinfection	\$ 11.00	120	\$ 1,320	120	\$ 1,320	\$ 58,800	\$ 15,400	\$ 76,840	
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200	
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	\$ -	\$ 165,600	\$ 239,300	
Total:								\$	1,577,340
Between 2020 - 2030*									
OPTION 4B									
Total:								\$	1,612,830

* O&M Costs for the period 2020 - 2030 includes annual O&M costs estimated for the period 2010 - 2020 plus additional O&M costs resulting from expansion in 2020

CITY OF ENID WASTEWATER FACILITY PLAN

PRESENT WORTH COST ANALYSIS

TABLE 10

Sep-06

OPTION	DESCRIPTION	CAPITAL COST		O & M COST		PRESENT WORTH COST AT 2006
		2010	2020	2010 - 2020	2020 - 2030	
1A	14 MGD New Plant Conventional Activated Sludge Process	\$ 48,316,100	\$ 4,935,100	\$ 1,717,680	\$ 1,888,480	\$ 62,646,975
1B	14 MGD New Plant SBR Process	\$ 46,580,700	\$ 4,935,100	\$ 1,442,030	\$ 1,612,830	\$ 58,184,959
3A	12 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 42,796,500	\$ 11,077,500	\$ 1,514,290	\$ 1,888,480	\$ 59,985,628
3B	12 MGD New Plant SBR Process W/ Expansion to 14 MGD	\$ 42,121,600	\$ 9,430,200	\$ 1,289,790	\$ 1,612,830	\$ 55,862,804
4A	7 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 33,039,300	\$ 26,421,000	\$ 1,627,910	\$ 1,888,480	\$ 60,842,593
4B	7 MGD New Plant SBR Process W/ Expansion to 14 MGD	\$ 31,930,500	\$ 24,026,400	\$ 1,577,340	\$ 1,612,830	\$ 57,106,473

APPENDICES

APPENDIX TM 1-1

RAW DATA FROM PLANT RECORDS

Historical Flow Peaking Data

Year	Average Annual Flow (mgd)	Maximum Month Flow (mgd)	Maximum Day Flow (mgd)	Maximum Month Factor	Maximum Day Factor
1996	6.264	7.064	11.922	1.13	1.90
1997	7.396	7.866	8.846	1.06	1.20
1998	7.937	9.637	14.724	1.21	1.86
1999	9.439	12.780	15.407	1.35	1.63
2000	6.804	8.207	11.387	1.21	1.67
2001	6.384	7.250	8.362	1.14	1.31
2002	6.015	6.358	8.887	1.06	1.48
2003	5.912	6.401	7.380	1.08	1.25
2004	6.121	6.400	7.800	1.05	1.27
Average	6.919			1.14	1.51

Influent Wastewater Characteristics

Year	Influent BOD ₅ (mg/l)	Influent TSS (mg/l)	Influent NH ₃ (mg/l)	Influent DO (mg/l)	Influent Alkalinity (mg/l)
1996	333	274	15.80	2.30	368
1997	245	257	14.60	1.20	359
1998	222	261	12.80	1.10	356
1999	196	227	11.10	1.00	354
2000	206	222	15.90	1.10	357
2001	268	283	16.67	-	-
2002	230	254	17.36	-	-
2003	220	248	18.30	-	-
2004	271	234	17.48	1.26	356
Mean	243	251	15.56	1.34	359
Std. Dev.	42	21	2.4	0.54	5

Per capita wastewater generation rate

Year	Total Service population	Average Annual Flow (mgd)	Percapita rate gpcd
1996	45,320	6.264	138
1997	45,190	7.396	164
1998	45,250	7.937	175
1999	45,200	9.439	209
2000	47,045	6.804	145
2001	46,590	6.384	137
2002	46,530	6.015	129
2003	46,480	5.912	127
2004	46,630	6.121	131

Sludge Production Records at the Existing Facility

SHEET	MONTH	TOTAL SLUDGE	TOTAL SLUDGE	TOTAL SLUDGE
	/ YR	GALLONS	CF PER MONTH	CF PER DAY
1	Jan-95	2590575	346334	11172
2	Feb-95	2790340	373040	13323
3	Mar-95	3041700	406644	13118
4	Apr-95	2887300	386003	12867
5	May-95	1794900	239960	7741
6	Jun-95	594000	79412	2647
7	Jul-95	1273545	170260	5492
8	Aug-95			
9	Sep-95			
10	Oct-95	1659812	221900	7158
11	Nov-95	1210972	161895	5396
12	Dec-95	1488050	198937	6417
13	Jan-96	1378331	184269	5944
14	Feb-96	1153731	154242	5509
15	Mar-96	1308950	174993	6734
16	Apr-96	1054483	140974	4699
17	May-96	1561451	208750	6734
18	Jun-96	1562531	208895	6963
19	Jul-96	1687081	225546	7276
20	Aug-96	13294371	1777322	57333
21	Sep-96	2175010	290777	9693
22	Oct-96	2191146	292934	9449
23	Nov-96	2706903	361885	12063
24	Dec-96	4016038	536903	17319
25	Jan-97	3080936	411890	13287
26	Feb-97	1947000	260294	9296
27	Mar-97	2112000	282353	9108
28	Apr-97	1503000	200936	6698
29	May-97	1321000	176604	5697
30	Jun-97	973000	130080	4336
31	Jul-97	971000	129813	4188
32	Aug-97	1009000	134893	4351
33	Sep-97	1017000	135963	4532
34	Oct-97	945000	126337	4075
35	Nov-97	872000	116578	3886
36	Dec-97	1157000	154679	4990
37	Jan-98	892000	119251	3847
38	Feb-98	660000	88235	3151
39	Mar-98	1196861	160008	5162
40	Apr-98	1903000	254412	8480
41	May-98	1226000	163904	5287
42	Jun-98	1228000	164171	5472
43	Jul-98	949000	126872	4093
44	Aug-98	1003500	134158	4328
45	Sep-98	714000	95455	3182
46	Oct-98	630000	84225	2717
47	Nov-98	512347	68496	2283
48	Dec-98	512347	68496	2210
49	Jan-99	921000	123128	3972
50	Feb-99	989495	132285	4724

51	Mar-99	582500	77874	2512
52	Apr-99	416384	55666	1856
53	May-99	416384	55666	1796
54	Jun-99	416384	55666	1856
55	Jul-99	571262	76372	2464
56	Aug-99	112452	15034	485
57	Sep-99	100381	13420	447
58	Oct-99	152188	20346	656
59	Nov-99			
60	Dec-99	349400	46711	1507
61	Jan-00	362932	48520	1565
62	Feb-00	326268	43619	1558
63	Mar-00	1172410	156739	5056
64	Apr-00	500448	66905	2230
65	May-00	500448	66905	2158
66	Jun-00	1480739	197960	6599
67	Jul-00	1280750	171223	5523
68	Aug-00	716337	95767	3089
69	Sep-00	775500	103676	3456
70	Oct-00	985500	131751	4250
71	Nov-00	945500	126404	4213
72	Dec-00	962000	128610	4149
73	Jan-01			
74	Feb-01	638865	85410	3050
75	Mar-01	989544	132292	4267
76	Apr-01	524446	70113	2337
77	May-01	664603	88851	2866
78	Jun-01	455591	60908	2030
	AVG.	1,352,242	180,781	5,951

Quantity of Solids Landfilled		
Year	ton/year	lb/d
1996	1513	8290
1997	1679	9200
1998	1062	5819
1999	-	-
2000	1164	6378
2001	1284	7036
2002	1067	5847
2003	1188	6510
Average	1280	7011

APPENDIX TM 1-2

INFORMATION ABOUT INDUSTRIES

September 13, 2005

Mr. Robert Hitt, P.E.
Director of Development Services
City of Enid
P.O. Box 1768
Enid, Oklahoma 73702

Re: City of Enid
Sanitary Sewer Master Plan Agreement
"Additional Organic Loading from Advance Foods and New Ethanol Plant"

Dear Mr. Hitt,

On Monday September 12, 2005, we were notified by your staff on the anticipated discharge from the proposed ethanol plant. As a result of this anticipated discharge and in addition to Advance Foods, we felt that it would be necessary to reevaluate the treatment capacity of the existing Water Pollution Control Facility.

Currently, the Influent flow and its BOD5 and TSS concentrations to the existing Water Pollution Control Facility average at 6.24 mgd, 280 mg/l and 226 mg/l, respectively. As you know both the North and South treatment plants were designed for an average BOD and TSS concentrations of 300 mg/l and 250 mg/l, respectively. In addition, our current evaluation of these two plants based on current ODEQ design standards has revealed that the North and South treatment plant are rated at 4.62 mgd and 3.23 mgd, respectively. Based on this information the total combined design capacity of the existing Water Pollution Control Facility for the City of Enid is about 19,641 pounds per day for BOD5 and 16,367 pounds per day for TSS.

With the anticipated discharge limits proposed by Advance Foods of 0.5 mgd, 664 mg/l BOD and 382 mg/l TSS and the new ethanol plant flow of 0.12 mgd, 1000 mg/l BOD and 350 mg/l TSS, we have estimated that the influent flow and raw wastewater characteristics for BOD and TSS to the existing facility will increase to 6.853 mgd, 320 mg/l and 240 TSS, respectively. Under these conditions the projected loading to the existing Water Pollution Control Facility will be approximately 18,313 pounds per day for BOD and 13,689 pounds per day for TSS.

From the information shown above it appears that the existing facility has the capacity to handle the additional loading, since the projected loading is slightly lesser. However, the BOD5 concentration of the projected influent flow (320 mg/l) is greater than the designed BOD5 concentration (300 mg/l) for the existing facility. Operating under these conditions could impact the effluent quality of the treatment plant and possibly exceed the current NPDES permit.

In order to maintain the influent BOD5 and TSS concentrations to the existing facility within the original design parameters, the BOD5 and TSS discharge concentration from these two industries will have to set at 500 mg/l, each. However, Conversations with your staff have also, revealed that Advance Foods is anticipating doubling production in the next two years that will add an additional flow of 0.5 mgd to the existing facility which will worsen conditions and exceed the BOD5 design parameter and possibly impact the effluent quality of the existing facility. With and anticipated additional flow of 1.0 mgd from Advance Foods and 0.12 mgd from the new ethanol plant, the ultimate combined flow to the existing plant will average at 7.4 mgd. Under this scenario the existing facility will be operating at about 94% capacity of its current rated capacity.

Based on the anticipated additional loadings described above and the operation of the existing Water Pollution Control Facility with both the North and South plants and the use of the Biological nutrient removal train as an effluent polishing process, we recommend that the City's pretreatment program shall ensure that any future pretreatment discharge limit for BOD5 does not exceed 300 mg/l until further expansion to the treatment plant is evaluated and designed.

Should you have any questions, please feel free to contact me.

Very truly yours,

Dewberry Design Group Incorporated

Jose A. Pereira, P.E.
Associate

Cc: James McClain, Public Service Director City of Enid
Muralikumar Katta-Muddanna, Project Engineer City of Enid
Barry Brummit, Pretreatment Director City of Enid
Joyce Hight, Superintendent City of Enid
Vel Subramanian, Dewberry

APPENDIX TM 1-3

CITY OF ENID OPDES PERMIT

**AUTHORIZATION TO DISCHARGE UNDER THE
OKLAHOMA POLLUTANT DISCHARGE ELIMINATION SYSTEM**

PART I.

In compliance with the Oklahoma Pollutant Discharge Elimination System Act (OPDES Act), Title 27A O.S., § 2-6-201 *et seq.* and the rules of the State of Oklahoma Department of Environmental Quality (DEQ) adopted there under (See OAC 252:605); the Federal Clean Water Act, Public Law 95-217 (33 U.S.C. 1251 *et seq.*), Section 402; and NPDES Regulations (40 CFR Parts 122, 124 and 403),

City of Enid
(State ID No. S-20931)
P.O. Box 1768
Enid, Oklahoma 73702

is hereby authorized to discharge treated wastewater from a facility located at approximately

NE¼ of SW¼ of NW¼ of Section 14
Township 22 North, Range 6 West, I.M.
Garfield County, State of Oklahoma

to receiving water: Boggy Creek, tributary to Skeleton Creek, tributary to the Cimarron River at a point located approximately

	Outfall 001	Outfall 002	
Latitude:	36° 23' 11.904" N	36° 23' 11.148" N	(GPS: NAD-27 CONUS)
Longitude:	97° 48' 58.968" W	97° 48' 49.787" W	(GPS: NAD-27 CONUS)
Planning Segment No. 620910 (Water body ID # 620910030250)			

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I, II, III and IV hereof.


This permit replaces and/or supersedes the previous permit modification issued on March 1, 2001

The issuance date of this permit is July 31, 2003


This permit shall become effective August 1, 2003

This permit and authorization to discharge shall expire at midnight, July 31, 3008

For the Oklahoma Department of Environmental Quality:



Edward Dibrberg, P.E., Manager
Municipal Permits Section
Water Quality Division



Jon L. Craig, Director
Water Quality Division

A. Effluent Limitations

During the period beginning the effective date and lasting through date of expiration the permittee is authorized to discharge treated wastewater in accordance with the following limitations:

1. Conventional and Non-Conventional Pollutants

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>			<u>Monitoring Requirements</u>	
	Mass (lbs/d)	Concentration (mg/l)		Measure- ment Frequency	Sample Type
	30-day Average	30-day Average	7-day Average		
Spring (April - May): Outfall 002 only					
Carbonaceous Biochemical Oxygen Demand - 5 Day (CBOD ₅) [80082]	1417.8	20.0	30.0	3/week	12-hour composite
Total Suspended Solids (TSS) [00530]	2126.7	30.0	45.0	2/week	
Ammonia (NH ₃ -N) [00610]	141.8	2.0	3.0	1/week	
Dissolved Oxygen (DO) [00300] ^b Minimum 6 mg/l				3/week	Grab
Summer (June - October): Outfall 002 only					
Carbonaceous Biochemical Oxygen Demand - 5 Day (CBOD ₅) [80082]	1063.4	15.0	22.5	3/week	12-hour composite
Total Suspended Solids (TSS) [00530]	2126.7	30.0	45.0	2/week	
Ammonia (NH ₃ -N) [00610]	141.8	2.0	3.0	1/week	
Dissolved Oxygen (DO) [00300] ^b Minimum 5 mg/l				3/week	Grab
Winter (November - March): Outfall 001 and/or Outfall 002					
Biochemical Oxygen Demand - 5 Day (BOD ₅) [00310]	1417.8 ^a	20.0	30.0	3/week	12-hour composite
Total Suspended Solids (TSS) [00530]	2126.7 ^a	30.0	45.0	2/week	
Ammonia (NH ₃ -N) [00610]	290.6 ^a	4.1	9.9 [Daily max]	3/week ^c	
Dissolved Oxygen (DO) [00300] ^b Minimum 5 mg/l				3/week	Grab

^a The combined mass loading from each outfall may not exceed this value if both outfalls are used simultaneously.

^b If simultaneously discharging from outfalls 001 and 002, grab samples will be taken from both outfalls, and the lower of the two dissolved oxygen values reported.

^c If the highest daily maximum ammonia level reported during this season for the first year after the effective date of these limits is less than or equal to 1.5 times the monthly average limit (i.e., $1.5 \times 4.1 = 6.15$ mg/l), the monitoring frequency may be reduced to 1/week for that season. Otherwise, the monitoring frequency continues at 3/week for that season for the remaining term of the permit.

There shall be no discharge of floating solids or visible foam in other than trace amounts.

The pH shall not be less than 6.5 standard units nor greater than 9.0 standard units at any time, it shall be monitored by grab samples collected 3/week.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit.

Flow (measured in million gallons per day) shall be monitored daily by totalized measurement and reported as a 30-day average and a daily maximum.

2. Whole Effluent Toxicity Reporting and Monitoring Requirements (Outfalls TX1, TX2).

During the period beginning the effective date of the permit and lasting through the expiration date, the permittee is authorized to discharge from Outfall TX1 and Outfall TX2 (functionally identical to Outfall 001 and Outfall 002). The discharge consists of biologically treated sanitary wastewater. Such discharges shall be limited and monitored by the permittee as specified below:

Whole Effluent Toxicity Reporting and Monitoring Requirements (Outfalls TX1 and TX2)

Effluent Characteristic			Reporting Requirements ^a		Monitoring Requirements		
Test	Critical Dilution	Parameter	30-day Avg Min	7-day Min	Testing Frequency ^b	Sample Type	
Routine Testing	100%	Pass/Fail Survival [TLP3B]	---	Report	2/season for TX1 ^c , and 1/quarter ^f for TX2	24-hr comp	
		NOEC _L Survival [TOP3B]	Report	Report			
		% Mortality at Critical Dilution [TJP3B]	Report	Report			
		Pass/Fail Reproduction [TGP3B]	---	Report			
		NOEC _S Reproduction [TPP3B]	Report	Report			
	100%	% Coeff of Variation [TQP3B]	Report	Report			
		100%	Pass/Fail Survival [TLP6C]	---	Report	2/season for TX1 ^c , and 1/quarter ^f for TX2	24-hr comp
			NOEC _L Survival [TOP6C]	Report	Report		
			% Mortality at Critical Dilution [TJP6C]	Report	Report		
			Pass/Fail Growth [TGP6C]	---	Report		
NOEC _S Growth [TPP6C]	Report		Report				
% Coeff of Variation [TQP6C]	Report	Report					
Retesting	Retest #1 [22415] ^e		---	Report	As required ^d	24-hr comp	
	Retest #2 [22416] ^e		---	Report			

- ^a See Part II, Section A, Whole Effluent Toxicity Testing, for additional monitoring and reporting conditions.
- ^b Reporting periods commence with the effective date of the permit. A valid WET test shall be reported for each species for each reporting period. Results of retests conducted pursuant to prior test failure shall not be submitted on DMRs in lieu of routine test results (see Part II, Section A, Item 2.a).
- ^c Applies to either or both test species, according to results of test failure triggering monthly retests.
- ^d Monthly retesting required only if the routine test for reporting period (for either species) fails.
- ^e When discharging, no frequency reduction will be applied to TX1 for biomonitoring (November - March).
- ^f The frequency of testing may be reduced to twice per year for TX2, if requested and if there are no lethal or sublethal failures in WET testing during the first two years of the permit. See the provision for WET testing monitoring frequency reduction after the first two years (Part II, Section A, Item 5).

Whole effluent toxicity reporting and monitoring requirements apply beginning the effective date of the permit.

WET testing summary reports: Reports of all WET testing initiated, regardless of whether such tests are carried to completion, shall follow the requirements of Part II, Section A, Item 4.

Whole effluent toxicity concurrent testing provision: Concurrent analysis of total ammonia and pH is required on all effluent samples, including static renewals, collected for Fathead minnow WET testing or retesting. Reporting of results shall be in accordance with the following requirements.

Concurrent Effluent Testing - Reporting Requirements

Effluent Characteristic	Concentration ^a			Monitoring Requirements	
	Daily Min	Monthly Avg	Daily Max	Monitoring Frequency	Sample Type
Ammonia, total [STORET 00610]	Report ^b	Report ^b	Report ^b	2/season for TX1 ^c , and 1/quarter ^d for TX2	24 hr composite
pH (std units) [STORET 00400]	Report ^b	---	Report ^b		Note ^e

- ^a Concentration units are mg/l unless otherwise specified.
- ^b Report only those effluent samples collected for Fathead minnow WET testing.
- ^c Measured in each composite effluent sample, including static renewals, just prior to first use.
- ^d The frequency of testing can be reduced to twice per year for TX2, if requested and if there are no lethal or sublethal failures in WET testing during the first two years of the permit.
- ^e When discharging (November - March).

3. Priority Pollutants

a. Monitoring Requirements for Copper for Outfall 002 (period effective beginning eighteen months before the expiration date of the permit and to last one year).

During the period stated above, the permittee shall monitor for one year the effluent for copper and report the results as follows:

Effluent Characteristics	Discharge Limitations			Monitoring Requirements	
	Mass (lbs/day)	Concentration(ug/l)		Measurement Frequency	Sample Type
	Monthly Avg.	Monthly Avg.	Daily Maximum		
Copper, Total	Report	Report	Report	1/month	24-hr composite

If any individual test result is less than the minimum quantification level (MQL) of 10 ug/l for copper (monthly and/or daily maximum), a value of zero (0) may be used for the discharge monitoring report (DMR) calculations and reporting requirements.

b. Monitoring Requirements for Hardness (Outfall 999)

During the period beginning eighteen months before the expiration of the permit, the permittee shall monitor the upstream hardness for one year, and report the results as follows:

Upstream Characteristics	Upstream Monitoring			Monitoring Requirements	
	Mass (lbs/day)	Concentration(mg/l)		Measurement Frequency	Sample Type
	Monthly Avg.	Monthly Avg.	Daily Maximum		
Hardness	NA	NA	Report	1/month	Grab

B. Sanitary Sewer Overflows

Any bypass in the collection system [sanitary sewer overflow (SSO)] shall be reported in accordance with Part III.B.6. of this permit.

In addition, all reports shall be summarized and reported in tabular format with the Discharge Monitoring report (DMR) for the month in which the bypasses occurred.

PART II. OTHER PERMIT REQUIREMENTS

**A. WHOLE EFFLUENT TOXICITY TESTING
(7-DAY CHRONIC NOEC, STATIC RENEWAL, FRESHWATER)**

1. SCOPE AND METHODOLOGY

a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section. Applicability to multiple outfalls is described in Item 3.d.5 of this section. The permittee shall biomonitor for *Ceriodaphnia dubia* and *Pimephales promelas* in accordance with the WET testing frequencies prescribed in Part I. Intervals between test initiation dates shall be a function of the required testing frequency, as follows:

- Monthly retests: No less than 20 days and no more than 40 days.
- Quarterly: No less than 2 months and no more than 4 months.
- Semi-annually: No less than 4 months and no more than 8 months.

APPLICABLE TO OUTFALL(S):	001 and 002
REPORTED ON DMR AS OUTFALL(S):	TX1 and TX2
CRITICAL DILUTION:	100%
EFFLUENT DILUTION SERIES (ALL TESTS):	32%, 42%, 56%, 75%, and 100%
COMPOSITE SAMPLE TYPE:	Defined at Part I
TEST SPECIES/METHODS:	40 CFR 136

Ceriodaphnia dubia chronic static renewal 7-day survival and reproduction test, Method 1002.0, EPA/600/4-91/002 or the most recent update thereof. A minimum of ten (10) replicates consisting of one (1) organism each must be used in the control and in each effluent dilution of this test. This test should be terminated when 60% of the surviving females in the control produce three broods or at the end of eight days, whichever comes first. If these criteria are not met at the end of 8 days, the test must be repeated.

Pimephales promelas (Fathead minnow) chronic static renewal 7-day larval survival and growth test, Method 1000.0, EPA/600/4-91/002, or the most recent update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

b. CHRONIC LETHAL EFFECT TEST FAILURE

The NOEC_L (No Observed Lethal Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic lethal test failure (chronic

NOEC_L test) is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.

c. CHRONIC SUBLETHAL EFFECT TEST FAILURE

The NOEC_S (No Observed Sublethal Effect Concentration) is defined as the greatest effluent dilution at and below which sublethality (inhibited reproduction in the *Ceriodaphnia dubia* test or inhibited growth in the Fathead minnow test) that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Chronic sublethal test failure (chronic NOEC_S test) is defined as a demonstration of a statistically significant sublethal effect at test completion to a test species at or below the critical dilution.

d. REOPENER CLAUSE

This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.

2. TESTING REQUIREMENTS DUE TO CHRONIC TEST FAILURE

Upon becoming aware of the failure of any test, the permittee shall notify the DEQ Water Quality Division Toxics Coordinator immediately, and in writing within 5 working days of the test failure, with a summary of the results of and any other pertinent circumstances associated with the failed test.

- a. Whenever there is a lethal effect test failure for either species during routine testing, the frequency of testing for the affected species shall automatically increase to, or continue at, as appropriate, the WET testing frequency prescribed in Part I for the remaining life of the permit. In addition, two (2) additional monthly tests (retests) of the affected species are required. The two additional tests shall be conducted monthly during the next two consecutive months. The permittee shall not substitute either of the two additional tests for routine toxicity testing. Additional tests are not required for a sublethal effect test failure. A full laboratory report for the failed routine test and both additional tests, if required, shall be prepared and submitted to the DEQ in accordance with procedures outlined in Item 4 of this section.

b. PERSISTENT LETHALITY

- (1) If either of the two additional tests result in an NOEC_L value less than the critical dilution, persistent lethality is exhibited, and the permittee shall initiate a Toxicity Reduction Evaluation (TRE) as specified in Item 5 of this section. The TRE initiation date will be the test completion date of the first failed retest.
- (2) The retesting requirements in Item 2.a are suspended upon submittal of the TRE Action Plan.

c. INTERMITTENT LETHALITY

If both additional tests result in an NOEC_L value greater than or equal to the critical dilution, persistent lethality is not exhibited. However, if any routine test lethal effect failure occurs within 18 months of a prior lethal effect test failure, intermittent lethality is

exhibited, and the permittee may be required by the DEQ to initiate a TRE, as described in Item 5 of this section, based on the severity and pattern of such lethal effect over time.

d. PERSISTENT SUBLETHALITY

Barring persistent lethality, if two consecutive routine tests result in a sublethal effect failure for a species, persistent sublethality is exhibited, and the permittee:

- (1) Shall increase the frequency of testing for the affected species to, or continue at, as appropriate, the WET testing frequency prescribed in Part I for the remaining life of the permit; and
- (2) May be required by the DEQ to initiate a TRE, as specified in Item 5 of this section, based on the severity and pattern of such sublethal effect over time.

3. REQUIRED TOXICITY TESTING CONDITIONS

a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- (1) The toxicity test control (0% effluent) must have survival equal to or greater than 80%.
- (2) The mean number of *Ceriodaphnia dubia* neonates produced per surviving female in the control (0% effluent) must be 15 or more.
- (3) Sixty (60) percent of the surviving *Ceriodaphnia dubia* control females must produce three broods.
- (4) The mean dry weight of surviving Fathead minnow larvae at the end of the 7 days in the control (0% effluent) must be 0.25 mg per larva or greater.
- (5) The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for the young of surviving females in the *Ceriodaphnia dubia* reproduction test and for the growth and survival endpoints of the Fathead minnow test.
- (6) The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal or sublethal effects are exhibited for the young of surviving females in the *Ceriodaphnia dubia* reproduction test and for the growth and survival endpoints of the Fathead minnow test.
- (7) As documented at test termination, no more than forty (40) percent of the *Ceriodaphnia dubia* test organisms in the control (0% effluent) or any effluent dilution shall be male.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40% in the critical dilution. A repeat test shall be conducted within the reporting period of any test determined to be invalid.

b. Statistical Interpretation

- (1) For the *Ceriodaphnia dubia* survival test, the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be Fisher's Exact Test as described in EPA/600/4-91/002, or the most recent update thereof.
- (2) For the *Ceriodaphnia dubia* reproduction test and the Fathead minnow larval survival and growth test the statistical analyses used to determine if there is a significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA/600/4-91/002, or the most recent update thereof.
- (3) If the conditions of test acceptability are met in Item 3.a above and the percent survival of the test organism is equal to or greater than 80% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report an NOEC_i of not less than the critical dilution for the DMR reporting requirements found in Item 4 below.

c. Dilution Water

- (1) Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness and alkalinity to the closest downstream perennial water where the toxicity test is conducted on an effluent discharge to a receiving stream classified as intermittent or to a receiving stream with no flow due to zero flow conditions.
- (2) If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 3.a.), the permittee must submit the test results exhibiting receiving water toxicity with the full test report required in Item 4 below and may thereafter substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
 - (a) A synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a. was run concurrently with the receiving water control;
 - (b) The test indicating receiving water toxicity was carried out to completion; and
 - (c) The synthetic dilution water had a pH, hardness and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- (1) The permittee shall collect three flow-weighted 24-hour composite samples representative of the flows during normal operation from the outfall(s) listed at item 1.a above. Unless otherwise specified in Part I of the permit, a 24-hour composite sample consists of a minimum of 12 effluent portions collected at equal time intervals

representative of a 24-hour operating day and combined proportional to flow or a sample continuously collected proportional to flow over a 24-hour operating day.

- (2) The first composite effluent sample shall be used to initiate each test and must be collected so that its holding time (between collection of the last portion of the sample and test initiation) does not exceed 36 hours. Collection of the second and third composite effluent samples must be timed so as to permit an approximately equal use distribution of the three composite samples for daily static renewals. In no case shall the holding time of the second and third composite samples (between collection of the last portion of the sample and its first use) exceed 72 hours. All samples shall be chilled to 4 °C during collection, shipping and/or storage.
- (3) The permittee shall collect the 24-hour composite samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
- (4) If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full test report required in Item 4 of this section.
- (5) MULTIPLE OUTFALLS: If the provisions of this section are applicable to multiple outfalls, as specified in Part I of the permit, the permittee shall combine the composite effluent samples in proportion to the average flow from the outfalls listed in Item 1.a of this section for the day the sample was collected. The permittee shall perform the toxicity test on the flow-weighted composite of the outfall samples.

4. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this section in accordance with the Report Preparation Section of EPA/600/4-91/002, or the most current publication, for every valid or invalid toxicity test initiated, whether carried to completion or not. The permittee shall retain each full report pursuant to the records retention provisions of Part III of this permit. The permittee shall submit full test reports for all tests initiated, regardless of whether the tests are carried to completion, to the DEQ no later than the 15th day of the month following completion of the test, including any test which is considered invalid, is terminated early for any reason, or which indicates receiving water toxicity.
- b. A valid test for each species (excluding retests) must be reported on the DMR for each reporting period specified in Part I of this permit unless the permittee is performing a TRF, which may increase the frequency of testing and reporting. A DMR must be submitted by the 15th day of the month following completion of any valid test. The full report for the test (see Item 4.a above) shall be submitted along with the DMR. If a survival test failure is experienced for either test species, two copies of the blank DMR for the applicable

reporting period shall be made in advance of completing and submitting the DMR so that the DMR copies may be used to report results of the required retests. If more than one valid test (excluding retests) is performed on a species during a reporting period, the permittee shall report the lowest survival test results as the 7-day minimum for each species tested, and the arithmetic average of the results of the survival tests shall be reported as the 30-day average minimum. The sublethal test results reported for each species on the DMR are determined in the same manner. If the permittee performs only one valid test (excluding retests) on a species during the reporting period, then the results of that test shall be reported as both the 7-day minimum and the 30-day average minimum on the DMR. The 30-day average minimum does not apply to the pass/fail parameters (TLP3B, TGP3B, TLP6C and TGP6C) in Item 4.c below.

If any test results in anomalous NOEC_L or NOEC_S findings (i.e., it indicates an interrupted dose response across the dilution series), the DEQ recommends that the permittee contact its DEQ toxicity coordinator for a technical review of the test results prior to submitting the full test report and DMR. A summary of all tests initiated during the reporting period, including invalid tests, repeat tests and retests, shall be attached to the reporting period DMR for DEQ review. A test is a REPEAT test if it is performed as a result of a previously invalid test. A test is a RETEST if it is performed as a result of a previously failed test. Each time a DMR is submitted, put the new submittal date in the lower right-hand corner of the DMR.

- (1) The reporting period test summary attached to the DMR shall be organized as follows:
 - (a) Invalid tests (basis for test invalidity must be described)
 - (b) Valid tests (other than retests) initiated during current reporting period
 - (c) Valid retests for tests failed during previous reporting period (if not submitted in the previous reporting period test summary)
 - (d) Valid retests for tests failed during current reporting period
 - (2) The following information shall be listed in the reporting period test summary for each valid test in categories (b) through (d) in Item 4.b(1) above:
 - (a) Test species
 - (b) Date of test initiation at laboratory
 - (c) Results of all concurrent effluent analyses specified in Part I of this permit
 - (d) All test result parameters for the test species specified in Item 4.c below.
- c. The permittee shall report the following results for all VALID toxicity tests (excluding retests) on the DMR(s) for that reporting period in accordance with Item 4.b above and Part III of this permit.
- (1) *Ceriodaphnia dubia*

- (a) Parameter TLP3B: If the *Ceriodaphnia dubia* NOEC_L for survival is less than the critical dilution, report a "1"; otherwise, report a "0".
 - (b) Parameter TOP3B: Report the *Ceriodaphnia dubia* NOEC_L value for survival.
 - (c) Parameter TJP3B: Report the *Ceriodaphnia dubia* percent mortality in the critical dilution at test completion.
 - (d) Parameter TGP3B: If the *Ceriodaphnia dubia* NOEC_S for reproduction is less than the critical dilution, report a "1"; otherwise, report a "0".
 - (e) Parameter TPP3B: Report the *Ceriodaphnia dubia* NOEC_S value for reproduction.
 - (f) Parameter TQP3B: Report the highest coefficient of variation (critical dilution or control) for *Ceriodaphnia dubia* reproduction.
- (2) *Pimephales promelas* (Fathead minnow)
- (a) Parameter TLP6C: If the Fathead minnow NOEC_L for survival is less than the critical dilution, report a "1"; otherwise, report a "0".
 - (b) Parameter TOP6C: Report the Fathead minnow NOEC_L value for survival.
 - (c) Parameter TJP6C: Report the Fathead minnow percent mortality in the critical dilution at test completion.
 - (d) Parameter TGP6C: If the Fathead minnow NOEC_S for growth is less than the critical dilution, report a "1"; otherwise, report a "0".
 - (e) Parameter TPP6C: Report the Fathead minnow NOEC_S value for growth.
 - (f) Parameter TQP6C: Report the highest coefficient of variation (critical dilution or control) for Fathead minnow survival and growth.
- d. The permittee shall report the following results for all VALID toxicity retests on the DMR(s) for that reporting period.
- (1) Retest #1 (STORET 22415): If the first monthly retest following failure of a routine test for either test species results in an NOEC_L for survival less than the critical dilution, report a "1"; otherwise, report a "0".
 - (2) Retest #2 (STORET 22416): If the second monthly retest following failure of a routine test for either test species results in an NOEC_L for survival less than the critical dilution, report a "1"; otherwise, report a "0".

Results of all retests shall be reported on a copy of the DMR for the reporting period (see Item 4.b above) in which the triggering routine test failure is experienced by no later than the 15th day of the month following completion of the retest. The full report for the retest (see Item 4.a above) shall be submitted along with the retest DMR. Even if a retest cannot be conducted before the end of the reporting period for which it is required (due to test initiation interval requirements), the retest results shall still be reported for the reporting

period in which the triggering test failure is experienced. In this manner, both retests are reported for the same reporting period as the failed routine test. Each time a DMR is submitted, put the new submittal date in the lower right-hand corner of the DMR. If retesting is not required during a given reporting period, the permittee shall leave these DMR fields blank.

5. MONITORING FREQUENCY REDUCTION

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first two years of testing for one or both test species with no lethal or sublethal effects demonstrated at or below the critical dilution. Certification in accordance with Item 5.b of this section shall be submitted at the time of such application for monitoring frequency reduction. If granted, the monitoring frequency may be reduced to not less than once per 6 months (once each during the periods June 1 through September 30 and December 1 through March 31) for either test species.
- b. **CERTIFICATION:** The permittee must certify in writing that no lethal or sublethal test failures have occurred for the species for which the monitoring frequency reduction is being requested and that all tests meet all test acceptability criteria in Item 3.a. above. In addition, the permittee must provide a summary of all tests initiated during the period of certification including test initiation dates, species, test acceptability parameters, NOEC_i values, percent mortality at the critical dilution, NOEC_s values, and coefficients of variation for the controls and critical dilutions. If the certification is approvable, the DEQ will issue a letter of confirmation of the monitoring frequency reduction. A copy of the confirmation letter will be forwarded to the DEQ's Permit Compliance System unit to update the permit reporting requirements. The DEQ may deny the certification if it determines that, during the period for which the certification is submitted, there were errors in meeting test acceptability requirements, errors in statistical interpretation affecting test results reported on DMRs, late submissions of test reports or submissions of substantively incomplete test reports. If the certification is denied, the permittee shall continue biomonitoring of the affected test species at a frequency of once per quarter until the permit is reissued.
- c. **SUBLETHAL FAILURES DURING FIRST YEAR OF TESTING:** If, during the first year of testing, only a sublethal effect is demonstrated to a test species, continued routine testing for that species is required for the remainder of the first year and, as necessary, into the following year(s) at the frequency prescribed in Part I until the effluent passes four consecutive routine tests for both lethal and sublethal test endpoints, at which time the permittee may apply for a monitoring frequency reduction in a manner consistent with Item 5.a above. Certification in accordance with Item 5.b of this section shall be submitted at the time of such application for monitoring frequency reduction. If granted, the monitoring frequency may be reduced in accordance with Item 5.a.
- d. **SURVIVAL FAILURES AFTER A MONITORING FREQUENCY REDUCTION:** If any test fails the survival endpoint at any time after the granting of a monitoring frequency reduction, two monthly retests are required in accordance with Item 2 of this section (unless the permittee is performing a TRE) and the monitoring frequency for the affected test species shall be increased to the WET testing frequency prescribed in Part I until the permit is reissued.

- e. This monitoring frequency reduction applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to the WET testing frequency prescribed in Part I until the permit is reissued.

6. TOXICITY REDUCTION EVALUATION (TRE)

- a. Within ninety (90) days of confirming lethality in the retests for a test species, the permittee shall submit to the DEQ a Toxicity Reduction Evaluation (TRE) Action Plan and Schedule for conducting a TRE. The TRE Action Plan shall specify the approach and methodology to be used in performing the TRE. A Toxicity Reduction Evaluation is an investigation intended to determine those actions necessary to achieve compliance with water quality-based effluent limits by reducing an effluent's toxicity to an acceptable level. A TRE is defined as a step-wise process which combines toxicity testing and analyses of the physical and chemical characteristics of a toxic effluent to identify the constituents causing effluent toxicity and/or treatment methods which will reduce the effluent toxicity. The TRE Action Plan shall lead to the successful elimination of effluent toxicity at the critical dilution and include the following:

- (1) Specific Activities. The plan shall detail the specific approach the permittee intends to utilize in conducting the TRE. The approach may include toxicity characterizations, identifications and confirmation activities, source evaluation, treatability studies, or alternative approaches. When the permittee conducts Toxicity Characterization Procedures the permittee shall perform multiple characterizations and follow the procedures specified in the documents "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA-600/6-91/003) and "Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I" (EPA-600/6-91/005F), or alternate procedures. When the permittee conducts Toxicity Identification Evaluations and Confirmations, the permittee shall perform multiple identifications and follow the methods specified in the documents "Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081), as appropriate.

The documents referenced above may be obtained through the National Technical Information Service (NTIS) by phone at (703) 487-4650, or by writing:

U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161

- (2) Sampling Plan (e.g., locations, methods, holding times, chain of custody, preservation, etc.). The effluent sample volume collected for all tests shall be adequate to perform the toxicity test, toxicity characterization, identification and confirmation procedures, and conduct chemical specific analyses when a probable toxicant has been identified. Where the permittee has identified or suspects specific pollutant(s) and/or source(s) of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical specific analyses for the identified and/or suspected pollutant(s) and/or source(s) of

effluent toxicity. Where lethality was demonstrated within 48 hours of test initiation, each composite sample shall be analyzed independently. Otherwise, the permittee may substitute a composite sample, comprised of equal portions of the individual composite samples, for the chemical specific analysis.

- (3) Quality Assurance Plan (e.g., QA/QC implementation, corrective actions, etc.).
 - (4) Project Organization (e.g., project staff, project manager, consulting services, etc.).
- b. The permittee shall initiate the TRE Action Plan within thirty (30) days of plan and schedule submittal. The permittee shall assume all risks for failure to achieve the required toxicity reduction.
 - c. The permittee shall submit to the DEQ a quarterly TRE Activities Report with the Discharge Monitoring Report in the months of (to be specified), containing information on toxicity reduction evaluation activities including:
 - (1) any data and/or substantiating documentation which identifies the pollutant(s) and/or source(s) of effluent toxicity;
 - (2) any studies/evaluations and results on the treatability of the facility's effluent toxicity; and
 - (3) any data which identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant lethality at the critical dilution.
 - d. The permittee shall submit to the DEQ a Final Report on Toxicity Reduction Evaluation Activities no later than twenty-eight (28) months from confirming lethality in the retests, which provides information pertaining to the specific control mechanism selected that will, when implemented, result in reduction of effluent toxicity to no significant lethality at the critical dilution. The report will also provide a specific corrective action schedule for implementing the selected control mechanism.
 - e. Quarterly testing during the TRE is a minimum monitoring requirement. The DEQ recommends that permittees required to perform a TRE not rely on quarterly testing alone to ensure success in the TRE, and that additional tests be performed to capture toxic samples for identification of toxicants. Failure to identify the specific chemical compound causing toxicity test failure will normally result in a permit limit for whole effluent toxicity per federal regulations at 40 CFR 122.44(d)(1)(v).

B. SEWAGE SLUDGE REQUIREMENTS

The sludge produced at the facility is presently sent to the Enid Municipal Landfill located in the NE of Sections 29, Township 22-N, Range 6 W. I.M., Garfield County, Oklahoma..

Sewage sludge disposal practices shall comply with the federal regulations for landfills, sludge, and solid waste disposal established at 40 CFR Part 257, 503 and the DEQ rules governing Sludge Management (OAC 252:648) as applicable.

The permittee shall give 120 days prior notice to DEQ of any change planned in the sewage sludge disposal practice.

In addition, the permittee shall comply with other sludge requirements specified in Part IV of this permit.

The permittee is required to maintain all records relevant to sewage sludge disposal for the life of the permit. These records shall be made available to DEQ upon request.

C. POLLUTION PREVENTION REQUIREMENTS

1. The permittee shall institute a program within 12 months of the effective date of the permit (or continue on existing one) directed towards optimizing the efficiency and extending the useful life of the facility. The permittee shall consider the following items in the program:
 - a. The influent loadings, flow and design capacity;
 - b. The effluent quality and plant performance;
 - c. The age and expected life of the wastewater treatment facility's equipment;
 - d. Bypasses and overflows of the tributary sewerage system and treatment works;
 - e. New developments at the facility;
 - f. Operator certification and training plans and status;
 - g. The financial status of the facility;
 - h. Preventative maintenance programs and equipment conditions and;
 - i. An overall evaluation of conditions at the facility.

2. The permittee shall prepare the following information on the sewage sludge generated by the facility.
 - a. An annual quantitative tabulation of the ultimate disposition of all sewage sludge (including, but not limited to, the amount beneficially reused, landfilled, surface disposed, and incinerated).
 - b. An assessment of technological processes and an economic analysis evaluating the potential for beneficial reuse of all sewage sludge not currently beneficially reused including a listing of any steps which would be required to achieve the sludge quality necessary to beneficially reuse the sludge.
 - c. A description of, including the expected results and the anticipated timing for, all projects in process, in planning and/or being considered which are directed towards additional beneficial reuse of sewage sludge.
 - d. An analysis of one composite sample of the sludge collected prior to ultimate re-use or disposal shall be performed for the pollutants listed in Part IV, Element 1, Section III, Table 3 of the permit.
 - e. A listing of the specific steps (controls/changes) which would be necessary to achieve and sustain the quality of the sludge so that the pollutant concentrations in the sludge fall below the pollutant concentration criteria listed in Part IV, Element 1, Section III, Table 3 of the permit.
 - f. A listing of, and the anticipated timing for, all projects in process, in planning, and/or being considered which are directed towards meeting the sludge quality referenced in (c) above.

The permittee shall certify in writing, within three years of the effective date of the permit, that all pertinent information is available. This certification shall be submitted to:

Oklahoma Department of Environmental Quality
Water Quality Division
Wastewater Discharge Permit Section
P. O. Box 1677;
707 North Robinson Street
Oklahoma City, Oklahoma 73101-1677

D. CONTRIBUTING INDUSTRIES AND PRETREATMENT REQUIREMENTS

1. The permittee shall operate an industrial pretreatment program in accordance with Section 402(b)(8) of the Clean Water Act, the General Pretreatment Regulations (40 CFR Part 403) and the approved POTW pretreatment program submitted by the permittee. The pretreatment program was approved on October 15, 1984 and modified on July 15, 1994 and March 1, 2001. A Publicly Owned Treatment Works (POTW) facility is defined in 40 CFR 403.3(o) "as any devices and systems used in storage, treatment, recycling and reclamation of municipal sewage and industrial wastes of a liquid nature. It also includes sewers, pipes and other conveyances only if they convey wastewater to a POTW Treatment Plant. The term also means the municipality as defined in section 502(4) of the Act, which has jurisdiction over the Indirect Discharges to and from such treatment works." The POTW pretreatment program is hereby incorporated by reference and shall be implemented in a manner consistent with the following requirements:
 - a. Industrial user information shall be updated at a frequency adequate to ensure that all IUs are properly characterized at all times;
 - b. The frequency and nature of industrial user compliance monitoring activities by the permittee shall be commensurate with the character, consistency and volume of waste. However, in keeping with the requirements of 40 CFR 403.8 (f)(2)(v), the permittee must inspect and sample the effluent from each Significant Industrial User at least once a year. This is in addition to any industrial self-monitoring activities;
 - c. The permittee shall enforce and obtain remedies for noncompliance by any industrial users with applicable pretreatment standards and requirements;
 - d. The The permittee shall control through permit, order, or similar means, the contribution to the POTW by each Industrial User to ensure compliance with applicable Pretreatment Standards and requirements. In the case of Industrial Users identified as significant under 40 CFR 403.3(t), this control shall be achieved through permits or equivalent individual control mechanisms issued to each such user. Such control mechanisms must be enforceable and contain, at a minimum, the following conditions:
 - (1). Statement of duration (in no case more than five years);
 - (2). Statement of non-transferability without, at a minimum, prior notification to the POTW and provision of a copy of the existing control mechanism to the new owner or operator;
 - (3). Effluent limits based on applicable general pretreatment standards, categorical pretreatment standards, local limits, and State and local law;

- (4). Self-monitoring, sampling, reporting, notification and record keeping requirements, including an identification of the pollutants to be monitored, sampling location, sampling frequency, and sample type, based on the applicable general pretreatment standards in 40 CFR 403, categorical pretreatment standards, local limits, and State and local law; and
 - (5). Statement of applicable civil and criminal penalties for violation of pretreatment standards and requirements and any applicable compliance schedule. Such schedules may not extend the compliance date beyond federal deadlines.
- e. The permittee shall evaluate, at least once every two years, whether each Significant Industrial User needs a plan to control slug discharges. If the POTW decides that a slug control plan is needed, the plan shall contain at least the minimum elements required in 40 CFR 403.8 (f)(2)(v);
 - f. The permittee shall provide adequate staff, equipment, and support capabilities to carry out all elements of the pretreatment program; and,
 - g. The approved program shall not be modified by the permittee without the prior approval of the DEQ.
2. The permittee shall establish and enforce specific limits to implement the provisions of 40 CFR Parts 403.5(a) and (b), as required by 40 CFR Part 403.5(c). Each POTW with an approved pretreatment program shall continue to develop these limits as necessary and effectively enforce such limits.

The permittee shall, within sixty days of the effective date of this permit, (1) submit a WRITTEN CERTIFICATION that a technical evaluation has been performed demonstrating that the existing technically based local limits (TBLL) are based on the current state water quality standards and are adequate to prevent pass through of pollutants, inhibition of or interference with the treatment facility, worker health and safety problems, and sludge contamination, OR (2) submit a WRITTEN NOTIFICATION that a technical evaluation revising the current TBLL and a draft sewer use ordinance which incorporates such revisions will be submitted within 12 months of the effective date of this permit.

All specific prohibitions or limits developed under this requirement are deemed to be conditions of this permit. The specific prohibitions set out in 40 CFR Part 403.5(b) shall be enforced by the permittee unless modified under this provision.

3. The permittee shall analyze the treatment facility influent and effluent for the presence of the toxic pollutants listed in 40 CFR 122 Appendix D (NPDES Application Testing Requirements) Table II at once per year and the toxic pollutants in Table III at least once every six months. If, based upon information available to the permittee there is reason to suspect the presence of any toxic or hazardous pollutant listed in Table V, or any other pollutant, known or suspected to adversely affect treatment plant operation, receiving water quality, or solids disposal procedures, analysis for those pollutants shall be performed at least once every six months on both the influent and the effluent.

The influent and effluent samples collected shall be composite samples consisting of at least 12 aliquots collected at approximately equal intervals over a representative 24 hour period and

composited according to flow. Sampling and analytical procedures shall be in accordance with guidelines established in 40 CFR 136. The effluent samples shall be analyzed to a level as required in item 6 below. Where composite samples are inappropriate, due to sampling, holding time, or analytical constraints, at least 4 grab samples, taken at equal intervals over a representative 24 hour period, shall be taken.

4. The permittee shall prepare annually a list of Industrial Users which during the preceding twelve months were in significant noncompliance with applicable pretreatment requirements. For the purposes of this Part, significant noncompliance shall be determined based upon the more stringent of either criteria established at 40 CFR Part 403.8(f)(2)(vii) [rev. 7/24/90] or criteria established in the approved POTW pretreatment program. This list is to be published annually in the largest daily newspaper in the municipality during the month of December.

In addition, during the month of December the permittee shall submit an updated status report to DEQ containing the following information:

- a. An updated list of all significant industrial users. For each industrial user listed the following information shall be included (Note: A sample table, which includes the requested information has been provided on Page 20 for your convenience):

(1). Standard Industrial Classification (SIC) code and categorical determination;

(2). Control document status. Whether the user has an effective control document, and the date such document was last issued, reissued, or modified, (indicate which industrial users were added to the system (or newly identified) within the previous 12 months);

(3). A summary of all monitoring activities performed within the previous 12 months. The following information shall be reported:

- total number of inspections performed;
- total number of sampling visits made;

(4). Status of compliance with both effluent limitations and reporting requirements. Compliance status shall be defined as follows:

- Compliant (C) - no violations during the previous 12 month period;
- Non-compliant (NC) - one or more violations during the previous 12 months but does not meet the criteria for significantly non-compliant industrial users;
- Significant Noncompliance (SN) - in accordance with requirements described in d. above; and

(5). For significantly noncompliant industrial users, indicate the nature of the violations, the type and number of actions taken (notice of violation, administrative order, criminal or civil suit, fines or penalties collected, etc.) and current compliance status. If ANY industrial user was on a schedule to attain compliance with effluent limits, indicate the date the schedule was issued and the date compliance is to be attained (Note: A sample table, which includes the requested information has been provided on Page 19 for your convenience);

- b. A list of all significant industrial users whose authorization to discharge was terminated or revoked during the preceding 12 month period and the reason for termination;
 - c. A report on any interference, pass through, upset or POTW permit violations known or suspected to be caused by industrial contributors and actions taken by the permittee in response;
 - d. The results of all influent and effluent analyses performed pursuant to "item 3 above". These results and comparisons to the appropriate technically based local limit allowances and effluent water quality standards may be presented in tabular form as per the sample table provided on Page 18 for your convenience;
 - e. A copy of the newspaper publication of the significantly non-compliant industrial users giving the name of the newspaper and the date published;
5. The permittee shall provide adequate notice of the following:
- a. Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the CWA and/or Sections 40 CFR 405-499 if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.
- Adequate notice shall include information on (i) the quality and quantity of effluent to be introduced into the treatment works, and (ii) any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.
6. All effluent monitoring conducted in accordance with "item 3 above" shall meet the Minimum Quantification Levels (MQLs) shown in the attached tables.

MINIMUM QUANTIFICATION LEVELS (MQLs)

<u>METALS AND CYANIDE</u>	(ug/L)	EPA METHOD	<u>VOLATILE COMPOUNDS</u>	(ug/L)	EPA METHOD
Antimony (Total) ¹	60	200.7	1,1,2,2-Tetrachloroethane ⁵	10	624
Arsenic (Total) ¹	10	206.2	Tetrachloroethylene ⁵	10	624
Beryllium (Total) ¹	5	200.7	Toluene ⁵	10	624
Cadmium (Total) ²	1	213.2	1,2-trans-Dichloroethylene ⁵	10	624
Chromium (Total) ¹	10	200.7	1,1,1-Trichloroethane ⁵	10	624
Chromium (3+) ¹	10	200.7	1,1,2-Trichloroethane ⁵	10	624
Chromium (6+) ¹	10	200.7	Trichloroethylene ⁵	10	624
Copper (Total) ²	10	220.2	Vinyl Chloride ⁵	10	624
Lead (Total) ²	5	239.2	<u>ACID COMPOUNDS</u>		
Mercury (Total) ¹	0.2	245.1	2-Chlorophenol ⁵	10	625
Nickel (Total) ¹ [Freshwater]	40	200.7	2,4-Dichlorophenol ⁵	10	625
Nickel (Total) ² [Marine]	5	249.2	2,4-Dimethylphenol ⁷	10	625
Selenium (Total) ¹	5	270.2	4,6-Dinitro-o-Cresol		
Silver (Total) ²	2	272.2	12 methyl 4,6-dinitrophenol ⁵	50	625
Thallium (Total) ¹	10	279.2	2,4-Dinitrophenol ⁵	50	625
Zinc (Total) ¹	20	200.7	2-Nitrophenol ⁵	20	625
Cyanide (Total) ¹	10	335.2	4-Nitrophenol ⁵	50	625
<u>DIOXIN</u>			p-Chloro-m-Cresol		
1,7,8-Tetrachloro-dibenzo- p-dioxin (TCDD) ³	.00001	1613	[4 chloro-3-methylphenol] ⁶	10	625
<u>VOLATILE COMPOUNDS</u>			Pentachlorophenol ⁵	50	625
Aerolein ⁴	50	624	Phenol ⁵	10	625
Acrylonitrile ⁴	50	624	2,4,6-Trichlorophenol ⁵	10	625
Benzene ⁴	10	624	<u>BASE/NEUTRAL COMPOUNDS</u>		
Bromoform ⁵	10	624	Acenaphthene ⁵	10	625
Carbon Tetrachloride ⁵	10	624	Acenaphthylene ⁵	10	625
Chlorobenzene ⁵	10	624	Anthracene ⁵	10	625
Chlorodibromomethane ⁵	10	624	Benzidine ⁴	50	625
Chloroethane ⁶	50	624	Benzo(a)anthracenes ⁵	10	625
2-Chloroethyl vinyl ether ⁴	10	624	Benzo(a)pyrene ⁵	10	625
Chloroform ⁵	10	624	3,4-Benzofluoranthene ⁵	10	625
Dichlorobromomethane ⁵	10	624	Benzo(ghi)perylene ⁶	20	625
1,1-Dichloroethane ⁵	10	624	Benzo(k)fluoranthene ⁵	10	625
1,2-Dichloroethane ⁵	10	624	Bis(2-chloroethoxy) methane ⁵	10	625
1,1-Dichloroethylene ⁵	10	624	Bis(2-chloroethyl) ether ⁵	10	625
1,2-Dichloropropane ⁵	10	624	Bis(2-chloroisopropyl) ether ⁵	10	625
1,3-Dichloropropylene ⁵	10	624	Bis(2-ethylhexyl) phthalate ⁵	10	625
Ethylbenzene ⁵	10	624	4-Bromophenyl phenyl ether ⁵	10	625
Methyl Bromide [Bromomethane] ⁶	50	624	Butyl benzyl phthalate ⁵	10	625
Methyl Chloride [Chloromethane] ⁶	50	624	2-Chloronaphthalene ⁵	10	625
Methylene Chloride ⁵	20	624	4-Chlorophenyl phenyl ethers ⁵	10	625
			Chrysene ⁵	10	625

MINIMUM QUANTIFICATION LEVELS (MQLs)

<u>BASE/NEUTRAL COMPOUNDS</u>	(ug/L)	EPA METHOD	<u>PESTICIDES</u>	(ug/L)	EPA METHOD
Dibenzo (a,h) anthracene ⁶	20	625	Endrin ⁷	.1	609
1,2-Dichlorobenzene ⁵	10	625	Endrin aldehyde ⁷	.1	609
1,3-Dichlorobenzene ⁵	10	625	Heptachlor ⁷	.05	608
1,4-Dichlorobenzene ⁵	10	625	Heptachlor epoxide ⁷	.05	608
3,3'-Dichlorobenzidirm ⁶	50	625	(BHC-hexachlorocyclohexane)		
Diethyl Phthalate ⁵	10	625	PCB-1242 ⁷	1.0	608
Dimethyl Phthalate ⁵	10	625	PCB-1254	1.0	608
Di-n-Butyl Phthalate ⁵	10	625	PCB-1221	1.0	608
2,4-Dinitrotoluene ⁵	10	625	PCB-1232	1.0	608
2,6-Dinitrotoluene ⁵	10	625	PCB-1248	1.0	608
Di-n-octyl Phthalate ⁵	10	625	PCB-1260	1.0	609
1,2-Diphenylhydrazine ⁴	20	625	PCB,1016	1.0	608
Fluoranthene ⁵	10	625	Toxaphene ⁷	5.0	608
Fluorene ⁵	10	625			
Hexachlorobenzene ⁵	10	625			
Hexachlorobutadiene ⁵	10	625			
Hexachlorocyclopentadiene ⁵	10	625			
Hexachloroethane ⁶	20	625			
Indeno (1,2,3-cd) pyrene ⁶	20	625			
(2,3-o-phenylene pyrene)					
Isophorone ⁵	10	625			
Naphthalene ⁵	10	625			
Nitrobenzene ⁵	10	625			
N-nitrosodimethylamine ⁶	50	625			
N-nitrosodi-n-propylamine ⁶	20	625			
N-nitrosodiphenylamine ⁶	20	625			
Phenanthrene ⁵	10	625			
Pyrene ⁵	10	625			
1,2,4-Trichlorobenzene ⁵	10	625			
<u>PESTICIDES</u>					
Aldrin ⁷	0.05	608			
Alpha-BHC ⁷	0.05	608			
Beta-BHC ⁷	0.05	609			
Gamma-BHC (Lindane) ⁷	0.05	608			
Delta-BHC ⁷	0.05	608			
Chlordane ⁷	0.2	608			
4,4'-DDE ⁷	0.1	608			
4,4'-DDE (p,p-DDX) ⁷	0.1	608			
4,4'-DDD (p,p-TDE) ⁷	0.1	608			
Dieldrin ⁷	0.1	608			
Alpha-endosulfan ⁷	0.1	608			
Beta-endosulfan ⁷	0.1	608			
Endosulfan sulfate ⁷	0.1	608			

¹Based on Contract Required Detection level (CRDL) developed pursuant to 40 CFR Part 300.430(b)(8)

²Method 213.2, 239.2, 220.2, 272.2

³Dioxin National Strategy

⁴No CRQL (Contract required Quantification Level developed pursuant to 40 CFR Part 300.430(b)(8)) established

⁵CRQL basis, equivalent to ML

⁶ML basis, higher than CRQL

⁷CRQL basis, no ML established

⁸CRQL basis, higher than ML

**OKLAHOMA DEQ SAMPLE
POTW MONITORING RESULTS SUMMARY TABLE
FOR THE (C.A. NAME) ANNUAL PRETREATMENT REPORT, (MONTH & YEAR)**

POLLUTANT	Minimum Quantification Level (MQL) Concentration (mg/l or ug/l) ?		Detection Level (DL) Concentration on Used (mg/l or ug/l)	POTW Monitoring Results (Concentrations in mg/l unless otherwise noted)					Comparative Standards (Loadings in lbs/day; concentration in mg/l unless otherwise noted)				
	Average Influent Concentration	POTW Average Flow (MGD)		Calculated Headworks Loading (lbs/d)	Maximum Effluent Concentration	Average Effluent Concentration	Maximum Allowable Headworks Loading or Concentration	Permit or OK Limits Concentrations	Daily Maximum	Daily Maximum			
Arsenic (Total)													
Cadmium (Total)													
Chromium (Total)													
Copper (Total)													
Lead (Total)													
Mercury (Total)													
Nickel (Total)													
Silver (Total)													
Zinc (Total)													
Cyanide (Total)													
Other pollutants detected:													

It is advised that the influent and effluent samples are collected considering flow detention time through each plant. Analytical MQLs should be used so that the data can also be used for Local Limits assessment and NPDES application purposes.

PART III. STANDARD CONDITIONS FOR OPDES MUNICIPAL/DOMESTIC PERMIT

SECTION A. Definitions

In addition to the definitions included in the Oklahoma Pollutant Discharge Elimination System Act (OPDES Act), Title 27 O.S. Supp. 1996, Section 2-6-201 et seq., and the rules of the State of Oklahoma Department of Environmental Quality (DEQ) adopted thereunder [Sec OAC 252:605], the following definitions shall apply to this permit:

1. "Act" means the OPDES Act as amended.
2. "Applicable effluent standards and limitations" means all state and federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards of performance, toxic effluent standards and prohibitions, and pretreatment standards.
3. "Applicable water quality standards" means all water quality standards to which a discharge is subject under the Act.
4. "Average limitations"
 - a. "7-day average" (or weekly average), other than for coliform bacteria, is the arithmetic mean of the daily values for all effluent samples collected during a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week. The "7-day average" for coliform bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
 - b. "30-day average" (or monthly average), other than for coliform bacteria, is the arithmetic mean of the daily values for all effluent samples collected during a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. The "30-day average" for coliform bacteria is the geometric mean of the values for all effluent samples collected during a calendar month.
5. "Bypass" means the diversion, whether intentional or unintentional, of waste streams from any portion of the collection system or treatment facility.
6. "Daily discharge" means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the sampling day. "Daily discharge" determination of concentrations made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the "daily discharge" determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that sampling day.
7. "Daily maximum" discharge limitation means the highest allowable "daily discharge" during the calendar month.
8. "Environmental Protection Agency" (EPA) means the U.S. Environmental Protection Agency.
9. "Executive Director" means the Executive Director of the State of Oklahoma Department of Environmental Quality (DEQ) or his/her authorized representative(s).
11. "Industrial user" means a nondomestic discharger, as identified in 40 CFR Part 403, introducing pollutants to a publicly owned treatment works.
12. "Oklahoma Pollutant Discharge Elimination System" (OPDES) means the state program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under the Act.
13. "Oklahoma Department of Environmental Quality" also known as (DEQ), means the State of Oklahoma Department of Environmental Quality.
14. "OPDES Act" means the Oklahoma Pollutant Discharge Elimination System Act, Title 27 O.S. Supp. 1996, Section 2-6-201 et seq.
15. "Samples"
 - a. For coliform bacteria, a sample consists of one effluent grab portion collected during a 24-hour period at peak loads.
 - b. "Grab sample" means an individual sample collected in less than 15 minutes.
 - c. "SBR (sequential batch reactor) sample and the various composite samples" are as defined in the OPDES Act, the Oklahoma Environmental Quality Code, rules transferred to or promulgated thereunder by DEQ.

SBR Composite Sample:

SBR Sample

A minimum of three aliquots collected from the discharge of a reactor. The first aliquot must be collected no later than $\frac{1}{4}$ time, the second approximately $\frac{1}{2}$ time, and the third no earlier than $\frac{3}{4}$ time from the initiation of a discharge cycle to the stoppage of the discharge cycle. The three aliquots shall consist of equal portions unless the rate of discharge from the reactor varies significantly during the cycle, in which case the measurement of the flow occurring at the time of their collection

Single Composite SBR Sample

One SBR sample collected from each reactor during one discharge cycle and composited proportional to the volume discharged from each of the reactors. The sample from at least one of the reactors shall represent the expected period of peak influent organic loading.

Two-Cycle Composite SBR Sample

One SBR sample collected from two consecutive discharge cycles of each reactor and composited proportional to the volume discharged during each cycle of each reactor. The sample from at least one cycle shall represent the expected period of peak influent organic loading.

Three-Cycle Composite SBR Sample

One SBR sample collected from three consecutive discharge cycles of each reactor and composited proportional to the volume discharged during each cycle of each reactor. The sample from at least one cycle shall represent the expected period of peak influent organic loading.

- d. "24-hour composite sample" consists of a minimum of 12 effluent portions collected at equal time intervals over the 24-hour period and combined proportional to flow or a sample collected at frequent intervals proportional to flow over the 24-hour period.
 - e. "12-hour composite sample" consists of 12 effluent portions collected no closer together than one hour and composited according to flow. The daily sampling intervals shall include the highest flow periods.
 - f. "6-hour composite sample" consists of six effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.
 - g. "3-hour composite sample" consists of three effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.
16. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 17. "Sewage sludge" means the solids, residues and precipitates separated from or created in sewage by the unit processes of a publicly owned treatment works. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and storm water runoff, that are discharged to or otherwise enter a publicly owned treatment works.
 18. "Treatment works" means any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage and industrial wastes of a liquid nature to implement the Act, or necessary to recycle or reuse water at the most economical cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and their appurtenances, extension, improvement, remodeling, additions, and alterations thereof.
 19. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
 20. "MGD" means million gallons per day.
 21. "mg/l" means milligrams per liter or parts per million (ppm).
 22. "µg/l" means micrograms per liter or parts per billion (ppb).

SECTION B. Monitoring, Record Keeping, Reporting and Liabilities

1. Monitoring

a. Site and Frequency

All monitoring undertaken in compliance with the terms of this permit shall be conducted at the frequency and sample site specified in Part I, Section A of this permit and in accordance with the OPDES Act and the Oklahoma Environmental Quality Code. Grab or composite in Part III, Section B.5 below.

b. Representative Samples

Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.

c. Averaging of Measurements

Calculations of all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Executive Director in the permit.

d. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the Discharge Monitoring Report (DMR). Such increased monitoring frequency shall also be indicated on the DMR.

2. Testing Requirements

a. Methods

All sampling and analytical methods used to meet monitoring requirements specified above shall conform to the Act, 40 CFR Part 136, and DEQ rules and regulations.

b. Maintenance and Calibration

The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instruments at intervals frequent enough to ensure accuracy of measurements and shall maintain appropriate records of such activities.

c. Quality Control

An adequate analytical quality control program, including the analyses of sufficient standards, spikes, and duplicate samples to insure the accuracy to all required analytical results shall be maintained by the permittee or designated commercial laboratory.

3. Flow Measurements

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure that the accuracy of the measurements is consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than 10% from true discharge rates throughout the range of expected discharge rates.

4. Records

a. Contents

Records of monitoring information shall include:

- (1) The date, exact place, and time of sampling or measurements;
- (2) The individual(s) who performed the sampling or measurements;
- (3) The date(s) and time(s) analyses were performed;
- (4) The individual(s) who performed the analyses;
- (5) The analytical techniques or methods used; and
- (6) The results of such analyses.

b. Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least three (3) years from the date of the sample, measurement, report, or application. This period may be extended by request of the Executive Director at any time.

5. Discharge Monitoring Reports (DMRs)

All monitoring information required in Part I, Section A of this permit shall be included on DMRs (EPA form 3320-1). Reporting periods shall end on the last day of the month. The reports shall be prepared monthly. The original and one copy shall be submitted to the Oklahoma Department of Environmental Quality at the address shown below no later than the tenth (10th) day of the following month. A copy shall also be submitted simultaneously to the appropriate local DEQ office. All operating records and reports shall comply with the OPDES Act, the Oklahoma Environmental Quality Code, and the requirements of 40 CFR 122.41(j).

Water Quality Division
Oklahoma Department of Environmental Quality
P.O. Box 1677
Oklahoma City, OK 73101-1677

6. Noncompliance Reports

a. Twenty-Four Hour Reporting

- (1) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. The DFCJ shall be notified by calling 1-800-256-2365 or 702-8290 (Oklahoma City Metropolitan Area). A written submission shall be provided within five (5) days of the time the permittee becomes aware of the circumstances. The report shall contain the following information:
- (a) A description of the noncompliance and its cause;
 - (b) The period of noncompliance including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and,
 - (c) Steps being taken to reduce, eliminate, and prevent recurrence of the noncomplying discharge.
- (2) The following shall be included as information which must be reported within 24 hours:
- (a) Any unanticipated bypass which exceeds any effluent limitation in the permit;
 - (b) Any upset which exceeds any effluent limitation in the permit;
 - (c) Any violation of a maximum daily discharge limit for any of the pollutants listed by the Executive Director in Part I, Section A; and,
 - (d) Any bypass in the collection system [sanitary sewer overflow (SSO)].
- (3) The Executive Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

b. Other Noncompliance

The permittee shall report all instances of noncompliance not reported under Part III, Sections B.5 and B.6.a or the reporting requirements of any Schedule of Compliance included in Part I, Section B at the time monitoring reports are submitted. The reports shall contain the information listed at Part III, Section B.6.a.

7. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under the Act.

8. Federal Penalties for Violations of Permit Conditions

Nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of the permit, the Act, or applicable regulations, which avoids or effectively defeats the regulatory purpose of the permit may subject the Permittee to criminal enforcement pursuant to 18 U.S.C. Section 1001.

a. Criminal

(1) Negligent Violations

The Act provides that any person who negligently violates permit conditions implementing the Act is subject to a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one (1) year, or both.

(2) Knowing Violations

The Act provides that any person who knowingly violates permit conditions implementing the Act is subject to a fine of not less than \$5,000 nor more than \$50,000 per day of violation, or by imprisonment for not more than three (3) years, or both.

(3) Knowing Endangerment

The Act provides that any person who knowingly violates permit conditions implementing the Act and who knows at that time that he is placing another person in imminent danger of death or serious bodily injury is subject to a fine of not more than \$250,000, or by imprisonment for not more than fifteen (15) years, or both.

(4) False Statements

The Act provides that any person who knowingly makes any false material statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under the Act or who knowingly falsifies, tampers with, or renders inaccurate, any monitoring device or method required to be maintained under the Act, shall upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two (2) years, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment shall be by a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or by both. (See Section 2-6-206 of the Act).

b. Civil Penalties

The Act provides that any person who violates a permit condition implementing the Act is subject to a civil penalty not to exceed \$27,500 per day for each violation.

c. Administrative Penalties

The Act provides that any person who violates a permit condition implementing the Act is subject to an administrative penalty, as follows:

(1) Class I Penalty

Not to exceed \$11,000 per violation nor shall the maximum amount exceed \$27,500.

(2) Class II Penalty

Not to exceed \$11,000 per day for each day during which the violation continues nor shall the maximum amount exceed \$137,500.

9. State Penalties

a. Civil and Administrative

For any violation of the limitations and/or conditions of this permit, the State may assess a fine of up to \$10,000 per day per violation.

b. Criminal

Violations of the terms of this permit constitute a misdemeanor under Oklahoma Statutes with various provisions for fines and jail terms.

SECTION C. Other Conditions

1. Permit Application

a. Timely Application

Upon timely application for a permit, any prior permit remains in effect until a new one is issued.

b. Date of Application

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The application shall be submitted at least 180 days before the expiration date of this permit unless otherwise authorized by the Executive Director. He or she may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated at 40 CFR 122.6 and any subsequent amendments.

c. Relevant Facts

When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Executive Director, it shall promptly submit such facts or information.

2. Changes

a. Change in discharge

(1) Anticipated Noncompliance

The permittee shall give advance notice of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

(2) Municipal Permits

Any change in the facility discharge (including the introduction of any new source or significant discharge or significant changes in the quantity or quality of existing discharges to the treatment system that may result in new or increased discharges of pollutants) must be reported to the permitting authorities. In no case are any new connections, increased flows, or significant changes in influent quality permitted that will cause violations or add to existing violations of the effluent limitations specified herein.

(3) Other Permits

The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:

(a) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or,

(b) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to all pollutants whether or not they are subject to effluent limitations in the permit.

b. Transfer of ownership or control

This permit is not transferable to any person except after notice to the Executive Director. The Executive Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as necessary under the Act.

3. Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege.

4. Duty to Comply

a. All authorized discharges shall comply with the rules of the DEQ, which are hereby incorporated by reference: the Act and OPDES Regulations, and all provisions, conditions, and requirements included in this permit.

b. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of applicable state and federal laws and the Act, the Oklahoma Environmental Quality Code and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

c. The permittee shall comply with effluent standards or prohibitions established under the Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Duty to mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

6. Duty to halt or reduce activity

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

7. Duty to provide information

The permittee shall furnish within a reasonable time, any information which the Executive Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish, upon request, copies of records required to be kept by this permit.

8. Permit modification, suspension and revocation

After notice and opportunity for a hearing, as is required by law, this permit may be modified, suspended, revoked and reissued, or terminated during its term in accordance with 40 CFR 122.62 and 122.64; and Title 27 O.S. Supp. 1996, Section 2-6-201 et seq., and the rules of the State of Oklahoma Department of Environmental Quality (DEQ) adopted thereunder [See OAC 252:605]. The filing of a request for a permit modification or reissuance, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

9. Proper operation and maintenance

a. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by permittee as efficiently as possible and in a manner which will minimize upsets and discharges of excessive pollutants and will achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of this permit.

b. The permittee shall provide an adequate operating staff which is duly qualified to carry out operation, maintenance and testing functions required to insure compliance with the conditions of this permit.

c. Collected screenings, slurries, sludges and other solids shall be disposed of in accordance with the Oklahoma Solid Waste Management Act and in such a manner as to prevent entry of those wastes (or runoff from the wastes) into waters of the state and in compliance with applicable rules of the DEQ.

10. Power Failure

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures either by means of alternative power sources, standby generators, or retention of inadequately treated effluent.

11. Upsets and Bypasses

a. Upsets

- (1) An upset constitutes an affirmative defense to an enforcement action brought for noncompliance with technology-based permit effluent limitations if the following requirements are met. A permittee who wishes to establish the affirmative defense of upset shall demonstrate through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (a) An upset occurred and that the permittee can identify the specific cause(s) of the upset;
 - (b) The permitted facility was at the time being properly operated;
 - (c) The permittee submitted notice of the upset as required in Part III, Section B.6 of this permit;
 - (d) The permittee complied with any remedial measures under Part III, Section C.5.
- (2) Burden of Proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

b. Bypasses

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
 - (a) Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the reporting requirements of Part III, Sections C.11.b(1) and (2).
 - (b) Bypass exceeding limitations is prohibited, and the Executive Director may take enforcement action against a permittee for bypass, unless:
 - i. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - ii. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgement to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and,
 - iii. The permittee submitted notices required by Part III, Section B.6.
 - (c) The Executive Director may allow an anticipated bypass that exceeds limitations after considering its adverse effects, if he/she determines that it will meet the three conditions listed at Part III, Section C.11.b.(1)(b).
- (2) Unanticipated bypass. The permittee shall, within 24 hours, submit notice of an unanticipated bypass as required in Part III, Section B.6.

12. Percent Removal

For publicly owned treatment works, the 30-day average (or monthly average) percent removal for Biochemical Oxygen Demand (BOD) and Total Suspended Solids (TSS) shall not be less than 85 percent unless otherwise authorized by the permitting authority in accordance with 40 CFR 133.103. This requirement may be waived in permits containing mass loading limits for BOD and TSS.

13. Right of entry

The permittee shall allow the Executive Director, and/or his/her authorized representative(s), upon presentation of credentials and such other documents as may be required by the law to:

- a. Enter upon the permittee's premises or other premises under the control of the permittee, where an effluent source is located or may be located or in which any records are required to be kept under the terms and conditions of this permit;
- b. Have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit, or the Act or DEQ rules;

- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), maintenance, practices or operations regulated or required under this permit; and
- d. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the Act, any substances or parameters at any location.

14. Toxic Effluent Standards

Notwithstanding Section III.C.8 of this permit, if any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under the Act for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or prohibition.

15. Signatory Requirements

All applications, reports, or information submitted to the Executive Director shall be signed and certified.

- a. All permit applications shall be signed as follows:

- (1) For a corporation - by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:

- (a) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation; or,
- (b) The manager of one or more manufacturing, production, or operating facilities employing more than 250 persons or having gross annual sales or expenditures exceeding \$25 million (in second-quarter 1980 dollars), if authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

- (2) For a partnership or sole proprietorship - by a general partner or the proprietor, respectively.

- (3) For a municipality, state, federal, or other public agency - by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a federal agency includes:

- (a) The chief executive officer of the agency, or
- (b) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.

- b. All reports required by the permit and other information requested by the Executive Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- (1) The authorization is made in writing by a person described above;

- (2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. A duly authorized representative may thus be either a named individual or an individual occupying a named position; and,

- (3) The written authorization is submitted to the Executive Director.

- c. Certification. Any person signing a document under this section shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

16. Confidentiality

Except for applications, effluent data, permits, and other data specified in 40 CFR 122.7, any information submitted pursuant to this permit may be claimed as confidential by the submitter. The Executive Director will rule upon such claim in accordance with the Act. If no claim is made at the time of submission, information may be made available to the public without further notice.

Part IV
SEWAGE SLUDGE REQUIREMENTS
PERMIT
INSTRUCTIONS TO PERMITTEES

Select only those Elements and Sections which apply to your sludge reuse or disposal practice.

If your facility utilizes more than one type of disposal or reuse method (for example, Element 1 and Element 2 apply) or the quality of your sludge varies (for example, Section II and Section III of Element 1 apply) use a separate Discharge Monitoring Report (DMR) for each Section that is applicable.

The sludge DMRs shall be due by February 19th of each year and shall cover the previous January through December time period.

The sludge conditions do not apply to wastewater treatment lagoons where sludge is not wasted for final reuse/disposal. If the sludge is not removed, the permittee shall indicate on the DMR "No Discharge."

ELEMENT 1 - LAND APPLICATION

- SECTION I: Page 1 - Requirements Applying to All Sewage Sludge Land Application
- SECTION II: Page 4 - Requirements Specific to Bulk Sewage Sludge for Application to the Land Meeting Class A or B Pathogen Reduction and the Cumulative Loading Rates in Table 2, or Class B Pathogen Reduction and the Pollutant Concentrations in Table 3
- SECTION III: Page 7 - Requirements Specific to Bulk Sewage Sludge Meeting Pollutant Concentrations in Table 3 and Class A Pathogen Reduction Requirements
- SECTION IV: Page 8 - Requirements Specific to Sludge Sold or Given Away in a Bag or Other Container for Application to the Land that does not Meet the Pollutant Concentrations in Table 3

ELEMENT 2 - MUNICIPAL SOLID WASTE LANDFILL DISPOSAL

- SECTION I: Page 10 - Requirements Applying to All Municipal Solid Waste Landfill Disposal Activities

ELEMENT 1 - LAND APPLICATION

SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE LAND APPLICATION

A. General Requirements

1. The permittee shall handle and dispose of sewage sludge in accordance with the Oklahoma Pollutant Discharge Elimination System (OPDES) Act (hereafter "the Act") and all other applicable federal and state regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants which may be present in the sludge.
2. If requirements for sludge management practices or pollutant criteria become more stringent than the sludge pollutant limits or acceptable management practices in this permit, or control a pollutant not listed in this permit, this permit may be modified or revoked and reissued to conform to the requirements promulgated under the Act. If new limits for molybdenum are promulgated prior to permit expiration, then those limits shall become directly enforceable.
3. In all cases, if the person (permit holder) who prepares the sewage sludge supplies the sewage sludge to another person for land application use or to the owner or lease holder of the land, the permit holder shall provide necessary information to the parties who receive the sludge to assure compliance with these regulations.
4. The permittee shall give prior notice to the Director, Water Quality Division, State of Oklahoma, Department of Environmental Quality (DEQ), 707 North Robinson, Oklahoma City, Oklahoma 73101-1677 of any planned changes in the sewage sludge disposal practice, in accordance with 40 CFR 122.41(i)(1)(iii). These changes may justify the application of permit conditions that are different from or absent in the existing permit. Change in the sludge use or disposal practice may be cause for modification of the permit in accordance with 40 CFR 122.62(a)(1).

B. Testing Requirements

1. Sewage sludge shall be tested once during the life of the permit within one year from the effective date of the permit in accordance with the method specified at 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other approved methods. Sludge shall be tested after final treatment prior to leaving the publicly owned treatment works (POTW) site. Sewage sludge determined to be a hazardous waste in accordance with 40 CFR Part 261, shall be handled according to Resource Conservation and Recovery Act (RCRA) standards for the disposal of hazardous waste in accordance with 40 CFR Part 262. The disposal of sewage sludge determined to be a hazardous waste, in other than a certified hazardous waste disposal facility shall be prohibited. The DEQ, Waste Management Division at 405-702-5100, shall be notified of test failure within 24 hours. A written report shall be provided to this division within 7 days after failing the TCLP. The report will contain test results, certification that unauthorized disposal has not occurred and a summary of alternative disposal plans that comply with RCRA standards for the disposal of hazardous waste. The report shall be addressed to the Director, Waste Management Division, DEQ, 707 N. Robinson, Oklahoma City, Oklahoma 73101-1677 and a copy sent to the Director, Water Quality Division, DEQ, at the same address.
2. Sewage sludge shall not be applied to the land if the concentration of the pollutants exceeds the pollutant concentration criteria in Table 1. The frequency of testing for pollutants in Table 1 is found in Element 1, Section 1.C.

TABLE 1

Pollutant	Ceiling Concentration (milligrams per kilogram)*
Arsenic	75
Cadmium	85
Copper	4300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
PCBs	49
Selenium	100
Zinc	7500

* Dry weight basis

3. Pathogen Control

All sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by either the Class A or Class B pathogen requirements. Sewage sludge that is applied to a lawn or home garden shall be treated by the Class A pathogen requirements. Sewage sludge that is sold or given away in a bag shall be treated by the Class A pathogen requirements.

Class A Sludge Requirements:

- a. Six alternatives are available to demonstrate compliance with Class A sewage sludge. All 6 options require either the density of fecal coliform in the sewage sludge be less than 1000 Most Probable Number (MPN) per gram of total solids (dry weight basis), or the density of *Salmonella sp.* bacteria in the sewage sludge be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed; at the time the sewage sludge is prepared for sale or given away in a bag or other container for application to the land. Below are the additional requirements necessary to meet the definition of a Class A sludge.

Alternative 1 - The temperature of the sewage sludge that is used or disposed shall be maintained at a specific value for a period of time. See 40 CFR 503.32(a)(3)(ii) and OAC 252:648 for specific information.

Alternative 2 - The pH of the sewage sludge that is used or disposed shall be raised to above 12 and shall remain above 12 for 72 hours.

The temperature of the sewage sludge shall be above 52 degrees Celsius for 12 hours or longer during the period that the pH of the sewage sludge is above 12.

At the end of the 72 hour period during which the pH of the sewage sludge is above 12, the sewage sludge shall be air dried to achieve a percent solids in the sewage sludge greater than 50 percent.

Alternative 3 - The sewage sludge shall be analyzed for enteric viruses prior to pathogen treatment. The limit for enteric viruses is one Plaque-forming Unit per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 40 CFR 503.32(a)(5)(ii) for specific information. The sewage sludge shall be analyzed for viable helminth ova prior to pathogen treatment. The limit for viable helminth ova is less than one per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 40 CFR 503.32(a)(5)(iii) and OAC 252:648 for specific information.

Alternative 4 - The density of enteric viruses in the sewage sludge shall be less than one Plaque-forming Unit per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed or at the time the sludge is prepared for sale or given away in a bag or other container for application to the land.

The density of viable helminth ova in the sewage sludge shall be less than one per four grams of total solids (dry weight

basis) at the time the sewage sludge is used or disposed or at the time the sewage sludge is prepared for sale or given away in a bag or other container for application to the land.

Alternative 5 - Sewage sludge shall be treated by one of the Processes to Further Reduce Pathogens (PFRP) described in 40 CFR 503 Appendix B. PFRPs include composting, heat drying, heat treatment, and thermophilic aerobic digestion.

Alternative 6 - Sewage sludge shall be treated by a process that is equivalent to a PFRP, if individually approved by the Pathogen Equivalency Committee representing the DEQ.

Class B Sludge Requirements:

b. Three alternatives are available to demonstrate compliance with Class B sewage sludge.

Alternative 1 - (i) Seven separate random samples representative of the sewage sludge shall be collected for one monitoring episode at the time the sewage sludge is used or disposed.

(ii) The geometric mean of the density of fecal coliform in the samples collected shall be less than either 2,000,000 MPN per gram of total solids (dry weight basis) or 2,000,000 Colony Forming Units per gram of total solids (dry weight basis).

Alternative 2 - Sewage sludge shall be treated in one of the Processes to Significantly Reduce Pathogens (PSRP) described in 40 CFR 503 Appendix B.

Alternative 3 - Sewage sludge shall be treated in a process that is equivalent to a PSRP, if individually approved by the Pathogen Equivalency Committee representing the DEQ.

In addition, the following site restrictions must be met if Class B sludge is land applied:

- i. Food crops with harvested parts that touch the sewage sludge/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of sewage sludge.
- ii. Food crops with harvested parts below the surface of the land shall not be harvested for 20 months after application of sewage sludge when the sewage sludge remains on the land surface for 4 months or longer prior to incorporation into the soil.
- iii. Food crops with harvested parts below the surface of the land shall not be harvested for 38 months after application of sewage sludge when the sewage sludge remains on the land surface for less than 4 months prior to incorporation into the soil.
- iv. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of sewage sludge.
- v. Animals shall not be allowed to graze on the land for 30 days after application of sewage sludge.
- vi. Turf grown on land where sewage sludge is applied shall not be harvested for 1 year after application of the sewage sludge when the harvested turf is placed on either land with a high potential for public exposure or a lawn, unless otherwise specified by the permitting authority.
- vii. Public access to land with a high potential for public exposure shall be restricted for 1 year after application of sewage sludge.
- viii. Public access to land with a low potential for public exposure shall be restricted for 30 days after application of sewage sludge.

4. Vector Attraction Reduction Requirements

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by one of the following alternatives 1 through 10 for Vector Attraction Reduction. If bulk sewage sludge is applied to a home garden, or bagged sewage sludge is applied to the land, only Alternatives 1 through 8 shall be used.

Alternative 1 - The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38 percent.

Alternative 2 - If Alternative 1 cannot be met for an anaerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge anaerobically in the laboratory in a bench-scale unit for 40 additional days at a temperature between 30 and 37 degrees Celsius. Volatile solids must be reduced by less than 17 percent to demonstrate compliance.

Alternative 3 - If Alternative 1 cannot be met for an aerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge with a percent solids of two percent or less aerobically in the laboratory in a bench-scale unit for 30 additional days at 20 degrees Celsius. Volatile solids must be reduced by less than 15 percent to demonstrate compliance.

Alternative 4 - The specific oxygen uptake rate (SOUR) for sewage sludge treated in an aerobic process shall be equal to or less than 1.5 milligrams of oxygen per hour per gram of total solids (dry weight basis) at a temperature of 20 degrees Celsius.

Alternative 5 - Sewage sludge shall be treated in an aerobic process for 14 days or longer. During that time, the temperature of the

sewage sludge shall be higher than 40 degrees Celsius and the average temperature of the sewage sludge shall be higher than 45 degrees Celsius.

Alternative 6 - The pH of sewage sludge shall be raised to 12 or higher by alkali addition and, without the addition of more alkali, shall remain at 12 or higher for two hours and then at 11.5 or higher for an additional 22 hours.

Alternative 7 - The percent solids of sewage sludge that does not contain unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 75 percent based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

Alternative 8 - The percent solids of sewage sludge that contains unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 90 percent based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

- Alternative 9 -
- (i) Sewage sludge shall be injected below the surface of the land.
 - (ii) No significant amount of the sewage sludge shall be present on the land surface within one hour after the sewage sludge is injected.
 - (iii) When sewage sludge that is injected below the surface of the land is Class A with respect to pathogens, the sewage sludge shall be injected below the land surface within eight hours after being discharged from the pathogen treatment process.
- Alternative 10 -
- (i) Sewage sludge applied to the land surface or placed on a surface disposal site shall be incorporated into the soil within six hours after application to or placement on the land.
 - (ii) When sewage sludge that is incorporated into the soil is Class A with respect to pathogens, the sewage sludge shall be applied to or placed on the land within eight hours after being discharged from the pathogen treatment process.

C. Monitoring Requirements

1. Toxicity Characteristic Leaching Procedure (TCLP) Test performed within one year from the effective date of the permit. Once/Permit Life
2. PCBs Once/Year
3. All other pollutants shall be monitored at the frequency shown below:

<u>Amount of sewage sludge* (metric tons per 365 day period)</u>	<u>Frequency</u>
0 ≤ Sludge < 290	Once/Year
290 ≤ Sludge < 1,500	Once/Quarter
1,500 ≤ Sludge < 15,000	Once/Two Months
15,000 ≤ Sludge	Once/Month

*Either the amount of bulk sewage sludge applied to the land or the amount of sewage sludge received by a person who prepares sewage sludge that is sold or given away in a bag or other container for application to the land (dry weight basis).

Representative samples of sewage sludge shall be collected and analyzed in accordance with the methods referenced in 40 CFR 503.8(b) and OAC 252:648.

SECTION II. REQUIREMENTS SPECIFIC TO BULK SEWAGE SLUDGE FOR APPLICATION TO THE LAND MEETING CLASS A OR B PATHOGEN REDUCTION AND THE CUMULATIVE LOADING RATES IN TABLE 2, OR CLASS B PATHOGEN REDUCTION AND THE POLLUTANT CONCENTRATIONS IN TABLE 3

For those permittees meeting Class A or B pathogen reduction requirements and that meet the cumulative loading rates in Table 2 below, or the Class B pathogen reduction requirements and contain concentrations of pollutants below those listed in Table 3 found in Element 1, Section III, the following conditions apply:

TABLE 2

Pollutant	Cumulative Pollutant Loading Rate (kilograms per hectare)
Arsenic	41
Cadmium	39
Copper	1500
Lead	300
Mercury	17
Molybdenum	Report
Nickel	420
Selenium	100
Zinc	2800

2. Pathogen Control

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, or lawn or home garden shall be treated by either Class A or Class B pathogen reduction requirements as defined above in Element 1, Section I.B.3.

3. Management Practices

- a. Bulk sewage sludge shall not be applied to agricultural land, forest, a public contact site, or a reclamation site that is flooded, frozen, or snow-covered so that the bulk sewage sludge enters a wetland or other waters of the state, as defined in 40 CFR 122.2, except as provided in a permit issued pursuant to the Act.
- b. Bulk sewage sludge shall not be applied within 100 feet of a water of the state.
- c. Bulk sewage sludge shall be applied at or below the agronomic rate in accordance with recommendations from the following references:
 - i. STANDARDS 1992, Standards, Engineering Practices and Data, 39th Edition (1992) American Society of Agricultural Engineers, 2950 Niles Road, St. Joseph, MI 49085-9659.
 - ii. National Engineering Handbook Part 651, Agricultural Waste Management Field Handbook (1992), P.O. Box 2890, Washington, D.C. 20013.
 - iii. Recommendations of local extension services or Soil Conservation Services.
 - iv. Recommendations of a major university's Agronomic Department.
- d. An information sheet shall be provided to the person who receives bulk sewage sludge that is sold or given away. The information sheet shall contain the following information:
 - i. The name and address of the person who prepared the sewage sludge that is sold or given away in a bag or other container for application to the land.
 - ii. A statement that application of the sewage sludge to the land is prohibited except in accordance with the instructions on the label or information sheet.
 - iii. The annual whole sludge application rate for the sewage sludge that does not cause any of the cumulative pollutant loading rates in Table 2 above to be exceeded, unless the pollutant concentrations in Table 3 found in Element 1, Section III below are met.

4. Notification requirements

- a. If bulk sewage sludge is applied to land in a state other than the state in which the sludge is prepared, written notice shall be provided prior to the initial land application to the permitting authority for the state in which the bulk sewage sludge is proposed to be applied. The notice shall include:
 - i. The location, by either street address or latitude and longitude, of each land application site.
 - ii. The approximate time period bulk sewage sludge will be applied to the site.
 - iii. The name, address, telephone number, and Oklahoma Pollutant Discharge Elimination System or National Pollutant Discharge Elimination System, whichever is applicable, permit number (if appropriate) for the person who prepares the bulk sewage sludge.
 - iv. The name, address, telephone number, and Oklahoma Pollutant Discharge Elimination System or National Pollutant Discharge Elimination System, whichever is applicable, permit number (if appropriate) for the person who will apply the bulk sewage sludge.

- b. The permittee shall give 60 days prior notice to the DEQ of any change planned in the sewage sludge practice. Any change shall include any planned physical alterations or additions to the permitted treatment works, changes in the permittee's sludge use or disposal practice, and also alterations, additions, or deletions of disposal sites. These changes may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional disposal sites not reported during the permit application process or absent in the existing permit. Change in the sludge use or disposal practice may be cause for modification of the permit in accordance with 40 CFR 122.62(a)(1).
- c. The permittee shall provide the location of all existing sludge disposal/use sites to the State Historical Commission within 90 days of the effective date of this permit. In addition, the permittee shall provide the location of any new disposal/use site to the State Historical Commission prior to use of the site.

The permittee shall within 30 days after notification by the State Historical Commission that a specific sludge disposal/use area will adversely effect a National Historic Site, cease use of such area.

5. Recordkeeping Requirements - The sludge documents will be retained on site at the same location as other OPDES records.

The person who prepares bulk sewage sludge or a sewage sludge material shall develop the following information and shall retain the information for five years. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for recordkeeping found in 40 CFR 503.17 and OAC 252:648 for persons who land apply.

- a. The concentration (mg/Kg) in the sludge of each pollutant listed in Table 3 found in Element I, Section III and the applicable pollutant concentration criteria (mg/Kg), or the applicable cumulative pollutant loading rate and the applicable cumulative pollutant loading rate limit (kg/ha) listed in Table 2 above.
- b. A description of how the pathogen reduction requirements are met (including site restrictions for Class B sludges, if applicable).
- c. A description of how the vector attraction reduction requirements are met.
- d. A description of how the management practices listed above in Section II.3 are being met.
- e. The recommended agronomic loading rate from the references listed in Section II.3.e above, as well as the actual agronomic loading rate shall be retained.
- f. A description of how the site restrictions in 40 CFR 503.32(h)(5) and OAC 252:648 are met for each site on which Class B bulk sewage sludge is applied.
- g. The following certification statement:
 "I certify, under penalty of law, that the management practices in 40 CFR 503.14 have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."
- h. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 40 CFR 503.17(a)(4)(i)(B) or 40 CFR 503.17(a)(5)(i)(B) as applicable to the permittees sludge treatment activities.
- i. The permittee shall maintain information that describes future geographical areas where sludge may be land applied.
- j. The permittee shall maintain information identifying site selection criteria regarding land application sites not identified at the time of permit application submission.
- k. The permittee shall maintain information regarding how future land application sites will be managed.

The person who prepares bulk sewage sludge or a sewage sludge material shall develop the following information and shall retain the information indefinitely. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for recordkeeping found in 40 CFR 503.17 and OAC 252:648 for persons who land apply.

- i. The location, by either street address or latitude and longitude, of each site on which sludge is applied.
- ii. The number of hectares in each site on which bulk sludge is applied.
- iii. The date and time sludge is applied to each site.
- iv. The cumulative amount of each pollutant in kilograms/hectare listed in Table 2 applied to each site.
- v. The total amount of sludge applied to each site in metric tons.
- vi. The following certification statement:

"I certify, under penalty of law, that the requirements to obtain information in 40 CFR 503.12(e)(2) have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision

in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the requirements to obtain information have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."

vii. A description of how the requirements to obtain information in 40 CFR 503.12(e)(2) and OAC 252:648 are met.

6. Reporting Requirements - The permittee shall report annually on the DMR the following information:

- a. Pollutant Table (2 or 3) appropriate for permittee's land application practices.
- b. The frequency of monitoring listed in Element 1, Section 1.C which applies to the permittee.
- c. Toxicity Characteristic Leaching Procedure (TCLP) results (Pass/Fail).
- d. The concentration (mg/Kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) as well as the applicable pollutant concentration criteria (mg/Kg) listed in Table 3 found in Element 1, Section III, or the applicable pollutant loading rate limit (kg/ha) listed in Table 2 above if it exceeds 90% of the limit.
- e. Level of pathogen reduction achieved (Class A or Class B).
- f. Alternative used as listed in Section 1.B.3.(a. or b.). Alternatives describe how the pathogen reduction requirements are met. If Class B sludge, include information on how site restrictions were met in the DMR comment section or attach a separate sheet to the DMR.
- g. Vector attraction reduction alternative used as listed in Section 1.B.4.
- h. Annual sludge production in dry metric tons/year.
- i. Amount of sludge land applied in dry metric tons/year.
- j. Amount of sludge transported interstate in dry metric tons/year.
- k. The certification statement listed in 40 CFR 503.17(a)(4)(i)(B) or 40 CFR 503.17(a)(5)(i)(B) whichever applies to the permittees sludge treatment activities shall be attached to the DMR.
- l. When the amount of any pollutant applied to the land exceeds 90% of the cumulative pollutant loading rate for that pollutant, as described in Table 2, the permittee shall report the following information as an attachment to the DMR.
 - i. The location, by either street address or latitude and longitude.
 - ii. The number of hectares in each site on which bulk sewage sludge is applied.
 - iii. The date and time bulk sewage sludge is applied to each site.
 - iv. The cumulative amount of each pollutant (i.e., kilograms/hectare) listed in Table 2 in the bulk sewage sludge applied to each site.
 - v. The amount of sewage sludge (i.e., metric tons) applied to each site.
 - vi. The following certification statement:

"I certify, under penalty of law, that the requirements to obtain information in 40 CFR 503.12(e)(2) have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the requirements to obtain information have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."
 - vii. A description of how the requirements to obtain information in 40 CFR 503.12(e)(2) and OAC 252:648 are met.

SECTION III. REQUIREMENTS SPECIFIC TO BULK OR BAGGED SEWAGE SLUDGE MEETING POLLUTANT CONCENTRATIONS IN TABLE 3 AND CLASS A PATHOGEN REDUCTION REQUIREMENTS

For those permittees with sludge that contains concentrations of pollutants below those pollutant limits listed in Table 3 for bulk or bagged (containerized) sewage sludge and also meet the Class A pathogen reduction requirements, the following conditions apply (Note: All bagged sewage sludge must be treated by Class A pathogen reduction requirements.):

1. Pollutant limits - The concentration of the pollutants in the municipal sewage sludge is at or below the values listed.

TABLE 3

Monthly Average Concentration
(milligrams per kilogram)*

Arsenic	41
Cadmium	39
Copper	1500
Lead	300
Mercury	17
Molybdenum	Report
Nickel	420
Selenium	36
Zinc	2800

* Dry weight basis

2. Pathogen Control

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, or lawn or home garden shall be treated by the Class A pathogen reduction requirements as defined above in Element 1, Section 1.B.3. All bagged sewage sludge must be treated by Class A pathogen reduction requirements.

3. Management Practices - None.

4. Notification Requirements - None.

5. Recordkeeping Requirements - The permittee shall develop the following information and shall retain the information for five years. The sludge documents will be retained on site at the same location as other OPIES records.

- a. The concentration (mg/Kg) in the sludge of each pollutant listed in Table 3 and the applicable pollutant concentration criteria listed in Table 3.
- b. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 40 CFR 503.17(a)(1)(ii) or 40 CFR 503.17(a)(3)(i)(B), and OAC 252:648 whichever applies to the permittees sludge treatment activities.
- c. A description of how the Class A pathogen reduction requirements are met.
- d. A description of how the vector attraction reduction requirements are met.

6. Reporting Requirements - The permittee shall report annually on the DMR the following information:

- a. Pollutant Table 3 appropriate for permittee's land application practices.
- b. The frequency of monitoring listed in Element 1, Section 1.C which applies to the permittee.
- c. Toxicity Characteristic Leaching Procedure (TCLP) results. (Pass/Fail).
- d. The concentration (mg/Kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) found in Element 1, Section 1. In addition, the applicable pollutant concentration criteria listed in Table 3 should be included on the DMR.
- e. Pathogen reduction Alternative used for Class A bagged or bulk sludge as listed in Section 1.B.3.a.
- f. Vector attraction reduction Alternative used as listed in Section 1.B.4.
- g. Annual sludge production in dry metric tons/year.
- h. Amount of sludge land applied in dry metric tons/year.
- i. Amount of sludge transported interstate in dry metric tons/year.
- j. The certification statement listed in 40 CFR 503.17(a)(1)(ii) or 40 CFR 503.17(a)(3)(i)(B), and OAC 252:648 whichever applies to the permittees sludge treatment activities, shall be attached to the DMR.

SECTION IV.

REQUIREMENTS SPECIFIC TO SLUDGE SOLD OR GIVEN AWAY IN A BAG OR OTHER CONTAINER FOR APPLICATION TO THE LAND THAT DOES NOT MEET THE POLLUTANT CONCENTRATIONS in Table 3

1. Pollutant Limits

TABLE 4

Pollutant	Annual Pollutant Loading Rate (kilograms per hectare per 365 day period)
-----------	---

Arsenic	2.0
Cadmium	1.9
Copper	75.0
Lead	15.0
Mercury	0.85
Molybdenum	Report
Nickel	21.0
Selenium	5.0
Zinc	140.0

2. Pathogen Control

All sewage sludge that is sold or given away in a bag or other container for application to the land shall be treated by the Class A pathogen requirements as defined in Section 1.B.3.a.

3. Management Practices

Either a label shall be affixed to the bag or other container in which sewage sludge that is sold or given away for application to the land, or an information sheet shall be provided to the person who receives sewage sludge sold or given away in another container for application to the land. The label or information sheet shall contain the following information:

- The name and address of the person who prepared the sewage sludge that is sold or given away in a bag or other container for application to the land.
- A statement that application of the sewage sludge to the land is prohibited except in accordance with the instructions on the label or information sheet.
- The annual whole sludge application rate for the sewage sludge that will not cause any of the annual pollutant loading rates in Table 4 above to be exceeded.

4. Notification Requirements - None.

5. Recordkeeping Requirements - The sludge documents will be retained on site at the same location as other OPIFS records.

The person who prepares sewage sludge or a sewage sludge material shall develop the following information and shall retain the information for five years.

- The concentration in the sludge of each pollutant listed above in found in Element 1, Section I, Table 1.
- The following certification statement found in 40 CFR 503.17(a)(6)(iii).

"I certify, under penalty of law, that the management practices in 40 CFR 503.14(c), the Class A pathogen requirement in 40 CFR 503.32(a), and the vector attraction reduction requirement in (insert vector attraction reduction option) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices, pathogen requirements, and vector attraction reduction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment".
- A description of how the Class A pathogen reduction requirements are met.
- A description of how the vector attraction reduction requirements are met.
- The annual whole sludge application rate for the sewage sludge that does not cause the annual pollutant loading rates in Table 4 to be exceeded. See Appendix A to 40 CFR Part 503 - Procedure to Determine the Annual Whole Sludge Application Rate for a Sewage Sludge.

6. Reporting Requirements - The permittee shall report annually on the DMR the following information:

- Pollutant listed in, Table 4 as appropriate for permittee's land application practices.
- The frequency of monitoring listed in Element 1, Section 1.C which applies to the permittee.
- Toxicity Characteristic Leaching Procedure (TCLP) results (Pass/Fail).
- The concentration (mg/Kg) in the sludge of each pollutant listed above in Table 1 (defined as a monthly average) found in Element 1, Section I.
- Class A pathogen reduction Alternative used as listed in Section 1.B.3.a. Alternatives describe how the pathogen reduction requirements are met.
- Vector attraction reduction Alternative used as listed in Section 1.B.4.
- Annual sludge production in dry metric tons/year.

- h. Amount of sludge land applied in dry metric tons/year.
- i. Amount of sludge transported interstate in dry metric tons/year.
- j. The following certification statement found in 40 CFR 503.17(a)(6)(iii) shall be attached to the DMR.

"I certify, under penalty of law, that the management practice in 40 CFR 503.14(c), the Class A pathogen requirement in 40 CFR 503.32(a), and the vector attraction reduction requirement (insert appropriate option) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel gather and evaluate the information used to determine that the management practice, pathogen requirements, and vector attraction reduction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment."

ELEMENT 2 - MUNICIPAL SOLID WASTE LANDFILL DISPOSAL

SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE DISPOSED IN A MUNICIPAL SOLID WASTE LANDFILL

1. The permittee shall handle and dispose of sewage sludge in accordance with the Act and all other applicable federal and state regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present. The permittee shall ensure that the sewage sludge meets the requirements in 40 CFR Part 258 concerning the quality of the sludge disposed in the municipal solid waste landfill (MSWLF) unit.
2. If requirements for sludge management practices or pollutant criteria become more stringent than the sludge pollutant limits or acceptable management practices in this permit, or control a pollutant not listed in this permit, this permit may be modified or revoked and reissued to conform to the requirements promulgated under the Act.
3. If the permittee generates sewage sludge and supplies that sewage sludge to the owner or operator of a MSWLF for disposal, the permittee shall provide to the owner or operator of the MSWLF appropriate information needed to be in compliance with the provisions of this permit.
4. The permittee shall give prior notice to the Director, Water Quality Division, DEQ, 707 N. Robinson, Oklahoma City, Oklahoma 73101-1677, of any planned changes in the sewage sludge disposal practice, in accordance with 40 CFR 122.41(l)(1)(iii). These changes may justify the application of permit conditions that are different from or absent in the existing permit. Change in the sludge use or disposal practice may be cause for modification of the permit in accordance with 40 CFR 122.62(a)(1).
5. The permittee shall provide the location of all existing sludge disposal/use sites to the State Historical Commission within 90 days of the effective date of this permit. In addition, the permittee shall provide the location of any new disposal/use site to the State Historical Commission prior to use of the site.
The permittee shall within 30 days after notification by the State Historical Commission that a specific sludge disposal/use area will adversely affect a National Historic Site, cease use of such area.
6. Sewage sludge shall be tested once during the life of the permit within one year from the effective date of the permit in accordance with the method specified at 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other approved methods. Sludge shall be tested after final treatment prior to leaving the POTW site. Sewage sludge determined to be a hazardous waste in accordance with 40 CFR Part 261, shall be handled according to RCRA standards for the disposal of hazardous waste in accordance with 40 CFR Part 262. The disposal of sewage sludge determined to be a hazardous waste, in other than a certified hazardous waste disposal facility shall be prohibited. The DEQ, Waste Management Division at (405) 271-5338, shall be notified of test failure within 24 hours. A written report shall be provided to this office within 7 days after failing the TCLP. The report will contain test results, certification that unauthorized disposal has not occurred and a summary of alternative disposal plans that comply with RCRA standards for the disposal of hazardous waste. The report shall be addressed to the Director, Waste Management Division, DEQ, 707 N. Robinson, Oklahoma City, Oklahoma 73101-1677, and a copy sent to the Director, Water Quality Division, DEQ, at the same address.
7. Sewage sludge shall be tested as needed, or at a minimum, once/year in accordance with the method 9095 (Paint Filter Liquids Test) as described in "Test Methods for Evaluating Solid Wastes, Physical/Chemical Methods" (EPA Pub. No. SW-846).
8. Recordkeeping requirements - The permittee shall develop the following information and shall retain the information for five years.
 - a. The description, including procedures followed, and results of the Paint Filter Tests performed.
 - b. The description, including procedures followed, and results of the TCLP Test.
9. Reporting requirements - The permittee shall report annually on the Discharge Monitoring Report the following information:
 - a. Results of the Toxicity Characteristic Leaching Procedure Test conducted on the sludge to be disposed (Pass/Fail).
 - b. Annual sludge production in dry metric tons/year.
 - c. Amount of sludge disposed in a municipal solid waste landfill in dry metric tons/year.
 - d. Amount of sludge transported interstate in dry metric tons/year.
 - e. A certification that sewage sludge meets the requirements in 40 CFR Part 258 concerning the quality of the sludge disposed in a

municipal solid waste landfill unit shall be attached to the DMR.





E:\standard municipal permit documents\part iv.doc
updated 8/21/98



APPENDIX TM 1-4

TEMPLATE FOR CONDITION RATING

FACILITY INSPECTIONS

Condition Assessment Ratings

Condition Rating	Percent of Useful Life Remaining	General Description of Condition	Photo Examples
New	100-90	<ul style="list-style-type: none"> ✓ Newly built to recently built ✓ No wear ✓ Operates as designed ✓ No maintenance needed 	
Excellent	90-75	<ul style="list-style-type: none"> ✓ Recently built ✓ Little to no appreciable wear ✓ Operates as designed ✓ Normal maintenance 	
Good	75-55	<ul style="list-style-type: none"> ✓ Within first half of useful life ✓ Slight wear ✓ Operates as designed ✓ Normal to slight maintenance needed 	
Fair	55-35	<ul style="list-style-type: none"> ✓ At or beyond first half of useful life ✓ Slight to significant wear ✓ Normally operates as designed ✓ Slight to supplementary maintenance needed 	

Condition Rating	Percent of Useful Life Remaining	General Description of Condition	Photo Examples
Poor	35-15	<ul style="list-style-type: none"> ✓ Beyond first half of useful life to at the end of useful life ✓ Significant to major wear ✓ Operates as designed with additional to significant maintenance ✓ Significant to burdensome maintenance necessary 	
Replace	15-0	<ul style="list-style-type: none"> ✓ Beyond useful life in need of replacement ✓ Major wear ✓ Will not operate as designed without significant and constant maintenance, is inoperable or abandoned ✓ Significant to burdensome constant maintenance necessary 	

APPENDIX TM 1-5

NITRIFICATION CLARIFIER OPERATIONAL ISSUES

Memorandum

To: Robert Hitt; Jim McClain, Muralikumar, Joyce Hight,

From: Jose Pereira

Date: September 19, 2005

Re: Nitrification Clarifiers – Handling capacity & operational issues - S-0505A

During a site visit on 08/31/05 to the City of Enid Water Pollution Control Facility, the facility staff indicated that when flows exceed 7 mgd there is high solids carryover in the final effluent, although the design capacity of the final clarifiers in the nitrification plant were designed to handle 8.5 mgd. This technical memorandum offers our comments/recommendation on the operation of the nitrification plant following our inspection of the nitrification plant and review of as-built plans.

As you know, the nitrification plant was originally designed to handle average and peak flows of 8.5 mgd and 21 mgd, respectively at an average BOD₅ of 30 mg/l and TSS of 20 mg/l. The nitrification plant is equipped with four rectangular clarifiers, each 30' wide by 120' long by 12' SWD. These rectangular clarifiers are equipped with traveling bridge mechanisms for the collection and removal of settled sludge and effluent troughs with V- notch weirs to distribute the flow uniformly and improve the effluent quality. Our calculations show that the surface overflow rates at average and peak flows are 590gpd/ft² and 1,458gpd/ft² respectively. The weir loading rates at average and peak flows are estimated to be 5,902 gpd/ft and 14,583 gpd/ft respectively, which are within recommended design criteria (10,000 gpd/ft at average flow and 15,000 gpd/ft at peak flow). However, during our visual inspection of the traveling bridge clarifiers, we noticed few operational issues that could possibly impair the effluent quality, particularly during high flow conditions. These Observations are as follow:

- a. The nitrification plant rectangular clarifier effluent troughs are not leveled, which affects the V-notch weirs elevation. The elevation of the V-notch weirs at the east end of the clarifiers is lower than the west end. As a result, there is no overflow on the V- notch weirs located at the west end of the clarifier troughs and most of the flow occurs through the east end creating more undercurrent and turbulence. This is confirmed by the operators when the flow exceeds 7 mgd the v-notch weirs at the east end of the clarifier troughs become submerged. The V-notch weir submergence does not reflect under designed of the weirs but instead overcharge due to the unleveled surface.
- b. The traveling bridge mechanism used for sludge collection has a supporting truss extending all the way down in to the clarifier bottom. The traveling bridge also has too many moving parts for its operation and the movement of the bridge on the rail is not smooth and at times, creating a jerk sudden movement possibly due to wear and tear on the traveling parts as result of the equipment age. The truss/other parts on the traveling bridge, and agitation due to the sudden jerk movement could possibly create an under current wave that could stir the settled/settling solids in the clarifier through out the basin and impact the effluent quality, particularly during the high flow conditions.

In summary, it is our opinion that if the plant is operated within the design range and if the above operational deficiencies are corrected, as well as other manufacturer recommendations to fine tune its operation, we anticipate that the final clarifiers could see a major improvement and handle the flow as originally designed. However, additional information and evaluation will be required before final conclusions are recommended.

NORTH
Scale: NTS





FIG. 3

PLAN VIEW
WASHINGTON AVENUE OPTION 1



Legend

- 2007 Improvements
- 2010 Improvements
- 2015 Improvements



Figure 5 - Capital Improvement Map
 Enid Sanitary Sewer Monitoring
 City of Enid

ENVIROTECH
 ENVIRONMENTAL CONSULTING, INC.
 2500 North 11th Street - Enid, Oklahoma 73701
 Phone (580) 234-8780, Fax (580) 237-4302
 C.A. #1960 - Expiration Date: 6-30-2008
 www.envirotechconsulting.com

Date:	August 2008
Scale:	1" = 1250'
Designed by:	J. Voss
Drawn by:	J. Voss
Checked by:	J. Stollings
Project No.:	05.123

TABLE 4.						
PIPELINES AND ASSOCIATED FLOW DATA AND CAPACITIES						
Name	Basin	Location	Actual Peak (gpm)	Model Flow (gpm)	Capacity (gpm)	Pipe Full (gpm)
North Main	1-A	West 16 TH	1,700	3,495	4,560	5,050
NOC	1-B	NOC	930	875	3,980	4,360
	1-C	19 TH & Randolph	65	71	1,150	1,260
30 TH Street	1-D	30 TH & Garriott	140	135	670	740
Downtown	1-F Fed by 1-G and 1-H	2 ND & Randolph	14	16	330	420
		Pastimes	78	77	760	970
		3 RD & Main	110	130	510	650
	1-G2	5 TH & Randolph	225	220	460	590
	1-I Fed by 1-J and 1-K	Indian & Oklahoma	300	280	540	660
		Integriss Pavilion	775	744	2,090	2,290
North Enid	1-N	4 TH & Beech	275	295	360	460
		3 RD & Beech	300	320	360	460
N. Van Buren	1-O	N. Van Buren	330	356	3,940	4,330
54 TH Street	1-P	54 TH Street Lift	1,200	1,210	1,300	1,420
Brookside	2-B	BS Trunk Line	1,750	2,470	10,160	11,150
		BS Res.	20	N/A	320	440
South Main	2-C	East 16 TH Street	1,650	1,450	14,180	15,550
		West 16 TH Street	1,700	2,373	9,220	10,120
S. Van Buren	2-D	S. Van Buren	240	245	1,800	1,980
Frantz Main	2-E	Jeff & Frantz	1,850	2,200	20,140	22,090
Oakwood Mall	2-G	Mall	920	890	1,670	1,830
		Indian Oaks	650	758	670	740
Cleveland	2-H	Randolph & McKinley	500	512	2,110	2,310
	2-I	Lisa Lane	143	130	1,000	1,100
	2-K	Cleveland & Chestnut	240	270	650	710

4.2.2 Wet Flow Condition Analysis. During precipitation events, flows in the sanitary sewer pipelines greatly increase due to Inflow and Infiltration (I/I). According to the wet condition model, the capacity of most pipelines is sufficient to accommodate the

Engineering Calculations (I/I Study)

Engineering Notes:

Problem: Determine amount of I/I in each Sewer Basin

Assumption: The maximum allowable inflow/infiltration for a sewer operating within "normal" limits is 200 gallons/mile/day/in-diameter

- Step 1: TM 2-1 From the flow data gathered from the city sewers, determine average and peak daily flows as well as peak storm water flows. Correlate the storm flows with their individual storm Flow data was divided into yearly quarters and analyzed for peak flows. Flow data was analyzed on a 15 minute basis to determine flow profile and base flow for each monitoring point. Some conditions were taken into account, such as line back ups, surcharging, and seasonal flows.
- Step 2: TM 2-2 Calculate the Municipal sewer inflows
Utilizing typical inflows from municipal sources, inflows in the various sub-basins were calculated throughout the city.
- Step 3: TM 2-3 Determine the US SCS curve numbers, % impervious, and conductivity for each sub-basin.
Calculated utilizing TR-55 techniques through observation
- Step 4: TM 2-3 Determine the length*in-diameter of the sewer pipe and area of each sub-basin.
Calculated by observation.
- Step 5: TM 2-4 Determine the rainfall for the 100-year storm and the individual storms in Enid
Data obtained from TR-55 and weatherunderground.com in combination with the City of Enid raingauges
- Step 6: TM 2-5 Determine the hydrograph of the infiltration/inflow
The SWMM model is divides the I/I hydrograph into Start Tern Response (ST), Median Term Response (MT), and Long Term Reponses (LT). Within each hydrograph is a ratio of the flow (R) Proportional to the Response Term, a Time to the Peak (T), and (K) the
Step 4a Find Proportionality between each response
From the CN values, a Proportionality curve was generated for each response time
Step 2b Determine the T and K factors
The conductivity of the soil divided by the depth of soil/manhole was used to calculate the T factor. In general the K factor is approximately 2:1 for a typical curve (Twice the lag time to initial concentration)
- Step 7: TM 2-5 Determine the sewer area necessary to provide a 200 gal/mil/day/in-dia flow.
Step 5a: Find the amount of inflow required to provide the 200 g/m/d/in for the sub-basin.
The 200 g/m/d/in term was multiplied by the observed length*dia term in Step 3.
Step 5b: Find the relationship between sewer inflow area and required inflow
The relationship between inflow and the sewer basin inflow area term is liner with a 0 y-intercept for a given CN value and MH depth.
Step 5c: Find the relationship between CN and sewer inflow
Since the inflow relationship is liner with a y-intercept = 0, the slopes of the CN values for each manhole depth were fit to a inflow*area vs. CN graph.
Step 5d: Determine the sewer inflow area.
The CN value was inputted into the graphical relationship in 5c and an area*inflow value was found. The factor was divided by the necessary inflow rate determined in Step 5a, and an area value was determined on a 5-ft depth basis (5, 10, 15, 20, and 25-ft deep sewers). The values were interpiated against the actual sewer depth and the inflow area term was determined for an infiltration value of 200 gallon/mile/in-diameter/day.
- Step 8: TM 2-6 SWMM Model and Output
The SWMM model was developed from the above data. The input/final output report appear in Appendix F.

TM 2-1.


FLOW METERS

Basin Inflow and Infiltration Study


Name	Basin	Location	Metered Flow		Model Flow	
			Base Flow	Peak Flow	Base Flow	Peak Flow
			gpm	gpm	gpm	gpm
North Main	1-A	West 16th	550	1700	1352	3495
NOC	1-B and 1-C	NOC	280	930	350	875
		19th & Randolph	15	65	30	71
30th St	1-D	30th and Garriott	65	140	56	135
Down Town	1-F Fed by 1-G and 1-H	2nd & Randolph	2	14	7	16
		Pasttimes	31	78	32	77
	1G2	3rd and Main	40	110	53	130
	1-I (Fed by 1-J and 1-	5th & Randolph	60	225	50	220
		Ind.&Okla	150	300	167	280
North Enid	1-N	Integris Pav	363	775	330	744
		4th and Beech	70	275	123	295
N. Van Buren	1-O	3rd and Beech	85	300	166	320
N. Van Buren	1-O	N. Van Buren	NA	330	148	356
54th Street	1-P	54th St. Lift	274	1200	504	1210
Brookside	2-B	BS Trunk Line	500	1750	1377	2470
		Brookside Res	2	20	NA	NA
South Main	2-C	East 16th St	440	1650	390	1450
		West 16th	550	1700	1258	2373
S. Van	2-D	S. Van Buren	40	240	101	245
Frantz Main	2-E	Jeff. & Frantz	650	1850	1050	2200
Oakwood Mall	2-G	Mall	330	920	278	890
		Indian Oaks	200	650	300	758
Cleveland	2-H	Rand & Mck	100	500	219	512
	2-I	Lisa Lane	35	143	53	130
	2-K	Cleve & Chest	120	240	111	270

DOWNTOWN


5th and Randolph - 2006 2nd Quarter




5th and Randolph - 2006 - 3rd Quarter




5th and Randolph - 2006 - 4th Quarter




5th and Randolph - 2007 - 1st Quarter



2nd and Randolph - 2006 - 2nd Quarter




2nd and Randolph - 2006 - 3rd Quarter




SW of Rail Road

SW of RailRoad




Integris Chart


Integris Pavilion




SW of Rail Road and Integris Pavilion




Past Times - 2006 - 3rd Quarter




Past Times - 2006 - 4th Quarter




Independence and Oklahoma - 2006 - 3rd Quarter




Independence and Oklahoma - 2006 - 4th Quarter




Independence and Oklahoma - 2007 - 1st Quarter



Independence and Oklahoma - 2007 - 2nd Quarter




Ino. & Oklahoma




EAST SIDE


NOC - 2006 - 2nd Quarter




NOC - 2006 - 2nd Quarter



19th and Randolph - 2006 - 2nd Quarter




30th and Garriott




NORTH SIDE

3rd and Beech. - 2006 - 2nd Quarter




Daily Chart

4th and Beech




North Van Buren - 2007 - 2nd Quarter




NORTHWEST

Lisa Lane - 2005 - 4th Quarter




Lisa_Lane 06 - 1st Quarter


Lisa Lane - 2006 - 1st Quarter




Lisa Lane - 2006 - 2nd Quarter




McKinley and Randolph - 2007 - 2nd Quarter



Cleveland and Chestnut - 2006 - 2nd Quarter




Cleveland and Chestnut - 2006 - 3rd Quarter




WEST SIDE

Daily Chart


Indian Oaks - 2007 - 1st Quarter



Oakwood Mall and Channel - 2006 - 2nd Quarter




Mall - 2007 - 1st Quarter




SOUTH SIDE


East 16th - 2006 - 2nd Quarter




East 16th - 2006 - 3rd Quarter




East 16th - 2006 - 4th Quarter



East 16th - 2007 - 1st Quarter




S. Van Buren - 2006 - 4th Quarter




South Van Buren - 2007 - 1st Quarter




South Van Buren - 2007 - 2nd Quarter



West 16th - 2006 - 2nd Quarter




West 16th - 2006 - 3rd Quarter




SOUTHEAST


Brookside - 2007 - 1st Quarter




Brookside - 2007 - 2nd Quarter




Brookside Residential - 2007 - 2nd Quarter




54th Street Lift Station - 2006 - 4th Quarter




54th Street Lift Station - 2007 - 1st Quarter



Advance South - 2006 - 2nd Quarter



Advance South - 2006 - 3rd Quarter



TM 2-2

**SANITARY SEWER
INFLOWS**

BASIN 1

Sanitary Sewer Municipal Inflows

Basin 1

Some Average Values
 Group Living (per person) 100
 Housing (2 bedroom) 225
 Housing (Multiple) 300
 Commercial (Laundry) 4000
 Commercial (Food) 1000
 Commercial (Stores) 500
 Commercial (Office) 85
 Industrial (High) 4000
 Industrial (Low) 400
 Recreation 100

gpm to cfs
448.83

% Base Flow
5%

% Dry Flow
38%

Dry Multiplier
33%

*Note Peak is 1/3 of average

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(1D)023	13125		800		13925	0.021548	0.021548	9.67152	0.484	3.49
(1D)022	4725				4725	0.007312	0.02886	12.95324	0.164	1.18
(1D)021	9875	2000	2000		13875	0.021471	0.050331	22.59003	0.482	3.48
(1D)020	11025	9000			20025	0.030988	0.081319	36.49827	0.695	5.02
(1D)018	7875	1000			8875	0.013734	0.095052	42.66234	0.308	2.23
(1D)017	7875	500			8375	0.01296	0.108012	48.47915	0.291	2.1
(1D)016	6300				6300	0.009749	0.117761	52.85477	0.219	1.58
(1D)015	4725				4725	0.007312	0.125073	56.13649	0.164	1.18
(1D)014	2362.5				2362.5	0.003656	0.128729	57.77735	0.082	0.59
(1D)012	14700				14700	0.022748	0.151476	67.98714	0.51	3.69
(1D)005	4200	2000			6200	0.009594	0.161071	72.29331	0.215	1.55
(1D)001	2700				2700	0.004178	0.165249	74.16858	0.094	0.68
(1A)017*					0	0	0.165249	74.16858		
(1C)182	10125				10125	0.015668	0.015668	7.032254	0.352	2.54
(1C)181	3375				3375	0.005223	0.020891	9.376339	0.117	0.85
(1C)180A	3375				3375	0.005223	0.026113	11.72042	0.117	0.85
(1C)180	3375				3375	0.005223	0.031336	14.06451	0.117	0.85
(1C)179	4500				4500	0.006964	0.038299	17.18996	0.156	1.13
(1C)178	21375				21375	0.033077	0.071376	32.03583	0.742	5.36
(1C)177	5625				5625	0.008704	0.080081	35.94263	0.195	1.41
(1C)176	3375				3375	0.005223	0.085303	38.28672	0.117	0.85
(1C)002	9450				9450	0.014623	0.099927	44.85016	0.328	2.37
(1C)001*					0	0	0.099927	44.85016		
					0	0		0		

Sanitary Sewer Municipal Inflows

Basin 1

Man Hole	Some Average Values		gpm to cfs	Total cfs	Total gpm	Base Flow	Dry Flow
	gpd	per person					
(1C)028	Housing	10800	10800	0.016713	7.501071	0.375	2.71
(1C)027	Housing	5400	5400	0.008356	11.25161	0.188	1.35
(1C)026	Housing (2 bedroom)	12000	12000	0.018569	19.58613	0.417	3.01
(1C)024	Housing (Multiple)	7200	7200	0.011142	24.58685	0.25	1.81
(1C)022	Commercial (Laundry)	5400	5400	0.008356	28.33738	0.188	1.35
(1C)020	Commercial (Food)	6000	6000	0.009285	32.50464	0.208	1.5
(1C)019	Commercial (Stores)	2400	2400	0.003714	34.17155	0.083	0.6
(1C)016*	Commercial (Office)	0	0	0	0		
(1C)021B	Industrial (High)	40800	82800	0.128129	57.50821	2.875	20.76
(1C)016A	Industrial (Low)	1200	1200	0.001857	58.34167	0.042	0.3
(1C)016*	Recreation	0	0	0	58.34167		
(1C)016	Commercial	2400	2400	0.003714	94.18012	0.083	0.6
(1C)015D	Commercial	32400	54400	0.084181	131.9633	1.889	13.64
(1C)015A	Commercial	9600	22600	0.034972	147.66	0.785	5.67
(1C)001B	Commercial	9000	9000	0.013927	153.9109	0.313	2.26
(1C)001*	Commercial	0	0	0	153.9109		
(1C)041	Commercial	4800	4800	0.007428	157.2447	0.167	1.2
(1C)007	Commercial	7200	7200	0.011142	162.2454	0.25	1.81
(1C)006	Commercial	1500	1500	0.002321	163.2872	0.052	0.38
(1C)004	Commercial	3600	3600	0.005571	165.7876	0.125	0.9
(1C)003	Commercial	2400	10400	0.016094	173.0108	0.361	2.61
(1C)001*	Commercial	0	0	0	173.0108		

*Note Peak is 1/3 of average

Dry Multiplier
33%

% Base Flow
5%

% Dry Flow
38%

Sanitary Sewer Municipal Inflows

Basin 1

Some Average Values
 Group Living (per person) 100
 Housing (2 bedroom) 225
 Housing (Multiple) 300
 Commercial (Laundry) 4000
 Commercial (Food) 1000
 Commercial (Stores) 500
 Commercial (Office) 85
 Industrial (High) 4000
 Industrial (Low) 400
 Recreation 100

gpm to cfs
 448.83
 % Base Flow
 5%
 % Dry Flow
 38%

Dry Multiplier
 33%

*Note Peak is 1/3 of average

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(1C)001		6000			6000	0.009285	0.837598	375.9391	0.208	1.5
(1B)014	52200	65500			117700	0.182135	1.019733	457.6869	4.087	29.51
(1B)010	3000	49000			52000	0.080468	1.100201	493.8032	1.806	13.04
(1B)009	16800	83000			99800	0.154436	1.254637	563.1186	3.466	25.02
(1B)005	4400	88100			92500	0.143139	1.397776	627.3639	3.212	23.19
(1B)001	0	0			0	0	1.397776	627.3639		
(1A)024A*					0	0	1.397776	627.3639		
(1N)025	19200		120000		139200	0.215406	0.215406	96.68048	4.834	34.9
(1N)022	4800	400		1500	6700	0.010368	0.225773	101.3339	0.233	1.68
(1N)021	4800	1800			6600	0.010213	0.235987	105.9179	0.229	1.65
(1N)020		3200			3200	0.004952	0.240939	108.1404	0.111	0.8
(1N)018		200	80000		80200	0.124106	0.365044	163.8428	2.785	20.11
(1N)015		500	1500		2000	0.003095	0.368139	165.2319	0.069	0.5
(1N)014	4800	3000			7800	0.01207	0.380209	170.6494	0.271	1.96
(1N)013	9600				9600	0.014856	0.395065	177.317	0.333	2.41
(1N)011	9600				9600	0.014856	0.40992	183.9846	0.333	2.41
(1N)009	6000				6000	0.009285	0.419205	188.1519	0.208	1.5
(1N)008	3300				3300	0.005107	0.424312	190.4439	0.115	0.83
(1N)007*					0	0	0.424312	190.4439		
(1N)047	22200	5425	202000		229625	0.355334	0.355334	159.4846	7.974	57.57
(1N)007*					0	0	0.355334	159.4846		

Sanitary Sewer Municipal Inflows

Basin 1

Man Hole	Some Average Values		Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
	gpd	gpm to cfs								
(1O)157	61400	28000	36000		125400	0.194051	0.194051	87.09577	4.355	31.44
(1O)308*					0	0	0.194051	87.09577		
(1O)309	62500	28850	60000		151350	0.234207	0.234207	105.1192	5.256	37.95
(1O)308*					0	0	0.234207	105.1192		
(1O)308					0	0	0.428258	192.215		
(1O)306A	10800	1850			1850	0.002863	0.431121	193.4999	0.064	0.46
(1O)306	3600	3000			13800	0.021355	0.452475	203.0846	0.479	3.46
(1O)305	54000	500			3600	0.005571	0.458046	205.5849	0.125	0.9
(1O)305A	12600				54000	0.083563	0.541609	243.0903	1.875	13.54
(1O)072	2100				13100	0.020272	0.56188	252.1888	0.455	3.28
(1O)303	11400				2100	0.00325	0.56513	253.6473	0.073	0.53
(1O)302	12000	1000			11400	0.017641	0.582771	261.5651	0.396	2.86
(1O)300	5625	800			13000	0.020117	0.602888	270.5942	0.451	3.26
(1M)286A	2250				5625	0.008704	0.611592	274.501	0.195	1.41
(1N)110					3050	0.00472	0.616312	276.6194	0.106	0.76
(1N)007*					0	0	0.616312	276.6194		
(1N)007	2250				2250	0.003482	1.39944	628.1105	0.078	0.56
(1N)006	4500	2500			7000	0.010832	1.410272	632.9724	0.243	1.76
(1N)005	2700	2425			5125	0.007931	1.418203	636.5319	0.178	1.28
(1N)004	4000	500			4500	0.006964	1.425166	639.6573	0.156	1.13
(1M)283	1350				1350	0.002089	1.427255	640.595	0.047	0.34
(1M)281B	18000		10000		28000	0.043329	1.470584	660.0422	0.972	7.02

*Note Peak is 1/3 of average

Dry Multiplier
33%

Sanitary Sewer Municipal Inflows

basin 1

Some Average Values
 Group Living (per person) 100
 Housing (2 bedroom) 225
 Housing (Multiple) 300
 Commercial (Laundry) 4000
 Commercial (Food) 1000
 Commercial (Stores) 500
 Commercial (Office) 85
 Industrial (High) 4000
 Industrial (Low) 400
 Recreation 100

gpm to cfs
 448.83

% Base Flow
 5%

% Dry Flow
 38%

Dry Multiplier
 33%

*Note Peak is 1/3 of average

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(1M)281*					0	0	1,470,584	660,042.2		
(1O)005A	12000	7350			19350	0.029943	0.029943	13,439.42	0.672	4.85
(1O)004	5400	800			6200	0.009594	0.039537	17,745.59	0.215	1.55
(1O)002	6300				6300	0.009749	0.049286	22,121.22	0.219	1.58
(1O)001	6000				6000	0.009285	0.058571	26,288.48	0.208	1.5
(1M)022	4500				4500	0.006964	0.065535	29,413.92	0.156	1.13
(1M)020	13500	15000	13600		42100	0.065148	0.130682	58,654.21	1.462	10.56
(1M)012*					0	0	0.130682	58,654.21		
(1M)133	6750	4000			10750	0.016635	0.016635	7,466.344	0.373	2.7
(1M)132	6300				6300	0.009749	0.026384	11,841.97	0.219	1.58
(1M)131	5850				5850	0.009053	0.035437	15,905.05	0.203	1.47
(1M)129	2700				2700	0.004178	0.039615	17,780.32	0.094	0.68
(1M)128	5175				5175	0.008008	0.047623	21,374.58	0.18	1.3
(1M)123	1800				1800	0.002785	0.050408	22,624.76	0.063	0.45
(1M)119	900				900	0.001393	0.051801	23,249.85	0.031	0.23
(1M)094	32175	3000	8000		43175	0.066811	0.118612	53,236.77	1.499	10.83
(1M)093	14400	4000			18400	0.028473	0.147085	66,016.37	0.639	4.61
(1M)092	5700	4000			9700	0.01501	0.162096	72,753.45	0.337	2.43
(1M)041	12375	6000			18375	0.028434	0.19053	85,515.69	0.638	4.61
(1M)039	4000	2000			6000	0.009285	0.199815	89,682.95	0.208	1.5
(1M)012*					0	0	0.199815	89,682.95		
(1M)012					0	0	0.330497	148,337.2		

Sanitary Sewer Municipal Inflows

Basin 1

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(1M)037	2700				2700	0.004178	0.334676	150.2124	0.094	0.68
(1M)035	2100				2100	0.00325	0.337925	151.671	0.073	0.53
(1M)281*					0	0	0.337925	151.671		
(1M)281					0	0	1.808509	811.7132		
(1M)278	9000				9000	0.013927	1.822436	817.9641	0.313	2.26
(1M)003	9000	1255	1200		11455	0.017726	1.840162	825.92	0.398	2.87
(1G)012	2700		1600		4300	0.006654	1.846816	828.9066	0.149	1.08
(1G)010	2025	170	800		2995	0.004635	1.851451	830.9867	0.104	0.75
(1G)009E*					0	0	1.851451	830.9867		
(1G)047	58500	28000			86500	0.133855	0.133855	60.07803	3.004	21.69
(1G)045		12000			12000	0.018569	0.152424	68.41255	0.417	3.01
(1G)020	73350	3500	6000		82850	0.128207	0.280631	125.9555	2.877	20.77
(1G)162	900	3000			3900	0.006035	0.286666	128.6642	0.135	0.98
(1G)009E*					0	0	0.286666	128.6642		
(1G)009E					0	0	2.138117	959.651		
(1G)009C			2400		2400	0.003714	2.141831	961.3179	0.083	0.6
(1G)009B*					0	0	2.141831	961.3179		
(1G)018	19000	6000	6000		31000	0.047971	0.047971	21.53085	1.077	7.77
(1G)016	1800	11000			12800	0.019807	0.067778	30.42101	0.445	3.21
(1G)014		1500			1500	0.002321	0.0701	31.46283	0.052	0.38
(1G)009B*					0	0	0.0701	31.46283		

*Note Peak is 1/3 of average

gpm to cfs
448.83

% Base Flow
5%

% Dry Flow
38%

Dry Multiplier
33%

Sanitary Sewer Municipal Inflows

Basin 1

Man Hole	Some Average Values				Recreation	Industrial	Commercial	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
	Housing	Group Living (per person)	Housing (2 bedroom)	Housing (Multiple)									
(1G)009B		100	225	300			0	0	2.21193	0	992.7807		
(1G)009A		100	225	300			3500	0.005416	2.217346	995.2116	0.122	0.88	
(1G)008C		100	225	300			4000	0.00619	2.223536	997.9898	0.139	1	
(1G)008A	675	4000	4000	1000			675	0.001045	2.224581	998.4586	0.023	0.17	
(1G)005		500	500	500	3600		3600	0.005571	2.230152	1000.959	0.125	0.9	
(1G)003	201600	85	4000	400	98560		310960	0.481196	2.711348	1216.934	10.799	77.97	
(1G)002	6840	4000	400	400			12740	0.019715	2.731062	1225.783	0.442	3.19	
(1G)001		400	400	100	1600		1600	0.002476	2.733538	1226.894	0.056	0.4	
(1F)017*		100	100	100			0	0	2.733538	1226.894			
(1F)030		100	100	100			9250	0.014314	0.014314	6.424529	0.321	2.32	
(1F)028		100	100	100			1700	0.002631	0.016945	7.605253	0.059	0.43	
(1F)027		100	100	100			1700	0.002631	0.019575	8.785977	0.059	0.43	
(1F)026A		100	100	100			4250	0.006577	0.026152	11.73779	0.148	1.07	
(1F)025		100	100	100			2125	0.003288	0.02944	13.21369	0.074	0.53	
(1F)023*		100	100	100			0	0	0.02944	13.21369			
(1H)045	28800	100	100	100			46650	0.072189	0.072189	32.40046	1.62	11.7	
(1H)044		100	100	100			1700	0.002631	0.074819	33.58119	0.059	0.43	
(1H)043		100	100	100			5950	0.009207	0.084027	37.71372	0.207	1.49	
(1H)038		100	100	100			5100	0.007892	0.091919	41.25589	0.177	1.28	
(1H)001		100	100	100	8000		8000	0.01238	0.104298	46.81224	0.278	2.01	
(1F)023*		100	100	100			0	0	0.104298	46.81224			

*Note Peak is 1/3 of average

gpm to cfs
448.83

% Base Flow
5%

% Dry Flow
38%

Dry Multiplier
33%

Sanitary Sewer Municipal Inflows

Basin 1

Man Hole	Some Average Values				Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
	Housing	Commercial	Industrial	Recreation						
(1F)023					0	0	0.133739	60.02593		
(1F)021		1700	12000		13700	0.0212	0.154939	69.54118	0.476	3.43
(1F)018		850			850	0.001315	0.156254	70.13154	0.03	0.21
(1F)017G		1020			1020	0.001578	0.157833	70.83998	0.035	0.26
(1F)017F*					0	0	0.157833	70.83998		
(1F)017F					0	0	2.891371	1297.734		
(1F)017C	5400	2550			7950	0.012302	2.903673	1303.256	0.276	1.99
(1F)017A	10237.5	2540			12777.5	0.019773	2.923446	1312.13	0.444	3.2
(1J)014*					0	0	2.923446	1312.13		
(1K)011	160200	2000			162200	0.250997	0.250997	112.655	5.633	40.67
(1K)010	3600				3600	0.005571	0.256568	115.1553	0.125	0.9
(1K)009	5400				5400	0.008356	0.264924	118.9059	0.188	1.35
(1K)008A	8100				8100	0.012534	0.277458	124.5317	0.281	2.03
(1K)008	2475				2475	0.00383	0.281288	126.2507	0.086	0.62
(1K)007	1350				1350	0.002089	0.283377	127.1883	0.047	0.34
(1K)006	3600				3600	0.005571	0.288948	129.6887	0.125	0.9
(1K)005	8700	850		500	10050	0.015552	0.3045	136.6688	0.349	2.52
(1K)004	8400	8400			16800	0.025997	0.330497	148.3372	0.583	4.21
(1K)002A	7200				7200	0.011142	0.341639	153.3379	0.25	1.81
(1K)001	2400				2400	0.003714	0.345353	155.0048	0.083	0.6
(1J)053	3900	4050			7950	0.012302	0.357655	160.5264	0.276	1.99
(1J)050*					0	0	0.357655	160.5264		
					0	0	0	0		

*Note Peak is 1/3 of average

Dry Multiplier
33%

gpm to cfs
448.83

% Base Flow
5%

% Dry Flow
38%

Sanitary Sewer Municipal Inflows

Basin 1

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(1H)011	54900	20875			75775	0.117258	0.117258	52.62904	2.631	19
(1H)009		1000			1000	0.001547	0.118806	53.32359	0.035	0.25
(1J)050*					0	0	0.118806	53.32359		
(1J)050	36000	43875	8000	200	88075	0.136292	0.612753	275.0219	3.059	22.08
(1J)046	44550	500			45050	0.069713	0.682466	306.3111	1.564	11.3
(1J)044	154800	20000			174800	0.270495	0.952961	427.7173	6.07	43.83
(1J)014*					0	0	0.952961	427.7173		
(1J)014					0	0	3.876406	1739.847		
(1J)011	13500	500			14000	0.021664	3.898071	1749.571	0.486	3.51
(1J)006	15000	6000		400	21400	0.033116	3.931186	1764.434	0.743	5.37
(1J)003	600				600	0.000928	3.932115	1764.851	0.021	0.15
(1J)002*					0	0	3.932115	1764.851		
(1F)016		17250			17250	0.026694	0.026694	11.98088	0.599	4.33
(1F)013		11000		100	11100	0.017177	0.04387	19.69031	0.385	2.78
(1F)011	1800	500			2300	0.003559	0.047429	21.28776	0.08	0.58
(1F)010	2250				2250	0.003482	0.050911	22.85049	0.078	0.56
(1F)009	1800				1800	0.002785	0.053697	24.10066	0.063	0.45
(1F)008	1350				1350	0.002089	0.055786	25.0383	0.047	0.34
(1F)006	13500	500	800		14800	0.022902	0.078688	35.31754	0.514	3.71
(1F)004	3375				3375	0.005223	0.083911	37.66163	0.117	0.85
(1F)003	5625				5625	0.008704	0.092615	41.56844	0.195	1.41
(1F)001	13800				13800	0.021355	0.11397	51.15314	0.479	3.46

*Note Peak is 1/3 of average

gpm to cfs
448.83

% Base Flow
5%

% Dry Flow
38%

Dry Multiplier
33%

Sanitary Sewer Municipal Inflows

Basin 1

Some Average Values
 Group Living (per person) 100
 Housing (2 bedroom) 225
 Housing (Multiple) 300
 Commercial (Laundry) 4000
 Commercial (Food) 1000
 Commercial (Stores) 500
 Commercial (Office) 85
 Industrial (High) 4000
 Industrial (Low) 400
 Recreation 100

gpm to cfs
 448.83

% Base Flow
 5%

% Dry Flow
 38%

Dry Multiplier
 33%

*Note Peak is 1/3 of average

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(1J)002*					0	0	0.11397	51.15314		
(1J)002			4275		0	0	4.046085	1816.004		
(1A)042					4275	0.006615	4.0527	1818.973	0.148	1.07
(1A)041*					0	0	4.0527	1818.973		
(1E)009	21037.5				21037.5	0.032555	0.032555	14.61146	0.731	5.27
(1E)005	1800				1800	0.002785	0.03534	15.86164	0.063	0.45
(1E)001					0	0	0.03534	15.86164		
(1A)041*					0	0	0.03534	15.86164		
(1A)041					0	0	4.08804	1834.835		
(1A)034					0	0	4.08804	1834.835		
(1A)027	28800				28800	0.044567	4.132607	1854.838	1	7.22
(1A)026	7200				7200	0.011142	4.143748	1859.839	0.25	1.81
(1A)024A*					0	0	4.143748	1859.839		
(1A)024A					0	0	5.541525	2487.202		
(1A)023				100	100	0.000155	5.541679	2487.272	0.003	0.03
(1A)017*					0	0	5.541679	2487.272		
(1A)017					0	0	5.706928	2561.441		
(1A)015		5000			5000	0.007737	5.714665	2564.913	0.174	1.25
(1A)014	3000				3000	0.004642	5.719308	2566.997	0.104	0.75
(1A)007	1200				1200	0.001857	5.721165	2567.83	0.042	0.3

Sanitary Sewer Municipal Inflows

Basin 1

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(1A)004	2250	1000	800		4050	0.006267	5.727432	2570.643	0.141	1.02
(1A)001		1500			1500	0.002321	5.729753	2571.685	0.052	0.38
(1A)000					0	0	5.729753	2571.685		
End										

gpm to cfs
448.83

% Base Flow
5%

% Dry Flow
38%

Dry Multiplier
33%

*Note Peak is 1/3 of average

BASIN 2

Sanitary Sewer Municipal Inflows

Basin 2

gpm to cfs
448.83

% Base Flow
5%

% Dry Flow
38%

PEAK DRY
GPM

PEAK DRY
GPM

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(2)029	19500				19500	0.030175	0.030175	13.5436	0.677	4.89
(2)028	37500	6000		300	43800	0.067778	0.097954	43.96461	1.521	10.98
(2)025A	18000				18000	0.027854	0.125808	56.4664	0.625	4.51
(2)021B	24000	2000			26000	0.040234	0.166042	74.52453	0.903	6.52
(2)020	5400				5400	0.008356	0.174398	78.27507	0.188	1.35
(2)017A	4800				4800	0.007428	0.181826	81.60888	0.167	1.2
(2)014	19200				19200	0.029711	0.211537	94.94412	0.667	4.81
(2)011	5100				5100	0.007892	0.219429	98.48629	0.177	1.28
(2)009	2700				2700	0.004178	0.223607	100.3616	0.094	0.68
(2)008	20400				20400	0.031568	0.255175	114.5302	0.708	5.12
(2)005*					0	0	0.255175	114.5302		
(2)059	36000	11250	5600		52850	0.081783	0.081783	36.70663	1.835	13.25
(2)055	20000	8000			28000	0.043329	0.125112	56.15385	0.972	7.02
(2)051	13200	1000		3200	17400	0.026926	0.152037	68.23891	0.604	4.36
(2)049	9000	10000			19000	0.029402	0.181439	81.43524	0.66	4.76
(2)005*					0	0	0.181439	81.43524		
(2)005	3900				0	0	0.436614	195.9655		
(2)003	9900				3900	0.006035	0.442649	198.6742	0.135	0.98
(2)002	24300	500			10400	0.016094	0.458743	205.8975	0.361	2.61
(2)001	9000	5400			29700	0.045959	0.504702	226.5254	1.031	7.45
(2H)002		1500			10500	0.016248	0.52095	233.8181	0.365	2.63
(2H)021*					0	0	0.52095	233.8181		

Sanitary Sewer Municipal Inflows

Basin 2

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow	Some Average Values	
											gpd	gpm to cfs
(2H)289	39000				39000	0.060351	0.060351	27.0872	1.354	9.78	100	448.83
(2H)286	10800				10800	0.016713	0.077063	34.58827	0.375	2.71	225	
(2H)285	6300				6300	0.009749	0.086812	38.9639	0.219	1.58	300	
(2H)053*	0				0	0	0.086812	38.9639			4000	
(2H)058	2400		12000		14400	0.022283	0.022283	10.00143	0.5	3.61	1000	
(2H)057	3600				3600	0.005571	0.027854	12.50179	0.125	0.9	500	
(2H)054A	3000				3000	0.004642	0.032497	14.58542	0.104	0.75	85	
(2H)053*	0				0	0	0.032497	14.58542			4000	
(2H)053	4500				0	0	0.119309	53.54932			400	
(2H)049					4500	0.006964	0.067314	30.21265	0.156	1.13	2500	
(2H)036		2500			2500	0.003869	0.071183	31.94901	0.087	0.63		
(2H)032	6000				6000	0.009285	0.080468	36.11627	0.208	1.5		
(2H)030	9000				9000	0.013927	0.094395	42.36716	0.313	2.26		
(2H)026	1500				1500	0.002321	0.096716	43.40898	0.052	0.38		
(2H)021*					0	0	0.096716	43.40898				
(2H)021	900				900	0.001393	0.619059	277.8522	0.031	0.23		
(2H)020	900				900	0.001393	0.620452	278.4773	0.031	0.23		
(2H)019	3000				3000	0.004642	0.625094	280.5609	0.104	0.75		
(2H)017A	4800				4800	0.007428	0.632522	283.8947	0.167	1.2		
(2H)016	2400				2400	0.003714	0.636236	285.5616	0.083	0.6		
(2H)014	2100				2100	0.00325	0.639485	287.0202	0.073	0.53		
(2H)013	4800	2000			6800	0.010523	0.650008	291.7431	0.236	1.71		

gpm to cfs
448.83

% Base Flow
5%

% Dry Flow
38%

Sanitary Sewer Municipal Inflows

Basin 2

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow	Some Average Values	
											gpd	gpm to cfs
(2H)012	54600				54600	0.084491	0.734499	329.6651	1.896	13.69	448.83	gpm to cfs
(2H)007	14175	500			14675	0.022709	0.757208	339.8576	0.51	3.68		% Base Flow
(2J)018*					0	0	0.757208	339.8576				5%
(2K)037	18300	42500			60800	0.094085	0.094085	42.22825	2.111	15.24		% Dry Flow
(2K)033A	1500				1500	0.002321	0.096406	43.27007	0.052	0.38		38%
(2K)033	5850				5850	0.009053	0.105459	47.33315	0.203	1.47		
(2K)032	2250				2250	0.003482	0.108941	48.89587	0.078	0.56		
(2K)029	40800				40800	0.063136	0.172077	77.23325	1.417	10.23		
(2K)027	600				600	0.000928	0.173005	77.64998	0.021	0.15		
(2K)025	24825				24825	0.038416	0.211421	94.89203	0.862	6.22		
(2K)024A	19200				19200	0.029711	0.241132	108.2273	0.667	4.81		
(2K)022	2400				2400	0.003714	0.244846	109.8942	0.083	0.6		
(2K)021	2700				2700	0.004178	0.249024	111.7694	0.094	0.68		
(2K)019	8400				8400	0.012999	0.262023	117.6036	0.292	2.11		
(2K)018	1800				1800	0.002785	0.264808	118.8538	0.063	0.45		
(2K)017	1200				1200	0.001857	0.266665	119.6872	0.042	0.3		
(2K)016	1800				1800	0.002785	0.26945	120.9374	0.063	0.45		
(2K)014	30000				30000	0.046424	0.315874	141.7737	1.042	7.52		
(2K)013	6300				6300	0.009749	0.325623	146.1493	0.219	1.58		
(2K)011	1800	2500			2500	0.003869	0.329492	147.8857	0.087	0.63		
(2K)003	1800				1800	0.002785	0.332277	149.1359	0.063	0.45		
(2K)002	30000				30000	0.046424	0.378701	169.9722	1.042	7.52		
(2K)001	42000				42000	0.064993	0.443694	199.143	1.459	10.53		
(2J)018*					0	0	0.443694	199.143				

Sanitary Sewer Municipal Inflows

Basin 2

Some Average Values
 Group Living (per person) 100
 Housing (2 bedroom) 225
 Housing (Multiple) 300
 Commercial (Laundry) 4000
 Commercial (Food) 1000
 Commercial (Stores) 500
 Commercial (Office) 85
 Industrial (High) 4000
 Industrial (Low) 400
 Recreation 100

gpm to cfs
 448.83

% Base Flow
 5%

% Dry Flow
 38%

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(2J)018	22500	5000			0	0	1.200901	539.0006	0.955	6.9
(2J)011					27500	0.042555	1.243456	558.1005		
(2J)010*					0	0	1.243456	558.1005		
(2J)026	73200	4500			77700	0.120237	0.120237	53.96604	2.698	19.48
(2J)025*					0	0	0.120237	53.96604		
(2J)060	50400				50400	0.077992	0.077992	35.005	1.75	12.64
(2J)056	8400				8400	0.012999	0.09099	40.83917	0.292	2.11
(2J)054	8100				8100	0.012534	0.103525	46.46497	0.281	2.03
(2J)053	8100	3000			11100	0.017177	0.120701	54.1744	0.385	2.78
(2J)050	4200				4200	0.006499	0.127201	57.09149	0.146	1.05
(2J)048	11100				11100	0.017177	0.144377	64.80092	0.385	2.78
(2J)047	7200	12500			19700	0.030485	0.174862	78.48343	0.684	4.94
(2J)046	4500				4500	0.006964	0.181826	81.60888	0.156	1.13
(2J)045	3300				3300	0.005107	0.186932	83.90087	0.115	0.83
(2J)044	5400	500			5900	0.00913	0.196062	87.99868	0.205	1.48
(2J)043	6000				6000	0.009285	0.205347	92.16594	0.208	1.5
(2J)040	4800	500			5300	0.008202	0.213549	95.84702	0.184	1.33
(2J)025*					0	0	0.213549	95.84702		
(2J)025					0	0	0.333786	149.8131		
(2J)021	4765				4765	0.007374	0.341159	153.1226	0.165	1.19
(2J)020	21415				21415	0.033139	0.374298	167.9962	0.744	5.37

Sanitary Sewer Municipal Inflows

Basin 2

Some Average Values
 Group Living (per person) 100
 Housing (2 bedroom) 225
 Housing (Multiple) 300
 Commercial (Laundry) 4000
 Commercial (Food) 1000
 Commercial (Stores) 500
 Commercial (Office) 85
 Industrial (High) 4000
 Industrial (Low) 400
 Recreation 100

gpm to cfs
 448.83

% Base Flow
 5%

% Dry Flow
 38%

gpd
 100
 225
 300
 4000
 1000
 500
 85
 4000
 400
 100

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(2J)010*					0	0	0.374298	167.9962		
(2J)010					0	0	1.617755	726.0968		
(2F)009*					0	0	1.617755	726.0968		
(2G)359	71700	15000			86700	0.134164	0.134164	60.21693	3.011	21.74
(2G)025*					0	0	0.134164	60.21693		
(2G)026	56100				56100	0.086812	0.086812	38.9639	1.948	14.07
(2G)025*					0	0	0.086812	38.9639		
(2G)025					0	0	0.220976	99.18083		
(2G)023	4500				4500	0.006964	0.22794	102.3063	0.156	1.13
(2G)022	4800				4800	0.007428	0.235368	105.6401	0.167	1.2
(2G)021	3000				3000	0.004642	0.24001	107.7237	0.104	0.75
(2G)020	3000				3000	0.004642	0.244652	109.8074	0.104	0.75
(2G)019	32400				32400	0.050138	0.29479	132.3106	1.125	8.12
(2G)018	21600				21600	0.033425	0.328215	147.3127	0.75	5.42
(2G)016	84000				84000	0.129986	0.458201	205.6544	2.917	21.06
(2G)015	7800				7800	0.01207	0.470271	211.0718	0.271	1.96
(2G)013A		22000			22000	0.034044	0.504315	226.3518	0.764	5.52
(2G)011		7500			7500	0.011606	0.515921	231.5609	0.26	1.88
(2G)009		3000			3000	0.004642	0.520563	233.6445	0.104	0.75
(2G)007		36500			36500	0.056482	0.577045	258.9953	1.268	9.15
(2G)006		11550			11550	0.017873	0.594919	267.0173	0.401	2.9

Sanitary Sewer Municipal Inflows

Basin 2

Some Average Values gpd
 Group Living (per person) 100
 Housing (2 bedroom) 225
 Housing (Multiple) 300
 Commercial (Laundry) 4000
 Commercial (Food) 1000
 Commercial (Stores) 500
 Commercial (Office) 85
 Industrial (High) 4000
 Industrial (Low) 400
 Recreation 100

gpm to cfs
 448.83

% Base Flow
 5%

% Dry Flow
 38%

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(2G)004		43200			43200	0.06685	0.661769	297.0216	1.5	10.83
(2G)002A*					0	0	0.661769	297.0216		
(2G)045	22500	171907			194407	0.300836	0.300836	135.0241	6.751	48.74
(2G)002A*					0	0	0.300836	135.0241		
(2G)002A					0	0	0.962604	432.0457		
(2G)002	32500				32500	0.050292	1.012897	454.6184	1.129	8.15
(2F)022*					0	0	1.012897	454.6184		
(2F)033	27000	40500			67500	0.104453	0.104453	46.8817	2.344	16.92
(2F)023	9300				9300	0.014391	0.118844	53.34095	0.323	2.33
(2F)022*					0	0	0.118844	53.34095		
(2F)022					0	0	1.131741	507.9594		
(2F)017	12300				12300	0.019034	1.150775	516.5022	0.427	3.08
(2F)009*					0	0	1.150775	516.5022		
(2F)009					0	0	2.768529	1242.599		
(2F)005	114225				114225	0.176758	2.945287	1321.933	3.967	28.64
(2F)004	39000				39000	0.060351	3.005638	1349.02	1.354	9.78
(2E)043	103500				103500	0.160161	3.165799	1420.906	3.594	25.95
(2E)003	63150	8000			71150	0.110101	3.275901	1470.323	2.471	17.84
(2E)002					0	0	3.275901	1470.323		
(2A)063*					0	0	3.275901	1470.323		

Sanitary Sewer Municipal Inflows

Basin 2

Some Average Values
 Group Living (per person) 100
 Housing (2 bedroom) 225
 Housing (Multiple) 300
 Commercial (Laundry) 4000
 Commercial (Food) 1000
 Commercial (Stores) 500
 Commercial (Office) 85
 Industrial (High) 4000
 Industrial (Low) 400
 Recreation 100

gpm to cfs
 448.83
 % Base Flow
 5%
 % Dry Flow
 38%

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(2D)013	119325				119325	0.18465	0.18465	82.87642	4.144	29.92
(2D)012				200	200	0.000309	0.184959	83.01533	0.007	0.05
(2D)011	4275				4275	0.006615	0.191575	85.9845	0.148	1.07
(2D)009		5200			5200	0.008047	0.199622	89.59613	0.181	1.3
(2D)006			16500		16500	0.025533	0.225155	101.0561	0.573	4.14
(2D)003*					0	0	0.225155	101.0561		
(2D)046A	25500	7475	121200		154175	0.238579	0.238579	107.0813	5.354	38.66
(2D)046		2000			2000	0.003095	0.241674	108.4704	0.069	0.5
(2D)045		4000			4000	0.00619	0.247863	111.2485	0.139	1
(2D)244*					0	0	0.247863	111.2485		
(2D)267	70000	52500	54000		176500	0.273126	0.273126	122.587	6.129	44.25
(2D)263	9000	5000			14000	0.021664	0.29479	132.3106	0.486	3.51
(2D)244*					0	0	0.273126	122.587		
(2D)244					0	0	0.520989	233.8355		
(2A)063*					0	0	0.520989	233.8355		
(2A)063					0	0	3.79689	1704.158		
(2A)043					0	0	3.79689	1704.158		
(2A)034		800			800	0.001238	3.798128	1704.714	0.028	0.2
(2A)020	129725				129725	0.200743	3.998871	1794.813	4.505	32.53
(2A)015	6750				6750	0.010445	4.009316	1799.501	0.234	1.69

Sanitary Sewer Municipal Inflows

Basin 2

gpm to cfs
448.83

% Base Flow
5%

% Dry Flow
38%

Some Average Values
 Group Living (per person) 100
 Housing (2 bedroom) 225
 Housing (Multiple) 300
 Commercial (Laundry) 4000
 Commercial (Food) 1000
 Commercial (Stores) 500
 Commercial (Office) 85
 Industrial (High) 4000
 Industrial (Low) 400
 Recreation 100

Man Hole	Housing	Commercial	Industrial	Recreation	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
(2A)001*					0	0	4.009316	1799.501		
(1P)024			40000		40000	0.061898	0.061898	27.78175	1.389	10.03
(1P)017*					0	0	0.061898	27.78175		
(1P)018			560000		560000	0.866574	0.866574	388.9444	19.447	140.41
(1P)017*					0	0	0.866574	388.9444		
(1P)073	850		4000		4850	0.007505	0.007505	3.368537	0.168	1.22
(1P)017*					0	0	0.007505	3.368537		
(1P)079			4425		4425	0.006847	0.006847	3.073356	0.154	1.11
(1P)017*					0	0	0.006847	3.073356		
(1P)017	1020	6000			7020	0.010863	0.953688	428.0438	0.244	1.76
(1P)011		4000			4000	0.00619	0.959878	430.822	0.139	1
(1P)008		320000			320000	0.495185	1.455063	653.0759	11.113	80.23
(1P)003*					0	0	1.455063	653.0759		
(1P)065		8000			8000	0.01238	0.01238	5.556349	0.278	2.01
(1P)043		40000			40000	0.061898	0.074278	33.3381	1.389	10.03
(1P)003*					0	0	0.074278	33.3381		
(1P)003					0	0	1.529341	686.414		
(2A)001*					0	0	1.529341	686.414		

Sanitary Sewer Municipal Inflows

Basin 2

Some Average Values	gpd	gpm to cfs	Total	Sum cfs	Total cfs	Total gpm	Base Flow	Dry Flow
Group Living (per person)	100	448.83						
Housing (2 bedroom)	225							
Housing (Multiple)	300							
Commercial (Laundry)	4000	% Base Flow						
Commercial (Food)	1000	5%						
Commercial (Stores)	500	% Dry Flow						
Commercial (Office)	85	38%						
Industrial (High)	4000							
Industrial (Low)	400							
Recreation	100							
Man Hole								
(2A)001			0	0	5.538657	0		
						2485.915		

TM 2-3

SUB-BASIN CALCULATIONS

SCS CN CALCULATIONS

Sanitary Sewer Basin CN Values

CN Values - Existing Conditions

- A Impervious Areas (Soil A,B,C,D) = CN Cond Dry
- B Commercial and Business (Soil D) = 98 0.00 7.84
- C Commercial and Business (Soil C) = 95 0.01 7.54
- D Commercial and Business (Soil B) = 94 0.01 7.43
- E Commercial and Business (Soil A) = 92 0.02 7.23
- F Residential 1/4 Acre Lots (Soil D) = 89 0.03 6.92
- G Residential Estate (Soil D) = 87 0.04 6.72
- H Small Grain Contoured Good (Soil D) = 85 0.06 6.52
- I Herbaceous Open Space / Pasture - Fair (Soil D) = 84 0.06 6.41
- J Residential 1/4 Acre Lots (Soil C) = 83 0.07 6.31
- K Residential Estate (Soil C) = 83 0.07 6.31
- L Pasture - Fair (Soil C) = 81 0.09 6.11
- M Residential (Soil B) = 76 0.14 5.6
- N Residential Estate (Soil B) = 75 0.15 5.5
- O Pasture - Fair (Soil B) = 70 0.21 4.99
- P Residential 1/4 Acre Lots (Soil A) = 69 0.23 4.88
- Q Small Grain St Good (Soil A) = 61 0.34 4.07
- R Residential Estate (Soil A) = 60 0.35 3.97
- S Residential 1/2 Acre (Soil A) = 57 0.39 3.66
- T Pasture - Open Space - Fair (Soil A) = 54 0.44 3.35

Basin	Area	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	Imp	Weighted Average	Comp
	acres	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	%	Acre*CN	CN
Basin 1																								
Basin1A1	131.1				31.1											100						10%	9761	74.5
Basin1A2	128.8			10	105					4						9.75						85%	11605	90.1
Basin1A3	94.48				7									60		27.5						75%	7040	74.5
Basin1B1	38														31	7						40%	2653	69.8
Basin1B2	51.57				36.6											15						65%	4399	85.3
Basin1B3	134.3				30						90					14						65%	11196	83.4
Basin1B4	66.24						10				40					4.2						65%	5620	84.8
Basin1C1	83.53			5	5		35			5	30					3.53						60%	7129	85.3
Basin1C1A	66.82			15			41.8			10												60%	5893	88.2
Basin1C1B	69.72						60			9.72												55%	6027	86.4
Basin1C1C	89.15						70			19.2												50%	7679	86.1
Basin1C1D	76.49						55			21.5												35%	6569	85.9
Basin1C2	59.5						50			9.5												65%	5139	86.4
Basin1C3	67			7			50			10												60%	5845	87.2
Basin1C4	62.19						55			7.19												60%	5382	86.5
Basin1D1	56.18			15	5					5				10	15	5.18						35%	4457	79.3
Basin1D2	50.46				2		10			2				30		6.46						55%	3916	77.6
Basin1D3	108.2			20			80			8.2												60%	9541	88.2

Sanitary Sewer Basin CN Values

CN Values - Existing Conditions

- A Impervious Areas (Soil A,B,C,D) = CN Cond Dry
- B Commercial and Business (Soil D) = 98 0.00 7.84
- C Commercial and Business (Soil C) = 95 0.01 7.54
- D Commercial and Business (Soil B) = 94 0.01 7.43
- E Commercial and Business (Soil A) = 92 0.02 7.23
- F Residential 1/4 Acre Lots (Soil D) = 89 0.03 6.92
- G Residential Estate (Soil D) = 87 0.04 6.72
- H Small Grain Contoured Good (Soil D) = 85 0.06 6.52
- I Herbaceous Open Space / Pasture - Fair (Soil D) = 84 0.06 6.41
- J Residential 1/4 Acre Lots (Soil C) = 83 0.07 6.31
- K Residential Estate (Soil C) = 83 0.07 6.31
- L Pasture - Fair (Soil C) = 81 0.09 6.11
- M Residential (Soil B) = 76 0.14 5.6
- N Residential Estate (Soil B) = 75 0.15 5.5
- O Pasture - Fair (Soil B) = 70 0.21 4.99
- P Residential 1/4 Acre Lots (Soil A) = 69 0.23 4.88
- Q Small Grain St Good (Soil A) = 61 0.34 4.07
- R Residential Estate (Soil A) = 60 0.35 3.97
- S Residential 1/2 Acre (Soil A) = 57 0.39 3.66
- T Pasture - Open Space - Fair (Soil A) = 54 0.44 3.35

Basin	Area acres	A acre	B acre	C acre	D acre	E acre	F acre	G acre	H acre	I acre	J acre	K acre	L acre	M acre	N acre	O acre	P acre	Q acre	R acre	S acre	T acre	Imp %	Weighted Average Acre*CN	Comp CN	
Basin1D4	95.17						82.2			13													50%	8228	86.5
Basin1E1	44.37												34.4		10								10%	3312	74.6
Basin1E2	55.58														7.58	48							55%	3843	69.1
Basin1F1	193.5				35									129		30							40%	14928	77.1
Basin1F2	52.03				20									10		22							20%	4110	79.0
Basin1F3	90.99				35									40		16							50%	7323	80.5
Basin1F4	71.78				20									46.8		5							60%	5694	79.3
Basin1F5	71.35				65									9		6.35							85%	6418	90.0
Basin1G1	46.72				35									120		2.72							80%	4083	87.4
Basin1G2	179.9						50							20		9.9							60%	14033	78.0
Basin1G3	93.49		5		60									30		8.49							60%	8081	86.4
Basin1G4	143.5		40		25		40			4.5				30		4							65%	12480	87.0
Basin1G5	173.2		70				80			23.2													55%	15536	89.7
Basin1G6	73.99		5				65			3.99													55%	6461	87.3
Basin1G7	97.06		10				75			12.1													50%	8476	87.3
Basin1G8	77.69		40							37.7													35%	6929	89.2
Basin1H1	165.3		50		35		80.3																70%	14956	90.5
Basin1I1	137.9		40		20		77.9																70%	12417	90.1
Basin1J1	145.3				90									50		5.3							75%	12396	85.3

Sanitary Sewer Basin CN Values

CN Values - Existing Conditions

Basin	Area	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	Imp %	Weighted Average	Comp CN
A	Impervious Areas (Soil A,B,C,D) =																							
B	Commercial and Business (Soil D) =																							
C	Commercial and Business (Soil C) =																							
D	Commercial and Business (Soil B) =																							
E	Commercial and Business (Soil A) =																							
F	Residential 1/4 Acre Lots (Soil D) =																							
G	Residential Estate (Soil D) =																							
H	Small Grain Contoured Good (Soil D) =																							
I	Herbaceous Open Space / Pasture - Fair (Soil D) =																							
J	Residential 1/4 Acre Lots (Soil C) =																							
K	Residential Estate (Soil C) =																							
L	Pasture - Fair (Soil C) =																							
M	Residential (Soil B) =																							
N	Residential Estate (Soil B) =																							
O	Pasture - Fair (Soil B) =																							
P	Residential 1/4 Acre Lots (Soil A) =																							
Q	Small Grain St Good (Soil A) =																							
R	Residential Estate (Soil A) =																							
S	Residential 1/2 Acre (Soil A) =																							
T	Pasture - Open Space - Fair (Soil A) =																							

Basin	Area	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	Imp %	Weighted Average	Comp CN	
Basin1J2	42.03				22									15		5.03							65%	3496	83.2
Basin1K1	70.39				5										60	5.39							60%	5032	71.5
Basin1K2	70.33														50	20.3							40%	4903	69.7
Basin1K3	170.8				15		63.8							40		30							50%	14091	82.5
Basin1K4	84.05				10										65	9.05							60%	6094	72.5
Basin1M1	59.94					15	23.9																30%	5168	86.2
Basin1M2	58.49					23.5	20																50%	5217	89.2
Basin1M3	89.58					25	54.6																55%	7953	88.8
Basin1M4	85.1					10	65																55%	7443	87.5
Basin1M5	172.6					62.6																	30%	15077	87.4
Basin1M6	61.75					31.8	30																70%	5626	91.1
Basin1N1	88.52					18.5	65																50%	7829	88.4
Basin1N2	72.03					25	40																60%	6438	89.4
Basin1N3	55.41						10																35%	4909	88.6
Basin1N4	155.9																						20%	12668	81.3
Basin1N5	25.71					3	20																50%	2250	87.5
Basin1N6	185					40	5																55%	15710	84.9
Basin1N7	219.4					85																	20%	19230	87.7
Basin1N8	26.64					5	15																60%	2331	87.5

Sanitary Sewer Basin CN Values

CN Values - Existing Conditions

- A Impervious Areas (Soil A,B,C,D) = CN Cond Lry = 98 0.00 7.84
- B Commercial and Business (Soil D) = 95 0.01 7.54
- C Commercial and Business (Soil C) = 94 0.01 7.43
- D Commercial and Business (Soil B) = 92 0.02 7.23
- E Commercial and Business (Soil A) = 89 0.03 6.92
- F Residential 1/4 Acre Lots (Soil D) = 87 0.04 6.72
- G Residential Estate (Soil D) = 85 0.06 6.52
- H Small Grain Contoured Good (Soil D) = 84 0.06 6.41
- I Herbaceous Open Space / Pasture - Fair (Soil D) = 83 0.07 6.31
- J Residential 1/4 Acre Lots (Soil C) = 83 0.07 6.31
- K Residential Estate (Soil C) = 81 0.09 6.11
- L Pasture - Fair (Soil C) = 76 0.14 5.6
- M Residential (Soil B) = 75 0.15 5.5
- N Residential Estate (Soil B) = 70 0.21 4.99
- O Pasture - Fair (Soil B) = 69 0.23 4.88
- P Residential 1/4 Acre Lots (Soil A) = 61 0.34 4.07
- Q Small Grain St Good (Soil A) = 60 0.35 3.97
- R Residential Estate (Soil A) = 57 0.39 3.66
- S Residential 1/2 Acre (Soil A) = 54 0.44 3.35
- T Pasture - Open Space - Fair (Soil A) = 49 0.52 2.84

Basin	Area	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	Imp	Weighted Average	Comp CN
	acres	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	%	Acre *CN	CN
Basin1O1	249.7		39.8	17	10		123			12.5	7		24		16.5					5	25	55%	21589	86.5
Basin1O2	79.92		35			35													90	6.7	6.7	20%	7935	99.3
Basin1O3	111.7					15																60%	6793	60.8
Basin1O4	174					20				20		14							65	38	17	35%	11164	64.1
Basin1O5	75.94		45	7						11.3			6.3								10	55%	6840	90.1
Basin1P1	291.6		115							177												20%	25583	87.7
Basin1P2	76.39		35							21.4						20						25%	6480	84.8
Basin1P3	180.6		35							100						45.6						20%	14771	81.8
Basin 2																								
Basin2A1	55.28						3						2			50.3						7%	3880	70.2
Basin2A2	160.4									35.4						125						2%	11564	72.1
Basin2B1	63.53						63.5															55%	5527	87.0
Basin2B2	65.39						65.4															60%	5689	87.0
Basin2B3	119.5						120															60%	10397	87.0
Basin2C1	72.7													65		7.7						45%	5406	74.4
Basin2C2	32.43													20		12.4						35%	2358	72.7
Basin2C3	114.7					15								82		17.7						55%	8751	76.3
Basin2D1	34.78												34.8									1%	2643	76.0
Basin2D2	315.1		7					75		17.1					2.16							60%	23579	74.8

Sanitary Sewer Basin CN Values

CN Values - Existing Conditions

- A Impervious Areas (Soil A,B,C,D) = 98
- B Commercial and Business (Soil D) = 95
- C Commercial and Business (Soil C) = 94
- D Commercial and Business (Soil B) = 92
- E Commercial and Business (Soil A) = 89
- F Residential 1/4 Acre Lots (Soil D) = 87
- G Residential Estate (Soil D) = 85
- H Small Grain Contoured Good (Soil D) = 84
- I Herbaceous Open Space / Pasture - Fair (Soil D) = 83
- J Residential 1/4 Acre Lots (Soil C) = 83
- K Residential Estate (Soil C) = 81
- L Pasture - Fair (Soil C) = 76
- M Residential (Soil B) = 75
- N Residential Estate (Soil B) = 70
- O Pasture - Fair (Soil B) = 69
- P Residential 1/4 Acre Lots (Soil A) = 61
- Q Small Grain St Good (Soil A) = 60
- R Residential Estate (Soil A) = 57
- S Residential 1/2 Acre (Soil A) = 54
- T Pasture - Open Space - Fair (Soil A) = 49

- CN Cond Dry 98
- 0.00 7.84
- 0.01 7.54
- 0.01 7.43
- 0.02 7.23
- 0.03 6.92
- 0.04 6.72
- 0.06 6.52
- 0.06 6.41
- 0.07 6.31
- 0.07 6.31
- 0.09 6.11
- 0.14 5.6
- 0.15 5.5
- 0.21 4.99
- 0.23 4.88
- 0.34 4.07
- 0.35 3.97
- 0.39 3.66
- 0.44 3.35
- 0.52 2.84

Basin	Area	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	Imp	Weighted Average	Comp CN
	acres	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	%	Acre*CN	CN
Basin2D3	257.9											20	238									2%	19700	76.4
Basin2D4	75.74	4	42							2.74			27									65%	6607	87.2
Basin2D5	152.2	17	41							25.2			69									35%	12805	84.1
Basin2E1	12.18				2											10.2						10%	886	72.8
Basin2E2	105.0				21							35.9		62	18	4.01						65%	8119	77.3
Basin2F1	42.9															7						40%	3391	79.0
Basin2F2	121.9										110											65%	10250	84.1
Basin2F3	60.13									1.13		44	10									40%	4888	81.3
Basin2F4	21.09												6.09									35%	1873	88.8
Basin2F5	81									19		55	7									45%	6564	81.0
Basin2G1	63.27											28										70%	5583	88.2
Basin2G2	267.5											65	42.5									70%	23580	88.2
Basin2G3	87.8																					90%	8291	94.4
Basin2G4	158.6						38				62				33.8							65%	13168	83.0
Basin2G5	83.08						52			5	21.1											60%	7164	86.2
Basin2G6	191.8											92	40		28.8	21						35%	14897	77.7
Basin2H1	36.16							29	2.16													50%	3116	86.2
Basin2H2	52.66							31	21.7													30%	4454	84.6
Basin2H3	137						45	70	22													40%	11713	85.5

Sanitary Sewer Basin CN Values

CN Values - Existing Conditions

Basin	Area	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	Imp	Weighted Average	Comp CN
Basin2H4	82.23			5				34				31				12.2						%	Acre*CN	CN
Basin2H5	166.4			12			26.4					98	30									35%	6715	81.7
Basin2H6	30.49											12				18.5						50%	13593	81.7
Basin2H7	54.59							54.6														25%	2248	73.7
Basin2H8	88.81							70											18.8			50%	4640	85.0
Basin2H9	56.11							5		15									10		26.1	10%	3519	62.7
Basin2I1	54.75				7												8	30			9.75	40%	3504	64.0
Basin2I2	64.12						28					8.12			28							55%	5054	78.8
Basin2I3	90.68							15			35			40.7								50%	6958	76.7
Basin2I4	31.78							28		3.78												45%	2694	84.8
Basin2I5	12.37																					50%	866	70.0
Basin2I6	51.47																35	16.5				40%	3586	69.7
Basin2I7	88.64							88.6														50%	7534	85.0
Basin2I8	161.3							71								84	6.3					45%	12350	76.5
Basin2I9	14.57							14.6														55%	1238	85.0
Basin2I10	59			9				50														50%	5105	86.5
Basin2I11	123.1			10				35				71	7.1									45%	10216	83.0
Basin2J1	37.17																					90%	3444	92.7
Basin2J2	79.2				25						50											65%	6790	85.7

Basin	Area	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	Imp	Weighted Average	Comp CN
Basin2H4	82.23			5				34				31				12.2						%	Acre*CN	CN
Basin2H5	166.4			12			26.4					98	30									35%	6715	81.7
Basin2H6	30.49											12				18.5						50%	13593	81.7
Basin2H7	54.59							54.6														25%	2248	73.7
Basin2H8	88.81							70											18.8			50%	4640	85.0
Basin2H9	56.11							5		15							8	30			26.1	10%	3519	62.7
Basin2I1	54.75				7																9.75	40%	3504	64.0
Basin2I2	64.12						28					8.12			28							55%	5054	78.8
Basin2I3	90.68							15			35			40.7								50%	6958	76.7
Basin2I4	31.78							28		3.78												45%	2694	84.8
Basin2I5	12.37																					50%	866	70.0
Basin2I6	51.47																35	16.5				40%	3586	69.7
Basin2I7	88.64							88.6														50%	7534	85.0
Basin2I8	161.3							71								84	6.3					45%	12350	76.5
Basin2I9	14.57							14.6														55%	1238	85.0
Basin2I10	59			9				50														50%	5105	86.5
Basin2I11	123.1			10				35				71	7.1									45%	10216	83.0
Basin2J1	37.17																					90%	3444	92.7
Basin2J2	79.2				25						50											65%	6790	85.7

Sanitary Sewer Basin CN Values

CN Values - Existing Conditions

A	Impervious Areas (Soil A,B,C,D) =	CN	Cond	Dry
B	Commercial and Business (Soil D) =	98	0.00	7.84
C	Commercial and Business (Soil C) =	95	0.01	7.54
D	Commercial and Business (Soil B) =	94	0.01	7.43
E	Commercial and Business (Soil A) =	92	0.02	7.23
F	Residential 1/4 Acre Lots (Soil D) =	89	0.03	6.92
G	Residential Estate (Soil D) =	87	0.04	6.72
H	Small Grain Contoured Good (Soil D) =	85	0.06	6.52
I	Herbaceous Open Space / Pasture - Fair (Soil D) =	84	0.06	6.41
J	Residential 1/4 Acre Lots (Soil C) =	83	0.07	6.31
K	Residential Estate (Soil C) =	83	0.07	6.31
L	Pasture - Fair (Soil C) =	81	0.09	6.11
M	Residential (Soil B) =	76	0.14	5.6
N	Residential Estate (Soil B) =	75	0.15	5.5
O	Pasture - Fair (Soil B) =	70	0.21	4.99
P	Residential 1/4 Acre Lots (Soil A) =	69	0.23	4.88
Q	Small Grain St Good (Soil A) =	61	0.34	4.07
R	Residential Estate (Soil A) =	60	0.35	3.97
S	Residential 1/2 Acre (Soil A) =	57	0.39	3.66
T	Pasture - Open Space - Fair (Soil A) =	54	0.44	3.35
		49	0.52	2.84

Basin	Area	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	Imp	Weighted Average	Comp CN
	acres	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	acre	%	Acre *CN	CN
Basin2J3	195.6		15	61							115		4.63									70%	17056	87.2
Basin2J4	63.78		4				57									2.78						65%	5531	86.7
Basin2J5	44.99		15				28									1.99						65%	3998	88.9
Basin2J6	37.15		18				10			9.15												50%	3339	89.9
Basin2K1	79.62	3	35					40		31.8												30%	9655	121.3
Basin2K2	50.15		17					28.2	5													50%	4428	88.3
Basin2K3	36.2	1						34	1.2													40%	3089	85.3
Basin2K4	57.59							37											20.6			45%	4319	75.0
Basin2K5	69.66							19.7											50			50%	4521	64.9
Basin2K6	159.2							9.2											150			45%	9332	58.6
Basin2K7	48.17							15.2											33			45%	3170	65.8
Basin2K8	82.65							50		32.7												25%	6960	84.2
Basin2K9	229.2					49.2				15									60		105	25%	14189	61.9

CONDUCTIVITY AND % IMPERVIOUS

Sanitary Sewer Basins Calculations

Basin	Area	Width	Slope	CN	Conductivity	Dry	% Imp
1A1	131.06	100	1	74.5	0.15818751	5.4454	10
1A2	128.75	400	0.3	90.1	0.02462142	7.0366	85
1A3	94.48	80	5	74.5	0.15818751	5.4454	75
1B1	38	690	1.2	69.8	0.21522456	4.966	40
1B2	51.57	720	2.7	85.3	0.05490537	6.547	65
1B3	134.29	745	0.79	83.4	0.06978605	6.3532	65
1B4	66.24	620	0.37	84.8	0.05867004	6.496	65
1C1	83.53	1020	2.8	85.3	0.05490537	6.547	60
1C1A	66.82	602	0.51	88.2	0.03530096	6.8428	60
1C1B	69.72	901	0.95	86.4	0.04701463	6.6592	55
1C1C	89.15	888	0.91	86.1	0.04911261	6.6286	50
1C1D	76.49	692	0.51	85.9	0.0505339	6.6082	35
1C2	59.5	938	0.625	86.4	0.04701463	6.6592	65
1C3	67	820	1.8	87.2	0.04162169	6.7408	60
1C4	62.19	750	1.02	86.5	0.04632441	6.6694	60
1D1	56.18	760	1.09	79.3	0.10693013	5.935	35
1D2	50.46	843	0.86	77.6	0.12418926	5.7616	55
1D3	108.15	827	1.2	88.2	0.03530096	6.8428	60
1D4	95.17	850	0.66	86.5	0.04632441	6.6694	50
1E1	44.37	720	5.5	74.6	0.15704283	5.4556	10
1E2	55.58	860	1.1	69.1	0.22421817	4.8946	55
1F1	193.54	1260	0.75	77.1	0.12945819	5.7106	40
1F2	52.03	980	2.58	79	0.1099006	5.9044	20
1F3	90.99	942	1.05	80.5	0.09538176	6.0574	50
1F4	71.78	1280	0.45	79.3	0.10693013	5.935	60
1F5	71.35	945	1.37	90	0.025139	7.0264	85
1G1	46.72	420	0.381	87.4	0.04031984	6.7612	80
1G2	179.88	1050	0.625	78	0.1200362	5.8024	60
1G3	93.49	1524	1.1	86.4	0.04701463	6.6592	60
1G4	143.49	1250	0.34	87	0.0429422	6.7204	65
1G5	173.22	840	0.32	89.7	0.02672179	6.9958	55
1G6	73.99	1100	0.28	87.3	0.04096843	6.751	55
1G7	97.06	1400	0.36	87.3	0.04096843	6.751	50
1G8	77.69	456	0.21	89.2	0.02945916	6.9448	35
1H1	165.29	766	0.603	90.5	0.02260151	7.0774	70
1I1	137.86	684	0.4	90.1	0.02462142	7.0366	70
1J1	145.34	845	0.5	85.3	0.05490537	6.547	75
1J2	42.03	621	0.81	83.2	0.0714418	6.3328	65
1K1	70.39	677	0.47	71.5	0.19389554	5.1394	60
1K2	70.33	420	0.85	69.7	0.21650205	4.9558	40
1K3	170.81	920	0.72	82.5	0.07736731	6.2614	50
1K4	84.05	1089	0.4	72.5	0.18170756	5.2414	60
1M1	59.94	981	1.8	86.2	0.04840874	6.6388	30
1M2	58.49	1026	0.9	89.2	0.02945916	6.9448	35
1M3	89.58	774	0.54	88.8	0.0317376	6.904	55
1M4	85.1	1148	1	87.5	0.03967594	6.7714	55
1M5	172.56	1073	0.35	87.4	0.04031984	6.7612	30
1M6	61.75	936	0.885	91.1	0.01972427	7.1386	70

Sanitary Sewer Basins Calculations

Basin	Area	Width	Slope	CN	Conductivity	Dry	% Imp
1N1	88.52	966	0.595	88.4	0.03409389	6.8632	50
1N2	72.03	1200	0.45	89.4	0.02834937	6.9652	60
1N3	55.41	1146	0.52	88.6	0.03290607	6.8836	35
1N4	155.89	1168	0.32	81.3	0.08798703	6.139	20
1N5	25.71	644	0.28	87.5	0.03967594	6.7714	50
1N6	184.98	1412	0.41	84.9	0.05790833	6.5062	55
1N7	219.38	1628	0.52	87.7	0.03840225	6.7918	20
1N8	26.64	528	0.4	87.5	0.03967594	6.7714	60
1O1	249.68	1975	0.28	86.5	0.04632441	6.6694	55
1O2	79.92	925	0.6	99.3	0.00015147	7.975	20
1O3	111.7	1524	0.84	60.8	0.33856351	4.048	60
1O4	174.04	994	0.71	64.1	0.3780946	3.7726	35
1O5	75.94	920	0.21	90.1	0.02462142	7.0366	55
1P1	291.6	3120	0.96	87.7	0.03840225	6.7918	20
1P2	76.39	1129	0.6	84.8	0.05867004	6.496	25
1P3	180.59	1324	0.89	81.8	0.0834923	6.19	20
2A1	55.28	882	0.85	70.2	0.21013943	5.0068	7
2A2	160.41	496	0.74	72.1	0.18654973	5.2006	2
2B1	63.53	700	2.7	87	0.0429422	6.7204	55
2B2	65.39	760	2.4	87	0.0429422	6.7204	60
2B3	119.54	980	1.2	87	0.0429422	6.7204	60
2C1	72.7	1572	2.73	74.4	0.15933525	5.4352	45
2C2	32.43	657	4.33	72.7	0.1793033	5.2618	35
2C3	114.7	1609	0.55	76.3	0.13806414	5.629	55
2D1	34.78	960	0.636	76	0.141346	5.5984	1
2D2	315.07	2542	0.8	74.8	0.15476272	5.476	60
2D3	257.89	1271	1.69	76.4	0.20509464	5.0476	2
2D4	75.74	1465	0.78	87.2	0.04162169	6.7408	65
2D5	152.22	1363	0.65	84.1	0.06412336	6.4246	35
2E1	12.18	124	0.87	72.8	0.17810541	5.272	10
2E2	105.01	1765	0.22	77.3	0.12734036	5.731	65
2F1	42.9	765	0.52	79	0.92845216	-0.4706	40
2F2	121.92	1406	0.4	84.1	0.06412336	6.4246	65
2F3	60.13	984	0.6	81.3	0.82781749	0.5596	40
2F4	21.09	571	0.65	88.8	0.0317376	6.904	35
2F5	81	859	0.54	81	0.78267654	0.937	45
2G1	63.27	1421	0.8	88.2	0.42135635	3.4768	70
2G2	267.45	2108	0.71	88.2	0.212677	4.9864	70
2G3	87.8	1512	0.476	94.4	0.00728941	7.4752	90
2G4	158.63	2019	0.67	83	0.0731142	6.3124	65
2G5	83.08	1633	0.817	86.2	0.04840874	6.6388	60
2G6	191.8	1938	0.754	77.7	0.62333262	2.11	35
2H1	36.16	734	1.07	86.2	0.04840874	6.6388	50
2H2	52.66	1074	0.652	84.6	0.06020651	6.4756	30
2H3	136.95	1518	1.25	85.5	0.05343039	6.5674	40
2H4	141.76	1331	1.46	81.7	0.44698319	3.3034	35
2H5	30.19	1904	1.6	81.7	0.6827399	1.6918	50
2H6	30.49	645	0.45	73.7	0.58618104	2.365	25

Sanitary Sewer Basins Calculations

Basin	Area	Width	Slope	CN	Conductivity	Dry	% Imp
2H7	54.59	1264	0.856	85	0.057151	6.5164	50
2H8	88.81	1519	0.64	79.1	0.1089068	5.9146	50
2H9	56.11	624	0.72	62.7	0.31131483	4.2418	10
2I1	54.75	1223	1.31	64	0.2929936	4.3744	40
2I2	64.12	1345	0.578	78.8	0.22034921	4.9252	55
2I3	90.68	1434	1.65	76.7	0.53191855	2.7322	50
2I4	31.78	998	0.74	84.8	0.05867004	6.496	45
2I5	12.37	520	1.07	70	0.212677	4.9864	50
2I6	51.47	1219	1.02	69.7	0.21650205	4.9558	40
2I7	88.64	1518	1.2	85	0.057151	6.5164	50
2I8	161.34	2820	0.85	76.5	0.13589266	5.6494	45
2I9	14.57	498	0.95	85	0.057151	6.5164	55
2I10	59	1140	1.14	86.5	0.04632441	6.6694	50
2I11	123.07	2708	0.87	83	0.65113645	1.9162	45
2J1	37.17	1245	0.4	92.7	0.01296624	7.3018	90
2J2	79.2	1159	0.665	85.7	0.0519732	6.5878	65
2J3	195.63	2624	0.08	87.2	0.04162169	6.7408	70
2J4	63.78	739	1.3	86.7	0.04495771	6.6898	65
2J5	44.99	835	1.74	88.9	0.03116066	6.9142	65
2J6	37.15	920	0.87	89.9	0.0256616	7.0162	50
2K1	79.62	1672	0.31	121.3	0.17245211	10.219	30
2K2	50.15	740	1.4	88.3	0.03469502	6.853	50
2K3	36.2	704	1.4	85.3	0.05490537	6.547	40
2K4	57.59	845	1.2	75	0.152495	5.4964	45
2K5	69.66	1017	1.1	64.9	0.28048027	4.4662	50
2K6	159.22	1602	1.2	58.6	0.37071183	3.8236	45
2K7	48.17	1289	0.87	65.8	0.26811707	4.558	45
2K8	82.62	1780	1.2	84.2	0.0633314	6.4348	25
2K9	229.15	3100	1.1	61.9	0.32272359	4.1602	25

End

**PIPE LENGTH
PIPE DIAMETER**

Pipe Length/Diameter Calculations

Feet in a mile =

5280 ft/mile

Infiltration

200 gal/mile/dia/day

	In	8	10	12	18	21	24	30	36	Length
	Ft	0.66667	0.83333	1	1.5	1.75	2	2.5	3	mile*dia
Basin1N1	(1M)286A	9800	850				5000			3.265467
Basin1N2	(1N)013	8000	2200							1.357323
Basin1N3	(1N)022	5700	2300							1.082702
Basin1N4	(1N)025	15000								1.893939
Basin1N5	(1N)047	2800								0.353535
Basin1N6	(1N)047	15000								1.893939
Basin1N7	(1N)047	6100	1450							0.999053
Basin1N8	(1N)022	5000								0.631313
Basin1O1	(1O)305	29500	1180	530			3200			5.223485
Basin1O2	(1O)308	5100								0.643939
Basin1O3	(1O)309	1400								0.176768
Basin1O4	(1O)157	11500								1.45202
Basin1O5	(1O)157	4900								0.618687
Basin1P1	(1P)009	5000	5600	10500						3.503788
Basin1P2	(1P)043	300	4100							0.684975
Basin1P3	(1P)043	3900	1300							0.697601
Basin2A1	(2A)014	800							4900	2.885101
Basin2A2	(2A)048	0						10000	19000	15.5303
Basin2B1	(2A)017	4600	900							0.722854
Basin2B2	(2A)020	5400	400							0.744949
Basin2B3	(2A)020	7200								0.909091
Basin2C1	(2C)003	7100		1680				1680		2.010101
Basin2C2	(2C)009	500	2600	640				640		0.897727
Basin2C3	(2E)003	9980								1.260101
Basin2D1	(2D)003	0	450	3500	3800					1.813447
Basin2D2	(2D)011	45000	990							5.838068
Basin2D3	(2D)251	20000		5500	7900					5.811237
Basin2D4	(2D)045A	3300	3200							0.921717
Basin2D5	(2D)046A	6700	1800							1.130051
Basin2E1	(2A)064	0						2200		1.041667
Basin2E2	(2E)003	11500						6490		4.524937
Basin2F1	(2F)004	3200					800	1500		1.417298
Basin2F2	(2F)010	16500			3400					3.049242
Basin2F3	(2F)023	5500			1890					1.231376
Basin2F4	(2F)011	2200								0.277778
Basin2F5	(2F)025	2200		8900						1.963384
Basin2G1	(2G)002	4500		2000						0.94697
Basin2G2	(2G)040	9700		6100						2.380051
Basin2G3	(2G)009	7000	1500	400						1.196338
Basin2G4	(2G)019	15600	2800							2.411616
Basin2G5	(2G)026	9500	1200							1.388889
Basin2G6	(2G)359	20500	3800							3.188131
Basin2H10	(2H)058	1900	3000							0.713384
Basin2H2	(2H)007	3125				1750				0.97459
Basin2H3	(2H)012	3700	1900							0.767045
Basin2H4	(2H)012	12000	1320							1.723485
Basin2H5	(2H)013	3900			2300	335				1.256866
Basin2H6	(2H)033	8500		3700						1.77399

TM 2-4

STORM EVENTS

TM 2-5

I/I CALCULATIONS

I/I HYDROGRAPH DEVELOPMENT

Sanitary Sewer Basin Calculations (Infiltration)

Basin	Inlet	Depth	ST			MT			LT			200 gal/mi/day/dia		
			R1	T1	K1	R2	T2	K2	R3	T3	K3	en of Pip mi/dia	Allowed gpm	Area acres
Basin1A1	(1A)007	7.83	0.53	0.51561	2	0.17	1.37495	2	0.3	2.94632	2	2.70202	540	0.79
Basin1A2	(1A)014	3.58	0.45	1.5146	2	0.14	4.03894	2	0.41	8.65487	2	1.31944	264	0.70
Basin1A3	(1A)027	18.54	0.53	1.22086	2	0.17	3.25563	2	0.3	6.97635	2	3.04609	609	1.29
Basin1B1	(1B)009	18.33	0.55	0.88715	2	0.18	2.36575	2	0.27	5.06946	2	1.18687	237	0.44
Basin1B2	(1B)005	9.87	0.48	1.87254	2	0.15	4.99344	2	0.37	10.7002	2	0.50505	101	0.21
Basin1B3	(1B)013	14.57	0.48	2.1748	2	0.15	5.79947	2	0.37	12.4274	2	2.00758	402	0.98
Basin1B4	(1B)014	15.35	0.48	2.72534	2	0.15	7.26758	2	0.37	15	2	1.1111	222	0.59
Basin1C1	(1C)001A	13.37	0.48	2.53656	2	0.15	6.76416	2	0.37	14.4946	2	2.28851	458	1.12
Basin1C1A	(1C)015L	12.75	0.46	3.76229	2	0.14	8	2	0.4	15	2	1.67298	335	0.87
Basin1C1B	(1C)021E	17.83	0.47	3.95045	2	0.15	8	2	0.38	15	2	1.23737	247	0.75
Basin1C1C	(1C)021	10.58	0.47	2.24399	2	0.15	5.98398	2	0.38	12.8228	2	2.03283	407	0.89
Basin1C1D	(1C)028	10.71	0.47	2.20768	2	0.15	5.88714	2	0.38	12.6153	2	1.1111	222	0.49
Basin1C2	(1C)179	17.25	0.47	3.82195	2	0.15	8	2	0.38	15	2	1.76136	352	1.05
Basin1C3	(1C)178	14.25	0.47	3.56635	2	0.15	8	2	0.38	15	2	1.26263	253	0.68
Basin1C4	(1C)182	12	0.47	2.69836	2	0.15	7.19563	2	0.38	15	2	1.16162	232	0.55
Basin1D1	(1D)005	8.08	0.51	0.78712	2	0.16	2.09898	2	0.33	4.49782	2	0.78283	157	0.26
Basin1D2	(1D)014	6.35	0.51	0.53262	2	0.16	1.42032	2	0.33	3.04355	2	0.89962	180	0.28
Basin1D3	(1D)018	13.83	0.46	4	2	0.14	8	2	0.4	15	2	1.83081	366	1.00
Basin1D4	(1D)023	14.72	0.47	3.30999	2	0.15	8	2	0.38	15	2	1.72033	344	0.94
Basin1E1	(1E)003A	5.91	0.53	0.39201	2	0.17	1.04536	2	0.3	2.24006	2	0.65657	131	0.19
Basin1E2	(1E)009	7.81	0.55	0.36283	2	0.18	0.96756	2	0.27	2.07334	2	0.85859	172	0.23
Basin1F1	(1F)004	9.94	0.52	0.79981	2	0.17	2.13282	2	0.31	4.57033	2	4.20518	841	1.31
Basin1F2	(1F)010	7.96	0.51	0.75447	2	0.16	2.01192	2	0.33	4.31126	2	1.29869	260	0.43
Basin1F3	(1J)011	12.3	0.5	1.34329	2	0.16	3.5821	2	0.34	7.67592	2	1.86869	374	0.73
Basin1F4	(1F)017A	17.37	0.51	1.69211	2	0.16	4.51229	2	0.33	9.6692	2	0.56818	114	0.27
Basin1F5	(1F)030	9.8252	0.45	4	2	0.14	8	2	0.41	15	2	1.12689	225	0.54
Basin1G1	(1G)002	15.43	0.46	3.98635	2	0.15	8	2	0.39	15	2	1.73658	347	1.00
Basin1G2	(1G)003	17.96	0.51	1.55856	2	0.16	4.15615	2	0.33	8.90604	2	2.30177	460	1.07
Basin1G3	(1G)009E	18.23	0.47	4	2	0.15	8	2	0.38	15	2	3.35227	670	2.07
Basin1G4	(1G)053	8.5	0.47	2.06188	2	0.15	5.49835	2	0.38	11.7822	2	2.24116	448	0.99
Basin1G5	(1G)046	12.54	0.45	4	2	0.14	8	2	0.41	15	2	1.92551	385	1.03
Basin1G6	(1G)071	10.15	0.47	2.58075	2	0.15	6.88199	2	0.38	14.7471	2	1.31944	264	0.59
Basin1G7	(1G)020	12.75	0.47	3.24183	2	0.15	8	2	0.38	15	2	1.89394	379	0.96

Sanitary Sewer Basin Calculations (Infiltration)

Basin	Inlet	Depth	ST			MT			LT			200 gal/mi/day/dia		
			R1	T1	K1	R2	T2	K2	R3	T3	K3	en of Pip mi/dia	Allowed gpm	Area acres
Basin1G8	(1G)018	13.08	0.46	4	2	0.14	8	2	0.4	15	2	0.66919	134	0.36
Basin1H1	(1H)045	9.5	0.45	4	2	0.14	8	2	0.41	15	2	1.89394	379	0.93
Basin1I1	(1H)011	12	0.45	4	2	0.14	8	2	0.41	15	2	2.08965	418	1.10
Basin1J1	(1J)053	9.51	0.48	1.80424	2	0.15	4.81131	2	0.37	10.3099	2	1.96338	393	0.82
Basin1J2	(1K)001	13.83	0.49	2.0165	2	0.15	5.37734	2	0.36	11.5229	2	0.78283	157	0.36
Basin1K1	(1K)004	7.95	0.54	0.4271	2	0.18	1.13893	2	0.28	2.44056	2	1.23737	247	0.35
Basin1K2	(1K)008	11.04	0.55	0.53117	2	0.18	1.41646	2	0.27	3.03527	2	1.62879	326	0.46
Basin1K3	(1K)014	8.77	0.49	1.18079	2	0.16	3.14876	2	0.35	6.74734	2	3.20076	640	1.19
Basin1K4	(2E)014	20.87	0.54	1.1964	2	0.18	3.19041	2	0.28	6.8366	2	1.51515	303	0.64
Basin1M1	(1M)003	19.45	0.47	4	2	0.15	8	2	0.38	15	2	1.61616	323	1.04
Basin1M2	(1M)281E	18.35	0.46	4	2	0.14	8	2	0.4	15	2	1.25631	251	0.85
Basin1M3	(1M)094	10.5	0.46	3.44623	2	0.14	8	2	0.4	15	2	1.98864	398	0.95
Basin1M4	(1M)122	10.87	0.46	2.85385	2	0.15	7.61027	2	0.39	15	2	1.74242	348	0.81
Basin1M5	(1M)165	15.81	0.46	4	2	0.15	8	2	0.39	15	2	0.90909	182	0.53
Basin1M6	(1M)162	12.5	0.45	4	2	0.14	8	2	0.41	15	2	0.79545	159	0.44
Basin1N1	(1M)286A	28.15	0.46	4	2	0.14	8	2	0.4	15	2	3.26547	653	1.85
Basin1N2	(1N)013	4.85	0.45	1.78208	2	0.14	4.75221	2	0.41	10.1833	2	1.35732	271	0.69
Basin1N3	(1N)022	11.25	0.46	3.56127	2	0.14	8	2	0.4	15	2	1.0827	217	0.53
Basin1N4	(1N)025	10.79	0.5	1.27741	2	0.16	3.40644	2	0.34	7.29951	2	1.89394	379	0.71
Basin1N5	(1N)047	17.5	0.46	4	2	0.15	8	2	0.39	15	2	0.35354	71	0.22
Basin1N6	(1N)048	17.2	0.48	3.09397	2	0.15	8	2	0.37	15	2	1.89394	379	1.07
Basin1N7	(1N)049	16.9	0.46	4	2	0.14	8	2	0.4	15	2	0.99905	200	0.61
Basin1N8	(1N)022	11.25	0.46	2.95362	2	0.15	7.87631	2	0.39	15	2	0.63131	126	0.30
Basin1O1	(1O)305	12.6461	0.47	2.84365	2	0.15	7.58305	2	0.38	15	2	5.22348	1045	2.56
Basin1O2	(1O)308	13.9625	0.4	4	2	0.12	8	2	0.48	15	2	0.64394	129	0.41
Basin1O3	(1O)309	13.1419	0.58	0.40434	2	0.2	1.07824	2	0.22	2.31052	2	0.17677	35	0.05
Basin1O4	(1O)157	14.0314	0.57	0.38657	2	0.19	1.03085	2	0.24	2.20897	2	1.45202	290	0.44
Basin1O5	(1O)308A	13.7865	0.45	4	2	0.14	8	2	0.41	15	2	0.61869	124	0.35
Basin1P1	(1P)009	11.67	0.46	3.1655	2	0.14	8	2	0.4	15	2	3.50379	701	1.70
Basin1P2	(1P)065	16.76	0.48	2.97568	2	0.15	7.93515	2	0.37	15	2	0.68497	137	0.38
Basin1P3	(1P)044	4.08	0.49	0.50903	2	0.16	1.35741	2	0.35	2.90874	2	0.6976	140	0.25
Basin2A1	(2A)014	6.06	0.55	0.3004	2	0.18	0.80106	2	0.27	1.71655	2	2.8851	577	0.81
Basin2A2	(2A)048	7.85	0.54	0.43833	2	0.18	1.16889	2	0.28	2.50476	2	15.5303	3106	4.37


Santuary Sewer Basin Calculations (Infiltration)

Basin	Inlet	Depth	ST			MT			LT			200 gal/mi/day/dia		
			R1	T1	K1	R2	T2	K2	R3	T3	K3	en of Pipl	Allowed	Area
												mi/dia	gpm	acres
Basin2B1	(2A)017	10.93	0.47	2.65134	2	0.15	7.07023	2	0.38	15	2	0.72285	145	0.33
Basin2B2	(2A)020	13.01	0.47	3.15589	2	0.15	8	2	0.38	15	2	0.74495	149	0.38
Basin2B3	(2A)021	7.53	0.47	1.82658	2	0.15	4.87089	2	0.38	10.4376	2	0.90909	182	0.40
Basin2C1	(2C)003	10.94	0.53	0.71521	2	0.17	1.90723	2	0.3	4.08692	2	2.0101	402	0.61
Basin2C2	(2C)009	9.83	0.54	0.57108	2	0.17	1.52287	2	0.29	3.26329	2	0.89773	180	0.25
Basin2C3	(2E)004	11.83	0.52	0.89255	2	0.17	2.38013	2	0.31	5.10029	2	1.2601	252	0.42
Basin2D1	(2D)003	8.17	0.52	0.6021	2	0.17	1.6056	2	0.31	3.44056	2	1.81345	363	0.55
Basin2D2	(2D)011	19.88	0.53	1.33807	2	0.17	3.56819	2	0.3	7.64611	2	5.83807	1168	2.61
Basin2D3	(2D)267	14.8121	0.52	0.7523	2	0.17	2.00613	2	0.31	4.29885	2	5.81124	1162	2.31
Basin2D4	(2D)045A	18	0.47	4	2	0.15	8	2	0.38	15	2	0.92172	184	0.58
Basin2D5	(2D)046A	1305	0.48	4	2	0.15	8	2	0.37	15	2	1.13005	226	0.03
Basin2E1	(2A)064	10.97	0.53	0.64159	2	0.17	1.71091	2	0.3	3.66623	2	1.04167	208	0.31
Basin2E2	(2E)003	15.41	0.51	1.26057	2	0.17	3.36151	2	0.32	7.20323	2	4.52494	905	1.89
Basin2F1	(2F)004	19.02	0.51	0.21339	2	0.16	0.56905	2	0.33	1.21939	2	1.4173	283	0.70
Basin2F2	(2F)010	17.58	0.48	2.85582	2	0.15	7.61553	2	0.37	15	2	3.04924	610	1.71
Basin2F3	(2F)023	22.17	0.5	0.27897	2	0.16	0.74392	2	0.34	1.59412	2	1.23138	246	0.67
Basin2F4	(2F)011	16.28	0.46	4	2	0.14	8	2	0.4	15	2	0.27778	56	0.17
Basin2F5	(2F)025	19.9385	0.5	0.26536	2	0.16	0.70763	2	0.34	1.51635	2	1.96338	393	1.08
Basin2G1	(2G)002	16.58	0.46	0.40989	2	0.14	1.09303	2	0.4	2.34221	2	0.94697	189	0.58
Basin2G2	(2G)040	16	0.46	0.78366	2	0.14	2.08976	2	0.4	4.47806	2	2.38005	476	1.43
Basin2G3	(2G)009	10.12	0.43	4	2	0.13	8	2	0.44	15	2	1.19634	239	0.61
Basin2G4	(2G)019	9.15	0.49	1.30361	2	0.15	3.4763	2	0.36	7.44921	2	2.41162	482	0.92
Basin2G5	(2G)026	5.62	0.47	1.20932	2	0.15	3.22485	2	0.38	6.9104	2	1.38889	278	0.59
Basin2G6	(2G)359	6.67	0.51	0.11146	2	0.16	0.29724	2	0.33	0.63694	2	3.18813	638	1.00
Basin2H1	(2H)007	16.73	0.47	3.59999	2	0.15	8	2	0.38	15	2	0.71338	143	0.41
Basin2H2	(2H)012	13.83	0.48	2.39281	2	0.15	6.38082	2	0.37	13.6732	2	0.97459	195	0.48
Basin2H3	(2H)011	14.48	0.47	2.82299	2	0.15	7.52797	2	0.38	15	2	0.76705	153	0.40
Basin2H4	(2H)013	16.91	0.49	0.39408	2	0.16	1.05087	2	0.35	2.25187	2	1.72348	345	0.87
Basin2H5	(2H)033	7.65	0.49	0.11672	2	0.16	0.31125	2	0.35	0.66696	2	1.25687	251	0.45
Basin2H6	(2H)049	12.17	0.53	0.21627	2	0.17	0.57671	2	0.3	1.2358	2	1.77399	355	0.56
Basin2H7	(2H)286	17.75	0.48	3.23522	2	0.15	8	2	0.37	15	2	1.17045	234	0.68
Basin2H8	(2H)290	20.92	0.51	2.00095	2	0.16	5.33586	2	0.33	11.434	2	1.1048	221	0.57
Basin2H9	(2H)058	15.24	0.57	0.50993	2	0.19	1.35982	2	0.24	2.91391	2	1.44413	289	0.45

Sanitary Sewer Basin Calculations (Infiltration)

Basin	Inlet	Depth	ST			MT			LT			200 gall/mi/day/dia		
			R1	T1	K1	R2	T2	K2	R3	T3	K3	en of Pip mi/dia	Allowed gpm	Area acres
Basin211	(2I)003	8.8	0.57	0.31286	2	0.19	0.8343	2	0.24	1.78778	2	0.5303	106	0.14
Basin212	(2I)001	9.71	0.51	0.45903	2	0.16	1.22407	2	0.33	2.623	2	1.11111	222	0.36
Basin213	(2I)008	12	0.52	0.235	2	0.17	0.62666	2	0.31	1.34285	2	1.73232	346	0.59
Basin214	(2I)014	8.61	0.48	1.52868	2	0.15	4.07647	2	0.37	8.73529	2	0.63131	126	0.26
Basin215	(2I)020	16.52	0.55	0.80913	2	0.18	2.15768	2	0.27	4.6236	2	0.31503	63	0.11
Basin216	(2I)025A	9.38	0.55	0.4513	2	0.18	1.20348	2	0.27	2.57888	2	0.6553	131	0.18
Basin217	(2I)021B	14.54	0.48	2.65014	2	0.15	7.06705	2	0.37	15	2	1.79293	359	0.92
Basin218	(2I)029	12.1	0.52	0.92751	2	0.17	2.47336	2	0.31	5.30005	2	3.29861	660	1.12
Basin219	(2I)049	16.16	0.48	2.94541	2	0.15	7.85444	2	0.37	15	2	0.41667	83	0.23
Basin2110	(2I)054	11.836	0.47	2.66148	2	0.15	7.09729	2	0.38	15	2	1.18434	237	0.56
Basin2111	(2I)059	10.244	0.49	0.16388	2	0.15	0.43701	2	0.36	0.93646	2	1.13952	228	0.44
Basin2J1	(2J)008	22.37	0.44	4	2	0.13	8	2	0.43	15	2	1.53409	307	1.08
Basin2J2	(2J)047	11.04	0.47	2.21268	2	0.15	5.90048	2	0.38	12.6439	2	1.22475	245	0.54
Basin2J3	(2J)056	5.33	0.47	1.33394	2	0.15	3.55717	2	0.38	7.62251	2	2.54893	510	1.14
Basin2J4	(2J)026	16.79	0.47	3.89023	2	0.15	8	2	0.38	15	2	0.81439	163	0.48
Basin2J5	(2J)029	17.83	0.46	4	2	0.14	8	2	0.4	15	2	0.50505	101	0.33
Basin2J6	(2J)032	13.22	0.45	4	2	0.14	8	2	0.41	15	2	0.65909	132	0.37
Basin2K1	(2K)317	14.67	0.34	0.88612	2	0.08	2.36297	2	0.58	5.06352	2	1.0827	217	0.69
Basin2K2	(2K)013	10.29	0.46	3.08942	2	0.14	8	2	0.4	15	2	1.58775	318	0.74
Basin2K3	(2K)019	6.8	0.48	1.2901	2	0.15	3.44026	2	0.37	7.37199	2	0.92172	184	0.38
Basin2K4	(2K)014	9.58	0.53	0.65439	2	0.17	1.74505	2	0.3	3.73939	2	1.0101	202	0.30
Basin2K5	(2K)025	9.18	0.57	0.34093	2	0.19	0.90915	2	0.24	1.94819	2	0.94697	189	0.25
Basin2K6	(2K)029	10	0.59	0.28099	2	0.2	0.74931	2	0.21	1.60566	2	2.34217	468	0.60
Basin2K7	(2K)033	13.7	0.56	0.53226	2	0.19	1.41936	2	0.25	3.04149	2	1.02273	205	0.31
Basin2K8	(2K)042	12.1817	0.48	2.00363	2	0.15	5.34302	2	0.37	11.4493	2	1.54356	309	0.68
Basin2K9	(2K)052	10.3488	0.58	0.33403	2	0.2	0.89076	2	0.22	1.90876	2	1.90657	381	0.50



Ratio of Hydrograph Responses





- ◆ Series1
- Series2
- ▲ Series3
- Poly. (Series1)
- Poly. (Series3)
- Poly. (Series2)

I/I FLOW DEVELOPMENT



5 ft





10 ft





15ft





20 ft




15ft



25 ft



Acres*GPM to CN Value Response



TM 2-6

**SWMM MODEL
AND
OUTPUT**

EPA STORM WATER MANAGEMENT MODEL - VERSION 5.0 (Build 5.0.011)

BASIN 1A SANITARY SEWER HYDRAULIC ANALYSIS: 1YR PRECIP.
 XYS=BAS1A.XYS

 Analysis Options

Flow Units GPM
 Infiltration Method CURVE NUMBER
 Flow Routing Method KINWAVE
 Starting Date JAN-01-2008 00:00:00
 Ending Date JAN-04-2008 12:00:00
 Antecedent Dry Days 0.0
 Report Time Step 00:01:00
 Wet Time Step 00:01:00
 Dry Time Step 00:03:00
 Routing Time Step 30.00 sec

 Element Count

Number of rain gages 1
 Number of subcatchments ... 125
 Number of nodes 952
 Number of links 961
 Number of pollutants 0
 Number of land uses 0

 Raingage Summary

Name	Data Source	Data Type	Interval hours
CurrentRainEvent	Event1	INTENSITY	1.00

 Subcatchment Summary

Name	Area	Width	%Imperv	%Slope	Rain
Basin1A1	131.06	100.00	10.00	1.0000	
CurrentRainEvent	(1A)007				
Basin1A2	128.75	400.00	85.00	0.3000	
CurrentRainEvent	(1A)014				
Basin1A3	94.48	80.00	75.00	5.0000	
CurrentRainEvent	(1A)027				
Basin1B1	38.00	690.00	40.00	1.2000	
CurrentRainEvent	(1B)009				
Basin1B2	51.57	720.00	65.00	2.7000	
CurrentRainEvent	(1B)005				
Basin1B3	134.29	745.00	65.00	0.7900	

CurrentRainEvent	(1B)014				
Basin1B4		66.24	620.00	65.00	0.3700
CurrentRainEvent	(1B)014				
Basin1C1		83.53	1020.00	60.00	2.8000
CurrentRainEvent	(1C)001A				
Basin1C1A		66.82	602.00	60.00	0.5100
CurrentRainEvent	(1C)015D				
Basin1C1B		69.72	901.00	55.00	0.9500
CurrentRainEvent	(1C)021B				
Basin1C1C		89.15	888.00	50.00	0.9100
CurrentRainEvent	(1C)021				
Basin1C1D		76.49	692.00	35.00	0.5100
CurrentRainEvent	(1C)028				
Basin1C2		59.50	938.00	65.00	0.6250
CurrentRainEvent	(1C)179				
Basin1C3		67.00	820.00	60.00	1.8000
CurrentRainEvent	(1C)178				
Basin1C4		62.19	750.00	60.00	1.0200
CurrentRainEvent	(1C)182				
Basin1D1		56.18	760.00	35.00	1.0900
CurrentRainEvent	(1D)005				
Basin1D2		50.46	843.00	55.00	0.8600
CurrentRainEvent	(1D)014				
Basin1D3		108.15	827.00	60.00	1.2000
CurrentRainEvent	(1D)018				
Basin1D4		95.17	850.00	50.00	0.6600
CurrentRainEvent	(1D)023				
Basin1E1		44.37	720.00	10.00	5.5000
CurrentRainEvent	(1E)003A				
Basin1E2		55.58	860.00	55.00	1.1000
CurrentRainEvent	(1E)009				
Basin1F1		193.54	1260.00	40.00	0.7500
CurrentRainEvent	(1F)004				
Basin1F2		52.03	980.00	20.00	2.5800
CurrentRainEvent	(1F)010				
Basin1F3		90.99	942.00	50.00	1.0500
CurrentRainEvent	(1J)011				
Basin1F4		71.78	1280.00	60.00	0.4500
CurrentRainEvent	(1F)017A				
Basin1F5		71.35	945.00	85.00	1.3700
CurrentRainEvent	(1F)021				
Basin1G1		46.72	420.00	80.00	0.3810
CurrentRainEvent	(1G)002				
Basin1G2		179.88	1050.00	60.00	0.6250
CurrentRainEvent	(1G)003				
Basin1G3		93.49	1524.00	60.00	1.1000
CurrentRainEvent	(1G)009B				
Basin1G4		143.49	1250.00	65.00	0.3400
CurrentRainEvent	(1G)053				
Basin1G5		173.22	840.00	55.00	0.3200
CurrentRainEvent	(1G)046				
Basin1G6		73.99	1100.00	55.00	0.2800
CurrentRainEvent	(1G)071				
Basin1G8		97.06	1400.00	50.00	0.3600
CurrentRainEvent	(1G)020				
Basin1G9		77.69	456.00	35.00	0.2100
CurrentRainEvent	(1G)020				
Basin1H1		165.29	766.00	70.00	0.6030
CurrentRainEvent	(1H)043				
Basin1I1		137.86	684.00	70.00	0.4000
CurrentRainEvent	(1H)011				

Basin1J1	145.34	845.00	75.00	0.5000
CurrentRainEvent	(1J)053			
Basin1J2	42.03	621.00	65.00	0.8100
CurrentRainEvent	(1K)001			
Basin1K1	70.39	677.00	60.00	0.4700
CurrentRainEvent	(1K)004			
Basin1K2	70.33	420.00	40.00	0.8500
CurrentRainEvent	(1K)008			
Basin1K3	170.81	920.00	50.00	0.7200
CurrentRainEvent	(1K)014			
Basin1K4	84.05	1089.00	60.00	0.4000
CurrentRainEvent	(2E)014			
Basin1M1	59.94	981.00	30.00	1.8000
CurrentRainEvent	(1M)003			
Basin1M2	58.49	1026.00	35.00	0.9000
CurrentRainEvent	(1M)281B			
Basin1M3	89.58	774.00	55.00	0.5400
CurrentRainEvent	(1M)094			
Basin1M4	85.10	1148.00	55.00	1.0000
CurrentRainEvent	(1M)122			
Basin1M5	172.56	1073.00	30.00	0.3500
CurrentRainEvent	(1M)165			
Basin1M6	61.75	936.00	70.00	0.8850
CurrentRainEvent	(1M)162			
Basin1N1	88.52	966.00	50.00	0.5950
CurrentRainEvent	(1M)286A			
Basin1N2	72.03	1200.00	60.00	0.4500
CurrentRainEvent	(1N)013			
Basin1N3	55.41	1146.00	35.00	0.5200
CurrentRainEvent	(1N)022			
Basin1N4	155.89	1168.00	20.00	0.3200
CurrentRainEvent	(1N)025			
Basin1N5	25.71	644.00	50.00	0.2800
CurrentRainEvent	(1N)047			
Basin1N6	184.98	1412.00	55.00	0.4100
CurrentRainEvent	(1N)047			
Basin1N7	219.38	1628.00	20.00	0.5200
CurrentRainEvent	(1N)047			
Basin1N8	26.64	528.00	60.00	0.4000
CurrentRainEvent	(1N)022			
Basin1O1	249.68	1975.00	55.00	0.2800
CurrentRainEvent	(1O)305			
Basin1O2	79.92	925.00	20.00	0.6000
CurrentRainEvent	(1O)308			
Basin1O3	111.70	1524.00	60.00	0.8400
CurrentRainEvent	(1O)309			
Basin1O4	174.04	994.00	35.00	0.7100
CurrentRainEvent	(1O)157			
Basin1O5	75.94	920.00	55.00	0.2100
CurrentRainEvent	(1O)157			
Basin1P1	291.60	3120.00	20.00	0.9600
CurrentRainEvent	(1P)009			
Basin1P2	76.39	1129.00	25.00	0.6000
CurrentRainEvent	(1P)043			
Basin1P3	180.59	1324.00	20.00	0.8900
CurrentRainEvent	(1P)043			
Basin2A1	55.23	882.00	7.00	0.8500
CurrentRainEvent	(2A)014			
Basin2A2	160.41	496.00	2.00	0.7400
CurrentRainEvent	(2A)048			
Basin2B1	63.53	700.00	55.00	2.7000

CurrentRainEvent	(2A)017				
Basin2B2		65.39	760.00	60.00	2.4000
CurrentRainEvent	(2A)020				
Basin2B3		119.54	980.00	60.00	1.2000
CurrentRainEvent	(2A)020				
Basin2C1		72.70	1572.00	45.00	2.7300
CurrentRainEvent	(2C)003				
Basin2C2		32.43	657.00	35.00	4.3300
CurrentRainEvent	(2C)009				
Basin2C3		114.70	1609.00	55.00	0.5500
CurrentRainEvent	(2E)003				
Basin2D1		34.78	960.00	1.00	0.6360
CurrentRainEvent	(2D)003				
Basin2D2		315.07	2542.00	60.00	0.8000
CurrentRainEvent	(2D)011				
Basin2D3		257.89	1271.00	2.00	1.6900
CurrentRainEvent	(2D)251				
Basin2D4		75.74	1465.00	65.00	0.7800
CurrentRainEvent	(2D)045A				
Basin2D5		152.22	1363.00	35.00	0.6500
CurrentRainEvent	(2D)046A				
Basin2E1		12.18	124.00	100.00	0.8700
CurrentRainEvent	(2A)064				
Basin2E2		12.18	124.00	10.00	0.8700
CurrentRainEvent	(2E)003				
Basin2F1		42.90	765.00	40.00	0.5200
CurrentRainEvent	(2F)004				
Basin2F2		121.92	1406.00	65.00	0.4000
CurrentRainEvent	(2F)010				
Basin2F3		60.13	984.00	40.00	0.6000
CurrentRainEvent	(2F)023				
Basin2F4		21.09	571.00	35.00	0.6500
CurrentRainEvent	(2F)011				
Basin2F5		81.00	859.00	45.00	0.5400
CurrentRainEvent	(2F)025				
Basin2G1		63.27	1421.00	70.00	0.8000
CurrentRainEvent	(2G)002				
Basin2G2		267.45	2108.00	70.00	0.7100
CurrentRainEvent	(2G)040				
Basin2G3		87.80	1512.00	90.00	0.4760
CurrentRainEvent	(2G)009				
Basin2G4		158.63	2019.00	65.00	0.6700
CurrentRainEvent	(2G)019				
Basin2G5		83.08	1633.00	60.00	0.8170
CurrentRainEvent	(2G)026				
Basin2G6		191.80	1938.00	35.00	0.7540
CurrentRainEvent	(2G)359				
Basin2H10		36.16	734.00	50.00	1.0700
CurrentRainEvent	(2H)058				
Basin2H2		52.66	1074.00	30.00	0.6520
CurrentRainEvent	(2H)007				
Basin2H3		136.95	1518.00	40.00	1.2500
CurrentRainEvent	(2H)012				
Basin2H4		141.76	1331.00	35.00	1.4600
CurrentRainEvent	(2H)012				
Basin2H5		30.19	1904.00	50.00	1.6000
CurrentRainEvent	(2H)013				
Basin2H6		30.49	645.00	25.00	0.4500
CurrentRainEvent	(2H)033				
Basin2H7		54.59	1264.00	50.00	0.8560
CurrentRainEvent	(2H)049				

Basin2H8	88.81	1519.00	50.00	0.6400
CurrentRainEvent	(2H) 286			
Basin2H9	56.11	624.00	10.00	0.7200
CurrentRainEvent	(2H) 290			
Basin2I1	54.75	1223.00	40.00	1.3100
CurrentRainEvent	(2I) 003			
Basin2I10	64.12	1345.00	55.00	0.5780
CurrentRainEvent	(2I) 054			
Basin2I11	90.68	1434.00	50.00	1.6500
CurrentRainEvent	(2I) 059			
Basin2I2	31.78	998.00	45.00	0.7400
CurrentRainEvent	(2I) 001			
Basin2I3	12.37	520.00	50.00	1.0700
CurrentRainEvent	(2I) 008			
Basin2I4	51.47	1219.00	40.00	1.0200
CurrentRainEvent	(2I) 014			
Basin2I5	88.64	1518.00	50.00	1.2000
CurrentRainEvent	(2I) 020			
Basin2I6	161.34	2820.00	45.00	0.8500
CurrentRainEvent	(2I) 025A			
Basin2I7	14.57	498.00	55.00	0.9500
CurrentRainEvent	(2I) 021B			
Basin2I8	59.00	1140.00	50.00	1.1400
CurrentRainEvent	(2I) 029			
Basin2I9	123.07	2708.00	45.00	0.8700
CurrentRainEvent	(2I) 049			
Basin2J1	37.17	1245.00	90.00	0.4000
CurrentRainEvent	(2J) 008			
Basin2J2	79.20	1159.00	65.00	0.6650
CurrentRainEvent	(2J) 047			
Basin2J3	195.63	2624.00	70.00	0.0800
CurrentRainEvent	(2J) 056			
Basin2J4	63.78	739.00	65.00	1.3000
CurrentRainEvent	(2J) 026			
Basin2J5	44.99	835.00	65.00	1.7400
CurrentRainEvent	(2J) 029			
Basin2J6	37.15	920.00	50.00	0.8700
CurrentRainEvent	(2J) 032			
Basin2K1	79.62	1672.00	30.00	0.3100
CurrentRainEvent	(2K) 317			
Basin2K2	50.15	740.00	50.00	1.4000
CurrentRainEvent	(2K) 013			
Basin2K3	36.20	704.00	40.00	1.4000
CurrentRainEvent	(2K) 019			
Basin2K4	57.59	845.00	45.00	1.2000
CurrentRainEvent	(2K) 014			
Basin2K5	69.66	1017.00	50.00	1.1000
CurrentRainEvent	(2K) 025			
Basin2K6	159.22	1602.00	45.00	1.2000
CurrentRainEvent	(2K) 029			
Basin2K7	48.17	1289.00	45.00	0.8700
CurrentRainEvent	(2K) 033			
Basin2K8	82.62	1780.00	25.00	1.2000
CurrentRainEvent	(2K) 042			
Basin2K9	229.15	3100.00	25.00	1.1000
CurrentRainEvent	(2K) 052			

Node Summary

External Name Inflow	Type	Invert Elev.	Max. Depth	Ponded Area

(1A)000	JUNCTION	1147.49	10.15	0.0
(1A)000A	JUNCTION	1148.49	10.47	0.0
(1A)000B	JUNCTION	1149.40	7.55	0.0
(1A)001	JUNCTION	1149.55	6.74	0.0
Yes				
(1A)002	JUNCTION	1149.66	6.55	0.0
(1A)003	JUNCTION	1150.86	7.10	0.0
(1A)004	JUNCTION	1151.49	7.41	0.0
Yes				
(1A)005	JUNCTION	1152.36	9.12	0.0
(1A)006	JUNCTION	1154.35	9.41	0.0
(1A)007	JUNCTION	1156.40	7.83	0.0
Yes				
(1A)008	JUNCTION	1158.45	9.50	0.0
(1A)009	JUNCTION	1159.30	9.00	0.0
(1A)010	JUNCTION	1161.15	6.85	0.0
(1A)011	JUNCTION	1161.40	7.50	0.0
(1A)012	JUNCTION	1161.75	3.95	0.0
(1A)013	JUNCTION	1162.72	10.33	0.0
(1A)014	JUNCTION	1163.35	3.58	0.0
Yes				
(1A)015	JUNCTION	1164.20	12.42	0.0
Yes				
(1A)016	JUNCTION	1165.05	21.79	0.0
(1A)017	JUNCTION	1165.63	13.58	0.0
(1A)018	JUNCTION	1166.65	13.04	0.0
(1A)019	JUNCTION	1166.75	11.75	0.0
(1A)020	JUNCTION	1168.08	12.95	0.0
(1A)021	JUNCTION	1169.85	10.15	0.0
(1A)022	JUNCTION	1171.98	8.15	0.0
(1A)023	JUNCTION	1173.48	6.27	0.0
Yes				
(1A)024	JUNCTION	1175.63	6.41	0.0
(1A)024A	JUNCTION	1176.10	8.06	0.0
(1A)025	JUNCTION	1177.78	6.43	0.0
(1A)026	JUNCTION	1179.98	13.58	0.0
Yes				
(1A)027	JUNCTION	1181.71	18.54	0.0
Yes				
(1A)028	JUNCTION	1182.25	8.75	0.0
(1A)029	JUNCTION	1182.97	11.21	0.0
(1A)030	JUNCTION	1183.48	17.42	0.0
(1A)031	JUNCTION	1184.51	11.73	0.0
(1A)032	JUNCTION	1185.30	21.91	0.0
(1A)033	JUNCTION	1186.13	19.58	0.0
(1A)034	JUNCTION	1186.60	9.66	0.0
(1A)035	JUNCTION	1187.51	11.75	0.0
(1A)035A	JUNCTION	1187.96	6.54	0.0
(1A)036	JUNCTION	1188.41	4.80	0.0
(1A)037	JUNCTION	1189.24	11.11	0.0
(1A)038	JUNCTION	1189.48	11.16	0.0
(1A)039	JUNCTION	1190.43	10.29	0.0
(1A)040	JUNCTION	1191.09	10.91	0.0
(1A)041	JUNCTION	1191.43	14.50	0.0

(1A) 042	JUNCTION	1192.10	13.90	0.0
Yes				
(1B) 001	JUNCTION	1177.46	5.91	0.0
(1B) 002	JUNCTION	1178.32	13.24	0.0
(1B) 003	JUNCTION	1179.43	10.07	0.0
(1B) 004	JUNCTION	1179.50	11.00	0.0
(1B) 005	JUNCTION	1181.13	9.87	0.0
Yes				
(1B) 006	JUNCTION	1182.17	13.68	0.0
(1B) 009	JUNCTION	1182.83	18.33	0.0
Yes				
(1B) 010	JUNCTION	1185.43	22.63	0.0
Yes				
(1B) 011	JUNCTION	1186.63	10.00	0.0
(1B) 013	JUNCTION	1187.94	14.57	0.0
(1B) 014	JUNCTION	1189.14	15.35	0.0
Yes				
(1C) 001	JUNCTION	1189.67	17.11	0.0
Yes				
(1C) 001A	JUNCTION	1190.63	13.37	0.0
(1C) 001C	JUNCTION	1197.00	9.32	0.0
(1C) 001D	JUNCTION	1197.78	15.70	0.0
(1C) 001E	JUNCTION	1200.96	8.31	0.0
(1C) 001F	JUNCTION	1203.51	8.86	0.0
(1C) 001G	JUNCTION	1192.50	12.10	0.0
(1C) 002	JUNCTION	1197.77	10.08	0.0
Yes				
(1C) 003	JUNCTION	1198.02	4.87	0.0
Yes				
(1C) 004	JUNCTION	1199.20	8.06	0.0
Yes				
(1C) 005	JUNCTION	1199.21	6.29	0.0
(1C) 006	JUNCTION	1200.19	6.50	0.0
Yes				
(1C) 006A	JUNCTION	1201.52	9.41	0.0
(1C) 007	JUNCTION	1201.72	9.71	0.0
Yes				
(1C) 009	JUNCTION	1204.48	7.66	0.0
(1C) 010	JUNCTION	1206.53	12.73	0.0
(1C) 011	JUNCTION	1207.35	12.45	0.0
(1C) 012	JUNCTION	1213.57	11.50	0.0
(1C) 015A	JUNCTION	1207.53	12.27	0.0
Yes				
(1C) 015B	JUNCTION	1210.11	13.16	0.0
(1C) 015C	JUNCTION	1211.45	6.82	0.0
(1C) 015D	JUNCTION	1213.01	12.75	0.0
Yes				
(1C) 016	JUNCTION	1214.45	13.65	0.0
Yes				
(1C) 016A	JUNCTION	1215.24	17.31	0.0
Yes				
(1C) 016B	JUNCTION	1216.58	12.15	0.0
(1C) 016C	JUNCTION	1217.91	16.94	0.0
(1C) 017	JUNCTION	1217.62	9.75	0.0
(1C) 018	JUNCTION	1219.18	13.83	0.0
(1C) 019	JUNCTION	1220.23	14.75	0.0
Yes				
(1C) 020	JUNCTION	1221.53	10.00	0.0
Yes				
(1C) 021	JUNCTION	1220.22	10.58	0.0
(1C) 021A	JUNCTION	1220.98	15.62	0.0

(1C)021B	JUNCTION	1221.82	17.83	0.0
Yes				
(1C)021C	JUNCTION	1222.98	16.12	0.0
(1C)021D	JUNCTION	1223.96	14.88	0.0
(1C)022	JUNCTION	1222.93	11.50	0.0
Yes				
(1C)023	JUNCTION	1224.25	11.08	0.0
(1C)024	JUNCTION	1225.16	11.96	0.0
Yes				
(1C)025	JUNCTION	1225.56	12.67	0.0
(1C)027	JUNCTION	1227.94	11.62	0.0
Yes				
(1C)028	JUNCTION	1229.01	10.71	0.0
Yes				
(1C)041	JUNCTION	1203.83	8.89	0.0
Yes				
(1C)176	JUNCTION	1200.93	12.83	0.0
Yes				
(1C)177	JUNCTION	1203.93	12.58	0.0
Yes				
(1C)178	JUNCTION	1207.12	14.25	0.0
Yes				
(1C)179	JUNCTION	1210.13	17.25	0.0
Yes				
(1C)179A	JUNCTION	1210.23	17.55	0.0
(1C)180	JUNCTION	1213.24	14.92	0.0
Yes				
(1C)180A	JUNCTION	1216.23	17.29	0.0
Yes				
(1C)181	JUNCTION	1219.17	13.22	0.0
Yes				
(1C)182	JUNCTION	1220.72	12.00	0.0
Yes				
(1D)001	JUNCTION	1172.98	8.92	0.0
Yes				
(1D)002	JUNCTION	1174.79	11.32	0.0
(1D)003	JUNCTION	1176.34	12.82	0.0
(1D)004	JUNCTION	1181.16	8.92	0.0
(1D)005	JUNCTION	1183.10	8.08	0.0
Yes				
(1D)006	JUNCTION	1185.15	7.67	0.0
(1D)007	JUNCTION	1188.98	6.25	0.0
(1D)008	JUNCTION	1192.99	12.83	0.0
(1D)009	JUNCTION	1194.68	12.20	0.0
(1D)010	JUNCTION	1195.50	13.04	0.0
(1D)011	JUNCTION	1196.22	7.04	0.0
(1D)012	JUNCTION	1197.04	11.51	0.0
Yes				
(1D)013	JUNCTION	1204.18	15.08	0.0
(1D)014	JUNCTION	1205.83	6.35	0.0
Yes				
(1D)015	JUNCTION	1207.25	9.46	0.0
Yes				
(1D)016	JUNCTION	1208.23	10.29	0.0
Yes				
(1D)017	JUNCTION	1209.21	9.75	0.0
Yes				
(1D)018	JUNCTION	1210.19	13.83	0.0
Yes				
(1D)019	JUNCTION	1211.19	14.45	0.0
(1D)020	JUNCTION	1212.14	16.45	0.0

Yes	(1D) 021	JUNCTION	1213.10	17.21	0.0
Yes	(1D) 022	JUNCTION	1214.12	16.91	0.0
Yes	(1D) 023	JUNCTION	1215.10	14.72	0.0
Yes	(1E) 001	JUNCTION	1191.96	9.12	0.0
	(1E) 002	JUNCTION	1193.20	7.50	0.0
	(1E) 003	JUNCTION	1194.72	6.75	0.0
	(1E) 003A	JUNCTION	1196.00	5.91	0.0
	(1E) 005	JUNCTION	1197.60	10.95	0.0
Yes	(1E) 006	JUNCTION	1199.00	26.26	0.0
	(1E) 007	JUNCTION	1200.04	27.04	0.0
	(1E) 008	JUNCTION	1201.70	10.00	0.0
	(1E) 009	JUNCTION	1202.53	7.81	0.0
Yes	(1F) 001	JUNCTION	1195.23	17.39	0.0
Yes	(1F) 003	JUNCTION	1199.20	28.61	0.0
Yes	(1F) 004	JUNCTION	1199.78	9.94	0.0
Yes	(1F) 005	JUNCTION	1199.88	6.43	0.0
	(1F) 006	JUNCTION	1200.11	6.80	0.0
Yes	(1F) 008	JUNCTION	1200.42	7.39	0.0
Yes	(1F) 008A	JUNCTION	1200.54	7.27	0.0
	(1F) 009	JUNCTION	1200.64	8.38	0.0
Yes	(1F) 010	JUNCTION	1200.81	7.96	0.0
Yes	(1F) 011	JUNCTION	1201.45	7.27	0.0
Yes	(1F) 012A	JUNCTION	1202.47	10.15	0.0
	(1F) 013	JUNCTION	1203.80	12.34	0.0
Yes	(1F) 014	JUNCTION	1203.90	13.03	0.0
	(1F) 015	JUNCTION	1204.98	11.22	0.0
	(1F) 016	JUNCTION	1205.75	12.60	0.0
Yes	(1F) 017	JUNCTION	1200.94	14.56	0.0
	(1F) 017A	JUNCTION	1201.33	17.37	0.0
Yes	(1F) 017B	JUNCTION	1201.48	18.52	0.0
	(1F) 017C	JUNCTION	1201.83	12.17	0.0
Yes	(1F) 017D	JUNCTION	1201.95	14.25	0.0
	(1F) 017E	JUNCTION	1202.33	10.67	0.0
	(1F) 017F	JUNCTION	1203.20	9.20	0.0
	(1F) 017G	JUNCTION	1206.11	5.41	0.0
Yes	(1F) 018	JUNCTION	1207.14	7.34	0.0
Yes	(1F) 019	JUNCTION	1207.88	8.75	0.0
	(1F) 020	JUNCTION	1210.44	9.83	0.0
	(1F) 021	JUNCTION	1212.29	8.00	0.0
Yes	(1F) 022	JUNCTION	1213.80	9.00	0.0

(1F)023	JUNCTION	1214.89	10.58	0.0
(1F)024	JUNCTION	1221.63	12.10	0.0
(1F)025	JUNCTION	1227.07	11.13	0.0
Yes				
(1F)026	JUNCTION	1233.06	11.31	0.0
(1F)026A	JUNCTION	1233.63	10.37	0.0
Yes				
(1F)027	JUNCTION	1234.23	10.77	0.0
Yes				
(1F)028	JUNCTION	1234.74	10.26	0.0
Yes				
(1F)029	JUNCTION	1235.33	11.17	0.0
(1F)029A	JUNCTION	1235.93	10.07	0.0
(1F)030	JUNCTION	1236.67	9.83	0.0
Yes				
(1G)001	JUNCTION	1203.21	14.39	0.0
Yes				
(1G)001A	JUNCTION	1203.60	14.91	0.0
(1G)002	JUNCTION	1204.07	15.43	0.0
Yes				
(1G)003	JUNCTION	1204.34	17.96	0.0
Yes				
(1G)004	JUNCTION	1204.67	17.93	0.0
(1G)005	JUNCTION	1205.17	16.83	0.0
Yes				
(1G)006	JUNCTION	1205.27	18.23	0.0
(1G)007	JUNCTION	1205.65	18.95	0.0
(1G)008A	JUNCTION	1206.37	17.13	0.0
Yes				
(1G)008B	JUNCTION	1207.27	16.46	0.0
(1G)008C	JUNCTION	1207.65	18.85	0.0
Yes				
(1G)009A	JUNCTION	1208.02	18.48	0.0
Yes				
(1G)009B	JUNCTION	1208.47	18.23	0.0
(1G)009C	JUNCTION	1208.92	23.78	0.0
Yes				
(1G)009D	JUNCTION	1208.98	23.62	0.0
(1G)009E	JUNCTION	1209.23	22.47	0.0
(1G)010	JUNCTION	1209.71	21.79	0.0
Yes				
(1G)011	JUNCTION	1210.07	19.53	0.0
(1G)012	JUNCTION	1210.60	18.40	0.0
Yes				
(1G)013	JUNCTION	1211.10	19.90	0.0
(1G)014	JUNCTION	1219.94	8.46	0.0
Yes				
(1G)014A	JUNCTION	1220.58	12.00	0.0
(1G)015	JUNCTION	1221.70	12.00	0.0
(1G)016	JUNCTION	1222.48	10.37	0.0
Yes				
(1G)017	JUNCTION	1223.20	11.51	0.0
(1G)018	JUNCTION	1224.02	13.08	0.0
Yes				
(1G)018A	JUNCTION	1224.19	14.08	0.0
(1G)020	JUNCTION	1225.79	12.75	0.0
Yes				
(1G)045	JUNCTION	1227.75	12.50	0.0
Yes				
(1G)046	JUNCTION	1228.74	12.54	0.0
(1G)047	JUNCTION	1229.09	10.39	0.0

Yes

(1G)048	JUNCTION	1230.30	9.50	0.0
(1G)049	JUNCTION	1230.86	8.76	0.0
(1G)050	JUNCTION	1231.25	8.50	0.0
(1G)051	JUNCTION	1231.67	8.62	0.0
(1G)052	JUNCTION	1232.08	8.50	0.0
(1G)053	JUNCTION	1232.91	8.50	0.0
(1G)054	JUNCTION	1233.71	8.50	0.0
(1G)055	JUNCTION	1234.52	8.50	0.0
(1G)056	JUNCTION	1235.32	9.00	0.0
(1G)057	JUNCTION	1237.14	9.00	0.0
(1G)058	JUNCTION	1238.97	9.00	0.0
(1G)059	JUNCTION	1240.68	9.00	0.0
(1G)060	JUNCTION	1240.82	10.00	0.0
(1G)061	JUNCTION	1242.52	10.00	0.0
(1G)062	JUNCTION	1244.52	10.00	0.0
(1G)063	JUNCTION	1244.88	10.00	0.0
(1G)064	JUNCTION	1247.02	10.15	0.0
(1G)065	JUNCTION	1248.49	10.15	0.0
(1G)066	JUNCTION	1249.44	10.15	0.0
(1G)067	JUNCTION	1251.15	10.15	0.0
(1G)068	JUNCTION	1253.26	10.15	0.0
(1G)069	JUNCTION	1255.78	10.15	0.0
(1G)070	JUNCTION	1257.94	10.15	0.0
(1G)071	JUNCTION	1259.60	10.15	0.0
(1G)146	JUNCTION	1204.48	16.00	0.0
(1G)146A	JUNCTION	1204.74	17.00	0.0
(1G)162	JUNCTION	1217.52	15.00	0.0

Yes

(1G)162A	JUNCTION	1218.46	15.00	0.0
(1G)162B	JUNCTION	1219.16	14.50	0.0
(1G)162C	JUNCTION	1219.99	14.00	0.0
(1G)162D	JUNCTION	1215.93	14.32	0.0
(1G)243	JUNCTION	1229.12	12.50	0.0
(1H)001	JUNCTION	1215.96	10.00	0.0

Yes

(1H)004	JUNCTION	1218.26	9.00	0.0
(1H)005	JUNCTION	1218.28	9.73	0.0
(1H)006	JUNCTION	1219.78	9.23	0.0
(1H)007	JUNCTION	1220.69	11.27	0.0
(1H)008	JUNCTION	1221.86	15.97	0.0
(1H)009	JUNCTION	1222.00	10.60	0.0

Yes

(1H)010	JUNCTION	1222.39	12.27	0.0
(1H)011	JUNCTION	1223.00	12.00	0.0

Yes

(1H)038	JUNCTION	1218.81	7.92	0.0
---------	----------	---------	------	-----

Yes

(1H)039	JUNCTION	1224.03	13.60	0.0
(1H)040	JUNCTION	1228.46	9.17	0.0
(1H)041	JUNCTION	1229.00	9.00	0.0
(1H)042	JUNCTION	1230.85	10.53	0.0
(1H)043	JUNCTION	1231.34	10.11	0.0

Yes

(1H)044	JUNCTION	1232.62	9.40	0.0
---------	----------	---------	------	-----

Yes

(1H)045	JUNCTION	1233.56	9.50	0.0
---------	----------	---------	------	-----

Yes

(1J)001	JUNCTION	1192.96	25.54	0.0
(1J)002	JUNCTION	1194.02	28.98	0.0
(1J)003	JUNCTION	1194.78	17.52	0.0

Yes					
	(1J)004	JUNCTION	1195.54	17.26	0.0
	(1J)005	JUNCTION	1196.30	16.90	0.0
	(1J)006	JUNCTION	1197.02	8.18	0.0
Yes					
	(1J)007	JUNCTION	1197.52	6.68	0.0
	(1J)008	JUNCTION	1197.85	9.55	0.0
	(1J)009	JUNCTION	1198.23	10.77	0.0
	(1J)010	JUNCTION	1198.82	13.18	0.0
	(1J)011	JUNCTION	1199.05	12.30	0.0
Yes					
	(1J)012	JUNCTION	1199.56	13.24	0.0
	(1J)013	JUNCTION	1200.07	19.59	0.0
	(1J)014	JUNCTION	1200.42	22.78	0.0
	(1J)041	JUNCTION	1200.90	20.10	0.0
	(1J)042	JUNCTION	1204.16	10.41	0.0
	(1J)042A	JUNCTION	1206.48	8.17	0.0
	(1J)042B	JUNCTION	1210.10	13.40	0.0
	(1J)043	JUNCTION	1213.06	20.17	0.0
	(1J)044	JUNCTION	1213.85	29.00	0.0
Yes					
	(1J)045	JUNCTION	1214.48	20.66	0.0
	(1J)046	JUNCTION	1214.69	10.05	0.0
Yes					
	(1J)047	JUNCTION	1214.79	9.79	0.0
	(1J)048	JUNCTION	1215.34	10.83	0.0
	(1J)050	JUNCTION	1216.89	11.08	0.0
Yes					
	(1J)050A	JUNCTION	1216.98	11.37	0.0
	(1J)051	JUNCTION	1218.77	12.17	0.0
	(1J)052	JUNCTION	1218.82	10.80	0.0
	(1J)053	JUNCTION	1218.97	9.51	0.0
Yes					
	(1J)054	JUNCTION	1220.30	16.33	0.0
	(1J)054A	JUNCTION	1220.61	13.91	0.0
	(1J)055	JUNCTION	1220.70	23.66	0.0
	(1J)056	JUNCTION	1221.52	17.41	0.0
	(1J)057	JUNCTION	1222.08	23.75	0.0
	(1J)058	JUNCTION	1222.75	12.50	0.0
	(1J)059	JUNCTION	1223.04	11.50	0.0
	(1J)060	JUNCTION	1223.25	10.58	0.0
	(1K)001	JUNCTION	1229.15	13.83	0.0
Yes					
	(1K)002	JUNCTION	1229.68	8.33	0.0
	(1K)002A	JUNCTION	1230.13	7.62	0.0
Yes					
	(1K)003	JUNCTION	1230.51	9.13	0.0
	(1K)004	JUNCTION	1231.11	7.95	0.0
Yes					
	(1K)005	JUNCTION	1231.97	7.66	0.0
Yes					
	(1K)006	JUNCTION	1231.98	7.45	0.0
Yes					
	(1K)007	JUNCTION	1232.87	6.91	0.0
Yes					
	(1K)008	JUNCTION	1233.66	11.04	0.0
Yes					
	(1K)008A	JUNCTION	1234.10	15.90	0.0
Yes					
	(1K)009	JUNCTION	1234.46	13.33	0.0
Yes					

(1K)010	JUNCTION	1235.24	12.91	0.0
Yes				
(1K)011	JUNCTION	1235.70	12.12	0.0
Yes				
(1K)012	JUNCTION	1236.58	10.80	0.0
(1K)013	JUNCTION	1237.18	23.41	0.0
(1K)014	JUNCTION	1237.66	8.77	0.0
(1M)000	JUNCTION	1211.52	18.28	0.0
(1M)001	JUNCTION	1214.55	19.45	0.0
(1M)001A	JUNCTION	1213.08	17.00	0.0
(1M)001B	JUNCTION	1212.04	17.00	0.0
(1M)002	JUNCTION	1215.45	18.05	0.0
(1M)003	JUNCTION	1216.05	19.45	0.0
Yes				
(1M)010	JUNCTION	1220.34	16.17	0.0
(1M)011	JUNCTION	1221.30	13.54	0.0
(1M)013	JUNCTION	1222.58	15.65	0.0
(1M)014	JUNCTION	1223.61	16.39	0.0
(1M)015	JUNCTION	1224.66	14.12	0.0
(1M)016	JUNCTION	1225.84	18.00	0.0
(1M)017	JUNCTION	1225.97	18.00	0.0
(1M)018	JUNCTION	1226.49	21.83	0.0
(1M)019	JUNCTION	1227.30	18.75	0.0
(1M)021	JUNCTION	1229.11	14.25	0.0
(1M)022	JUNCTION	1229.75	13.12	0.0
Yes				
(1M)023	JUNCTION	1230.40	14.08	0.0
(1M)024	JUNCTION	1231.80	13.08	0.0
(1M)025	JUNCTION	1232.70	11.58	0.0
(1M)026	JUNCTION	1233.51	11.58	0.0
(1M)027	JUNCTION	1234.86	11.50	0.0
(1M)028	JUNCTION	1235.85	11.50	0.0
(1M)035	JUNCTION	1219.42	10.00	0.0
Yes				
(1M)036	JUNCTION	1219.87	8.00	0.0
(1M)037	JUNCTION	1220.45	8.81	0.0
Yes				
(1M)038	JUNCTION	1221.00	8.75	0.0
(1M)039	JUNCTION	1222.37	8.58	0.0
Yes				
(1M)040	JUNCTION	1223.02	9.00	0.0
(1M)041	JUNCTION	1224.04	9.25	0.0
Yes				
(1M)092	JUNCTION	1225.07	8.65	0.0
Yes				
(1M)093	JUNCTION	1225.23	8.83	0.0
Yes				
(1M)094	JUNCTION	1226.75	10.50	0.0
Yes				
(1M)116	JUNCTION	1226.94	10.54	0.0
(1M)117	JUNCTION	1227.17	10.12	0.0
(1M)118	JUNCTION	1227.76	10.46	0.0
(1M)119	JUNCTION	1228.92	7.08	0.0
Yes				
(1M)120	JUNCTION	1229.10	7.08	0.0
(1M)121	JUNCTION	1230.22	5.80	0.0
(1M)122	JUNCTION	1230.83	10.87	0.0
(1M)123	JUNCTION	1231.73	6.15	0.0
Yes				
(1M)124	JUNCTION	1232.93	8.67	0.0
(1M)125	JUNCTION	1233.60	4.13	0.0

(1M) 126	JUNCTION	1234.19	5.08	0.0
(1M) 127	JUNCTION	1235.51	4.29	0.0
(1M) 128	JUNCTION	1236.19	4.38	0.0
Yes				
(1M) 129	JUNCTION	1237.12	43.00	0.0
Yes				
(1M) 130	JUNCTION	1237.35	43.00	0.0
(1M) 131	JUNCTION	1237.88	4.50	0.0
Yes				
(1M) 132	JUNCTION	1238.94	6.04	0.0
Yes				
(1M) 133	JUNCTION	1239.94	5.39	0.0
Yes				
(1M) 161	JUNCTION	1236.00	18.25	0.0
(1M) 162	JUNCTION	1237.77	12.50	0.0
(1M) 163	JUNCTION	1239.56	17.79	0.0
(1M) 164	JUNCTION	1241.36	15.56	0.0
(1M) 165	JUNCTION	1243.19	15.81	0.0
(1M) 278	JUNCTION	1217.03	21.77	0.0
Yes				
(1M) 279	JUNCTION	1217.50	17.50	0.0
(1M) 279B	JUNCTION	1217.94	16.66	0.0
(1M) 281	JUNCTION	1218.99	18.51	0.0
(1M) 281B	JUNCTION	1219.65	18.35	0.0
Yes				
(1M) 282	JUNCTION	1220.15	18.35	0.0
(1M) 283	JUNCTION	1220.70	16.80	0.0
Yes				
(1M) 284	JUNCTION	1228.47	24.03	0.0
(1M) 285	JUNCTION	1229.45	27.05	0.0
(1M) 285A	JUNCTION	1229.86	28.04	0.0
(1M) 286	JUNCTION	1230.38	27.12	0.0
(1M) 286A	JUNCTION	1231.05	28.15	0.0
Yes				
(1M) 287	JUNCTION	1231.72	26.98	0.0
(1M) 288	JUNCTION	1232.47	26.23	0.0
(1M) 288A	JUNCTION	1233.02	24.98	0.0
(1M) 288B	JUNCTION	1233.66	25.34	0.0
(1M) 288C	JUNCTION	1234.21	25.79	0.0
(1N) 004	JUNCTION	1221.21	17.39	0.0
Yes				
(1N) 005	JUNCTION	1222.11	13.00	0.0
Yes				
(1N) 006	JUNCTION	1223.16	22.14	0.0
Yes				
(1N) 007	JUNCTION	1224.19	17.91	0.0
Yes				
(1N) 007D	JUNCTION	1224.47	17.50	0.0
(1N) 007E	JUNCTION	1224.72	17.20	0.0
(1N) 008	JUNCTION	1225.77	5.42	0.0
Yes				
(1N) 009	JUNCTION	1226.30	8.10	0.0
Yes				
(1N) 011	JUNCTION	1227.43	3.44	0.0
Yes				
(1N) 013	JUNCTION	1228.60	4.85	0.0
Yes				
(1N) 014	JUNCTION	1229.77	6.75	0.0
Yes				
(1N) 015	JUNCTION	1230.32	7.65	0.0
Yes				

(1N) 016	JUNCTION	1231.22	6.54	0.0
(1N) 017	JUNCTION	1232.30	8.00	0.0
(1N) 018	JUNCTION	1232.88	9.13	0.0
Yes				
(1N) 019	JUNCTION	1233.44	8.92	0.0
(1N) 020	JUNCTION	1234.51	9.60	0.0
Yes				
(1N) 021	JUNCTION	1235.58	10.21	0.0
Yes				
(1N) 022	JUNCTION	1236.64	11.25	0.0
Yes				
(1N) 023	JUNCTION	1237.73	12.50	0.0
(1N) 024	JUNCTION	1238.78	11.83	0.0
(1N) 025	JUNCTION	1240.18	10.79	0.0
Yes				
(1N) 045	JUNCTION	1227.96	16.25	0.0
(1N) 046	JUNCTION	1229.55	16.83	0.0
(1N) 047	JUNCTION	1230.68	17.50	0.0
Yes				
(1N) 109A	JUNCTION	1225.06	20.24	0.0
(1N) 110	JUNCTION	1225.92	22.58	0.0
Yes				
(1N) 111A	JUNCTION	1226.78	22.42	0.0
(1N) 112A	JUNCTION	1227.62	22.18	0.0
(1N) 112B	JUNCTION	1228.10	23.10	0.0
(10) 001	JUNCTION	1236.24	11.10	0.0
Yes				
(10) 001A	JUNCTION	1237.05	12.57	0.0
(10) 002	JUNCTION	1237.20	12.36	0.0
Yes				
(10) 002A	JUNCTION	1237.34	11.95	0.0
(10) 003	JUNCTION	1238.00	11.50	0.0
(10) 004	JUNCTION	1238.55	12.00	0.0
Yes				
(10) 005A	JUNCTION	1239.29	16.70	0.0
Yes				
(10) 005B	JUNCTION	1239.48	16.22	0.0
(10) 005C	JUNCTION	1239.66	16.12	0.0
(10) 005D	JUNCTION	1239.82	15.92	0.0
(10) 005E	JUNCTION	1239.83	13.25	0.0
(10) 010	JUNCTION	1251.71	12.79	0.0
(10) 011	JUNCTION	1251.77	12.81	0.0
(10) 012	JUNCTION	1252.51	12.91	0.0
(10) 013	JUNCTION	1253.50	13.20	0.0
(10) 014	JUNCTION	1253.87	13.43	0.0
(10) 015	JUNCTION	1255.16	21.64	0.0
(10) 016	JUNCTION	1256.10	21.40	0.0
(10) 017	JUNCTION	1257.34	20.86	0.0
(10) 018	JUNCTION	1258.62	18.78	0.0
(10) 019	JUNCTION	1260.25	17.02	0.0
(10) 020	JUNCTION	1261.74	14.53	0.0
(10) 021	JUNCTION	1262.57	15.24	0.0
(10) 072	JUNCTION	1238.16	19.54	0.0
Yes				
(10) 157	JUNCTION	1251.77	14.03	0.0
Yes				
(10) 300	JUNCTION	1234.84	27.06	0.0
Yes				
(10) 301	JUNCTION	1235.62	27.38	0.0
(10) 302	JUNCTION	1236.45	23.55	0.0
Yes				

(10) 303	JUNCTION	1237.31	21.59	0.0
Yes				
(10) 304A	JUNCTION	1249.69	12.00	0.0
(10) 304B	JUNCTION	1240.00	20.00	0.0
(10) 305	JUNCTION	1248.55	12.65	0.0
Yes				
(10) 305A	JUNCTION	1248.50	10.80	0.0
Yes				
(10) 306	JUNCTION	1249.39	12.61	0.0
Yes				
(10) 306A	JUNCTION	1250.23	13.57	0.0
Yes				
(10) 307	JUNCTION	1250.66	13.34	0.0
(10) 308	JUNCTION	1251.17	13.96	0.0
(10) 308A	JUNCTION	1251.31	13.79	0.0
(10) 309	JUNCTION	1251.58	13.14	0.0
Yes				
(1P) 002	JUNCTION	1130.00	12.35	0.0
(1P) 003	JUNCTION	1130.42	12.25	0.0
(1P) 004	JUNCTION	1131.88	12.50	0.0
(1P) 005	JUNCTION	1134.50	11.80	0.0
(1P) 006	JUNCTION	1136.62	12.78	0.0
(1P) 007	JUNCTION	1140.56	13.39	0.0
(1P) 008	JUNCTION	1143.00	14.00	0.0
Yes				
(1P) 008A	JUNCTION	1143.50	14.00	0.0
(1P) 009	JUNCTION	1146.76	11.67	0.0
(1P) 010	JUNCTION	1147.05	11.17	0.0
(1P) 011	JUNCTION	1149.42	11.58	0.0
Yes				
(1P) 012	JUNCTION	1151.82	12.08	0.0
(1P) 013	JUNCTION	1154.18	12.85	0.0
(1P) 014	JUNCTION	1156.54	12.79	0.0
(1P) 015	JUNCTION	1158.90	13.85	0.0
(1P) 016	JUNCTION	1160.71	14.88	0.0
(1P) 016A	JUNCTION	1161.55	15.58	0.0
(1P) 017	JUNCTION	1161.88	16.25	0.0
Yes				
(1P) 018	JUNCTION	1163.77	14.63	0.0
Yes				
(1P) 024	JUNCTION	1164.09	11.56	0.0
Yes				
(1P) 042	JUNCTION	1133.28	9.92	0.0
(1P) 042A	JUNCTION	1134.72	12.37	0.0
(1P) 043	JUNCTION	1136.16	13.92	0.0
Yes				
(1P) 044	JUNCTION	1136.52	4.08	0.0
(1P) 065	JUNCTION	1137.24	16.76	0.0
Yes				
(1P) 073	JUNCTION	1164.26	13.87	0.0
Yes				
(1P) 079	JUNCTION	1162.58	15.90	0.0
Yes				
(2A) 001	JUNCTION	1146.85	12.25	0.0
(2A) 002	JUNCTION	1148.65	11.82	0.0
(2A) 003	JUNCTION	1149.77	11.98	0.0
(2A) 004	JUNCTION	1150.99	10.51	0.0
(2A) 005	JUNCTION	1152.28	14.52	0.0
(2A) 006	JUNCTION	1152.81	15.99	0.0
(2A) 007	JUNCTION	1153.44	13.91	0.0
(2A) 008	JUNCTION	1153.93	10.47	0.0

(2A) 009	JUNCTION	1154.63	7.97	0.0
(2A) 010	JUNCTION	1155.34	9.46	0.0
(2A) 011	JUNCTION	1156.05	10.55	0.0
(2A) 012	JUNCTION	1156.66	6.64	0.0
(2A) 013	JUNCTION	1157.26	7.69	0.0
(2A) 014	JUNCTION	1157.94	6.06	0.0
(2A) 015	JUNCTION	1158.17	10.03	0.0
Yes				
(2A) 016	JUNCTION	1158.49	10.51	0.0
(2A) 017	JUNCTION	1159.12	10.93	0.0
(2A) 018	JUNCTION	1159.49	8.51	0.0
(2A) 019	JUNCTION	1159.85	8.20	0.0
(2A) 020	JUNCTION	1160.69	13.01	0.0
Yes				
(2A) 021	JUNCTION	1162.47	7.53	0.0
(2A) 022	JUNCTION	1164.35	8.20	0.0
(2A) 023	JUNCTION	1165.27	5.98	0.0
(2A) 024	JUNCTION	1165.74	12.71	0.0
(2A) 025	JUNCTION	1166.00	12.95	0.0
(2A) 026	JUNCTION	1166.39	9.86	0.0
(2A) 027	JUNCTION	1167.09	10.96	0.0
(2A) 028	JUNCTION	1167.45	10.75	0.0
(2A) 029	JUNCTION	1167.80	7.47	0.0
(2A) 030	JUNCTION	1168.20	10.00	0.0
(2A) 031	JUNCTION	1169.51	7.79	0.0
(2A) 032	JUNCTION	1169.69	11.81	0.0
(2A) 033	JUNCTION	1170.06	12.99	0.0
(2A) 034	JUNCTION	1170.29	11.06	0.0
Yes				
(2A) 035	JUNCTION	1172.03	11.17	0.0
(2A) 036	JUNCTION	1173.77	10.83	0.0
(2A) 037	JUNCTION	1175.50	7.00	0.0
(2A) 038	JUNCTION	1177.24	13.84	0.0
(2A) 039	JUNCTION	1178.79	15.51	0.0
(2A) 040	JUNCTION	1180.22	19.20	0.0
(2A) 041	JUNCTION	1181.95	14.05	0.0
(2A) 042	JUNCTION	1183.55	23.75	0.0
(2A) 043	JUNCTION	1185.38	19.02	0.0
(2A) 044	JUNCTION	1186.70	7.95	0.0
(2A) 045	JUNCTION	1187.90	9.50	0.0
(2A) 046	JUNCTION	1189.40	6.00	0.0
(2A) 047	JUNCTION	1190.00	9.00	0.0
(2A) 049	JUNCTION	1191.47	8.03	0.0
(2A) 050	JUNCTION	1192.29	10.01	0.0
(2A) 051	JUNCTION	1193.69	16.01	0.0
(2A) 052	JUNCTION	1195.09	12.01	0.0
(2A) 053	JUNCTION	1196.14	14.46	0.0
(2A) 054	JUNCTION	1199.19	11.99	0.0
(2A) 055	JUNCTION	1199.85	10.50	0.0
(2A) 056	JUNCTION	1200.67	9.73	0.0
(2A) 057	JUNCTION	1202.00	7.52	0.0
(2A) 058	JUNCTION	1203.10	14.00	0.0
(2A) 059	JUNCTION	1204.22	7.78	0.0
(2A) 060	JUNCTION	1205.74	7.96	0.0
(2A) 061	JUNCTION	1206.97	7.54	0.0
(2A) 062	JUNCTION	1209.26	6.75	0.0
(2A) 063	JUNCTION	1212.01	7.36	0.0
(2A) 064	JUNCTION	1213.93	10.97	0.0
(2A) 065	JUNCTION	1215.87	24.03	0.0
(2A) 066	JUNCTION	1225.01	20.64	0.0
(2A) 067	JUNCTION	1225.79	20.01	0.0

(2A) 068	JUNCTION	1227.02	20.68	0.0
(2A) 069	JUNCTION	1205.82	20.33	0.0
(2C) 001	JUNCTION	1206.10	13.90	0.0
(2C) 002	JUNCTION	1206.40	13.60	0.0
(2C) 003	JUNCTION	1207.06	10.94	0.0
(2C) 004	JUNCTION	1207.78	12.22	0.0
(2C) 005	JUNCTION	1208.49	7.51	0.0
(2C) 006	JUNCTION	1209.02	5.79	0.0
(2C) 007	JUNCTION	1209.50	5.21	0.0
(2C) 008	JUNCTION	1209.91	3.33	0.0
(2D) 001	JUNCTION	1211.09	3.41	0.0
(2D) 001A	JUNCTION	1211.45	5.83	0.0
(2D) 002	JUNCTION	1213.00	7.00	0.0
(2D) 003	JUNCTION	1214.70	8.17	0.0
(2D) 004	JUNCTION	1216.27	8.37	0.0
(2D) 005	JUNCTION	1217.86	9.75	0.0
(2D) 006	JUNCTION	1219.49	12.21	0.0
Yes				
(2D) 007	JUNCTION	1221.35	6.75	0.0
(2D) 008	JUNCTION	1222.34	16.66	0.0
(2D) 009	JUNCTION	1225.04	19.96	0.0
Yes				
(2D) 010	JUNCTION	1225.44	20.56	0.0
(2D) 011	JUNCTION	1226.12	19.88	0.0
Yes				
(2D) 012	JUNCTION	1227.96	24.04	0.0
Yes				
(2D) 013	JUNCTION	1229.15	24.85	0.0
Yes				
(2D) 014	JUNCTION	1229.96	25.04	0.0
(2D) 015	JUNCTION	1240.96	10.04	0.0
(2D) 016	JUNCTION	1243.40	12.60	0.0
(2D) 017	JUNCTION	1245.11	13.89	0.0
(2D) 018	JUNCTION	1245.82	14.18	0.0
(2D) 019	JUNCTION	1246.10	13.90	0.0
(2D) 020	JUNCTION	1246.74	14.26	0.0
(2D) 021	JUNCTION	1248.58	13.42	0.0
(2D) 022	JUNCTION	1249.58	12.42	0.0
(2D) 023	JUNCTION	1249.81	12.19	0.0
(2D) 024	JUNCTION	1251.25	11.75	0.0
(2D) 025	JUNCTION	1251.56	10.44	0.0
(2D) 039	JUNCTION	1216.06	5.75	0.0
(2D) 040	JUNCTION	1217.64	21.42	0.0
(2D) 041	JUNCTION	1219.24	10.76	0.0
(2D) 042	JUNCTION	1220.74	24.71	0.0
(2D) 043	JUNCTION	1222.54	23.08	0.0
(2D) 044	JUNCTION	1224.34	6.66	0.0
(2D) 045	JUNCTION	1226.14	21.81	0.0
Yes				
(2D) 045A	JUNCTION	1226.86	18.00	0.0
(2D) 046	JUNCTION	1227.76	15.08	0.0
Yes				
(2D) 046A	JUNCTION	1228.58	1305.00	0.0
Yes				
(2D) 241	JUNCTION	1213.87	16.13	0.0
(2D) 242	JUNCTION	1214.91	18.09	0.0
(2D) 243	JUNCTION	1215.83	19.17	0.0
(2D) 245	JUNCTION	1217.50	19.50	0.0
(2D) 246	JUNCTION	1218.27	11.73	0.0
(2D) 247	JUNCTION	1219.05	11.95	0.0
(2D) 248	JUNCTION	1219.87	11.13	0.0

(2D) 249	JUNCTION	1220.73	13.27	0.0
(2D) 250	JUNCTION	1221.22	4.78	0.0
(2D) 251	JUNCTION	1221.92	12.94	0.0
(2D) 252	JUNCTION	1223.01	13.99	0.0
(2D) 253	JUNCTION	1223.49	10.51	0.0
(2D) 254	JUNCTION	1224.43	20.57	0.0
(2D) 255	JUNCTION	1225.31	14.69	0.0
(2D) 256	JUNCTION	1226.09	13.91	0.0
(2D) 257	JUNCTION	1226.72	14.28	0.0
(2D) 258	JUNCTION	1227.40	10.60	0.0
(2D) 259	JUNCTION	1228.12	14.88	0.0
(2D) 260	JUNCTION	1228.76	11.24	0.0
(2D) 261	JUNCTION	1229.46	10.54	0.0
(2D) 262	JUNCTION	1230.61	9.39	0.0
(2D) 263	JUNCTION	1231.64	6.36	0.0
Yes				
(2D) 264	JUNCTION	1232.56	12.44	0.0
(2D) 265	JUNCTION	1233.31	9.69	0.0
(2D) 266	JUNCTION	1234.21	9.79	0.0
(2D) 267	JUNCTION	1235.19	14.81	0.0
Yes				
(2E) 001	JUNCTION	1227.46	19.08	0.0
(2E) 002	JUNCTION	1228.25	22.41	0.0
(2E) 003	JUNCTION	1229.22	15.41	0.0
Yes				
(2E) 004	JUNCTION	1229.58	11.83	0.0
(2E) 005	JUNCTION	1229.72	18.33	0.0
(2E) 006	JUNCTION	1229.96	18.50	0.0
(2E) 007	JUNCTION	1230.66	18.54	0.0
(2E) 008	JUNCTION	1231.37	20.25	0.0
(2E) 009	JUNCTION	1232.08	19.12	0.0
(2E) 010	JUNCTION	1232.79	20.32	0.0
(2E) 011	JUNCTION	1233.35	21.08	0.0
(2E) 012	JUNCTION	1233.90	22.75	0.0
(2E) 013	JUNCTION	1234.62	20.25	0.0
(2E) 014	JUNCTION	1235.12	20.87	0.0
(2E) 043	JUNCTION	1247.51	6.39	0.0
Yes				
(2F) 001	JUNCTION	1235.77	22.25	0.0
(2F) 002	JUNCTION	1236.42	22.48	0.0
(2F) 003	JUNCTION	1237.07	18.53	0.0
(2F) 004	JUNCTION	1237.38	19.02	0.0
Yes				
(2F) 005	JUNCTION	1237.73	18.47	0.0
Yes				
(2F) 006	JUNCTION	1237.87	15.13	0.0
(2F) 007	JUNCTION	1238.31	14.39	0.0
(2F) 008	JUNCTION	1238.48	15.02	0.0
(2F) 009	JUNCTION	1238.55	17.45	0.0
(2F) 010	JUNCTION	1239.42	17.58	0.0
(2F) 011	JUNCTION	1239.72	16.28	0.0
(2F) 012	JUNCTION	1240.82	16.38	0.0
(2F) 013	JUNCTION	1241.75	17.55	0.0
(2F) 014	JUNCTION	1242.68	16.52	0.0
(2F) 015	JUNCTION	1243.61	20.19	0.0
(2F) 016	JUNCTION	1244.54	20.46	0.0
(2F) 017	JUNCTION	1245.47	21.33	0.0
Yes				
(2F) 018	JUNCTION	1246.40	21.37	0.0
(2F) 019	JUNCTION	1247.33	19.17	0.0
(2F) 020	JUNCTION	1248.26	18.54	0.0

(2F)021	JUNCTION	1249.19	15.62	0.0
(2F)022	JUNCTION	1250.52	22.00	0.0
(2F)023	JUNCTION	1250.57	22.17	0.0
Yes				
(2F)024	JUNCTION	1251.93	22.07	0.0
(2F)025	JUNCTION	1252.06	19.94	0.0
(2F)026	JUNCTION	1252.21	19.79	0.0
(2F)027	JUNCTION	1252.32	21.68	0.0
(2F)028	JUNCTION	1252.47	20.53	0.0
(2F)029	JUNCTION	1252.59	21.41	0.0
(2F)030	JUNCTION	1252.71	21.29	0.0
(2F)031	JUNCTION	1252.85	21.15	0.0
(2F)032	JUNCTION	1252.98	21.32	0.0
(2F)033	JUNCTION	1253.07	25.93	0.0
Yes				
(2G)001	JUNCTION	1252.28	15.90	0.0
(2G)002	JUNCTION	1253.00	16.58	0.0
Yes				
(2G)002A	JUNCTION	1253.49	17.21	0.0
(2G)003	JUNCTION	1253.81	15.80	0.0
(2G)004	JUNCTION	1255.41	13.50	0.0
Yes				
(2G)005	JUNCTION	1257.05	12.17	0.0
(2G)006	JUNCTION	1259.57	12.23	0.0
Yes				
(2G)007	JUNCTION	1260.37	11.58	0.0
Yes				
(2G)008	JUNCTION	1260.48	10.46	0.0
(2G)009	JUNCTION	1261.35	10.12	0.0
Yes				
(2G)010	JUNCTION	1261.89	8.67	0.0
(2G)011	JUNCTION	1263.02	10.80	0.0
Yes				
(2G)012	JUNCTION	1263.82	10.43	0.0
(2G)012A	JUNCTION	1264.27	10.42	0.0
(2G)013	JUNCTION	1265.10	10.22	0.0
(2G)013A	JUNCTION	1265.63	11.17	0.0
Yes				
(2G)014	JUNCTION	1267.95	9.37	0.0
(2G)015	JUNCTION	1268.00	9.29	0.0
Yes				
(2G)016	JUNCTION	1268.62	12.58	0.0
Yes				
(2G)016A	JUNCTION	1268.77	13.25	0.0
(2G)018	JUNCTION	1269.22	12.46	0.0
Yes				
(2G)019	JUNCTION	1269.72	9.15	0.0
Yes				
(2G)020	JUNCTION	1270.55	9.42	0.0
Yes				
(2G)021	JUNCTION	1271.18	10.46	0.0
Yes				
(2G)022	JUNCTION	1271.88	8.83	0.0
Yes				
(2G)023	JUNCTION	1272.48	8.17	0.0
Yes				
(2G)024	JUNCTION	1272.87	6.87	0.0
(2G)025	JUNCTION	1273.43	7.08	0.0
(2G)026	JUNCTION	1276.53	5.62	0.0
Yes				
(2G)040	JUNCTION	1255.99	16.00	0.0

(2G) 041	JUNCTION	1256.24	15.76	0.0
(2G) 042	JUNCTION	1256.51	15.49	0.0
(2G) 043	JUNCTION	1256.74	15.26	0.0
(2G) 043A	JUNCTION	1256.89	15.11	0.0
(2G) 044	JUNCTION	1257.03	14.97	0.0
(2G) 045	JUNCTION	1257.19	14.81	0.0
Yes				
(2G) 359	JUNCTION	1274.22	6.67	0.0
Yes				
(2H) 001	JUNCTION	1248.90	22.10	0.0
(2H) 002	JUNCTION	1249.59	22.41	0.0
Yes				
(2H) 003	JUNCTION	1250.32	21.68	0.0
(2H) 005	JUNCTION	1251.05	21.95	0.0
(2H) 006	JUNCTION	1251.66	18.34	0.0
(2H) 007	JUNCTION	1252.27	16.73	0.0
Yes				
(2H) 008	JUNCTION	1253.49	16.51	0.0
(2H) 009	JUNCTION	1253.59	16.41	0.0
(2H) 010	JUNCTION	1253.70	16.30	0.0
(2H) 011	JUNCTION	1255.52	14.48	0.0
(2H) 012	JUNCTION	1256.17	13.83	0.0
Yes				
(2H) 013	JUNCTION	1257.09	16.91	0.0
Yes				
(2H) 014	JUNCTION	1257.73	14.27	0.0
Yes				
(2H) 015	JUNCTION	1258.46	11.04	0.0
(2H) 016	JUNCTION	1259.00	10.00	0.0
Yes				
(2H) 017	JUNCTION	1259.56	8.94	0.0
(2H) 017A	JUNCTION	1260.40	9.60	0.0
Yes				
(2H) 018	JUNCTION	1260.70	10.30	0.0
(2H) 019	JUNCTION	1261.30	11.75	0.0
Yes				
(2H) 020	JUNCTION	1261.40	14.40	0.0
Yes				
(2H) 021	JUNCTION	1262.54	11.46	0.0
Yes				
(2H) 022	JUNCTION	1265.22	13.78	0.0
(2H) 023	JUNCTION	1265.49	14.51	0.0
(2H) 024	JUNCTION	1268.18	10.82	0.0
(2H) 025	JUNCTION	1268.74	9.26	0.0
(2H) 026	JUNCTION	1264.94	8.50	0.0
Yes				
(2H) 027	JUNCTION	1266.12	12.33	0.0
(2H) 028	JUNCTION	1267.29	14.00	0.0
(2H) 029	JUNCTION	1268.48	14.00	0.0
(2H) 030	JUNCTION	1269.40	9.00	0.0
Yes				
(2H) 031	JUNCTION	1269.64	7.20	0.0
(2H) 032	JUNCTION	1269.73	7.73	0.0
Yes				
(2H) 033	JUNCTION	1270.81	7.65	0.0
(2H) 034	JUNCTION	1271.83	6.97	0.0
(2H) 036	JUNCTION	1272.81	12.67	0.0
Yes				
(2H) 037	JUNCTION	1274.02	9.38	0.0
(2H) 038	JUNCTION	1275.22	11.78	0.0
(2H) 039	JUNCTION	1276.64	11.35	0.0

(2H) 040	JUNCTION	1277.55	7.37	0.0
(2H) 041	JUNCTION	1278.45	8.05	0.0
(2H) 042	JUNCTION	1279.87	9.13	0.0
(2H) 043	JUNCTION	1280.82	9.58	0.0
(2H) 044	JUNCTION	1281.64	10.06	0.0
(2H) 045	JUNCTION	1282.34	11.15	0.0
(2H) 046	JUNCTION	1283.01	11.15	0.0
(2H) 047	JUNCTION	1283.25	16.92	0.0
(2H) 048	JUNCTION	1284.37	12.62	0.0
(2H) 049	JUNCTION	1285.60	12.17	0.0
Yes				
(2H) 050	JUNCTION	1286.56	12.04	0.0
(2H) 051	JUNCTION	1287.28	11.75	0.0
(2H) 051A	JUNCTION	1288.06	10.45	0.0
(2H) 052	JUNCTION	1289.23	12.00	0.0
(2H) 053	JUNCTION	1289.54	18.44	0.0
(2H) 054	JUNCTION	1290.05	18.94	0.0
(2H) 054A	JUNCTION	1290.90	19.10	0.0
Yes				
(2H) 055	JUNCTION	1291.92	19.08	0.0
(2H) 055A	JUNCTION	1292.46	19.54	0.0
(2H) 056	JUNCTION	1294.11	17.02	0.0
(2H) 057	JUNCTION	1294.81	14.53	0.0
Yes				
(2H) 058	JUNCTION	1295.28	15.24	0.0
Yes				
(2H) 285	JUNCTION	1289.98	14.49	0.0
Yes				
(2H) 286	JUNCTION	1290.62	17.75	0.0
Yes				
(2H) 287	JUNCTION	1291.69	22.13	0.0
(2H) 288	JUNCTION	1293.09	22.14	0.0
(2H) 289	JUNCTION	1294.43	22.15	0.0
Yes				
(2H) 290	JUNCTION	1295.06	20.92	0.0
(2I) 001	JUNCTION	1269.29	9.71	0.0
Yes				
(2I) 001A	JUNCTION	1269.10	10.90	0.0
(2I) 002	JUNCTION	1271.86	8.14	0.0
Yes				
(2I) 003	JUNCTION	1273.20	8.80	0.0
Yes				
(2I) 004	JUNCTION	1273.70	9.30	0.0
(2I) 005	JUNCTION	1275.54	9.46	0.0
(2I) 006	JUNCTION	1276.60	13.40	0.0
(2I) 008	JUNCTION	1278.00	12.00	0.0
Yes				
(2I) 009	JUNCTION	1279.64	9.36	0.0
Yes				
(2I) 010	JUNCTION	1280.00	10.00	0.0
(2I) 011	JUNCTION	1280.60	9.40	0.0
Yes				
(2I) 012	JUNCTION	1281.28	9.72	0.0
(2I) 013	JUNCTION	1282.76	11.24	0.0
(2I) 014	JUNCTION	1283.39	8.61	0.0
Yes				
(2I) 015	JUNCTION	1283.87	11.13	0.0
(2I) 016	JUNCTION	1284.40	12.60	0.0
(2I) 017	JUNCTION	1284.54	12.46	0.0
(2I) 017A	JUNCTION	1284.60	12.40	0.0
Yes				

(2I) 018	JUNCTION	1285.34	11.66	0.0
(2I) 019	JUNCTION	1286.15	10.85	0.0
(2I) 020	JUNCTION	1287.48	16.52	0.0
Yes				
(2I) 021	JUNCTION	1288.56	15.44	0.0
(2I) 021A	JUNCTION	1288.86	15.14	0.0
(2I) 021B	JUNCTION	1289.46	14.54	0.0
Yes				
(2I) 021C	JUNCTION	1289.55	14.45	0.0
(2I) 022	JUNCTION	1289.64	11.42	0.0
(2I) 023	JUNCTION	1290.72	9.27	0.0
(2I) 024	JUNCTION	1291.80	11.20	0.0
(2I) 025	JUNCTION	1292.88	10.12	0.0
(2I) 025A	JUNCTION	1293.62	9.38	0.0
Yes				
(2I) 026	JUNCTION	1293.96	9.04	0.0
(2I) 027	JUNCTION	1294.94	12.06	0.0
(2I) 028	JUNCTION	1295.09	11.90	0.0
Yes				
(2I) 029	JUNCTION	1295.29	12.10	0.0
Yes				
(2I) 044	JUNCTION	1276.65	8.72	0.0
(2I) 045	JUNCTION	1277.38	10.43	0.0
(2I) 046	JUNCTION	1281.61	13.50	0.0
(2I) 047	JUNCTION	1285.58	19.42	0.0
(2I) 048	JUNCTION	1289.53	18.96	0.0
(2I) 049	JUNCTION	1290.84	16.16	0.0
Yes				
(2I) 050	JUNCTION	1292.77	15.73	0.0
(2I) 051	JUNCTION	1293.24	14.56	0.0
Yes				
(2I) 052	JUNCTION	1293.62	14.38	0.0
(2I) 053	JUNCTION	1294.99	13.21	0.0
(2I) 054	JUNCTION	1296.16	11.84	0.0
(2I) 055	JUNCTION	1297.06	10.74	0.0
Yes				
(2I) 056	JUNCTION	1298.45	9.55	0.0
(2I) 057	JUNCTION	1299.11	11.89	0.0
(2I) 058	JUNCTION	1300.43	11.57	0.0
(2I) 059	JUNCTION	1302.26	10.24	0.0
Yes				
(2J) 001	JUNCTION	1239.36	15.64	0.0
(2J) 002	JUNCTION	1239.73	15.27	0.0
(2J) 003	JUNCTION	1239.81	15.19	0.0
(2J) 004	JUNCTION	1240.04	17.96	0.0
(2J) 005	JUNCTION	1240.09	17.91	0.0
(2J) 006	JUNCTION	1240.57	19.43	0.0
(2J) 007	JUNCTION	1241.10	19.90	0.0
(2J) 008	JUNCTION	1241.63	22.37	0.0
(2J) 009	JUNCTION	1241.85	22.15	0.0
(2J) 010	JUNCTION	1242.09	20.91	0.0
(2J) 011	JUNCTION	1242.66	21.34	0.0
Yes				
(2J) 012	JUNCTION	1243.17	21.83	0.0
(2J) 013	JUNCTION	1244.14	21.86	0.0
(2J) 014	JUNCTION	1244.99	22.01	0.0
(2J) 015	JUNCTION	1245.91	24.09	0.0
(2J) 016	JUNCTION	1246.81	24.19	0.0
(2J) 017	JUNCTION	1247.72	22.28	0.0
(2J) 018	JUNCTION	1247.88	22.12	0.0
(2J) 019	JUNCTION	1248.90	22.10	0.0

(2J) 020	JUNCTION	1242.31	21.69	0.0
Yes				
(2J) 021	JUNCTION	1246.20	16.80	0.0
Yes				
(2J) 022	JUNCTION	1246.37	17.63	0.0
(2J) 023	JUNCTION	1247.35	16.65	0.0
(2J) 026	JUNCTION	1249.21	16.79	0.0
Yes				
(2J) 027	JUNCTION	1250.42	17.58	0.0
(2J) 028	JUNCTION	1251.06	18.94	0.0
(2J) 029	JUNCTION	1252.17	17.83	0.0
(2J) 030	JUNCTION	1253.86	16.14	0.0
(2J) 031	JUNCTION	1255.43	15.57	0.0
(2J) 032	JUNCTION	1256.78	13.22	0.0
(2J) 033	JUNCTION	1258.11	11.89	0.0
(2J) 040	JUNCTION	1248.95	17.05	0.0
Yes				
(2J) 041	JUNCTION	1249.37	17.63	0.0
(2J) 042	JUNCTION	1251.74	12.26	0.0
(2J) 043	JUNCTION	1252.07	10.93	0.0
Yes				
(2J) 044	JUNCTION	1252.69	8.52	0.0
Yes				
(2J) 045	JUNCTION	1253.12	9.93	0.0
Yes				
(2J) 045A	JUNCTION	1253.53	8.47	0.0
(2J) 046	JUNCTION	1254.04	8.96	0.0
Yes				
(2J) 047	JUNCTION	1254.96	11.04	0.0
Yes				
(2J) 048	JUNCTION	1255.88	12.12	0.0
Yes				
(2J) 049	JUNCTION	1256.02	11.98	0.0
(2J) 050	JUNCTION	1257.00	13.00	0.0
Yes				
(2J) 051	JUNCTION	1257.54	15.17	0.0
(2J) 052	JUNCTION	1258.18	15.08	0.0
(2J) 053	JUNCTION	1258.73	12.58	0.0
Yes				
(2J) 054	JUNCTION	1260.19	10.09	0.0
Yes				
(2J) 055	JUNCTION	1261.11	6.42	0.0
(2J) 056	JUNCTION	1261.74	5.33	0.0
Yes				
(2J) 057	JUNCTION	1262.30	4.70	0.0
(2J) 060	JUNCTION	1263.42	4.58	0.0
Yes				
(2K) 001	JUNCTION	1249.05	21.95	0.0
Yes				
(2K) 002	JUNCTION	1254.77	16.23	0.0
Yes				
(2K) 003	JUNCTION	1256.06	13.44	0.0
Yes				
(2K) 004	JUNCTION	1257.14	12.33	0.0
(2K) 005	JUNCTION	1258.22	10.78	0.0
(2K) 006	JUNCTION	1259.48	10.52	0.0
(2K) 007	JUNCTION	1261.13	9.67	0.0
(2K) 008	JUNCTION	1262.27	8.73	0.0
(2K) 009	JUNCTION	1263.41	8.59	0.0
(2K) 010	JUNCTION	1264.55	8.45	0.0
(2K) 011	JUNCTION	1265.69	8.31	0.0

Yes					
	(2K) 012	JUNCTION	1266.83	8.17	0.0
	(2K) 013	JUNCTION	1267.71	10.29	0.0
Yes					
	(2K) 014	JUNCTION	1268.42	9.58	0.0
Yes					
	(2K) 015	JUNCTION	1269.02	8.98	0.0
	(2K) 016	JUNCTION	1270.08	7.92	0.0
Yes					
	(2K) 017	JUNCTION	1270.60	7.60	0.0
Yes					
	(2K) 018	JUNCTION	1271.60	9.00	0.0
Yes					
	(2K) 018A	JUNCTION	1272.00	8.12	0.0
	(2K) 019	JUNCTION	1272.70	6.80	0.0
Yes					
	(2K) 020	JUNCTION	1273.70	7.25	0.0
	(2K) 021	JUNCTION	1273.80	7.17	0.0
Yes					
	(2K) 022	JUNCTION	1275.00	7.00	0.0
Yes					
	(2K) 022A	JUNCTION	1275.40	8.00	0.0
	(2K) 023	JUNCTION	1276.20	8.10	0.0
	(2K) 024	JUNCTION	1277.00	7.25	0.0
	(2K) 024A	JUNCTION	1277.10	9.00	0.0
Yes					
	(2K) 025	JUNCTION	1278.50	9.18	0.0
Yes					
	(2K) 026	JUNCTION	1279.82	8.92	0.0
	(2K) 027	JUNCTION	1284.20	12.80	0.0
Yes					
	(2K) 028	JUNCTION	1285.03	15.97	0.0
	(2K) 029	JUNCTION	1286.00	10.00	0.0
Yes					
	(2K) 030	JUNCTION	1286.96	12.04	0.0
	(2K) 031	JUNCTION	1288.10	12.90	0.0
	(2K) 032	JUNCTION	1289.21	11.79	0.0
Yes					
	(2K) 033	JUNCTION	1290.30	13.70	0.0
Yes					
	(2K) 033A	JUNCTION	1290.96	11.23	0.0
Yes					
	(2K) 034	JUNCTION	1291.39	9.70	0.0
	(2K) 035	JUNCTION	1292.49	8.70	0.0
	(2K) 036	JUNCTION	1293.59	10.67	0.0
	(2K) 037	JUNCTION	1294.71	11.29	0.0
Yes					
	(2K) 038	JUNCTION	1295.09	12.41	0.0
	(2K) 039	JUNCTION	1295.96	12.54	0.0
	(2K) 040	JUNCTION	1296.66	13.34	0.0
	(2K) 041	JUNCTION	1297.51	11.99	0.0
	(2K) 042	JUNCTION	1298.02	12.18	0.0
	(2K) 043	JUNCTION	1298.87	11.13	0.0
	(2K) 044	JUNCTION	1299.72	12.28	0.0
	(2K) 045	JUNCTION	1300.58	11.42	0.0
	(2K) 046	JUNCTION	1301.43	9.57	0.0
	(2K) 047	JUNCTION	1302.28	11.72	0.0
	(2K) 048	JUNCTION	1303.14	14.36	0.0
	(2K) 049	JUNCTION	1303.99	11.21	0.0
	(2K) 050	JUNCTION	1304.68	11.12	0.0
	(2K) 051	JUNCTION	1305.36	10.54	0.0

(2K) 052	JUNCTION	1306.05	10.35	0.0
Yes				
(2K) 314	JUNCTION	1250.64	18.26	0.0
(2K) 315	JUNCTION	1251.52	17.08	0.0
(2K) 316	JUNCTION	1252.40	16.30	0.0
(2K) 317	JUNCTION	1252.76	14.67	0.0
ForcedMain	JUNCTION	1148.50	10.00	0.0
(PLANT)	OUTFALL	1145.00	0.00	0.0
(1C) 026	DIVIDER	1226.87	12.67	0.0
Yes				
(1F) 012	DIVIDER	1202.30	7.93	0.0
(1G) 019	DIVIDER	1225.09	13.00	0.0
(2A) 048	DIVIDER	1190.65	7.85	0.0
(2C) 009	DIVIDER	1210.66	9.83	0.0
(2D) 244	DIVIDER	1217.17	11.83	0.0
(1M) 012	DIVIDER	1221.44	14.25	0.0
(2J) 025	DIVIDER	1248.28	17.72	0.0
(1C) 001B	DIVIDER	1193.50	13.50	0.0
Yes				
(1M) 020	DIVIDER	1228.05	14.73	0.0
Yes				
(1A) STOR	STORAGE	1100.00	58.00	0.0
(1A) DIV	STORAGE	1147.99	8.01	0.0
(2A) 000	STORAGE	1130.00	29.00	0.0
NorthEndStorage	STORAGE	1239.83	0.00	0.0
(1O) 304C	STORAGE	1239.83	21.17	0.0
LiftStation	STORAGE	1124.35	22.00	0.0
(1O) 304	STORAGE	1238.81	19.95	0.0
(1C) Storage	STORAGE	1191.30	6.90	0.0
PlantStorage	STORAGE	1152.00	11.00	0.0

Link Summary

Name	From Node	To Node	Type	Length
%Slope Roughness				

(1A) 000A	(1A) 000A	(1A) 000	CONDUIT	98.7
1.0133 0.0160				
(1A) 000B	(1A) 000B	(1A) 000A	CONDUIT	406.7
0.2237 0.0160				
(1A) 001	(1A) 001	(1A) 000B	CONDUIT	521.0
0.0288 0.0160				
(1A) 002	(1A) 002	(1A) 001	CONDUIT	98.4
0.1118 0.0160				
(1A) 003	(1A) 003	(1A) 002	CONDUIT	391.7
0.3064 0.0160				
(1A) 004	(1A) 004	(1A) 003	CONDUIT	331.5
0.1900 0.0160				
(1A) 005	(1A) 005	(1A) 004	CONDUIT	353.4
0.2462 0.0160				
(1A) 006	(1A) 006	(1A) 005	CONDUIT	446.4
0.4458 0.0160				
(1A) 007	(1A) 007	(1A) 006	CONDUIT	506.3
0.4049 0.0160				
(1A) 008	(1A) 008	(1A) 007	CONDUIT	499.1
0.4107 0.0160				
(1A) 009	(1A) 009	(1A) 008	CONDUIT	504.6

0.1685	0.0160					
(1A) 010		(1A) 010	(1A) 009	CONDUIT		502.8
0.3679	0.0160					
(1A) 011		(1A) 011	(1A) 010	CONDUIT		484.6
0.0516	0.0160					
(1A) 012		(1A) 012	(1A) 011	CONDUIT		555.5
0.0630	0.0160					
(1A) 013		(1A) 013	(1A) 012	CONDUIT		424.4
0.2285	0.0160					
(1A) 014		(1A) 014	(1A) 013	CONDUIT		184.0
0.3424	0.0160					
(1A) 015		(1A) 015	(1A) 014	CONDUIT		185.8
0.4575	0.0160					
(1A) 016		(1A) 016	(1A) 015	CONDUIT		495.5
0.1716	0.0160					
(1A) 017		(1A) 017	(1A) 016	CONDUIT		524.9
0.1105	0.0160					
(1A) 018		(1A) 018	(1A) 017	CONDUIT		271.3
0.3760	0.0160					
(1A) 019		(1A) 019	(1A) 018	CONDUIT		183.4
0.0545	0.0160					
(1A) 020		(1A) 020	(1A) 019	CONDUIT		298.7
0.4452	0.0160					
(1A) 021		(1A) 021	(1A) 020	CONDUIT		537.4
0.3294	0.0160					
(1A) 022		(1A) 022	(1A) 021	CONDUIT		382.5
0.5568	0.0160					
(1A) 023		(1A) 023	(1A) 022	CONDUIT		499.1
0.3005	0.0160					
(1A) 024		(1A) 024	(1A) 023	CONDUIT		479.1
0.4488	0.0160					
(1A) 024A		(1A) 024A	(1A) 024	CONDUIT		468.2
0.1004	0.0160					
(1A) 025		(1A) 025	(1A) 024A	CONDUIT		29.4
5.7201	0.0160					
(1A) 026		(1A) 026	(1A) 025	CONDUIT		568.5
0.3870	0.0160					
(1A) 027		(1A) 027	(1A) 026	CONDUIT		345.5
0.5008	0.0160					
(1A) 028		(1A) 028	(1A) 027	CONDUIT		407.0
0.1327	0.0160					
(1A) 029		(1A) 029	(1A) 028	CONDUIT		234.5
0.3070	0.0160					
(1A) 030		(1A) 030	(1A) 029	CONDUIT		424.8
0.1200	0.0160					
(1A) 031		(1A) 031	(1A) 030	CONDUIT		501.1
0.2056	0.0160					
(1A) 032		(1A) 032	(1A) 031	CONDUIT		452.1
0.1747	0.0160					
(1A) 033		(1A) 033	(1A) 032	CONDUIT		448.3
0.1851	0.0160					
(1A) 034		(1A) 034	(1A) 033	CONDUIT		424.7
0.1107	0.0160					
(1A) 035		(1A) 035	(1A) 034	CONDUIT		360.5
0.2524	0.0160					
(1A) 035A		(1A) 035A	(1A) 035	CONDUIT		382.1
0.1178	0.0160					
(1A) 036		(1A) 036	(1A) 035A	CONDUIT		128.5
0.3503	0.0160					
(1A) 037		(1A) 037	(1A) 036	CONDUIT		450.2
0.1844	0.0160					

(1A)038		(1A)038	(1A)037	CONDUIT	337.0
0.0712	0.0160				
(1A)039		(1A)039	(1A)038	CONDUIT	307.6
0.3089	0.0160				
(1A)040		(1A)040	(1A)039	CONDUIT	374.6
0.1762	0.0160				
(1A)041		(1A)041	(1A)040	CONDUIT	177.1
0.1920	0.0160				
(1A)042		(1A)042	(1A)041	CONDUIT	338.6
0.1979	0.0160				
(1B)001		(1B)001	(1A)024A	CONDUIT	54.4
2.5014	0.0160				
(1B)002		(1B)002	(1B)001	CONDUIT	257.9
0.3334	0.0160				
(1B)003		(1B)003	(1B)002	CONDUIT	362.2
0.3065	0.0160				
(1B)004		(1B)004	(1B)003	CONDUIT	284.2
0.0246	0.0160				
(1B)005		(1B)005	(1B)004	CONDUIT	236.2
0.6902	0.0160				
(1B)006		(1B)006	(1B)005	CONDUIT	334.7
0.3108	0.0160				
(1B)009		(1B)009	(1B)006	CONDUIT	202.2
0.3264	0.0160				
(1B)010		(1B)010	(1B)009	CONDUIT	414.0
0.6280	0.0160				
(1B)011		(1B)011	(1B)010	CONDUIT	415.3
0.2889	0.0160				
(1B)013		(1B)013	(1B)011	CONDUIT	277.0
0.4730	0.0160				
(1B)014		(1B)014	(1B)013	CONDUIT	368.3
0.3258	0.0160				
(1C)001		(1C)001	(1B)014	CONDUIT	147.8
0.3585	0.0160				
(1C)001A		(1C)001A	(1C)001	CONDUIT	306.4
0.3133	0.0160				
(1C)001B		(1C)001B	(1C)001A	CONDUIT	143.9
1.9943	0.0160				
(1C)001BO		(1C)001B	(1C)001G	CONDUIT	133.3
1.4998	0.0160				
(1C)001C		(1C)001C	(1C)001B	CONDUIT	243.0
1.4404	0.0160				
(1C)001D		(1C)001D	(1C)001C	CONDUIT	273.6
0.2851	0.0160				
(1C)001E		(1C)001E	(1C)001D	CONDUIT	170.8
1.8614	0.0160				
(1C)001F		(1C)001F	(1C)001E	CONDUIT	239.7
1.0639	0.0160				
(1C)001G		(1C)001G	(1C)Storage	CONDUIT	94.0
1.2766	0.0160				
(1C)002		(1C)002	(1C)001	CONDUIT	304.7
2.6584	0.0160				
(1C)003		(1C)003	(1C)002	CONDUIT	149.9
0.1667	0.0160				
(1C)004		(1C)004	(1C)003	CONDUIT	200.9
0.5874	0.0160				
(1C)005		(1C)005	(1C)004	CONDUIT	29.3
0.0341	0.0160				
(1C)006		(1C)006	(1C)005	CONDUIT	217.1
0.4513	0.0160				
(1C)006A		(1C)006A	(1C)006	CONDUIT	204.5

0.6503	0.0160					
(1C)007		(1C)007	(1C)006A	CONDUIT		39.4
0.5079	0.0160					
(1C)009		(1C)009	(1C)001F	CONDUIT		141.3
0.6863	0.0160					
(1C)010		(1C)010	(1C)009	CONDUIT		152.7
1.3422	0.0160					
(1C)011		(1C)011	(1C)010	CONDUIT		84.8
0.9672	0.0160					
(1C)012		(1C)012	(1C)015A	CONDUIT		178.0
3.3931	0.0160					
(1C)015A		(1C)015A	(1C)011	CONDUIT		42.6
0.4223	0.0160					
(1C)015B		(1C)015B	(1C)015A	CONDUIT		341.3
0.7560	0.0160					
(1C)015C		(1C)015C	(1C)015B	CONDUIT		187.8
0.7135	0.0160					
(1C)016		(1C)016	(1C)015D	CONDUIT		317.3
0.4538	0.0160					
(1C)016A		(1C)016A	(1C)016	CONDUIT		141.5
0.5583	0.0160					
(1C)016B		(1C)016B	(1C)016A	CONDUIT		325.4
0.4118	0.0160					
(1C)016C		(1C)016C	(1C)016B	CONDUIT		334.3
0.3979	0.0160					
(1C)017		(1C)017	(1C)016	CONDUIT		26.7
11.8593	0.0160					
(1C)018		(1C)018	(1C)017	CONDUIT		381.8
0.4085	0.0160					
(1C)019		(1C)019	(1C)018	CONDUIT		274.9
0.3819	0.0160					
(1C)01D		(1C)015D	(1C)015C	CONDUIT		308.0
0.5064	0.0160					
(1C)020		(1C)020	(1C)019	CONDUIT		318.8
0.4078	0.0160					
(1C)021		(1C)021	(1C)016C	CONDUIT		320.8
0.7202	0.0160					
(1C)021A		(1C)021A	(1C)021	CONDUIT		423.9
0.1793	0.0160					
(1C)021B		(1C)021B	(1C)021A	CONDUIT		229.1
0.3666	0.0160					
(1C)021C		(1C)021C	(1C)021B	CONDUIT		347.5
0.3338	0.0160					
(1C)021D		(1C)021D	(1C)021C	CONDUIT		320.8
0.3055	0.0160					
(1C)022		(1C)022	(1C)021	CONDUIT		160.4
0.4426	0.0160					
(1C)023		(1C)023	(1C)022	CONDUIT		404.8
0.3261	0.0160					
(1C)024		(1C)024	(1C)023	CONDUIT		248.3
0.3665	0.0160					
(1C)025		(1C)025	(1C)024	CONDUIT		263.5
0.1518	0.0160					
(1C)026		(1C)026	(1C)025	CONDUIT		397.1
0.3299	0.0160					
(1C)026A		(1C)026	(1C)021D	CONDUIT		168.1
1.7315	0.0160					
(1C)027		(1C)027	(1C)026	CONDUIT		324.6
0.3296	0.0160					
(1C)028		(1C)028	(1C)027	CONDUIT		328.4
0.3258	0.0160					

(1C)041		(1C)041	(1C)007	CONDUIT	325.0
0.6492	0.0160				
(1C)176		(1C)176	(1C)002	CONDUIT	334.0
0.9461	0.0160				
(1C)177		(1C)177	(1C)176	CONDUIT	319.4
0.9394	0.0160				
(1C)178		(1C)178	(1C)177	CONDUIT	342.3
0.9320	0.0160				
(1C)179		(1C)179	(1C)178	CONDUIT	319.3
0.9427	0.0160				
(1C)179A		(1C)179A	(1C)179	CONDUIT	16.7
0.5992	0.0160				
(1C)180		(1C)180	(1C)179A	CONDUIT	321.4
0.9365	0.0160				
(1C)180A		(1C)180A	(1C)180	CONDUIT	319.4
0.9362	0.0160				
(1C)181		(1C)181	(1C)180A	CONDUIT	317.3
0.9266	0.0160				
(1C)182		(1C)182	(1C)181	CONDUIT	169.1
0.9168	0.0160				
(1C)Storage		(1C)Storage	(1C)001	CONDUIT	194.4
0.8386	0.0160				
(1D)001		(1D)001	(1A)017	CONDUIT	287.6
2.5558	0.0160				
(1D)002		(1D)002	(1D)001	CONDUIT	203.8
0.8880	0.0160				
(1D)003		(1D)003	(1D)002	CONDUIT	143.9
1.0771	0.0160				
(1D)004		(1D)004	(1D)003	CONDUIT	264.9
1.8196	0.0160				
(1D)005		(1D)005	(1D)004	CONDUIT	252.6
0.7680	0.0160				
(1D)006		(1D)006	(1D)005	CONDUIT	214.3
0.9567	0.0160				
(1D)007		(1D)007	(1D)006	CONDUIT	412.1
0.9293	0.0160				
(1D)008		(1D)008	(1D)007	CONDUIT	428.9
0.9349	0.0160				
(1D)009		(1D)009	(1D)008	CONDUIT	404.2
0.4181	0.0160				
(1D)010		(1D)010	(1D)009	CONDUIT	204.6
0.4008	0.0160				
(1D)011		(1D)011	(1D)010	CONDUIT	54.9
1.3120	0.0160				
(1D)012		(1D)012	(1D)011	CONDUIT	182.1
0.4502	0.0160				
(1D)013		(1D)013	(1D)012	CONDUIT	352.9
2.0229	0.0160				
(1D)014		(1D)014	(1D)013	CONDUIT	327.5
0.5038	0.0160				
(1D)015		(1D)015	(1D)014	CONDUIT	338.4
0.4196	0.0160				
(1D)016		(1D)016	(1D)015	CONDUIT	328.5
0.2983	0.0160				
(1D)017		(1D)017	(1D)016	CONDUIT	336.3
0.2914	0.0160				
(1D)018		(1D)018	(1D)017	CONDUIT	328.9
0.2980	0.0160				
(1D)019		(1D)019	(1D)018	CONDUIT	331.6
0.3016	0.0160				
(1D)020		(1D)020	(1D)019	CONDUIT	318.2

0.2986	0.0160				
(1D)021		(1D)021	(1D)020	CONDUIT	317.9
0.3020	0.0160				
(1D)022		(1D)022	(1D)021	CONDUIT	343.1
0.2973	0.0160				
(1D)023		(1D)023	(1D)022	CONDUIT	329.3
0.2976	0.0160				
(1E)001		(1E)001	(1A)041	CONDUIT	147.8
0.3585	0.0160				
(1E)002		(1E)002	(1E)001	CONDUIT	378.7
0.3274	0.0160				
(1E)003		(1E)003	(1E)002	CONDUIT	482.1
0.3153	0.0160				
(1E)003A		(1E)003A	(1E)003	CONDUIT	391.1
0.3273	0.0160				
(1E)005		(1E)005	(1E)003A	CONDUIT	502.3
0.3185	0.0160				
(1E)006		(1E)006	(1E)005	CONDUIT	425.5
0.3290	0.0160				
(1E)007		(1E)007	(1E)006	CONDUIT	316.1
0.3290	0.0160				
(1E)008		(1E)008	(1E)007	CONDUIT	536.0
0.3097	0.0160				
(1E)009		(1E)009	(1E)008	CONDUIT	234.2
0.3544	0.0160				
(1F)001		(1F)001	(1J)002	CONDUIT	275.9
0.4386	0.0160				
(1F)003		(1F)003	(1F)001	CONDUIT	340.6
1.1655	0.0160				
(1F)004		(1F)004	(1F)003	CONDUIT	294.1
0.1972	0.0160				
(1F)005		(1F)005	(1F)004	CONDUIT	174.0
0.0575	0.0160				
(1F)006		(1F)006	(1F)005	CONDUIT	180.9
0.1271	0.0160				
(1F)008		(1F)008	(1F)006	CONDUIT	333.2
0.0930	0.0160				
(1F)008A		(1F)008A	(1F)008	CONDUIT	158.3
0.0758	0.0160				
(1F)009		(1F)009	(1F)008A	CONDUIT	19.7
0.5066	0.0160				
(1F)010		(1F)010	(1F)009	CONDUIT	159.3
0.1067	0.0160				
(1F)011		(1F)011	(1F)010	CONDUIT	347.2
0.1843	0.0160				
(1F)012		(1F)012	(1F)011	CONDUIT	389.9
0.2180	0.0160				
(1F)012A		(1F)012A	(1F)012	CONDUIT	78.9
0.2154	0.0160				
(1F)012O		(1F)012	(1J)011	CONDUIT	130.3
2.4948	0.0160				
(1F)013		(1F)013	(1F)012A	CONDUIT	481.6
0.2762	0.0160				
(1F)014		(1F)014	(1F)013	CONDUIT	182.0
0.0549	0.0160				
(1F)015		(1F)015	(1F)014	CONDUIT	253.0
0.4269	0.0160				
(1F)016		(1F)016	(1F)015	CONDUIT	204.8
0.3759	0.0160				
(1F)017		(1F)017	(1J)014	CONDUIT	249.3
0.2086	0.0160				

(1F)017A	(1F)017A	(1F)017	CONDUIT	188.8
0.2066 0.0160				
(1F)017B	(1F)017B	(1F)017A	CONDUIT	69.7
0.2153 0.0160				
(1F)017C	(1F)017C	(1F)017B	CONDUIT	148.4
0.2358 0.0160				
(1F)017D	(1F)017D	(1F)017C	CONDUIT	94.5
0.1269 0.0160				
(1F)017E	(1F)017E	(1F)017D	CONDUIT	183.7
0.2068 0.0160				
(1F)017F	(1F)017F	(1F)017E	CONDUIT	26.5
3.2867 0.0160				
(1F)017G-1	(1F)017G	(1F)017F	CONDUIT	98.6
2.9513 0.0160				
(1F)018	(1F)018	(1F)017G	CONDUIT	165.3
0.6231 0.0160				
(1F)019	(1F)019	(1F)018	CONDUIT	145.7
0.5080 0.0160				
(1F)020	(1F)020	(1F)019	CONDUIT	510.5
0.5015 0.0160				
(1F)021	(1F)021	(1F)020	CONDUIT	426.6
0.4336 0.0160				
(1F)022	(1F)022	(1F)021	CONDUIT	325.8
0.4635 0.0160				
(1F)023	(1F)023	(1F)022	CONDUIT	209.0
0.5215 0.0160				
(1F)024	(1F)024	(1F)023	CONDUIT	263.7
2.5557 0.0160				
(1F)025	(1F)025	(1F)024	CONDUIT	209.0
2.6025 0.0160				
(1F)026	(1F)026	(1F)025	CONDUIT	222.4
2.6933 0.0160				
(1F)026A	(1F)026A	(1F)026	CONDUIT	213.9
0.2665 0.0160				
(1F)027	(1F)027	(1F)026A	CONDUIT	212.7
0.2821 0.0160				
(1F)028	(1F)028	(1F)027	CONDUIT	186.6
0.2733 0.0160				
(1F)029	(1F)029	(1F)028	CONDUIT	204.3
0.2887 0.0160				
(1F)029A	(1F)029A	(1F)029	CONDUIT	216.3
0.2773 0.0160				
(1F)030	(1F)030	(1F)029A	CONDUIT	264.9
0.2793 0.0160				
(1G)001	(1G)001	(1F)017E	CONDUIT	495.7
0.1775 0.0160				
(1G)001A	(1G)001A	(1G)001	CONDUIT	186.6
0.2090 0.0160				
(1G)002	(1G)002	(1G)001A	CONDUIT	221.2
0.2124 0.0160				
(1G)003	(1G)003	(1G)002	CONDUIT	255.8
0.1056 0.0160				
(1G)004	(1G)004	(1G)003	CONDUIT	209.7
0.1574 0.0160				
(1G)005	(1G)005	(1G)004	CONDUIT	199.2
0.2510 0.0160				
(1G)006	(1G)006	(1G)005	CONDUIT	179.5
0.0557 0.0160				
(1G)007	(1G)007	(1G)006	CONDUIT	125.3
0.3032 0.0160				
(1G)008	(1G)008A	(1G)007	CONDUIT	420.1

0.1714	0.0160	(1G)008C	(1G)008B	CONDUIT	228.5
0.1663	0.0160	(1G)009	(1G)008A	CONDUIT	205.5
0.4380	0.0160	(1G)009A	(1G)008C	CONDUIT	168.8
0.2192	0.0160	(1G)009B	(1G)009A	CONDUIT	204.4
0.2201	0.0160	(1G)009C	(1G)009B	CONDUIT	218.1
0.2064	0.0160	(1G)009D	(1G)009C	CONDUIT	31.4
0.1908	0.0160	(1G)009E	(1G)009D	CONDUIT	148.9
0.1679	0.0160	(1G)010	(1G)009E	CONDUIT	227.8
0.2107	0.0160	(1G)011	(1G)010	CONDUIT	168.8
0.2133	0.0160	(1G)012	(1G)011	CONDUIT	255.6
0.2074	0.0160	(1G)013	(1G)012	CONDUIT	249.6
0.2003	0.0160	(1G)014	(1G)009B	CONDUIT	149.9
7.6518	0.0160	(1G)014A	(1G)014	CONDUIT	179.3
0.3570	0.0160	(1G)015	(1G)014A	CONDUIT	341.2
0.3283	0.0160	(1G)016	(1G)015	CONDUIT	230.4
0.3385	0.0160	(1G)017	(1G)016	CONDUIT	205.1
0.3511	0.0160	(1G)018	(1G)017	CONDUIT	238.3
0.3441	0.0160	(1G)018A	(1G)018	CONDUIT	20.3
0.8374	0.0160	(1G)019	(1G)162C	CONDUIT	232.2
2.1961	0.0160	(1G)019O	(1G)018A	CONDUIT	275.0
0.3272	0.0160	(1G)020	(1G)019	CONDUIT	194.9
0.3591	0.0160	(1G)045	(1G)020	CONDUIT	194.9
1.0056	0.0160	(1G)046	(1G)045	CONDUIT	271.2
0.3650	0.0160	(1G)047	(1G)046	CONDUIT	108.3
0.3232	0.0160	(1G)048	(1G)047	CONDUIT	382.0
0.3168	0.0160	(1G)049	(1G)048	CONDUIT	190.0
0.2947	0.0160	(1G)050	(1G)049	CONDUIT	185.0
0.2108	0.0160	(1G)051	(1G)050	CONDUIT	193.0
0.2200	0.0160	(1G)052	(1G)051	CONDUIT	182.0
0.2200	0.0160	(1G)053	(1G)052	CONDUIT	380.0
0.2200	0.0160				

(1G)054		(1G)054	(1G)053	CONDUIT	365.0
0.2200	0.0160				
(1G)055		(1G)055	(1G)054	CONDUIT	365.0
0.2200	0.0160				
(1G)056		(1G)056	(1G)055	CONDUIT	363.0
0.2200	0.0160				
(1G)057		(1G)057	(1G)056	CONDUIT	365.0
0.5000	0.0160				
(1G)058		(1G)058	(1G)057	CONDUIT	365.0
0.5000	0.0160				
(1G)059		(1G)059	(1G)058	CONDUIT	342.0
0.5000	0.0160				
(1G)060		(1G)060	(1G)059	CONDUIT	29.0
0.5000	0.0160				
(1G)061		(1G)061	(1G)060	CONDUIT	339.0
0.5000	0.0160				
(1G)062		(1G)062	(1G)061	CONDUIT	334.0
0.6000	0.0160				
(1G)063		(1G)063	(1G)062	CONDUIT	60.0
0.6000	0.0160				
(1G)064		(1G)064	(1G)063	CONDUIT	356.0
0.6000	0.0160				
(1G)065		(1G)065	(1G)064	CONDUIT	245.0
0.6000	0.0160				
(1G)066		(1G)066	(1G)065	CONDUIT	159.0
0.6000	0.0160				
(1G)067		(1G)067	(1G)066	CONDUIT	285.0
0.6000	0.0160				
(1G)068		(1G)068	(1G)067	CONDUIT	351.0
0.6000	0.0160				
(1G)069		(1G)069	(1G)068	CONDUIT	421.0
0.6000	0.0160				
(1G)070		(1G)070	(1G)069	CONDUIT	360.0
0.6000	0.0160				
(1G)071		(1G)071	(1G)070	CONDUIT	277.0
0.6000	0.0160				
(1G)146		(1G)146	(1G)002	CONDUIT	103.8
0.3951	0.0160				
(1G)146A		(1G)146A	(1G)146	CONDUIT	49.8
0.5221	0.0160				
(1G)162		(1G)162	(1G)162D	CONDUIT	495.8
0.3207	0.0160				
(1G)162A		(1G)162A	(1G)162	CONDUIT	280.9
0.3346	0.0160				
(1G)162B		(1G)162B	(1G)162A	CONDUIT	198.6
0.3525	0.0160				
(1G)162C		(1G)162C	(1G)162B	CONDUIT	249.4
0.3328	0.0160				
(1G)162D		(1G)162D	(1G)009E	CONDUIT	51.4
13.0401	0.0160				
(1G)243		(1G)243	(1G)045	CONDUIT	432.8
0.3166	0.0160				
(1H)001		(1H)001	(1F)023	CONDUIT	209.5
0.5108	0.0160				
(1H)004		(1H)004	(1J)050	CONDUIT	60.0
2.2818	0.0160				
(1H)005		(1H)005	(1H)004	CONDUIT	289.0
0.0069	0.0160				
(1H)006		(1H)006	(1H)005	CONDUIT	350.8
0.4276	0.0160				
(1H)007		(1H)007	(1H)006	CONDUIT	184.1

0.4942	0.0160				
(1H)008		(1H)008	(1H)007	CONDUIT	259.0
0.4518	0.0160				
(1H)009		(1H)009	(1H)008	CONDUIT	25.2
0.5564	0.0160				
(1H)010		(1H)010	(1H)009	CONDUIT	139.4
0.2798	0.0160				
(1H)011		(1H)011	(1H)010	CONDUIT	32.9
1.8530	0.0160				
(1H)038		(1H)038	(1H)001	CONDUIT	201.7
1.4129	0.0160				
(1H)039		(1H)039	(1H)038	CONDUIT	271.1
1.9258	0.0160				
(1H)040		(1H)040	(1H)039	CONDUIT	38.6
11.4678	0.0160				
(1H)041		(1H)041	(1H)040	CONDUIT	253.5
0.2130	0.0160				
(1H)042		(1H)042	(1H)041	CONDUIT	156.1
1.1854	0.0160				
(1H)043		(1H)043	(1H)042	CONDUIT	77.1
0.6357	0.0160				
(1H)044		(1H)044	(1H)043	CONDUIT	246.0
0.5203	0.0160				
(1H)045		(1H)045	(1H)044	CONDUIT	189.0
0.4974	0.0160				
(1J)001		(1J)001	(1A)042	CONDUIT	243.9
0.3526	0.0160				
(1J)002		(1J)002	(1J)001	CONDUIT	397.0
0.2670	0.0160				
(1J)003		(1J)003	(1J)002	CONDUIT	323.9
0.2346	0.0160				
(1J)004		(1J)004	(1J)003	CONDUIT	415.8
0.1828	0.0160				
(1J)005		(1J)005	(1J)004	CONDUIT	456.3
0.1665	0.0160				
(1J)006		(1J)006	(1J)005	CONDUIT	380.4
0.1893	0.0160				
(1J)007		(1J)007	(1J)006	CONDUIT	226.3
0.2210	0.0160				
(1J)008		(1J)008	(1J)007	CONDUIT	98.0
0.3368	0.0160				
(1J)009		(1J)009	(1J)008	CONDUIT	228.5
0.1663	0.0160				
(1J)010		(1J)010	(1J)009	CONDUIT	260.2
0.2267	0.0160				
(1J)011		(1J)011	(1J)010	CONDUIT	185.4
0.1241	0.0160				
(1J)012		(1J)012	(1J)011	CONDUIT	274.3
0.1860	0.0160				
(1J)013		(1J)013	(1J)012	CONDUIT	247.8
0.2058	0.0160				
(1J)014		(1J)014	(1J)013	CONDUIT	135.9
0.2576	0.0160				
(1J)041		(1J)041	(1J)014	CONDUIT	61.7
0.7778	0.0160				
(1J)042		(1J)042	(1J)041	CONDUIT	230.3
1.4152	0.0160				
(1J)042A		(1J)042A	(1J)042	CONDUIT	179.8
1.2905	0.0160				
(1J)042B		(1J)042B	(1J)042A	CONDUIT	211.0
1.7153	0.0160				

(1J)043		(1J)043	(1J)042B	CONDUIT	301.4
0.9822	0.0160				
(1J)044		(1J)044	(1J)043	CONDUIT	505.5
0.1563	0.0160				
(1J)045		(1J)045	(1J)044	CONDUIT	400.3
0.1574	0.0160				
(1J)046		(1J)046	(1J)045	CONDUIT	205.1
0.1024	0.0160				
(1J)047		(1J)047	(1J)046	CONDUIT	63.8
0.1568	0.0160				
(1J)048		(1J)048	(1J)047	CONDUIT	56.8
0.9685	0.0160				
(1J)050		(1J)050	(1J)048	CONDUIT	352.9
0.4393	0.0160				
(1J)050A		(1J)050A	(1J)050	CONDUIT	56.7
0.1586	0.0160				
(1J)051		(1J)051	(1J)050A	CONDUIT	347.4
0.5153	0.0160				
(1J)052		(1J)052	(1J)051	CONDUIT	236.6
0.0211	0.0160				
(1J)053		(1J)053	(1J)052	CONDUIT	84.6
0.1773	0.0160				
(1J)054		(1J)054	(1J)053	CONDUIT	290.7
0.4575	0.0160				
(1J)054A		(1J)054A	(1J)054	CONDUIT	70.5
0.4394	0.0160				
(1J)055		(1J)055	(1J)054A	CONDUIT	296.5
0.0304	0.0160				
(1J)056		(1J)056	(1J)055	CONDUIT	411.3
0.1994	0.0160				
(1J)057		(1J)057	(1J)056	CONDUIT	344.8
0.1624	0.0160				
(1J)058		(1J)058	(1J)057	CONDUIT	312.6
0.2143	0.0160				
(1J)059		(1J)059	(1J)058	CONDUIT	336.4
0.0862	0.0160				
(1J)060		(1J)060	(1J)059	CONDUIT	332.2
0.0632	0.0160				
(1K)001		(1K)001	(1J)060	CONDUIT	266.1
2.2169	0.0160				
(1K)002		(1K)002	(1K)001	CONDUIT	28.1
1.8855	0.0160				
(1K)002A		(1K)002A	(1K)002	CONDUIT	23.8
1.8900	0.0160				
(1K)003		(1K)003	(1K)002A	CONDUIT	106.2
0.3580	0.0160				
(1K)004		(1K)004	(1K)003	CONDUIT	326.6
0.1837	0.0160				
(1K)005		(1K)005	(1K)004	CONDUIT	363.5
0.2366	0.0160				
(1K)006		(1K)006	(1K)005	CONDUIT	41.2
0.0243	0.0160				
(1K)007		(1K)007	(1K)006	CONDUIT	377.3
0.2359	0.0160				
(1K)008		(1K)008	(1K)007	CONDUIT	349.3
0.2262	0.0160				
(1K)008A		(1K)008A	(1K)008	CONDUIT	103.6
0.4248	0.0160				
(1K)009		(1K)009	(1K)008A	CONDUIT	263.0
0.1369	0.0160				
(1K)010		(1K)010	(1K)009	CONDUIT	364.3

0.2141	0.0160					
(1K)011		(1K)011	(1K)010	CONDUIT		181.1
0.2539	0.0160					
(1K)012		(1K)012	(1K)011	CONDUIT		419.6
0.2097	0.0160					
(1K)013		(1K)013	(1K)012	CONDUIT		510.8
0.1175	0.0160					
(1K)014		(1K)014	(1K)013	CONDUIT		263.4
0.1822	0.0160					
(1M)000		(1M)000	(1G)013	CONDUIT		165.1
0.2543	0.0160					
(1M)000A		(1M)001B	(1M)000	CONDUIT		58.7
0.8856	0.0160					
(1M)000B		(1M)001A	(1M)001B	CONDUIT		385.8
0.2696	0.0160					
(1M)001		(1M)001	(1M)001A	CONDUIT		301.0
0.4884	0.0160					
(1M)002		(1M)002	(1M)001	CONDUIT		337.5
0.2667	0.0160					
(1M)003		(1M)003	(1M)002	CONDUIT		181.4
0.3307	0.0160					
(1M)010		(1M)010	(1M)282	CONDUIT		38.8
0.4898	0.0160					
(1M)011		(1M)011	(1M)010	CONDUIT		396.6
0.2421	0.0160					
(1M)012		(1M)012	(1M)011	CONDUIT		20.7
0.6760	0.0160					
(1M)012O		(1M)012	(1M)038	CONDUIT		297.0
0.1482	0.0160					
(1M)013		(1M)013	(1M)012	CONDUIT		474.8
0.2401	0.0160					
(1M)014		(1M)014	(1M)013	CONDUIT		421.3
0.2445	0.0160					
(1M)015		(1M)015	(1M)014	CONDUIT		431.0
0.2436	0.0160					
(1M)016		(1M)016	(1M)015	CONDUIT		492.3
0.2397	0.0160					
(1M)017		(1M)017	(1M)016	CONDUIT		14.2
0.9142	0.0160					
(1M)018		(1M)018	(1M)017	CONDUIT		191.8
0.2711	0.0160					
(1M)019		(1M)019	(1M)018	CONDUIT		322.0
0.2516	0.0160					
(1M)020		(1M)020	(1M)019	CONDUIT		299.5
0.2504	0.0160					
(1M)020O		(1M)020	(1M)123	CONDUIT		22.2
1.4401	0.0160					
(1M)021		(1M)021	(1M)020	CONDUIT		321.0
0.3302	0.0160					
(1M)022		(1M)022	(1M)021	CONDUIT		178.5
0.3586	0.0160					
(1M)023		(1M)023	(1M)022	CONDUIT		178.6
0.3640	0.0160					
(1M)024		(1M)024	(1M)023	CONDUIT		435.4
0.3216	0.0160					
(1M)024A		(1M)025	(1M)024	CONDUIT		266.5
0.3377	0.0160					
(1M)025		(1M)026	(1M)025	CONDUIT		239.3
0.3384	0.0160					
(1M)027		(1M)027	(1M)026	CONDUIT		414.2
0.3259	0.0160					

(1M) 028	(1M) 028	(1M) 027	CONDUIT	296.9
0.3334	0.0160			
(1M) 035	(1M) 035	(1M) 281	CONDUIT	147.0
0.2925	0.0160			
(1M) 036	(1M) 036	(1M) 035	CONDUIT	158.3
0.2842	0.0160			
(1M) 037	(1M) 037	(1M) 036	CONDUIT	163.4
0.3549	0.0160			
(1M) 038	(1M) 038	(1M) 037	CONDUIT	153.3
0.3588	0.0160			
(1M) 039	(1M) 039	(1M) 012	CONDUIT	97.6
0.9526	0.0160			
(1M) 040	(1M) 040	(1M) 039	CONDUIT	166.0
0.3917	0.0160			
(1M) 041	(1M) 041	(1M) 040	CONDUIT	306.9
0.3324	0.0160			
(1M) 092	(1M) 092	(1M) 041	CONDUIT	316.7
0.3252	0.0160			
(1M) 093	(1M) 093	(1M) 092	CONDUIT	14.8
1.0825	0.0160			
(1M) 094	(1M) 094	(1M) 093	CONDUIT	481.1
0.3159	0.0160			
(1M) 116	(1M) 116	(1M) 094	CONDUIT	27.6
0.6874	0.0160			
(1M) 117	(1M) 117	(1M) 116	CONDUIT	42.8
0.5376	0.0160			
(1M) 118	(1M) 118	(1M) 117	CONDUIT	160.2
0.3682	0.0160			
(1M) 119	(1M) 119	(1M) 118	CONDUIT	339.8
0.3414	0.0160			
(1M) 120	(1M) 120	(1M) 119	CONDUIT	24.9
0.7232	0.0160			
(1M) 121	(1M) 121	(1M) 120	CONDUIT	341.4
0.3281	0.0160			
(1M) 122	(1M) 122	(1M) 121	CONDUIT	167.3
0.3647	0.0160			
(1M) 123	(1M) 123	(1M) 122	CONDUIT	270.4
0.3328	0.0160			
(1M) 124	(1M) 124	(1M) 123	CONDUIT	363.2
0.3304	0.0160			
(1M) 125	(1M) 125	(1M) 124	CONDUIT	195.8
0.3423	0.0160			
(1M) 126	(1M) 126	(1M) 125	CONDUIT	158.8
0.3716	0.0160			
(1M) 127	(1M) 127	(1M) 126	CONDUIT	407.8
0.3237	0.0160			
(1M) 128	(1M) 128	(1M) 127	CONDUIT	190.2
0.3575	0.0160			
(1M) 129	(1M) 129	(1M) 128	CONDUIT	280.5
0.3315	0.0160			
(1M) 130	(1M) 130	(1M) 129	CONDUIT	44.2
0.5208	0.0160			
(1M) 131	(1M) 131	(1M) 130	CONDUIT	140.5
0.3773	0.0160			
(1M) 132	(1M) 132	(1M) 131	CONDUIT	321.8
0.3294	0.0160			
(1M) 133	(1M) 133	(1M) 132	CONDUIT	302.2
0.3309	0.0160			
(1M) 161	(1M) 161	(1M) 020	CONDUIT	424.0
1.8750	0.0160			
(1M) 162	(1M) 162	(1M) 161	CONDUIT	354.0

0.5000	0.0160					
(1M)163		(1M)163	(1M)162	CONDUIT		358.0
0.5000	0.0160					
(1M)164		(1M)164	(1M)163	CONDUIT		360.0
0.5000	0.0160					
(1M)165		(1M)165	(1M)164	CONDUIT		366.0
0.5000	0.0160					
(1M)278		(1M)278	(1M)003	CONDUIT		369.7
0.2651	0.0160					
(1M)279		(1M)279	(1M)278	CONDUIT		168.9
0.2782	0.0160					
(1M)279B		(1M)279B	(1M)279	CONDUIT		140.3
0.3137	0.0160					
(1M)281		(1M)281	(1M)279B	CONDUIT		255.6
0.4108	0.0160					
(1M)281B		(1M)281B	(1M)281	CONDUIT		148.2
0.4454	0.0160					
(1M)282		(1M)282	(1M)281B	CONDUIT		290.2
0.1723	0.0160					
(1M)283		(1M)283	(1M)282	CONDUIT		183.4
0.2999	0.0160					
(1M)284		(1M)284	(1N)112B	CONDUIT		165.6
0.2235	0.0160					
(1M)285		(1M)285	(1M)284	CONDUIT		404.9
0.2420	0.0160					
(1M)285A		(1M)285A	(1M)285	CONDUIT		171.8
0.2387	0.0160					
(1M)286		(1M)286	(1M)285A	CONDUIT		237.4
0.2191	0.0160					
(1M)287		(1M)287	(1M)286A	CONDUIT		241.6
0.2774	0.0160					
(1M)2876A		(1M)286A	(1M)286	CONDUIT		244.4
0.2742	0.0160					
(1M)288		(1M)288	(1M)287	CONDUIT		270.9
0.2768	0.0160					
(1M)288A		(1M)288A	(1M)288	CONDUIT		189.9
0.2896	0.0160					
(1M)288B		(1M)288B	(1M)288A	CONDUIT		224.8
0.2847	0.0160					
(1M)288C		(1M)288C	(1M)288B	CONDUIT		226.2
0.2431	0.0160					
(1N)004		(1N)004	(1M)283	CONDUIT		193.4
0.2637	0.0160					
(1N)005		(1N)005	(1N)004	CONDUIT		336.5
0.2675	0.0160					
(1N)006		(1N)006	(1N)005	CONDUIT		371.4
0.2828	0.0160					
(1N)007		(1N)007	(1N)006	CONDUIT		358.0
0.2877	0.0160					
(1N)007D		(1N)007D	(1N)007	CONDUIT		59.2
0.4727	0.0160					
(1N)007E		(1N)007E	(1N)007	CONDUIT		98.0
0.5408	0.0160					
(1N)008		(1N)008	(1N)007E	CONDUIT		315.6
0.3327	0.0160					
(1N)009		(1N)009	(1N)008	CONDUIT		146.6
0.3615	0.0160					
(1N)011		(1N)011	(1N)009	CONDUIT		344.9
0.3276	0.0160					
(1N)013		(1N)013	(1N)011	CONDUIT		353.3
0.3312	0.0160					

(1N) 014		(1N) 014	(1N) 013	CONDUIT	358.9
0.3260	0.0160				
(1N) 015		(1N) 015	(1N) 014	CONDUIT	148.7
0.3699	0.0160				
(1N) 016		(1N) 016	(1N) 015	CONDUIT	269.8
0.3336	0.0160				
(1N) 017		(1N) 017	(1N) 016	CONDUIT	324.0
0.3334	0.0160				
(1N) 018		(1N) 018	(1N) 017	CONDUIT	160.6
0.3612	0.0160				
(1N) 019		(1N) 019	(1N) 018	CONDUIT	198.4
0.2822	0.0160				
(1N) 020		(1N) 020	(1N) 019	CONDUIT	277.7
0.3853	0.0160				
(1N) 021		(1N) 021	(1N) 020	CONDUIT	322.6
0.3317	0.0160				
(1N) 022		(1N) 022	(1N) 021	CONDUIT	319.8
0.3315	0.0160				
(1N) 023		(1N) 023	(1N) 022	CONDUIT	328.1
0.3322	0.0160				
(1N) 024		(1N) 024	(1N) 023	CONDUIT	319.8
0.3284	0.0160				
(1N) 025		(1N) 025	(1N) 024	CONDUIT	431.5
0.3245	0.0160				
(1N) 045		(1N) 045	(1N) 007D	CONDUIT	360.3
0.9687	0.0160				
(1N) 046		(1N) 046	(1N) 045	CONDUIT	434.4
0.3660	0.0160				
(1N) 047		(1N) 047	(1N) 046	CONDUIT	334.2
0.3381	0.0160				
(1N) 109A		(1N) 109A	(1N) 007	CONDUIT	391.0
0.2225	0.0160				
(1N) 110		(1N) 110	(1N) 109A	CONDUIT	230.4
0.3732	0.0160				
(1N) 111A		(1N) 111A	(1N) 110	CONDUIT	374.2
0.2298	0.0160				
(1N) 112A		(1N) 112A	(1N) 111A	CONDUIT	333.7
0.2517	0.0160				
(1N) 112B		(1N) 112B	(1N) 112A	CONDUIT	150.8
0.3182	0.0160				
(1O) 001		(1O) 001	(1M) 028	CONDUIT	103.1
0.3782	0.0160				
(1O) 001A		(1O) 001A	(1O) 001	CONDUIT	229.3
0.3532	0.0160				
(1O) 002		(1O) 002	(1O) 001A	CONDUIT	19.6
0.7637	0.0160				
(1O) 002A		(1O) 002A	(1O) 002	CONDUIT	17.8
0.7874	0.0160				
(1O) 003		(1O) 003	(1O) 002A	CONDUIT	183.0
0.3607	0.0160				
(1O) 004		(1O) 004	(1O) 003	CONDUIT	154.1
0.3569	0.0160				
(1O) 005A		(1O) 005A	(1O) 004	CONDUIT	209.1
0.3540	0.0160				
(1O) 005B		(1O) 005B	(1O) 005A	CONDUIT	43.4
0.4379	0.0160				
(1O) 005C		(1O) 005C	(1O) 005B	CONDUIT	34.9
0.5152	0.0160				
(1O) 005D		(1O) 005D	(1O) 005C	CONDUIT	30.6
0.5225	0.0160				
(1O) 005E		(1O) 005E	(1O) 005C	CONDUIT	32.8

0.5183	0.0160					
(10)010		(10)010	(10)309	CONDUIT		295.0
0.0447	0.0160					
(10)011		(10)011	(10)010	CONDUIT		146.0
0.0440	0.0160					
(10)012		(10)012	(10)011	CONDUIT		245.0
0.3000	0.0160					
(10)013		(10)013	(10)012	CONDUIT		330.0
0.3000	0.0160					
(10)014		(10)014	(10)013	CONDUIT		124.0
0.3000	0.0160					
(10)015		(10)015	(10)014	CONDUIT		429.0
0.3000	0.0160					
(10)016		(10)016	(10)015	CONDUIT		315.0
0.3000	0.0160					
(10)017		(10)017	(10)016	CONDUIT		412.0
0.3000	0.0160					
(10)018		(10)018	(10)017	CONDUIT		428.0
0.3000	0.0160					
(10)019		(10)019	(10)018	CONDUIT		406.0
0.4000	0.0160					
(10)020		(10)020	(10)019	CONDUIT		372.0
0.4000	0.0160					
(10)021		(10)021	(10)020	CONDUIT		208.0
0.4000	0.0160					
(10)072		(10)072	(10)303	CONDUIT		314.2
0.2705	0.0160					
(10)157		(10)157	(10)308A	CONDUIT		169.9
0.2679	0.0160					
(10)300		(10)300	(1M)288C	CONDUIT		217.0
0.2903	0.0160					
(10)301		(10)301	(10)300	CONDUIT		266.7
0.2924	0.0160					
(10)302		(10)302	(10)301	CONDUIT		304.4
0.2727	0.0160					
(10)303		(10)303	(10)302	CONDUIT		312.7
0.2750	0.0160					
(10)304		(10)304	(10)072	CONDUIT		261.1
0.2489	0.0160					
(10)304A		(10)304A	(10)304B	CONDUIT		190.9
5.0765	0.0160					
(10)304B		(10)304B	(10)304C	CONDUIT		60.8
0.2796	0.0160					
(10)304C		(10)304C	(10)005D	CONDUIT		33.0
0.0303	0.0160					
(10)305		(10)305	(10)305A	CONDUIT		305.8
0.0176	0.0160					
(10)305A		(10)305A	(10)304	CONDUIT		40.6
23.8729	0.0160					
(10)306		(10)306	(10)305	CONDUIT		301.6
0.2767	0.0160					
(10)306A		(10)306A	(10)306	CONDUIT		305.8
0.2759	0.0160					
(10)307		(10)307	(10)306A	CONDUIT		155.0
0.2767	0.0160					
(10)308		(10)308	(10)307	CONDUIT		185.3
0.2733	0.0160					
(10)308A		(10)308A	(10)308	CONDUIT		52.4
0.2786	0.0160					
(10)309		(10)309	(10)308	CONDUIT		160.0
0.2566	0.0160					

(1P)003	(1P)003	(1P)002	CONDUIT	46.9
0.8953 0.0130				
(1P)004	(1P)004	(1P)003	CONDUIT	378.6
0.3857 0.0130				
(1P)005	(1P)005	(1P)004	CONDUIT	389.2
0.6732 0.0130				
(1P)006	(1P)006	(1P)005	CONDUIT	472.2
0.4490 0.0130				
(1P)007	(1P)007	(1P)006	CONDUIT	472.1
0.8345 0.0130				
(1P)008	(1P)008	(1P)007	CONDUIT	486.5
0.5015 0.0130				
(1P)008A	(1P)008A	(1P)008	CONDUIT	27.0
1.8525 0.0130				
(1P)009	(1P)009	(1P)008A	CONDUIT	232.4
1.4032 0.0130				
(1P)010	(1P)010	(1P)009	CONDUIT	52.7
0.5414 0.0130				
(1P)011	(1P)011	(1P)010	CONDUIT	394.9
0.6011 0.0130				
(1P)012	(1P)012	(1P)011	CONDUIT	403.4
0.5937 0.0130				
(1P)013	(1P)013	(1P)012	CONDUIT	403.4
0.5869 0.0130				
(1P)014	(1P)014	(1P)013	CONDUIT	401.1
0.5880 0.0130				
(1P)015	(1P)015	(1P)014	CONDUIT	397.5
0.5940 0.0130				
(1P)016	(1P)016	(1P)015	CONDUIT	403.0
0.4472 0.0130				
(1P)016A	(1P)016A	(1P)016	CONDUIT	186.4
0.4521 0.0130				
(1P)017	(1P)017	(1P)016A	CONDUIT	74.1
0.4496 0.0130				
(1P)018	(1P)018	(1P)017	CONDUIT	422.2
0.4464 0.0130				
(1P)024	(1P)024	(1P)017	CONDUIT	493.4
0.4478 0.0130				
(1P)042	(1P)042	(1P)003	CONDUIT	208.1
1.3760 0.0130				
(1P)042A	(1P)042A	(1P)042	CONDUIT	474.9
0.3019 0.0130				
(1P)043	(1P)043	(1P)042A	CONDUIT	466.4
0.3103 0.0130				
(1P)044	(1P)044	(1P)043	CONDUIT	115.7
0.3110 0.0130				
(1P)065	(1P)065	(1P)043	CONDUIT	369.1
0.2915 0.0130				
(1P)073	(1P)073	(1P)016A	CONDUIT	460.6
0.5892 0.0130				
(1P)079	(1P)079	(1P)017	CONDUIT	120.2
0.5775 0.0130				
(2A)001	(2A)001	(2A)000	CONDUIT	444.9
0.1349 0.0160				
(2A)002	(2A)002	(2A)001	CONDUIT	46.6
3.8660 0.0160				
(2A)003	(2A)003	(2A)002	CONDUIT	268.3
0.4174 0.0160				
(2A)004	(2A)004	(2A)003	CONDUIT	343.0
0.3556 0.0160				
(2A)005	(2A)005	(2A)004	CONDUIT	367.6

0.3509	0.0160				
(2A)006		(2A)006	(2A)005	CONDUIT	378.7
0.1399	0.0160				
(2A)007		(2A)007	(2A)006	CONDUIT	354.1
0.1779	0.0160				
(2A)008		(2A)008	(2A)007	CONDUIT	313.9
0.1561	0.0160				
(2A)009		(2A)009	(2A)008	CONDUIT	453.5
0.1544	0.0160				
(2A)010		(2A)010	(2A)009	CONDUIT	463.6
0.1532	0.0160				
(2A)011		(2A)011	(2A)010	CONDUIT	488.3
0.1454	0.0160				
(2A)012		(2A)012	(2A)011	CONDUIT	398.9
0.1529	0.0160				
(2A)013		(2A)013	(2A)012	CONDUIT	419.3
0.1431	0.0160				
(2A)014		(2A)014	(2A)013	CONDUIT	325.6
0.2089	0.0160				
(2A)015		(2A)015	(2A)014	CONDUIT	111.5
0.2064	0.0160				
(2A)016		(2A)016	(2A)015	CONDUIT	179.1
0.1787	0.0160				
(2A)017		(2A)017	(2A)016	CONDUIT	308.5
0.2042	0.0160				
(2A)018		(2A)018	(2A)017	CONDUIT	203.6
0.1817	0.0160				
(2A)019		(2A)019	(2A)018	CONDUIT	150.3
0.2395	0.0160				
(2A)020		(2A)020	(2A)019	CONDUIT	473.1
0.1775	0.0160				
(2A)021		(2A)021	(2A)020	CONDUIT	440.3
0.4042	0.0160				
(2A)022		(2A)022	(2A)021	CONDUIT	431.7
0.4355	0.0160				
(2A)023		(2A)023	(2A)022	CONDUIT	204.5
0.4499	0.0160				
(2A)024		(2A)024	(2A)023	CONDUIT	91.4
0.5144	0.0160				
(2A)025		(2A)025	(2A)024	CONDUIT	41.5
0.6268	0.0160				
(2A)026		(2A)026	(2A)025	CONDUIT	72.5
0.5379	0.0160				
(2A)027		(2A)027	(2A)026	CONDUIT	381.4
0.1835	0.0160				
(2A)028		(2A)028	(2A)027	CONDUIT	265.2
0.1358	0.0160				
(2A)029		(2A)029	(2A)028	CONDUIT	215.2
0.1626	0.0160				
(2A)030		(2A)030	(2A)029	CONDUIT	205.2
0.1949	0.0160				
(2A)031		(2A)031	(2A)030	CONDUIT	537.1
0.2439	0.0160				
(2A)032		(2A)032	(2A)031	CONDUIT	116.3
0.1547	0.0160				
(2A)033		(2A)033	(2A)032	CONDUIT	168.1
0.2201	0.0160				
(2A)034		(2A)034	(2A)033	CONDUIT	66.9
0.3440	0.0160				
(2A)035		(2A)035	(2A)034	CONDUIT	500.3
0.3478	0.0160				

(2A) 036		(2A) 036	(2A) 035	CONDUIT	497.5
0.3498	0.0160				
(2A) 037		(2A) 037	(2A) 036	CONDUIT	573.9
0.3015	0.0160				
(2A) 038		(2A) 038	(2A) 037	CONDUIT	483.6
0.3598	0.0160				
(2A) 039		(2A) 039	(2A) 038	CONDUIT	444.6
0.3486	0.0160				
(2A) 040		(2A) 040	(2A) 039	CONDUIT	418.7
0.3416	0.0160				
(2A) 041		(2A) 041	(2A) 040	CONDUIT	495.1
0.3494	0.0160				
(2A) 042		(2A) 042	(2A) 041	CONDUIT	458.1
0.3493	0.0160				
(2A) 043		(2A) 043	(2A) 042	CONDUIT	460.4
0.3975	0.0160				
(2A) 044		(2A) 044	(2A) 043	CONDUIT	392.9
0.3360	0.0160				
(2A) 045		(2A) 045	(2A) 044	CONDUIT	379.5
0.3162	0.0160				
(2A) 046		(2A) 046	(2A) 045	CONDUIT	497.9
0.3013	0.0160				
(2A) 047		(2A) 047	(2A) 046	CONDUIT	395.2
0.1518	0.0160				
(2A) 048		(2A) 048	(2A) 047	CONDUIT	437.2
0.1487	0.0160				
(2A) 048O		(2A) 048	(1A) 038	CONDUIT	38.4
6.5172	0.0160				
(2A) 049		(2A) 049	(2A) 048	CONDUIT	517.1
0.1586	0.0160				
(2A) 050		(2A) 050	(2A) 049	CONDUIT	581.4
0.1410	0.0160				
(2A) 051		(2A) 051	(2A) 050	CONDUIT	390.7
0.3583	0.0160				
(2A) 052		(2A) 052	(2A) 051	CONDUIT	402.9
0.3475	0.0160				
(2A) 053		(2A) 053	(2A) 052	CONDUIT	290.0
0.3620	0.0160				
(2A) 054		(2A) 054	(2A) 053	CONDUIT	301.0
1.0134	0.0160				
(2A) 055		(2A) 055	(2A) 054	CONDUIT	433.7
0.1522	0.0160				
(2A) 056		(2A) 056	(2A) 055	CONDUIT	543.8
0.1508	0.0160				
(2A) 057		(2A) 057	(2A) 056	CONDUIT	550.0
0.2418	0.0160				
(2A) 058		(2A) 058	(2A) 057	CONDUIT	519.6
0.2117	0.0160				
(2A) 059		(2A) 059	(2A) 058	CONDUIT	494.9
0.2263	0.0160				
(2A) 060		(2A) 060	(2A) 059	CONDUIT	393.6
0.3862	0.0160				
(2A) 061		(2A) 061	(2A) 060	CONDUIT	382.6
0.3215	0.0160				
(2A) 062		(2A) 062	(2A) 061	CONDUIT	489.8
0.4676	0.0160				
(2A) 063		(2A) 063	(2A) 062	CONDUIT	197.8
1.3904	0.0160				
(2A) 064		(2A) 064	(2A) 063	CONDUIT	453.5
0.4234	0.0160				
(2A) 065		(2A) 065	(2A) 064	CONDUIT	479.3

0.4047	0.0160					
(2A)066		(2A)066	(2A)065	CONDUIT		475.3
1.9229	0.0160					
(2A)067		(2A)067	(2A)066	CONDUIT		171.1
0.4559	0.0160					
(2A)068		(2A)068	(2A)067	CONDUIT		291.9
0.4214	0.0160					
(2A)069		(2A)069	(2A)057	CONDUIT		29.9
12.7802	0.0160					
(2C)001		(2C)001	(2A)069	CONDUIT		182.9
0.1531	0.0160					
(2C)002		(2C)002	(2C)001	CONDUIT		190.8
0.1572	0.0160					
(2C)003		(2C)003	(2C)002	CONDUIT		298.7
0.2210	0.0160					
(2C)004		(2C)004	(2C)003	CONDUIT		316.5
0.2275	0.0160					
(2C)005		(2C)005	(2C)004	CONDUIT		299.3
0.2372	0.0160					
(2C)006		(2C)006	(2C)005	CONDUIT		261.6
0.2026	0.0160					
(2C)007		(2C)007	(2C)006	CONDUIT		211.9
0.2265	0.0160					
(2C)008		(2C)008	(2C)007	CONDUIT		171.6
0.2390	0.0160					
(2C)009		(2C)009	(2C)008	CONDUIT		334.1
0.2245	0.0160					
(2C)0090		(2C)009	(2A)062	CONDUIT		29.4
1.3601	0.0160					
(2D)001		(2D)001	(2C)009	CONDUIT		348.4
0.1234	0.0160					
(2D)001A		(2D)001A	(2D)001	CONDUIT		326.0
0.1104	0.0160					
(2D)002		(2D)002	(2D)001A	CONDUIT		380.9
0.4070	0.0160					
(2D)003		(2D)003	(2D)002	CONDUIT		405.1
0.4196	0.0160					
(2D)004		(2D)004	(2D)003	CONDUIT		422.9
0.3712	0.0160					
(2D)005		(2D)005	(2D)004	CONDUIT		377.0
0.4217	0.0160					
(2D)006		(2D)006	(2D)005	CONDUIT		352.6
0.4623	0.0160					
(2D)007		(2D)007	(2D)006	CONDUIT		543.9
0.3420	0.0160					
(2D)008		(2D)008	(2D)007	CONDUIT		347.0
0.2853	0.0160					
(2D)009		(2D)009	(2D)008	CONDUIT		277.8
0.9719	0.0160					
(2D)010		(2D)010	(2D)009	CONDUIT		116.5
0.3433	0.0160					
(2D)011		(2D)011	(2D)010	CONDUIT		161.5
0.4212	0.0160					
(2D)012		(2D)012	(2D)011	CONDUIT		321.2
0.5729	0.0160					
(2D)013		(2D)013	(2D)012	CONDUIT		214.4
0.5549	0.0160					
(2D)014		(2D)014	(2D)013	CONDUIT		173.3
0.4673	0.0160					
(2D)015		(2D)015	(2D)014	CONDUIT		545.2
2.0176	0.0160					

(2D) 016		(2D) 016	(2D) 015	CONDUIT	588.6
0.4146	0.0160				
(2D) 017		(2D) 017	(2D) 016	CONDUIT	331.7
0.5156	0.0160				
(2D) 018		(2D) 018	(2D) 017	CONDUIT	124.1
0.5720	0.0160				
(2D) 019		(2D) 019	(2D) 018	CONDUIT	48.8
0.5741	0.0160				
(2D) 020		(2D) 020	(2D) 019	CONDUIT	159.8
0.4004	0.0160				
(2D) 021		(2D) 021	(2D) 020	CONDUIT	446.6
0.4120	0.0160				
(2D) 022		(2D) 022	(2D) 021	CONDUIT	249.5
0.4008	0.0160				
(2D) 023		(2D) 023	(2D) 022	CONDUIT	37.4
0.6155	0.0160				
(2D) 024		(2D) 024	(2D) 023	CONDUIT	298.8
0.4819	0.0160				
(2D) 025		(2D) 025	(2D) 024	CONDUIT	37.4
0.8293	0.0160				
(2D) 039		(2D) 039	(2D) 003	CONDUIT	151.6
0.8974	0.0160				
(2D) 040		(2D) 040	(2D) 244	CONDUIT	311.1
0.1511	0.0160				
(2D) 041		(2D) 041	(2D) 040	CONDUIT	393.5
0.4066	0.0160				
(2D) 042		(2D) 042	(2D) 041	CONDUIT	384.6
0.3900	0.0160				
(2D) 043		(2D) 043	(2D) 042	CONDUIT	444.8
0.4047	0.0160				
(2D) 044		(2D) 044	(2D) 043	CONDUIT	443.8
0.4056	0.0160				
(2D) 045		(2D) 045	(2D) 044	CONDUIT	442.1
0.4071	0.0160				
(2D) 045A		(2D) 045A	(2D) 045	CONDUIT	211.3
0.3408	0.0160				
(2D) 046		(2D) 046	(2D) 045A	CONDUIT	221.1
0.4071	0.0160				
(2D) 046A		(2D) 046A	(2D) 046	CONDUIT	228.6
0.3587	0.0160				
(2D) 241		(2D) 241	(2A) 063	CONDUIT	263.5
0.7058	0.0160				
(2D) 242		(2D) 242	(2D) 241	CONDUIT	406.5
0.2558	0.0160				
(2D) 243		(2D) 243	(2D) 242	CONDUIT	361.3
0.2547	0.0160				
(2D) 244		(2D) 244	(2D) 243	CONDUIT	395.9
0.3385	0.0160				
(2D) 244O		(2D) 244	(2D) 039	CONDUIT	92.0
2.8360	0.0160				
(2D) 245		(2D) 245	(2D) 244	CONDUIT	236.7
0.1394	0.0160				
(2D) 246		(2D) 246	(2D) 245	CONDUIT	295.5
0.2606	0.0160				
(2D) 247		(2D) 247	(2D) 246	CONDUIT	302.6
0.2578	0.0160				
(2D) 248		(2D) 248	(2D) 247	CONDUIT	297.8
0.2753	0.0160				
(2D) 249		(2D) 249	(2D) 248	CONDUIT	338.0
0.2544	0.0160				
(2D) 250		(2D) 250	(2D) 249	CONDUIT	168.8

0.2902	0.0160				
(2D) 251		(2D) 251	(2D) 250	CONDUIT	262.0
0.2672	0.0160				
(2D) 252		(2D) 252	(2D) 251	CONDUIT	408.0
0.2672	0.0160				
(2D) 253		(2D) 253	(2D) 252	CONDUIT	181.0
0.2672	0.0160				
(2D) 254		(2D) 254	(2D) 253	CONDUIT	351.0
0.2672	0.0160				
(2D) 255		(2D) 255	(2D) 254	CONDUIT	330.0
0.2672	0.0160				
(2D) 256		(2D) 256	(2D) 255	CONDUIT	289.0
0.2672	0.0160				
(2D) 257		(2D) 257	(2D) 256	CONDUIT	239.0
0.2672	0.0160				
(2D) 258		(2D) 258	(2D) 257	CONDUIT	253.0
0.2672	0.0160				
(2D) 259		(2D) 259	(2D) 258	CONDUIT	270.0
0.2672	0.0160				
(2D) 260		(2D) 260	(2D) 259	CONDUIT	238.0
0.2672	0.0160				
(2D) 261		(2D) 261	(2D) 260	CONDUIT	263.0
0.2672	0.0160				
(2D) 262		(2D) 262	(2D) 261	CONDUIT	432.0
0.2672	0.0160				
(2D) 263		(2D) 263	(2D) 262	CONDUIT	383.0
0.2672	0.0160				
(2D) 264		(2D) 264	(2D) 263	CONDUIT	347.0
0.2672	0.0160				
(2D) 265		(2D) 265	(2D) 264	CONDUIT	280.0
0.2672	0.0160				
(2D) 266		(2D) 266	(2D) 265	CONDUIT	336.0
0.2672	0.0160				
(2D) 267		(2D) 267	(2D) 266	CONDUIT	366.0
0.2672	0.0160				
(2E) 001		(2E) 001	(2A) 068	CONDUIT	433.6
0.1015	0.0160				
(2E) 002		(2E) 002	(2E) 001	CONDUIT	479.7
0.1647	0.0160				
(2E) 003		(2E) 003	(2E) 002	CONDUIT	207.5
0.4675	0.0160				
(2E) 004		(2E) 004	(2E) 003	CONDUIT	254.6
0.1414	0.0160				
(2E) 005		(2E) 005	(2E) 004	CONDUIT	277.8
0.0504	0.0160				
(2E) 006		(2E) 006	(2E) 005	CONDUIT	501.6
0.0478	0.0160				
(2E) 007		(2E) 007	(2E) 006	CONDUIT	464.0
0.1509	0.0160				
(2E) 008		(2E) 008	(2E) 007	CONDUIT	198.7
0.3573	0.0160				
(2E) 009		(2E) 009	(2E) 008	CONDUIT	354.3
0.2004	0.0160				
(2E) 010		(2E) 010	(2E) 009	CONDUIT	495.4
0.1433	0.0160				
(2E) 011		(2E) 011	(2E) 010	CONDUIT	398.2
0.1406	0.0160				
(2E) 012		(2E) 012	(2E) 011	CONDUIT	385.6
0.1426	0.0160				
(2E) 013		(2E) 013	(2E) 012	CONDUIT	536.1
0.1343	0.0160				

(2E) 014	(2E) 014	(2E) 013	CONDUIT	370.1
0.1351 0.0160				
(2E) 043	(2E) 043	(2E) 014	CONDUIT	104.6
0.3919 0.0160				
(2F) 001	(2F) 001	(2E) 014	CONDUIT	514.3
0.1264 0.0160				
(2F) 002	(2F) 002	(2F) 001	CONDUIT	501.6
0.1296 0.0160				
(2F) 003	(2F) 003	(2F) 002	CONDUIT	498.5
0.1304 0.0160				
(2F) 004	(2F) 004	(2F) 003	CONDUIT	244.5
0.1268 0.0160				
(2F) 005	(2F) 005	(2F) 004	CONDUIT	266.5
0.1313 0.0160				
(2F) 006	(2F) 006	(2F) 005	CONDUIT	106.4
0.1315 0.0160				
(2F) 007	(2F) 007	(2F) 006	CONDUIT	336.8
0.1306 0.0160				
(2F) 008	(2F) 008	(2F) 007	CONDUIT	146.6
0.1160 0.0160				
(2F) 009	(2F) 009	(2F) 008	CONDUIT	50.2
0.1394 0.0160				
(2F) 010	(2F) 010	(2F) 009	CONDUIT	38.9
2.2354 0.0160				
(2F) 011	(2F) 011	(2F) 010	CONDUIT	123.8
0.2423 0.0160				
(2F) 012	(2F) 012	(2F) 011	CONDUIT	478.6
0.2298 0.0160				
(2F) 013	(2F) 013	(2F) 012	CONDUIT	470.9
0.1975 0.0160				
(2F) 014	(2F) 014	(2F) 013	CONDUIT	455.0
0.2044 0.0160				
(2F) 015	(2F) 015	(2F) 014	CONDUIT	445.5
0.2088 0.0160				
(2F) 016	(2F) 016	(2F) 015	CONDUIT	470.9
0.1975 0.0160				
(2F) 017	(2F) 017	(2F) 016	CONDUIT	470.9
0.1975 0.0160				
(2F) 018	(2F) 018	(2F) 017	CONDUIT	461.5
0.2015 0.0160				
(2F) 019	(2F) 019	(2F) 018	CONDUIT	461.4
0.2015 0.0160				
(2F) 020	(2F) 020	(2F) 019	CONDUIT	480.5
0.1935 0.0160				
(2F) 021	(2F) 021	(2F) 020	CONDUIT	467.8
0.1988 0.0160				
(2F) 022	(2F) 022	(2F) 021	CONDUIT	454.8
0.2924 0.0160				
(2F) 023	(2F) 023	(2F) 022	CONDUIT	25.2
0.2151 0.0160				
(2F) 024	(2F) 024	(2F) 023	CONDUIT	597.0
0.2264 0.0160				
(2F) 025	(2F) 025	(2F) 024	CONDUIT	603.0
0.0225 0.0160				
(2F) 026	(2F) 026	(2F) 025	CONDUIT	647.0
0.0225 0.0150				
(2F) 027	(2F) 027	(2F) 026	CONDUIT	517.0
0.0225 0.0150				
(2F) 028	(2F) 028	(2F) 027	CONDUIT	637.0
0.0225 0.0150				
(2F) 029	(2F) 029	(2F) 028	CONDUIT	570.0

0.0225	0.0150					
(2F)030		(2F)030	(2F)029	CONDUIT		518.0
0.0225	0.0150					
(2F)031		(2F)031	(2F)030	CONDUIT		609.0
0.0225	0.0150					
(2F)032		(2F)032	(2F)031	CONDUIT		585.0
0.0225	0.0150					
(2F)033		(2F)033	(2F)032	CONDUIT		387.0
0.0225	0.0150					
(2G)001		(2G)001	(2F)022	CONDUIT		521.2
0.3374	0.0160					
(2G)002		(2G)002	(2G)001	CONDUIT		224.6
0.3202	0.0160					
(2G)002A		(2G)002A	(2G)002	CONDUIT		148.6
0.3305	0.0160					
(2G)003		(2G)003	(2G)002A	CONDUIT		99.1
0.3246	0.0160					
(2G)004		(2G)004	(2G)003	CONDUIT		485.5
0.3303	0.0160					
(2G)005		(2G)005	(2G)004	CONDUIT		495.3
0.3295	0.0160					
(2G)006		(2G)006	(2G)005	CONDUIT		498.7
0.5053	0.0160					
(2G)007		(2G)007	(2G)006	CONDUIT		163.5
0.4920	0.0160					
(2G)008		(2G)008	(2G)007	CONDUIT		30.4
0.3564	0.0160					
(2G)009		(2G)009	(2G)008	CONDUIT		158.6
0.5478	0.0160					
(2G)010		(2G)010	(2G)009	CONDUIT		115.0
0.4735	0.0160					
(2G)011		(2G)011	(2G)010	CONDUIT		227.8
0.4969	0.0160					
(2G)012		(2G)012	(2G)011	CONDUIT		369.8
0.2138	0.0160					
(2G)012A		(2G)012A	(2G)012	CONDUIT		82.6
0.5550	0.0160					
(2G)013		(2G)013	(2G)012A	CONDUIT		132.1
0.6273	0.0160					
(2G)013A		(2G)013A	(2G)013	CONDUIT		52.8
0.9994	0.0160					
(2G)014		(2G)014	(2G)013A	CONDUIT		346.8
0.6691	0.0160					
(2G)015		(2G)015	(2G)014	CONDUIT		33.0
0.1647	0.0160					
(2G)016		(2G)016	(2G)015	CONDUIT		303.8
0.2037	0.0160					
(2G)016A		(2G)016A	(2G)016	CONDUIT		82.5
0.1803	0.0160					
(2G)018		(2G)018	(2G)016A	CONDUIT		214.6
0.2087	0.0160					
(2G)019		(2G)019	(2G)018	CONDUIT		254.2
0.1979	0.0160					
(2G)020		(2G)020	(2G)019	CONDUIT		419.4
0.1978	0.0160					
(2G)021		(2G)021	(2G)020	CONDUIT		313.7
0.2011	0.0160					
(2G)022		(2G)022	(2G)021	CONDUIT		346.7
0.2009	0.0160					
(2G)023		(2G)023	(2G)022	CONDUIT		297.2
0.2008	0.0160					

(2G)024		(2G)024	(2G)023	CONDUIT	198.1
0.1986	0.0160				
(2G)025		(2G)025	(2G)024	CONDUIT	112.3
0.4951	0.0160				
(2G)026		(2G)026	(2G)025	CONDUIT	307.1
1.0114	0.0160				
(2G)040		(2G)040	(2G)002A	CONDUIT	505.2
0.4960	0.0160				
(2G)041		(2G)041	(2G)040	CONDUIT	499.0
0.0500	0.0150				
(2G)042		(2G)042	(2G)041	CONDUIT	524.0
0.0500	0.0150				
(2G)043		(2G)043	(2G)042	CONDUIT	469.0
0.0500	0.0150				
(2G)043A		(2G)043A	(2G)043	CONDUIT	292.0
0.0500	0.0150				
(2G)044		(2G)044	(2G)043A	CONDUIT	293.0
0.0500	0.0150				
(2G)045		(2G)045	(2G)044	CONDUIT	313.0
0.0500	0.0150				
(2G)359		(2G)359	(2G)025	CONDUIT	386.4
0.2061	0.0160				
(2H)001		(2H)001	(2J)018	CONDUIT	430.1
0.2371	0.0160				
(2H)002		(2H)002	(2H)001	CONDUIT	418.5
0.1649	0.0160				
(2H)003		(2H)003	(2H)002	CONDUIT	465.1
0.1570	0.0160				
(2H)005		(2H)005	(2H)003	CONDUIT	450.9
0.1619	0.0160				
(2H)006		(2H)006	(2H)005	CONDUIT	380.8
0.1602	0.0160				
(2H)007		(2H)007	(2H)006	CONDUIT	310.5
0.1965	0.0160				
(2H)008		(2H)008	(2H)007	CONDUIT	316.5
0.3854	0.0160				
(2H)009		(2H)009	(2H)008	CONDUIT	30.2
0.3312	0.0160				
(2H)010		(2H)010	(2H)009	CONDUIT	35.1
0.3134	0.0160				
(2H)011		(2H)011	(2H)010	CONDUIT	488.8
0.3724	0.0160				
(2H)012		(2H)012	(2H)011	CONDUIT	299.7
0.2169	0.0160				
(2H)013		(2H)013	(2H)012	CONDUIT	499.5
0.1842	0.0160				
(2H)014		(2H)014	(2H)013	CONDUIT	164.7
0.3885	0.0160				
(2H)015		(2H)015	(2H)014	CONDUIT	261.9
0.2787	0.0160				
(2H)016		(2H)016	(2H)015	CONDUIT	369.9
0.1460	0.0160				
(2H)017		(2H)017	(2H)016	CONDUIT	59.5
0.9418	0.0160				
(2H)017A		(2H)017A	(2H)017	CONDUIT	311.2
0.2699	0.0160				
(2H)018		(2H)018	(2H)017A	CONDUIT	124.1
0.2417	0.0160				
(2H)019		(2H)019	(2H)018	CONDUIT	235.0
0.2554	0.0160				
(2H)020		(2H)020	(2H)019	CONDUIT	43.3

0.2311	0.0160				
(2H)021		(2H)021	(2H)020	CONDUIT	391.5
0.2912	0.0160				
(2H)022		(2H)022	(2H)021	CONDUIT	448.6
0.5974	0.0160				
(2H)023		(2H)023	(2H)022	CONDUIT	42.8
0.6311	0.0160				
(2H)024		(2H)024	(2H)023	CONDUIT	522.0
0.5153	0.0160				
(2H)025		(2H)025	(2H)024	CONDUIT	357.9
0.1565	0.0160				
(2H)026		(2H)026	(2H)021	CONDUIT	333.4
0.7202	0.0160				
(2H)027		(2H)027	(2H)026	CONDUIT	339.0
0.3472	0.0160				
(2H)028		(2H)028	(2H)027	CONDUIT	326.7
0.3572	0.0160				
(2H)029		(2H)029	(2H)028	CONDUIT	321.3
0.3707	0.0160				
(2H)030		(2H)030	(2H)029	CONDUIT	332.1
0.2776	0.0160				
(2H)031		(2H)031	(2H)030	CONDUIT	259.3
0.0929	0.0160				
(2H)032		(2H)032	(2H)031	CONDUIT	62.8
0.1497	0.0160				
(2H)033		(2H)033	(2H)032	CONDUIT	30.2
3.5773	0.0160				
(2H)034		(2H)034	(2H)033	CONDUIT	299.9
0.3385	0.0160				
(2H)036		(2H)036	(2H)034	CONDUIT	276.1
0.3560	0.0160				
(2H)037		(2H)037	(2H)036	CONDUIT	276.1
0.4368	0.0160				
(2H)038		(2H)038	(2H)037	CONDUIT	335.8
0.3580	0.0160				
(2H)039		(2H)039	(2H)038	CONDUIT	334.9
0.4246	0.0160				
(2H)040		(2H)040	(2H)039	CONDUIT	391.6
0.2308	0.0160				
(2H)041		(2H)041	(2H)040	CONDUIT	253.5
0.3577	0.0160				
(2H)042		(2H)042	(2H)041	CONDUIT	253.5
0.5609	0.0160				
(2H)043		(2H)043	(2H)042	CONDUIT	388.7
0.2444	0.0160				
(2H)044		(2H)044	(2H)043	CONDUIT	268.3
0.3034	0.0160				
(2H)045		(2H)045	(2H)044	CONDUIT	226.9
0.3093	0.0160				
(2H)046		(2H)046	(2H)045	CONDUIT	189.1
0.3543	0.0160				
(2H)047		(2H)047	(2H)046	CONDUIT	274.2
0.0883	0.0160				
(2H)048		(2H)048	(2H)047	CONDUIT	97.2
1.1528	0.0160				
(2H)049		(2H)049	(2H)048	CONDUIT	442.2
0.2775	0.0160				
(2H)050		(2H)050	(2H)049	CONDUIT	493.0
0.1947	0.0160				
(2H)051		(2H)051	(2H)050	CONDUIT	380.2
0.1881	0.0160				

(2H)051A	(2H)051A	(2H)051	CONDUIT	294.7
0.2653 0.0160				
(2H)052	(2H)052	(2H)051A	CONDUIT	310.3
0.3780 0.0160				
(2H)053	(2H)053	(2H)052	CONDUIT	471.0
0.0658 0.0160				
(2H)054	(2H)054	(2H)053	CONDUIT	124.1
0.4125 0.0160				
(2H)054A	(2H)054A	(2H)054	CONDUIT	205.0
0.4130 0.0160				
(2H)055	(2H)055	(2H)054A	CONDUIT	246.0
0.4140 0.0160				
(2H)055A	(2H)055A	(2H)055	CONDUIT	130.0
0.4140 0.0160				
(2H)056	(2H)056	(2H)055A	CONDUIT	399.0
0.4140 0.0160				
(2H)057	(2H)057	(2H)056	CONDUIT	170.0
0.4140 0.0160				
(2H)058	(2H)058	(2H)057	CONDUIT	113.0
0.4140 0.0160				
(2H)285	(2H)285	(2H)053	CONDUIT	120.4
0.3655 0.0160				
(2H)286	(2H)286	(2H)285	CONDUIT	193.0
0.3316 0.0160				
(2H)287	(2H)287	(2H)286	CONDUIT	324.0
0.3302 0.0160				
(2H)288	(2H)288	(2H)287	CONDUIT	424.0
0.3302 0.0160				
(2H)289	(2H)289	(2H)288	CONDUIT	408.0
0.3284 0.0160				
(2H)290	(2H)290	(2H)289	CONDUIT	189.0
0.3333 0.0160				
(2I)001	(2I)001	(2I)001A	CONDUIT	60.8
0.3126 0.0160				
(2I)001A	(2I)001A	(2H)025	CONDUIT	225.6
0.1596 0.0160				
(2I)002	(2I)002	(2I)001	CONDUIT	255.3
1.0068 0.0160				
(2I)003	(2I)003	(2I)002	CONDUIT	328.2
0.4083 0.0160				
(2I)004	(2I)004	(2I)003	CONDUIT	131.3
0.3809 0.0160				
(2I)005	(2I)005	(2I)004	CONDUIT	447.3
0.4113 0.0160				
(2I)006	(2I)006	(2I)005	CONDUIT	250.8
0.4226 0.0160				
(2I)008	(2I)008	(2I)006	CONDUIT	343.9
0.4071 0.0160				
(2I)009	(2I)009	(2I)008	CONDUIT	418.2
0.3921 0.0160				
(2I)010	(2I)010	(2I)009	CONDUIT	84.4
0.4266 0.0160				
(2I)011	(2I)011	(2I)010	CONDUIT	147.4
0.4070 0.0160				
(2I)012	(2I)012	(2I)011	CONDUIT	166.4
0.4087 0.0160				
(2I)013	(2I)013	(2I)012	CONDUIT	374.3
0.3954 0.0160				
(2I)014	(2I)014	(2I)013	CONDUIT	212.3
0.2968 0.0160				
(2I)015	(2I)015	(2I)014	CONDUIT	161.0

0.2981	0.0160				
(2I)016		(2I)016	(2I)015	CONDUIT	167.5
0.3165	0.0160				
(2I)017		(2I)017	(2I)016	CONDUIT	36.5
0.3839	0.0160				
(2I)018		(2I)018	(2I)017A	CONDUIT	294.0
0.2517	0.0160				
(2I)019		(2I)019	(2I)018	CONDUIT	230.2
0.3518	0.0160				
(2I)020		(2I)020	(2I)019	CONDUIT	352.6
0.3771	0.0160				
(2I)021		(2I)021	(2I)020	CONDUIT	359.8
0.3002	0.0160				
(2I)021A		(2I)021A	(2I)021	CONDUIT	102.1
0.2937	0.0160				
(2I)021B		(2I)021B	(2I)021A	CONDUIT	206.6
0.2905	0.0160				
(2I)021C		(2I)021C	(2I)021B	CONDUIT	105.5
0.0853	0.0160				
(2I)022		(2I)022	(2I)021C	CONDUIT	32.4
0.2774	0.0160				
(2I)023		(2I)023	(2I)022	CONDUIT	362.3
0.2981	0.0160				
(2I)024		(2I)024	(2I)023	CONDUIT	364.7
0.2961	0.0160				
(2I)025		(2I)025	(2I)024	CONDUIT	362.3
0.2981	0.0160				
(2I)025A		(2I)025A	(2I)025	CONDUIT	252.8
0.2927	0.0160				
(2I)026		(2I)026	(2I)025A	CONDUIT	104.6
0.3251	0.0160				
(2I)027		(2I)027	(2I)026	CONDUIT	328.2
0.2986	0.0160				
(2I)028		(2I)028	(2I)027	CONDUIT	56.0
0.2704	0.0160				
(2I)029		(2I)029	(2I)028	CONDUIT	63.2
0.3192	0.0160				
(2I)044		(2I)044	(2I)005	CONDUIT	111.0
1.0000	0.0160				
(2I)045		(2I)045	(2I)044	CONDUIT	73.0
1.0000	0.0160				
(2I)046		(2I)046	(2I)045	CONDUIT	423.0
1.0000	0.0160				
(2I)047		(2I)047	(2I)046	CONDUIT	397.0
1.0000	0.0160				
(2I)048		(2I)048	(2I)047	CONDUIT	395.0
1.0000	0.0160				
(2I)049		(2I)049	(2I)048	CONDUIT	131.0
1.0000	0.0160				
(2I)050		(2I)050	(2I)049	CONDUIT	482.0
0.4000	0.0160				
(2I)051		(2I)051	(2I)050	CONDUIT	118.0
0.4000	0.0160				
(2I)052		(2I)052	(2I)051	CONDUIT	96.0
0.4000	0.0160				
(2I)053		(2I)053	(2I)052	CONDUIT	341.0
0.4000	0.0160				
(2I)054		(2I)054	(2I)053	CONDUIT	294.0
0.4000	0.0160				
(2I)055		(2I)055	(2I)054	CONDUIT	225.0
0.4000	0.0160				

(2I)056		(2I)056	(2I)055	CONDUIT	346.0
0.4000	0.0160				
(2I)057		(2I)057	(2I)056	CONDUIT	166.0
0.4000	0.0160				
(2I)058		(2I)058	(2I)057	CONDUIT	329.0
0.4000	0.0160				
(2I)059		(2I)059	(2I)058	CONDUIT	457.0
0.4000	0.0160				
(2J)001		(2J)001	(2F)009	CONDUIT	457.0
0.1772	0.0160				
(2J)002		(2J)002	(2J)001	CONDUIT	313.8
0.1179	0.0160				
(2J)003		(2J)003	(2J)002	CONDUIT	66.3
0.1207	0.0160				
(2J)004		(2J)004	(2J)003	CONDUIT	198.9
0.1157	0.0160				
(2J)005		(2J)005	(2J)004	CONDUIT	34.8
0.1438	0.0160				
(2J)006		(2J)006	(2J)005	CONDUIT	395.6
0.1213	0.0160				
(2J)007		(2J)007	(2J)006	CONDUIT	445.7
0.1189	0.0160				
(2J)008		(2J)008	(2J)007	CONDUIT	445.6
0.1189	0.0160				
(2J)009		(2J)009	(2J)008	CONDUIT	106.2
0.2072	0.0160				
(2J)010		(2J)010	(2J)009	CONDUIT	113.7
0.2111	0.0160				
(2J)011		(2J)011	(2J)010	CONDUIT	152.3
0.3741	0.0160				
(2J)012		(2J)012	(2J)011	CONDUIT	253.8
0.2010	0.0160				
(2J)013		(2J)013	(2J)012	CONDUIT	498.4
0.1946	0.0160				
(2J)014		(2J)014	(2J)013	CONDUIT	411.3
0.2067	0.0160				
(2J)015		(2J)015	(2J)014	CONDUIT	471.6
0.1951	0.0160				
(2J)016		(2J)016	(2J)015	CONDUIT	444.8
0.2023	0.0160				
(2J)017		(2J)017	(2J)016	CONDUIT	389.1
0.2339	0.0160				
(2J)018		(2J)018	(2J)017	CONDUIT	79.1
0.2023	0.0160				
(2J)019		(2J)019	(2J)018	CONDUIT	415.7
0.2453	0.0160				
(2J)020		(2J)020	(2J)010	CONDUIT	61.4
0.0163	0.0160				
(2J)021		(2J)021	(2J)020	CONDUIT	266.0
1.4622	0.0160				
(2J)022		(2J)022	(2J)021	CONDUIT	56.2
0.3023	0.0160				
(2J)023		(2J)023	(2J)022	CONDUIT	478.4
0.2049	0.0160				
(2J)024		(2J)025	(2J)023	CONDUIT	99.6
0.9341	0.0160				
(2J)0250		(2J)025	(2J)013	CONDUIT	31.4
26.4115	0.0160				
(2J)026		(2J)026	(2J)025	CONDUIT	298.3
0.3117	0.0160				
(2J)027		(2J)027	(2J)026	CONDUIT	371.0

0.3261	0.0160				
(2J) 028		(2J) 028	(2J) 027	CONDUIT	207.9
0.3079	0.0160				
(2J) 029		(2J) 029	(2J) 028	CONDUIT	339.7
0.3267	0.0160				
(2J) 030		(2J) 030	(2J) 029	CONDUIT	357.6
0.4726	0.0160				
(2J) 031		(2J) 031	(2J) 030	CONDUIT	355.4
0.4418	0.0160				
(2J) 032		(2J) 032	(2J) 031	CONDUIT	333.1
0.4053	0.0160				
(2J) 033		(2J) 033	(2J) 032	CONDUIT	315.1
0.4220	0.0160				
(2J) 040		(2J) 040	(2J) 025	CONDUIT	119.5
0.5606	0.0160				
(2J) 041		(2J) 041	(2J) 040	CONDUIT	131.9
0.3183	0.0160				
(2J) 042		(2J) 042	(2J) 041	CONDUIT	766.6
0.3091	0.0160				
(2J) 043		(2J) 043	(2J) 042	CONDUIT	92.4
0.3573	0.0160				
(2J) 044		(2J) 044	(2J) 043	CONDUIT	210.9
0.2940	0.0160				
(2J) 045		(2J) 045	(2J) 044	CONDUIT	129.6
0.3317	0.0160				
(2J) 045A		(2J) 045A	(2J) 045	CONDUIT	143.8
0.2851	0.0160				
(2J) 046		(2J) 046	(2J) 045A	CONDUIT	161.6
0.3156	0.0160				
(2J) 047		(2J) 047	(2J) 046	CONDUIT	309.4
0.2974	0.0160				
(2J) 048		(2J) 048	(2J) 047	CONDUIT	301.7
0.3049	0.0160				
(2J) 049		(2J) 049	(2J) 048	CONDUIT	27.7
0.5052	0.0160				
(2J) 050		(2J) 050	(2J) 049	CONDUIT	306.3
0.3199	0.0160				
(2J) 051		(2J) 051	(2J) 050	CONDUIT	178.6
0.3024	0.0160				
(2J) 052		(2J) 052	(2J) 051	CONDUIT	144.7
0.4422	0.0160				
(2J) 053		(2J) 053	(2J) 052	CONDUIT	133.9
0.4106	0.0160				
(2J) 054		(2J) 054	(2J) 053	CONDUIT	343.3
0.4253	0.0160				
(2J) 055		(2J) 055	(2J) 054	CONDUIT	212.4
0.4331	0.0160				
(2J) 056		(2J) 056	(2J) 055	CONDUIT	144.7
0.4354	0.0160				
(2J) 057		(2J) 057	(2J) 056	CONDUIT	138.6
0.4041	0.0160				
(2J) 058		(2J) 060	(2J) 057	CONDUIT	303.2
0.3694	0.0160				
(2K) 001		(2K) 001	(2J) 019	CONDUIT	397.9
0.0377	0.0160				
(2K) 002		(2K) 002	(2K) 001	CONDUIT	333.0
1.7176	0.0160				
(2K) 003		(2K) 003	(2K) 002	CONDUIT	359.9
0.3585	0.0160				
(2K) 004		(2K) 004	(2K) 003	CONDUIT	366.6
0.2946	0.0160				

(2K) 005		(2K) 005	(2K) 004	CONDUIT	359.9
0.3001	0.0160				
(2K) 006		(2K) 006	(2K) 005	CONDUIT	411.4
0.3063	0.0160				
(2K) 007		(2K) 007	(2K) 006	CONDUIT	404.6
0.4078	0.0160				
(2K) 008		(2K) 008	(2K) 007	CONDUIT	368.8
0.3091	0.0160				
(2K) 009		(2K) 009	(2K) 008	CONDUIT	344.2
0.3312	0.0160				
(2K) 010		(2K) 010	(2K) 009	CONDUIT	391.1
0.2915	0.0160				
(2K) 011		(2K) 011	(2K) 010	CONDUIT	458.3
0.2488	0.0160				
(2K) 012		(2K) 012	(2K) 011	CONDUIT	321.1
0.3551	0.0160				
(2K) 013		(2K) 013	(2K) 012	CONDUIT	304.0
0.2895	0.0160				
(2K) 014		(2K) 014	(2K) 013	CONDUIT	161.9
0.4385	0.0160				
(2K) 015		(2K) 015	(2K) 014	CONDUIT	243.6
0.2463	0.0160				
(2K) 016		(2K) 016	(2K) 015	CONDUIT	254.8
0.4160	0.0160				
(2K) 017		(2K) 017	(2K) 016	CONDUIT	131.9
0.3943	0.0160				
(2K) 018		(2K) 018	(2K) 017	CONDUIT	292.8
0.3415	0.0160				
(2K) 018A		(2K) 018A	(2K) 018	CONDUIT	105.1
0.3807	0.0160				
(2K) 019		(2K) 019	(2K) 018A	CONDUIT	154.2
0.4539	0.0160				
(2K) 020		(2K) 020	(2K) 019	CONDUIT	236.9
0.4221	0.0160				
(2K) 021		(2K) 021	(2K) 020	CONDUIT	38.5
0.2601	0.0160				
(2K) 022		(2K) 022	(2K) 021	CONDUIT	257.8
0.4656	0.0160				
(2K) 022A		(2K) 022A	(2K) 022	CONDUIT	99.4
0.4023	0.0160				
(2K) 023		(2K) 023	(2K) 022A	CONDUIT	212.3
0.3768	0.0160				
(2K) 024		(2K) 024	(2K) 023	CONDUIT	176.6
0.4531	0.0160				
(2K) 024A		(2K) 024A	(2K) 024	CONDUIT	27.8
0.3601	0.0160				
(2K) 025		(2K) 025	(2K) 024A	CONDUIT	330.4
0.4237	0.0160				
(2K) 026		(2K) 026	(2K) 025	CONDUIT	435.8
0.3029	0.0160				
(2K) 027		(2K) 027	(2K) 026	CONDUIT	60.4
7.2577	0.0160				
(2K) 028		(2K) 028	(2K) 027	CONDUIT	371.0
0.2237	0.0160				
(2K) 029		(2K) 029	(2K) 028	CONDUIT	449.3
0.2159	0.0160				
(2K) 030		(2K) 030	(2K) 029	CONDUIT	433.6
0.2214	0.0160				
(2K) 031		(2K) 031	(2K) 030	CONDUIT	520.8
0.2189	0.0160				
(2K) 032		(2K) 032	(2K) 031	CONDUIT	498.4

0.2227	0.0160					
(2K)033		(2K)033	(2K)032	CONDUIT		502.9
0.2167	0.0160					
(2K)033A		(2K)033A	(2K)033	CONDUIT		321.9
0.2051	0.0160					
(2K)034		(2K)034	(2K)033A	CONDUIT		203.5
0.2113	0.0160					
(2K)035		(2K)035	(2K)034	CONDUIT		469.4
0.2344	0.0160					
(2K)036		(2K)036	(2K)035	CONDUIT		494.0
0.2227	0.0160					
(2K)037		(2K)037	(2K)036	CONDUIT		525.3
0.2132	0.0160					
(2K)038		(2K)038	(2K)037	CONDUIT		177.0
0.2133	0.0160					
(2K)039		(2K)039	(2K)038	CONDUIT		409.0
0.2133	0.0160					
(2K)040		(2K)040	(2K)039	CONDUIT		327.0
0.2133	0.0160					
(2K)041		(2K)041	(2K)040	CONDUIT		399.0
0.2133	0.0160					
(2K)042		(2K)042	(2K)041	CONDUIT		239.0
0.2133	0.0160					
(2K)043		(2K)043	(2K)042	CONDUIT		400.0
0.2133	0.0160					
(2K)044		(2K)044	(2K)043	CONDUIT		400.0
0.2133	0.0160					
(2K)045		(2K)045	(2K)044	CONDUIT		400.0
0.2133	0.0160					
(2K)046		(2K)046	(2K)045	CONDUIT		400.0
0.2133	0.0160					
(2K)047		(2K)047	(2K)046	CONDUIT		400.0
0.2133	0.0160					
(2K)048		(2K)048	(2K)047	CONDUIT		400.0
0.2133	0.0160					
(2K)049		(2K)049	(2K)048	CONDUIT		400.0
0.2133	0.0160					
(2K)050		(2K)050	(2K)049	CONDUIT		322.0
0.2133	0.0160					
(2K)051		(2K)051	(2K)050	CONDUIT		322.0
0.2133	0.0160					
(2K)052		(2K)052	(2K)051	CONDUIT		322.0
0.2133	0.0160					
(2K)314		(2K)314	(2K)001	CONDUIT		310.7
0.5118	0.0160					
(2K)315		(2K)315	(2K)314	CONDUIT		377.8
0.2329	0.0160					
(2K)316		(2K)316	(2K)315	CONDUIT		252.6
0.3484	0.0160					
(2K)317		(2K)317	(2K)316	CONDUIT		108.0
0.3333	0.0160					
ForcedMain2		ForcedMain	(2A)001	CONDUIT		1693.0
0.0975	0.0160					
Line2ToPlant		(1A)000	(2A)000	CONDUIT		387.0
0.3204	0.0160					
NorthEnid		NorthEnidStorage(10)005E		CONDUIT		101.4
0.0010	0.0160					
1		(1P)002	LiftStation	CONDUIT		7.0
23.5714	0.0160					
PUMP1@ (2A)000-		(PLANT) (2A)000	(PLANT)	TYPE4 PUMP		
ForcedMain		LiftStation	ForcedMain	TYPE4 PUMP		

OverflowPump (2A)000
 (IO)304C-O (10)304C
 WEIR1@ (1A)DIV- (1A)STOR (1A)DIV
 (10)304-1 (10)304

PlantStorage TYPE1 PUMP
 NorthEndStorageORIFICE
 (1A)STOR WEIR
 (10)304A WEIR

 Cross Section Summary

No. of Conduit Barrels	Full Flow	Shape	Full Depth	Full Area	Hyd. Rad.	Max. Width
1	(1A)000A 19414.02	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)000B 9122.73	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)001 3272.59	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)002 6449.69	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)003 10675.22	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)004 8407.38	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)005 9569.40	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)006 12876.77	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)007 12272.52	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)008 12360.35	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)009 7915.83	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)010 11698.54	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)011 4380.48	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)012 4840.93	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)013 9219.98	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)014 11285.62	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)015 13044.84	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)016 7988.19	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)017 6411.09	CIRCULAR	2.75	5.94	0.69	2.75
1	(1A)018 9172.48	CIRCULAR	2.50	4.91	0.63	2.50
1	(1A)019 3492.31	CIRCULAR	2.50	4.91	0.63	2.50
1	(1A)020 9980.46	CIRCULAR	2.50	4.91	0.63	2.50
1	(1A)021	CIRCULAR	2.50	4.91	0.63	2.50

1	8584.63				
	(1A)022	CIRCULAR	2.50	4.91	0.63 2.50
1	11161.95				
	(1A)023	CIRCULAR	2.50	4.91	0.63 2.50
1	8200.10				
	(1A)024	CIRCULAR	2.50	4.91	0.63 2.50
1	10020.34				
	(1A)024A	CIRCULAR	2.50	4.91	0.63 2.50
1	4739.20				
	(1A)025	CIRCULAR	2.50	4.91	0.63 2.50
1	35774.56				
	(1A)026	CIRCULAR	2.50	4.91	0.63 2.50
1	9304.70				
	(1A)027	CIRCULAR	2.50	4.91	0.63 2.50
1	10584.97				
	(1A)028	CIRCULAR	2.50	4.91	0.63 2.50
1	5448.56				
	(1A)029	CIRCULAR	2.50	4.91	0.63 2.50
1	8287.61				
	(1A)030	CIRCULAR	2.50	4.91	0.63 2.50
1	5182.62				
	(1A)031	CIRCULAR	2.50	4.91	0.63 2.50
1	6781.81				
	(1A)032	CIRCULAR	2.50	4.91	0.63 2.50
1	6252.43				
	(1A)033	CIRCULAR	2.50	4.91	0.63 2.50
1	6436.08				
	(1A)034	CIRCULAR	2.50	4.91	0.63 2.50
1	4975.75				
	(1A)035	CIRCULAR	2.50	4.91	0.63 2.50
1	7515.50				
	(1A)035A	CIRCULAR	2.50	4.91	0.63 2.50
1	5133.21				
	(1A)036	CIRCULAR	2.50	4.91	0.63 2.50
1	8852.73				
	(1A)037	CIRCULAR	2.50	4.91	0.63 2.50
1	6422.48				
	(1A)038	CIRCULAR	2.50	4.91	0.63 2.50
1	3991.80				
	(1A)039	CIRCULAR	2.50	4.91	0.63 2.50
1	8313.07				
	(1A)040	CIRCULAR	2.50	4.91	0.63 2.50
1	6278.81				
	(1A)041	CIRCULAR	2.50	4.91	0.63 2.50
1	6554.48				
	(1A)042	CIRCULAR	3.00	7.07	0.75 3.00
1	10819.87				
	(1B)001	CIRCULAR	2.00	3.14	0.50 2.00
1	13047.72				
	(1B)002	CIRCULAR	2.00	3.14	0.50 2.00
1	4763.87				
	(1B)003	CIRCULAR	2.00	3.14	0.50 2.00
1	4567.14				
	(1B)004	CIRCULAR	2.00	3.14	0.50 2.00
1	1294.81				
	(1B)005	CIRCULAR	2.00	3.14	0.50 2.00
1	6853.72				
	(1B)006	CIRCULAR	2.00	3.14	0.50 2.00
1	4598.89				
	(1B)009	CIRCULAR	2.00	3.14	0.50 2.00
1	4713.43				

1	(1B)010 6537.95	CIRCULAR	2.00	3.14	0.50	2.00
1	(1B)011 4434.44	CIRCULAR	2.00	3.14	0.50	2.00
1	(1B)013 5673.67	CIRCULAR	2.00	3.14	0.50	2.00
1	(1B)014 4709.00	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)001 4939.88	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)001A 4617.74	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)001B 11650.39	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)001BO 10103.30	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)001C 9901.33	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)001D 4404.88	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)001E 11255.47	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)001F 8509.40	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)001G 9321.19	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)002 2118.38	CIRCULAR	1.00	0.79	0.25	1.00
1	(1C)003 325.91	CIRCULAR	0.83	0.54	0.21	0.83
1	(1C)004 611.73	CIRCULAR	0.83	0.54	0.21	0.83
1	(1C)005 147.48	CIRCULAR	0.83	0.54	0.21	0.83
1	(1C)006 536.21	CIRCULAR	0.83	0.54	0.21	0.83
1	(1C)006A 643.64	CIRCULAR	0.83	0.54	0.21	0.83
1	(1C)007 568.80	CIRCULAR	0.83	0.54	0.21	0.83
1	(1C)009 6834.61	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)010 9557.52	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)011 8113.44	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)012 1470.22	CIRCULAR	0.83	0.54	0.21	0.83
1	(1C)015A 5361.35	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)015B 7172.97	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)015C 6968.48	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)016 5557.65	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)016A 6164.47	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)016B 5294.30	CIRCULAR	2.00	3.14	0.50	2.00
1	(1C)016C	CIRCULAR	2.00	3.14	0.50	2.00

1	5203.89					
	(1C)017	CIRCULAR	2.00	3.14	0.50	2.00
1	28410.25					
	(1C)018	CIRCULAR	0.83	0.54	0.21	0.83
1	510.16					
	(1C)019	CIRCULAR	0.83	0.54	0.21	0.83
1	493.25					
	(1C)01D	CIRCULAR	2.00	3.14	0.50	2.00
1	5870.89					
	(1C)020	CIRCULAR	0.83	0.54	0.21	0.83
1	509.66					
	(1C)021	CIRCULAR	2.00	3.14	0.50	2.00
1	7001.12					
	(1C)021A	CIRCULAR	1.50	1.77	0.38	1.50
1	1622.09					
	(1C)021B	CIRCULAR	1.50	1.77	0.38	1.50
1	2319.34					
	(1C)021C	CIRCULAR	1.50	1.77	0.38	1.50
1	2213.23					
	(1C)021D	CIRCULAR	1.50	1.77	0.38	1.50
1	2117.34					
	(1C)022	CIRCULAR	0.83	0.54	0.21	0.83
1	530.99					
	(1C)023	CIRCULAR	0.83	0.54	0.21	0.83
1	455.80					
	(1C)024	CIRCULAR	0.83	0.54	0.21	0.83
1	483.17					
	(1C)025	CIRCULAR	0.83	0.54	0.21	0.83
1	310.99					
	(1C)026	CIRCULAR	0.83	0.54	0.21	0.83
1	458.40					
	(1C)026A	CIRCULAR	1.50	1.77	0.38	1.50
1	5040.68					
	(1C)027	CIRCULAR	0.83	0.54	0.21	0.83
1	458.26					
	(1C)028	CIRCULAR	0.83	0.54	0.21	0.83
1	455.58					
	(1C)041	CIRCULAR	0.83	0.54	0.21	0.83
1	643.11					
	(1C)176	CIRCULAR	1.00	0.79	0.25	1.00
1	1263.73					
	(1C)177	CIRCULAR	1.00	0.79	0.25	1.00
1	1259.27					
	(1C)178	CIRCULAR	1.00	0.79	0.25	1.00
1	1254.34					
	(1C)179	CIRCULAR	1.00	0.79	0.25	1.00
1	1261.47					
	(1C)179A	CIRCULAR	1.00	0.79	0.25	1.00
1	1005.70					
	(1C)180	CIRCULAR	1.00	0.79	0.25	1.00
1	1257.32					
	(1C)180A	CIRCULAR	1.00	0.79	0.25	1.00
1	1257.17					
	(1C)181	CIRCULAR	1.00	0.79	0.25	1.00
1	1250.69					
	(1C)182	CIRCULAR	1.00	0.79	0.25	1.00
1	1244.07					
	(1C)Storage	CIRCULAR	1.00	0.79	0.25	1.00
1	1189.84					
	(1D)001	CIRCULAR	0.83	0.54	0.21	0.83
1	1263.78					

1	(1D)002	CIRCULAR	0.83	0.54	0.21	0.83
	744.92					
1	(1D)003	CIRCULAR	0.83	0.54	0.21	0.83
	820.43					
1	(1D)004	CIRCULAR	0.83	0.54	0.21	0.83
	1066.34					
1	(1D)005	CIRCULAR	0.83	0.54	0.21	0.83
	692.76					
1	(1D)006	CIRCULAR	0.83	0.54	0.21	0.83
	773.20					
1	(1D)007	CIRCULAR	0.83	0.54	0.21	0.83
	762.05					
1	(1D)008	CIRCULAR	0.83	0.54	0.21	0.83
	764.34					
1	(1D)009	CIRCULAR	0.83	0.54	0.21	0.83
	511.15					
1	(1D)010	CIRCULAR	0.83	0.54	0.21	0.83
	500.45					
1	(1D)011	CIRCULAR	0.83	0.54	0.21	0.83
	905.45					
1	(1D)012	CIRCULAR	0.83	0.54	0.21	0.83
	530.42					
1	(1D)013	CIRCULAR	0.83	0.54	0.21	0.83
	1124.34					
1	(1D)014	CIRCULAR	0.83	0.54	0.21	0.83
	561.08					
1	(1D)015	CIRCULAR	0.83	0.54	0.21	0.83
	512.05					
1	(1D)016	CIRCULAR	0.83	0.54	0.21	0.83
	431.76					
1	(1D)017	CIRCULAR	0.83	0.54	0.21	0.83
	426.73					
1	(1D)018	CIRCULAR	0.83	0.54	0.21	0.83
	431.53					
1	(1D)019	CIRCULAR	0.83	0.55	0.21	0.83
	438.75					
1	(1D)020	CIRCULAR	0.83	0.55	0.21	0.83
	436.53					
1	(1D)021	CIRCULAR	0.83	0.55	0.21	0.83
	439.02					
1	(1D)022	CIRCULAR	0.83	0.55	0.21	0.83
	435.60					
1	(1D)023	CIRCULAR	0.83	0.54	0.21	0.83
	435.44					
1	(1E)001	CIRCULAR	1.00	0.79	0.25	1.00
	777.96					
1	(1E)002	CIRCULAR	1.00	0.79	0.25	1.00
	743.45					
1	(1E)003	CIRCULAR	1.00	0.79	0.25	1.00
	729.54					
1	(1E)003A	CIRCULAR	1.00	0.79	0.25	1.00
	743.27					
1	(1E)005	CIRCULAR	1.00	0.79	0.25	1.00
	733.28					
1	(1E)006	CIRCULAR	1.00	0.79	0.25	1.00
	745.23					
1	(1E)007	CIRCULAR	1.00	0.79	0.25	1.00
	745.23					
1	(1E)008	CIRCULAR	1.00	0.79	0.25	1.00
	723.07					
1	(1E)009	CIRCULAR	1.00	0.79	0.25	1.00

1	(1F)023	CIRCULAR	0.83	0.54	0.21	0.83
	576.36					
1	(1F)024	CIRCULAR	0.83	0.54	0.21	0.83
	1275.98					
1	(1F)025	CIRCULAR	0.83	0.54	0.21	0.83
	1287.60					
1	(1F)026	CIRCULAR	0.83	0.54	0.21	0.83
	1309.88					
1	(1F)026A	CIRCULAR	0.83	0.54	0.21	0.83
	412.02					
1	(1F)027	CIRCULAR	0.83	0.54	0.21	0.83
	423.92					
1	(1F)028	CIRCULAR	0.83	0.54	0.21	0.83
	417.26					
1	(1F)029	CIRCULAR	0.83	0.54	0.21	0.83
	428.88					
1	(1F)029A	CIRCULAR	0.83	0.54	0.21	0.83
	420.32					
1	(1F)030	CIRCULAR	0.83	0.54	0.21	0.83
	421.83					
1	(1G)001	CIRCULAR	3.00	7.07	0.75	3.00
	10248.75					
1	(1G)001A	CIRCULAR	3.00	7.07	0.75	3.00
	11120.72					
1	(1G)002	CIRCULAR	3.00	7.07	0.75	3.00
	11211.11					
1	(1G)003	CIRCULAR	3.00	7.07	0.75	3.00
	7902.60					
1	(1G)004	CIRCULAR	3.00	7.07	0.75	3.00
	9648.47					
1	(1G)005	CIRCULAR	3.00	7.07	0.75	3.00
	12185.71					
1	(1G)006	CIRCULAR	3.00	7.07	0.75	3.00
	5741.02					
1	(1G)007	CIRCULAR	3.00	7.07	0.75	3.00
	13392.71					
1	(1G)008	CIRCULAR	3.00	7.07	0.75	3.00
	10069.70					
1	(1G)008C	CIRCULAR	3.00	7.07	0.75	3.00
	9918.40					
1	(1G)009	CIRCULAR	3.00	7.07	0.75	3.00
	16097.49					
1	(1G)009A	CIRCULAR	3.00	7.07	0.75	3.00
	11387.71					
1	(1G)009B	CIRCULAR	3.00	7.07	0.75	3.00
	11412.39					
1	(1G)009C	CIRCULAR	3.00	7.07	0.75	3.00
	11049.68					
1	(1G)009D	CIRCULAR	3.00	7.07	0.75	3.00
	10623.97					
1	(1G)009E	CIRCULAR	3.00	7.07	0.75	3.00
	9967.87					
1	(1G)010	CIRCULAR	3.00	7.07	0.75	3.00
	11165.66					
1	(1G)011	CIRCULAR	3.00	7.07	0.75	3.00
	11232.43					
1	(1G)012	CIRCULAR	3.00	7.07	0.75	3.00
	11076.55					
1	(1G)013	CIRCULAR	3.00	7.07	0.75	3.00
	10885.96					
1	(1G)014	CIRCULAR	0.83	0.54	0.21	0.83

1	2207.83					
	(1G) 014A	CIRCULAR	0.83	0.54	0.21	0.83
1	476.88					
	(1G) 015	CIRCULAR	0.83	0.54	0.21	0.83
1	457.29					
	(1G) 016	CIRCULAR	0.83	0.54	0.21	0.83
1	464.38					
	(1G) 017	CIRCULAR	0.83	0.54	0.21	0.83
1	472.95					
	(1G) 018	CIRCULAR	0.83	0.54	0.21	0.83
1	468.21					
	(1G) 018A	CIRCULAR	0.83	0.54	0.21	0.83
1	730.40					
	(1G) 019	CIRCULAR	0.83	0.54	0.21	0.83
1	1182.80					
	(1G) 0190	CIRCULAR	0.83	0.54	0.21	0.83
1	456.57					
	(1G) 020	CIRCULAR	0.83	0.54	0.21	0.83
1	478.29					
	(1G) 045	CIRCULAR	0.83	0.54	0.21	0.83
1	800.40					
	(1G) 046	CIRCULAR	0.83	0.54	0.21	0.83
1	482.23					
	(1G) 047	CIRCULAR	0.83	0.54	0.21	0.83
1	453.78					
	(1G) 048	CIRCULAR	0.83	0.54	0.21	0.83
1	449.21					
	(1G) 049	CIRCULAR	0.83	0.54	0.21	0.83
1	433.31					
	(1G) 050	CIRCULAR	0.83	0.54	0.21	0.83
1	366.46					
	(1G) 051	CIRCULAR	0.83	0.54	0.21	0.83
1	374.37					
	(1G) 052	CIRCULAR	0.67	0.35	0.17	0.67
1	206.97					
	(1G) 053	CIRCULAR	0.67	0.35	0.17	0.67
1	206.97					
	(1G) 054	CIRCULAR	0.67	0.35	0.17	0.67
1	206.97					
	(1G) 055	CIRCULAR	0.67	0.35	0.17	0.67
1	206.97					
	(1G) 056	CIRCULAR	0.67	0.35	0.17	0.67
1	206.97					
	(1G) 057	CIRCULAR	0.67	0.35	0.17	0.67
1	312.02					
	(1G) 058	CIRCULAR	0.67	0.35	0.17	0.67
1	312.02					
	(1G) 059	CIRCULAR	0.67	0.35	0.17	0.67
1	312.02					
	(1G) 060	CIRCULAR	0.67	0.35	0.17	0.67
1	312.02					
	(1G) 061	CIRCULAR	0.67	0.35	0.17	0.67
1	312.02					
	(1G) 062	CIRCULAR	0.67	0.35	0.17	0.67
1	341.80					
	(1G) 063	CIRCULAR	0.67	0.35	0.17	0.67
1	341.80					
	(1G) 064	CIRCULAR	0.67	0.35	0.17	0.67
1	341.80					
	(1G) 065	CIRCULAR	0.67	0.35	0.17	0.67
1	341.80					

1	(1G) 066 341.80	CIRCULAR	0.67	0.35	0.17	0.67
1	(1G) 067 341.80	CIRCULAR	0.67	0.35	0.17	0.67
1	(1G) 068 341.80	CIRCULAR	0.67	0.35	0.17	0.67
1	(1G) 069 341.80	CIRCULAR	0.67	0.35	0.17	0.67
1	(1G) 070 341.80	CIRCULAR	0.67	0.35	0.17	0.67
1	(1G) 071 341.80	CIRCULAR	0.67	0.35	0.17	0.67
1	(1G) 146 816.65	CIRCULAR	1.00	0.79	0.25	1.00
1	(1G) 146A 938.79	CIRCULAR	1.00	0.79	0.25	1.00
1	(1G) 162 451.97	CIRCULAR	0.83	0.54	0.21	0.83
1	(1G) 162A 461.67	CIRCULAR	0.83	0.54	0.21	0.83
1	(1G) 162B 473.89	CIRCULAR	0.83	0.54	0.21	0.83
1	(1G) 162C 460.45	CIRCULAR	0.83	0.54	0.21	0.83
1	(1G) 162D 2882.21	CIRCULAR	0.83	0.54	0.21	0.83
1	(1G) 243 449.08	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 001 570.46	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 004 1962.63	CIRCULAR	1.00	0.79	0.25	1.00
1	(1H) 005 66.40	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 006 521.92	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 007 561.12	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 008 536.47	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 009 595.38	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 010 422.17	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 011 1086.48	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 038 948.73	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 039 1107.61	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 040 2702.87	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 041 368.35	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 042 1414.57	CIRCULAR	1.00	0.79	0.25	1.00
1	(1H) 043 636.37	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 044 575.73	CIRCULAR	0.83	0.54	0.21	0.83
1	(1H) 045	CIRCULAR	0.83	0.54	0.21	0.83

1	562.88					
	(1J) 001	CIRCULAR	3.00	7.07	0.75	3.00
1	14442.36					
	(1J) 002	CIRCULAR	3.00	7.07	0.75	3.00
1	12568.54					
	(1J) 003	CIRCULAR	3.00	7.07	0.75	3.00
1	11781.38					
	(1J) 004	CIRCULAR	3.00	7.07	0.75	3.00
1	10398.99					
	(1J) 005	CIRCULAR	3.00	7.07	0.75	3.00
1	9926.33					
	(1J) 006	CIRCULAR	3.00	7.07	0.75	3.00
1	10581.86					
	(1J) 007	CIRCULAR	3.00	7.07	0.75	3.00
1	11433.87					
	(1J) 008	CIRCULAR	3.00	7.07	0.75	3.00
1	14115.94					
	(1J) 009	CIRCULAR	3.00	7.07	0.75	3.00
1	9919.49					
	(1J) 010	CIRCULAR	3.00	7.07	0.75	3.00
1	11581.61					
	(1J) 011	CIRCULAR	3.00	7.07	0.75	3.00
1	8567.27					
	(1J) 012	CIRCULAR	3.00	7.07	0.75	3.00
1	10488.98					
	(1J) 013	CIRCULAR	3.00	7.07	0.75	3.00
1	11034.59					
	(1J) 014	CIRCULAR	3.00	7.07	0.75	3.00
1	12345.08					
	(1J) 041	CIRCULAR	1.25	1.23	0.31	1.25
1	2077.63					
	(1J) 042	CIRCULAR	1.25	1.23	0.31	1.25
1	2802.46					
	(1J) 042A	CIRCULAR	1.25	1.23	0.31	1.25
1	2676.15					
	(1J) 042B	CIRCULAR	1.25	1.23	0.31	1.25
1	3085.30					
	(1J) 043	CIRCULAR	1.25	1.23	0.31	1.25
1	2334.64					
	(1J) 044	CIRCULAR	1.25	1.23	0.31	1.25
1	931.27					
	(1J) 045	CIRCULAR	1.75	2.41	0.44	1.75
1	2292.33					
	(1J) 046	CIRCULAR	1.75	2.41	0.44	1.75
1	1849.05					
	(1J) 047	CIRCULAR	1.75	2.41	0.44	1.75
1	2287.83					
	(1J) 048	CIRCULAR	1.75	2.41	0.44	1.75
1	5686.50					
	(1J) 050	CIRCULAR	1.75	2.41	0.44	1.75
1	3829.64					
	(1J) 050A	CIRCULAR	1.75	2.41	0.44	1.75
1	2301.32					
	(1J) 051	CIRCULAR	1.75	2.41	0.44	1.75
1	4148.04					
	(1J) 052	CIRCULAR	1.25	1.23	0.31	1.25
1	342.47					
	(1J) 053	CIRCULAR	1.25	1.23	0.31	1.25
1	991.94					
	(1J) 054	CIRCULAR	1.25	1.23	0.31	1.25
1	1593.36					

1	(1J) 054A	CIRCULAR	1.25	1.23	0.31	1.25
	1561.55					
1	(1J) 055	CIRCULAR	1.25	1.23	0.31	1.25
	410.45					
1	(1J) 056	CIRCULAR	1.25	1.23	0.31	1.25
	1051.87					
1	(1J) 057	CIRCULAR	1.25	1.23	0.31	1.25
	949.33					
1	(1J) 058	CIRCULAR	1.25	1.23	0.31	1.25
	1090.57					
1	(1J) 059	CIRCULAR	1.25	1.23	0.31	1.25
	691.71					
1	(1J) 060	CIRCULAR	1.25	1.23	0.31	1.25
	592.25					
1	(1K) 001	CIRCULAR	1.25	1.23	0.31	1.25
	3507.49					
1	(1K) 002	CIRCULAR	1.25	1.23	0.31	1.25
	3234.69					
1	(1K) 002A	CIRCULAR	1.25	1.23	0.31	1.25
	3238.56					
1	(1K) 003	CIRCULAR	1.00	0.79	0.25	1.00
	777.34					
1	(1K) 004	CIRCULAR	1.00	0.79	0.25	1.00
	556.91					
1	(1K) 005	CIRCULAR	1.00	0.79	0.25	1.00
	631.94					
1	(1K) 006	CIRCULAR	1.00	0.79	0.25	1.00
	202.44					
1	(1K) 007	CIRCULAR	1.00	0.79	0.25	1.00
	631.05					
1	(1K) 008	CIRCULAR	1.00	0.79	0.25	1.00
	617.93					
1	(1K) 008A	CIRCULAR	1.00	0.79	0.25	1.00
	846.85					
1	(1K) 009	CIRCULAR	1.00	0.79	0.25	1.00
	480.70					
1	(1K) 010	CIRCULAR	1.00	0.79	0.25	1.00
	601.17					
1	(1K) 011	CIRCULAR	1.00	0.79	0.25	1.00
	654.74					
1	(1K) 012	CIRCULAR	1.00	0.79	0.25	1.00
	595.04					
1	(1K) 013	CIRCULAR	1.00	0.79	0.25	1.00
	445.31					
1	(1K) 014	CIRCULAR	1.00	0.79	0.25	1.00
	554.63					
1	(1M) 000	CIRCULAR	3.00	7.07	0.75	3.00
	12266.85					
1	(1M) 000A	CIRCULAR	3.00	7.07	0.75	3.00
	22889.18					
1	(1M) 000B	CIRCULAR	3.00	7.07	0.75	3.00
	12629.31					
1	(1M) 001	CIRCULAR	3.00	7.07	0.75	3.00
	16998.53					
1	(1M) 002	CIRCULAR	3.00	7.07	0.75	3.00
	12560.66					
1	(1M) 003	CIRCULAR	3.00	7.07	0.75	3.00
	13987.58					
1	(1M) 010	CIRCULAR	2.00	3.14	0.50	2.00
	5773.80					
1	(1M) 011	CIRCULAR	1.00	0.79	0.25	1.00

1	639.26				
	(1M) 012	CIRCULAR	1.00	0.79	0.25 1.00
1	1068.25				
	(1M) 0120	CIRCULAR	0.83	0.54	0.21 0.83
1	307.21				
	(1M) 013	CIRCULAR	1.00	0.79	0.25 1.00
1	636.62				
	(1M) 014	CIRCULAR	1.00	0.79	0.25 1.00
1	642.43				
	(1M) 015	CIRCULAR	1.00	0.79	0.25 1.00
1	641.30				
	(1M) 016	CIRCULAR	1.00	0.79	0.25 1.00
1	636.10				
	(1M) 017	CIRCULAR	1.00	0.79	0.25 1.00
1	1242.28				
	(1M) 018	CIRCULAR	1.00	0.79	0.25 1.00
1	676.55				
	(1M) 019	CIRCULAR	1.00	0.79	0.25 1.00
1	651.65				
	(1M) 020	CIRCULAR	1.00	0.79	0.25 1.00
1	650.20				
	(1M) 0200	CIRCULAR	0.83	0.54	0.21 0.83
1	957.83				
	(1M) 021	CIRCULAR	0.83	0.54	0.21 0.83
1	458.67				
	(1M) 022	CIRCULAR	0.83	0.54	0.21 0.83
1	477.93				
	(1M) 023	CIRCULAR	0.83	0.54	0.21 0.83
1	481.57				
	(1M) 024	CIRCULAR	0.83	0.54	0.21 0.83
1	452.61				
	(1M) 024A	CIRCULAR	0.83	0.54	0.21 0.83
1	463.79				
	(1M) 025	CIRCULAR	0.83	0.54	0.21 0.83
1	464.33				
	(1M) 027	CIRCULAR	0.83	0.54	0.21 0.83
1	455.64				
	(1M) 028	CIRCULAR	0.83	0.54	0.21 0.83
1	460.89				
	(1M) 035	CIRCULAR	1.00	0.79	0.25 1.00
1	702.63				
	(1M) 036	CIRCULAR	1.00	0.79	0.25 1.00
1	692.66				
	(1M) 037	CIRCULAR	0.83	0.54	0.21 0.83
1	475.48				
	(1M) 038	CIRCULAR	0.83	0.54	0.21 0.83
1	478.12				
	(1M) 039	CIRCULAR	0.83	0.54	0.21 0.83
1	779.00				
	(1M) 040	CIRCULAR	0.83	0.54	0.21 0.83
1	499.51				
	(1M) 041	CIRCULAR	0.83	0.54	0.21 0.83
1	460.16				
	(1M) 092	CIRCULAR	0.83	0.54	0.21 0.83
1	455.19				
	(1M) 093	CIRCULAR	0.83	0.54	0.21 0.83
1	830.44				
	(1M) 094	CIRCULAR	0.83	0.54	0.21 0.83
1	448.61				
	(1M) 116	CIRCULAR	0.83	0.54	0.21 0.83
1	661.75				

1	(1M) 117	CIRCULAR	0.83	0.54	0.21	0.83
1	585.23					
1	(1M) 118	CIRCULAR	0.83	0.54	0.21	0.83
1	484.31					
1	(1M) 119	CIRCULAR	0.83	0.54	0.21	0.83
1	466.35					
1	(1M) 120	CIRCULAR	0.83	0.54	0.21	0.83
1	678.75					
1	(1M) 121	CIRCULAR	0.83	0.54	0.21	0.83
1	457.18					
1	(1M) 122	CIRCULAR	0.83	0.54	0.21	0.83
1	482.01					
1	(1M) 123	CIRCULAR	0.83	0.54	0.21	0.83
1	460.47					
1	(1M) 124	CIRCULAR	0.83	0.54	0.21	0.83
1	458.76					
1	(1M) 125	CIRCULAR	0.83	0.54	0.21	0.83
1	466.95					
1	(1M) 126	CIRCULAR	0.83	0.54	0.21	0.83
1	486.56					
1	(1M) 127	CIRCULAR	0.83	0.54	0.21	0.83
1	454.10					
1	(1M) 128	CIRCULAR	0.83	0.54	0.21	0.83
1	477.21					
1	(1M) 129	CIRCULAR	0.83	0.54	0.21	0.83
1	459.56					
1	(1M) 130	CIRCULAR	43.00	1452.20	10.75	43.00
1	21279601.62					
1	(1M) 131	CIRCULAR	0.83	0.54	0.21	0.83
1	490.28					
1	(1M) 132	CIRCULAR	0.83	0.54	0.21	0.83
1	458.10					
1	(1M) 133	CIRCULAR	0.83	0.54	0.21	0.83
1	459.12					
1	(1M) 161	CIRCULAR	0.67	0.35	0.17	0.67
1	604.23					
1	(1M) 162	CIRCULAR	0.67	0.35	0.17	0.67
1	312.02					
1	(1M) 163	CIRCULAR	0.67	0.35	0.17	0.67
1	312.02					
1	(1M) 164	CIRCULAR	0.67	0.35	0.17	0.67
1	312.02					
1	(1M) 165	CIRCULAR	0.67	0.35	0.17	0.67
1	312.02					
1	(1M) 278	CIRCULAR	3.00	7.07	0.75	3.00
1	12522.37					
1	(1M) 279	CIRCULAR	3.00	7.07	0.75	3.00
1	12829.34					
1	(1M) 279B	CIRCULAR	3.00	7.07	0.75	3.00
1	13623.26					
1	(1M) 281	CIRCULAR	3.00	7.07	0.75	3.00
1	15590.54					
1	(1M) 281B	CIRCULAR	2.00	3.14	0.50	2.00
1	5506.01					
1	(1M) 282	CIRCULAR	2.00	3.14	0.50	2.00
1	3424.61					
1	(1M) 283	CIRCULAR	2.00	3.14	0.50	2.00
1	4518.16					
1	(1M) 284	CIRCULAR	2.00	3.14	0.50	2.00
1	3900.15					
1	(1M) 285	CIRCULAR	2.00	3.14	0.50	2.00

1	4058.67				
	(1M) 285A	CIRCULAR	2.00	3.14	0.50 2.00
1	4030.77				
	(1M) 286	CIRCULAR	2.00	3.14	0.50 2.00
1	3861.22				
	(1M) 287	CIRCULAR	2.00	3.14	0.50 2.00
1	4344.71				
	(1M) 2876A	CIRCULAR	2.00	3.14	0.50 2.00
1	4319.84				
	(1M) 288	CIRCULAR	2.00	3.14	0.50 2.00
1	4340.73				
	(1M) 288A	CIRCULAR	2.00	3.14	0.50 2.00
1	4439.80				
	(1M) 288B	CIRCULAR	2.00	3.14	0.50 2.00
1	4401.57				
	(1M) 288C	CIRCULAR	2.00	3.14	0.50 2.00
1	4067.81				
	(1N) 004	CIRCULAR	2.00	3.14	0.50 2.00
1	4236.34				
	(1N) 005	CIRCULAR	2.00	3.14	0.50 2.00
1	4266.45				
	(1N) 006	CIRCULAR	2.00	3.14	0.50 2.00
1	4386.80				
	(1N) 007	CIRCULAR	2.00	3.14	0.50 2.00
1	4425.09				
	(1N) 007D	CIRCULAR	0.83	0.54	0.21 0.83
1	548.73				
	(1N) 007E	CIRCULAR	0.83	0.54	0.21 0.83
1	586.96				
	(1N) 008	CIRCULAR	0.83	0.54	0.21 0.83
1	460.38				
	(1N) 009	CIRCULAR	0.83	0.54	0.21 0.83
1	479.87				
	(1N) 011	CIRCULAR	0.83	0.54	0.21 0.83
1	456.85				
	(1N) 013	CIRCULAR	0.83	0.54	0.21 0.83
1	459.32				
	(1N) 014	CIRCULAR	0.83	0.54	0.21 0.83
1	455.73				
	(1N) 015	CIRCULAR	0.83	0.54	0.21 0.83
1	485.46				
	(1N) 016	CIRCULAR	0.83	0.54	0.21 0.83
1	461.02				
	(1N) 017	CIRCULAR	0.83	0.54	0.21 0.83
1	460.84				
	(1N) 018	CIRCULAR	0.83	0.54	0.21 0.83
1	479.67				
	(1N) 019	CIRCULAR	0.83	0.54	0.21 0.83
1	424.03				
	(1N) 020	CIRCULAR	0.83	0.54	0.21 0.83
1	495.40				
	(1N) 021	CIRCULAR	0.83	0.54	0.21 0.83
1	459.70				
	(1N) 022	CIRCULAR	0.83	0.54	0.21 0.83
1	459.54				
	(1N) 023	CIRCULAR	0.83	0.54	0.21 0.83
1	460.01				
	(1N) 024	CIRCULAR	0.83	0.54	0.21 0.83
1	457.36				
	(1N) 025	CIRCULAR	0.83	0.54	0.21 0.83
1	454.64				

1	(1N)045 785.58	CIRCULAR	0.83	0.54	0.21	0.83
1	(1N)046 482.87	CIRCULAR	0.83	0.54	0.21	0.83
1	(1N)047 464.10	CIRCULAR	0.83	0.54	0.21	0.83
1	(1N)109A 3891.64	CIRCULAR	2.00	3.14	0.50	2.00
1	(1N)110 5039.82	CIRCULAR	2.00	3.14	0.50	2.00
1	(1N)111A 3954.86	CIRCULAR	2.00	3.14	0.50	2.00
1	(1N)112A 4138.86	CIRCULAR	2.00	3.14	0.50	2.00
1	(1N)112B 4653.95	CIRCULAR	2.00	3.14	0.50	2.00
1	(10)001 490.85	CIRCULAR	0.83	0.54	0.21	0.83
1	(10)001A 474.34	CIRCULAR	0.83	0.54	0.21	0.83
1	(10)002 697.53	CIRCULAR	0.83	0.54	0.21	0.83
1	(10)002A 708.24	CIRCULAR	0.83	0.54	0.21	0.83
1	(10)003 479.37	CIRCULAR	0.83	0.54	0.21	0.83
1	(10)004 476.83	CIRCULAR	0.83	0.54	0.21	0.83
1	(10)005A 474.86	CIRCULAR	0.83	0.54	0.21	0.83
1	(10)005B 859.77	CIRCULAR	1.00	0.79	0.25	1.00
1	(10)005C 932.55	CIRCULAR	1.00	0.79	0.25	1.00
1	(10)005D 939.19	CIRCULAR	1.00	0.79	0.25	1.00
1	(10)005E 935.38	CIRCULAR	1.00	0.79	0.25	1.00
1	(10)010 93.32	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)011 92.56	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)012 241.69	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)013 241.69	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)014 241.69	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)015 241.69	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)016 241.69	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)017 241.69	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)018 241.69	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)019 279.08	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)020 279.08	CIRCULAR	0.67	0.35	0.17	0.67
1	(10)021	CIRCULAR	0.67	0.35	0.17	0.67

1	279.08					
1	(10)072	CIRCULAR	2.00	3.14	0.50	2.00
1	4291.06					
1	(10)157	CIRCULAR	2.00	3.14	0.50	2.00
1	4269.98					
1	(10)300	CIRCULAR	2.00	3.14	0.50	2.00
1	4445.34					
1	(10)301	CIRCULAR	2.00	3.14	0.50	2.00
1	4461.33					
1	(10)302	CIRCULAR	2.00	3.14	0.50	2.00
1	4307.79					
1	(10)303	CIRCULAR	2.00	3.14	0.50	2.00
1	4326.23					
1	(10)304	CIRCULAR	2.00	3.14	0.50	2.00
1	4116.06					
1	(10)304A	CIRCULAR	1.00	0.79	0.25	1.00
1	2927.39					
1	(10)304B	CIRCULAR	1.00	0.79	0.25	1.00
1	686.97					
1	(10)304C	CIRCULAR	1.00	0.79	0.25	1.00
1	226.00					
1	(10)305	CIRCULAR	2.00	3.14	0.50	2.00
1	1095.29					
1	(10)305A	CIRCULAR	2.00	3.14	0.50	2.00
1	40308.56					
1	(10)306	CIRCULAR	2.00	3.14	0.50	2.00
1	4339.64					
1	(10)306A	CIRCULAR	2.00	3.14	0.50	2.00
1	4333.24					
1	(10)307	CIRCULAR	2.00	3.14	0.50	2.00
1	4339.90					
1	(10)308	CIRCULAR	2.00	3.14	0.50	2.00
1	4312.68					
1	(10)308A	CIRCULAR	2.00	3.14	0.50	2.00
1	4354.22					
1	(10)309	CIRCULAR	2.00	3.14	0.50	2.00
1	4179.35					
1	(1P)003	CIRCULAR	1.00	0.79	0.25	1.00
1	1513.10					
1	(1P)004	CIRCULAR	1.00	0.79	0.25	1.00
1	993.07					
1	(1P)005	CIRCULAR	1.00	0.79	0.25	1.00
1	1312.02					
1	(1P)006	CIRCULAR	1.00	0.79	0.25	1.00
1	1071.50					
1	(1P)007	CIRCULAR	1.00	0.79	0.25	1.00
1	1460.80					
1	(1P)008	CIRCULAR	1.00	0.79	0.25	1.00
1	1132.44					
1	(1P)008A	CIRCULAR	1.00	0.79	0.25	1.00
1	2176.50					
1	(1P)009	CIRCULAR	1.00	0.79	0.25	1.00
1	1894.23					
1	(1P)010	CIRCULAR	1.00	0.79	0.25	1.00
1	1176.67					
1	(1P)011	CIRCULAR	1.00	0.79	0.25	1.00
1	1239.82					
1	(1P)012	CIRCULAR	1.00	0.79	0.25	1.00
1	1232.18					
1	(1P)013	CIRCULAR	1.00	0.79	0.25	1.00
1	1225.03					

1	(1P)014 1226.25	CIRCULAR	1.00	0.79	0.25	1.00
1	(1P)015 1232.47	CIRCULAR	1.00	0.79	0.25	1.00
1	(1P)016 1069.41	CIRCULAR	1.00	0.79	0.25	1.00
1	(1P)016A 1075.26	CIRCULAR	1.00	0.79	0.25	1.00
1	(1P)017 1072.20	CIRCULAR	1.00	0.79	0.25	1.00
1	(1P)018 1068.42	CIRCULAR	1.00	0.79	0.25	1.00
1	(1P)024 1070.05	CIRCULAR	1.00	0.79	0.25	1.00
1	(1P)042 1152.31	CIRCULAR	0.83	0.54	0.21	0.83
1	(1P)042A 539.73	CIRCULAR	0.83	0.54	0.21	0.83
1	(1P)043 547.19	CIRCULAR	0.83	0.54	0.21	0.83
1	(1P)044 547.82	CIRCULAR	0.83	0.54	0.21	0.83
1	(1P)065 530.40	CIRCULAR	0.83	0.54	0.21	0.83
1	(1P)073 1227.42	CIRCULAR	1.00	0.79	0.25	1.00
1	(1P)079 1215.19	CIRCULAR	1.00	0.79	0.25	1.00
1	(2A)001 8932.36	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)002 47824.60	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)003 15714.33	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)004 14505.38	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)005 14408.24	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)006 9099.02	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)007 10258.98	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)008 9609.86	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)009 9556.02	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)010 9518.94	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)011 9275.24	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)012 9511.38	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)013 9201.10	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)014 11115.96	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)015 11049.08	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)016 10281.03	CIRCULAR	3.00	7.07	0.75	3.00
1	(2A)017	CIRCULAR	3.00	7.07	0.75	3.00

1	10992.04					
	(2A)018	CIRCULAR	3.00	7.07	0.75	3.00
1	10369.18					
	(2A)019	CIRCULAR	3.00	7.07	0.75	3.00
1	11904.41					
	(2A)020	CIRCULAR	3.00	7.07	0.75	3.00
1	10248.75					
	(2A)021	CIRCULAR	3.00	7.07	0.75	3.00
1	15464.73					
	(2A)022	CIRCULAR	3.00	7.07	0.75	3.00
1	16051.09					
	(2A)023	CIRCULAR	3.00	7.07	0.75	3.00
1	16314.31					
	(2A)024	CIRCULAR	3.00	7.07	0.75	3.00
1	17444.91					
	(2A)025	CIRCULAR	3.00	7.07	0.75	3.00
1	19257.01					
	(2A)026	CIRCULAR	3.00	7.07	0.75	3.00
1	17839.59					
	(2A)027	CIRCULAR	3.00	7.07	0.75	3.00
1	10419.62					
	(2A)028	CIRCULAR	3.00	7.07	0.75	3.00
1	8961.78					
	(2A)029	CIRCULAR	3.00	7.07	0.75	3.00
1	9809.45					
	(2A)030	CIRCULAR	3.00	7.07	0.75	3.00
1	10739.24					
	(2A)031	CIRCULAR	3.00	7.07	0.75	3.00
1	12012.40					
	(2A)032	CIRCULAR	3.00	7.07	0.75	3.00
1	9566.97					
	(2A)033	CIRCULAR	3.00	7.07	0.75	3.00
1	11411.05					
	(2A)034	CIRCULAR	3.00	7.07	0.75	3.00
1	14266.00					
	(2A)035	CIRCULAR	3.00	7.07	0.75	3.00
1	14344.93					
	(2A)036	CIRCULAR	3.00	7.07	0.75	3.00
1	14385.10					
	(2A)037	CIRCULAR	3.00	7.07	0.75	3.00
1	13355.05					
	(2A)038	CIRCULAR	3.00	7.07	0.75	3.00
1	14589.17					
	(2A)039	CIRCULAR	3.00	7.07	0.75	3.00
1	14361.27					
	(2A)040	CIRCULAR	3.00	7.07	0.75	3.00
1	14215.39					
	(2A)041	CIRCULAR	3.00	7.07	0.75	3.00
1	14377.99					
	(2A)042	CIRCULAR	3.00	7.07	0.75	3.00
1	14375.57					
	(2A)043	CIRCULAR	3.00	7.07	0.75	3.00
1	15334.35					
	(2A)044	CIRCULAR	3.00	7.07	0.75	3.00
1	14098.50					
	(2A)045	CIRCULAR	3.00	7.07	0.75	3.00
1	13677.67					
	(2A)046	CIRCULAR	3.00	7.07	0.75	3.00
1	13351.13					
	(2A)047	CIRCULAR	3.00	7.07	0.75	3.00
1	9477.75					

1	(2A) 048	CIRCULAR	3.00	7.07	0.75	3.00
	9378.28					
1	(2A) 0480	CIRCULAR	1.00	0.79	0.25	1.00
	3316.87					
1	(2A) 049	CIRCULAR	3.00	7.07	0.75	3.00
	9685.55					
1	(2A) 050	CIRCULAR	3.00	7.07	0.75	3.00
	9134.39					
1	(2A) 051	CIRCULAR	3.00	7.07	0.75	3.00
	14559.53					
1	(2A) 052	CIRCULAR	3.00	7.07	0.75	3.00
	14338.48					
1	(2A) 053	CIRCULAR	3.00	7.07	0.75	3.00
	14635.32					
1	(2A) 054	CIRCULAR	3.00	7.07	0.75	3.00
	24485.14					
1	(2A) 055	CIRCULAR	3.00	7.07	0.75	3.00
	9488.64					
1	(2A) 056	CIRCULAR	3.00	7.07	0.75	3.00
	9444.98					
1	(2A) 057	CIRCULAR	3.00	7.07	0.75	3.00
	11960.96					
1	(2A) 058	CIRCULAR	3.00	7.07	0.75	3.00
	11190.94					
1	(2A) 059	CIRCULAR	2.50	4.91	0.63	2.50
	7116.06					
1	(2A) 060	CIRCULAR	2.50	4.91	0.63	2.50
	9295.82					
1	(2A) 061	CIRCULAR	2.50	4.91	0.63	2.50
	8480.87					
1	(2A) 062	CIRCULAR	2.50	4.91	0.63	2.50
	10228.16					
1	(2A) 063	CIRCULAR	1.50	1.77	0.38	1.50
	4516.89					
1	(2A) 064	CIRCULAR	2.50	4.91	0.63	2.50
	9733.03					
1	(2A) 065	CIRCULAR	2.50	4.91	0.63	2.50
	9516.11					
1	(2A) 066	CIRCULAR	2.50	4.91	0.63	2.50
	20742.05					
1	(2A) 067	CIRCULAR	2.50	4.91	0.63	2.50
	10099.95					
1	(2A) 068	CIRCULAR	2.50	4.91	0.63	2.50
	9709.56					
1	(2A) 069	CIRCULAR	1.00	0.79	0.25	1.00
	4644.80					
1	(2C) 001	CIRCULAR	1.00	0.79	0.25	1.00
	508.32					
1	(2C) 002	CIRCULAR	1.00	0.79	0.25	1.00
	515.22					
1	(2C) 003	CIRCULAR	1.00	0.79	0.25	1.00
	610.74					
1	(2C) 004	CIRCULAR	1.00	0.79	0.25	1.00
	619.72					
1	(2C) 005	CIRCULAR	1.00	0.79	0.25	1.00
	632.84					
1	(2C) 006	CIRCULAR	1.00	0.79	0.25	1.00
	584.87					
1	(2C) 007	CIRCULAR	1.00	0.79	0.25	1.00
	618.39					
1	(2C) 008	CIRCULAR	1.00	0.79	0.25	1.00

1	635.12					
	(2C)009	CIRCULAR	1.00	0.79	0.25	1.00
1	615.62					
	(2C)0090	CIRCULAR	0.67	0.35	0.17	0.67
1	514.62					
	(2D)001	CIRCULAR	1.00	0.79	0.25	1.00
1	456.44					
	(2D)001A	CIRCULAR	1.00	0.79	0.25	1.00
1	431.78					
	(2D)002	CIRCULAR	1.00	0.79	0.25	1.00
1	828.87					
	(2D)003	CIRCULAR	1.00	0.79	0.25	1.00
1	841.62					
	(2D)004	CIRCULAR	1.00	0.79	0.25	1.00
1	791.61					
	(2D)005	CIRCULAR	1.00	0.79	0.25	1.00
1	843.73					
	(2D)006	CIRCULAR	1.00	0.79	0.25	1.00
1	883.44					
	(2D)007	CIRCULAR	1.00	0.79	0.25	1.00
1	759.80					
	(2D)008	CIRCULAR	1.00	0.79	0.25	1.00
1	694.03					
	(2D)009	CIRCULAR	0.67	0.35	0.17	0.67
1	440.26					
	(2D)010	CIRCULAR	0.67	0.35	0.17	0.67
1	261.64					
	(2D)011	CIRCULAR	0.67	0.35	0.17	0.67
1	289.81					
	(2D)012	CIRCULAR	0.67	0.35	0.17	0.67
1	338.01					
	(2D)013	CIRCULAR	0.67	0.35	0.17	0.67
1	332.67					
	(2D)014	CIRCULAR	0.67	0.35	0.17	0.67
1	305.27					
	(2D)015	CIRCULAR	0.67	0.35	0.17	0.67
1	634.34					
	(2D)016	CIRCULAR	0.67	0.35	0.17	0.67
1	287.54					
	(2D)017	CIRCULAR	0.67	0.35	0.17	0.67
1	320.66					
	(2D)018	CIRCULAR	0.67	0.35	0.17	0.67
1	337.74					
	(2D)019	CIRCULAR	0.67	0.35	0.17	0.67
1	338.38					
	(2D)020	CIRCULAR	0.67	0.35	0.17	0.67
1	282.58					
	(2D)021	CIRCULAR	0.67	0.35	0.17	0.67
1	286.63					
	(2D)022	CIRCULAR	0.67	0.35	0.17	0.67
1	282.72					
	(2D)023	CIRCULAR	0.67	0.35	0.17	0.67
1	350.35					
	(2D)024	CIRCULAR	0.67	0.35	0.17	0.67
1	310.02					
	(2D)025	CIRCULAR	0.67	0.35	0.17	0.67
1	406.69					
	(2D)039	CIRCULAR	0.83	0.54	0.21	0.83
1	748.86					
	(2D)040	CIRCULAR	0.83	0.54	0.21	0.83
1	307.25					

1	(2D) 041	CIRCULAR	0.83	0.54	0.21	0.83
	504.09					
1	(2D) 042	CIRCULAR	0.83	0.54	0.21	0.83
	493.70					
1	(2D) 043	CIRCULAR	0.83	0.54	0.21	0.83
	502.86					
1	(2D) 044	CIRCULAR	0.83	0.54	0.21	0.83
	503.43					
1	(2D) 045	CIRCULAR	0.83	0.54	0.21	0.83
	504.40					
1	(2D) 045A	CIRCULAR	0.83	0.54	0.21	0.83
	461.50					
1	(2D) 046	CIRCULAR	0.83	0.54	0.21	0.83
	509.27					
1	(2D) 046A	CIRCULAR	0.83	0.54	0.21	0.83
	478.03					
1	(2D) 241	CIRCULAR	1.50	1.77	0.38	1.50
	3218.22					
1	(2D) 242	CIRCULAR	1.50	1.77	0.38	1.50
	1937.49					
1	(2D) 243	CIRCULAR	1.50	1.77	0.38	1.50
	1933.12					
1	(2D) 244	CIRCULAR	1.50	1.77	0.38	1.50
	2228.70					
1	(2D) 244O	CIRCULAR	0.83	0.54	0.21	0.83
	1344.13					
1	(2D) 245	CIRCULAR	1.50	1.77	0.38	1.50
	1430.35					
1	(2D) 246	CIRCULAR	1.50	1.77	0.38	1.50
	1955.36					
1	(2D) 247	CIRCULAR	1.50	1.77	0.38	1.50
	1945.02					
1	(2D) 248	CIRCULAR	1.50	1.77	0.38	1.50
	2010.04					
1	(2D) 249	CIRCULAR	1.50	1.77	0.38	1.50
	1932.23					
1	(2D) 250	CIRCULAR	1.50	1.77	0.38	1.50
	2063.59					
1	(2D) 251	CIRCULAR	1.50	1.77	0.38	1.50
	1980.04					
1	(2D) 252	CIRCULAR	1.00	0.79	0.25	1.00
	671.58					
1	(2D) 253	CIRCULAR	1.50	1.77	0.38	1.50
	1980.04					
1	(2D) 254	CIRCULAR	1.50	1.77	0.38	1.50
	1980.04					
1	(2D) 255	CIRCULAR	1.50	1.77	0.38	1.50
	1980.04					
1	(2D) 256	CIRCULAR	1.50	1.77	0.38	1.50
	1980.04					
1	(2D) 257	CIRCULAR	1.50	1.77	0.38	1.50
	1980.04					
1	(2D) 258	CIRCULAR	1.50	1.77	0.38	1.50
	1980.04					
1	(2D) 259	CIRCULAR	1.50	1.77	0.38	1.50
	1980.04					
1	(2D) 260	CIRCULAR	1.50	1.77	0.38	1.50
	1980.04					
1	(2D) 261	CIRCULAR	1.50	1.77	0.38	1.50
	1980.04					
1	(2D) 262	CIRCULAR	1.50	1.77	0.38	1.50

1	1980.04					
	(2D)263	CIRCULAR	1.50	1.77	0.38	1.50
1	1980.04					
	(2D)264	CIRCULAR	1.50	1.77	0.38	1.50
1	1980.04					
	(2D)265	CIRCULAR	1.25	1.23	0.31	1.25
1	1217.65					
	(2D)266	CIRCULAR	1.25	1.23	0.31	1.25
1	1217.65					
	(2D)267	CIRCULAR	1.25	1.23	0.31	1.25
1	1217.65					
	(2E)001	CIRCULAR	2.50	4.91	0.63	2.50
1	4764.84					
	(2E)002	CIRCULAR	2.50	4.91	0.63	2.50
1	6070.23					
	(2E)003	CIRCULAR	2.50	4.91	0.63	2.50
1	10227.00					
	(2E)004	CIRCULAR	2.50	4.91	0.63	2.50
1	5624.29					
	(2E)005	CIRCULAR	2.50	4.91	0.63	2.50
1	3358.16					
	(2E)006	CIRCULAR	2.50	4.91	0.63	2.50
1	3271.92					
	(2E)007	CIRCULAR	2.50	4.91	0.63	2.50
1	5809.93					
	(2E)008	CIRCULAR	2.50	4.91	0.63	2.50
1	8940.87					
	(2E)009	CIRCULAR	2.50	4.91	0.63	2.50
1	6696.37					
	(2E)010	CIRCULAR	2.50	4.91	0.63	2.50
1	5662.63					
	(2E)011	CIRCULAR	2.50	4.91	0.63	2.50
1	5609.45					
	(2E)012	CIRCULAR	2.50	4.91	0.63	2.50
1	5649.17					
	(2E)013	CIRCULAR	2.50	4.91	0.63	2.50
1	5481.75					
	(2E)014	CIRCULAR	2.50	4.91	0.63	2.50
1	5497.61					
	(2E)043	CIRCULAR	1.00	0.79	0.25	1.00
1	813.32					
	(2F)001	CIRCULAR	2.50	4.91	0.63	2.50
1	5317.76					
	(2F)002	CIRCULAR	2.50	4.91	0.63	2.50
1	5384.39					
	(2F)003	CIRCULAR	2.50	4.91	0.63	2.50
1	5401.43					
	(2F)004	CIRCULAR	2.50	4.91	0.63	2.50
1	5325.82					
	(2F)005	CIRCULAR	2.50	4.91	0.63	2.50
1	5420.82					
	(2F)006	CIRCULAR	2.50	4.91	0.63	2.50
1	5424.79					
	(2F)007	CIRCULAR	2.50	4.91	0.63	2.50
1	5406.45					
	(2F)008	CIRCULAR	2.50	4.91	0.63	2.50
1	5093.65					
	(2F)009	CIRCULAR	2.25	3.98	0.56	2.25
1	4216.18					
	(2F)010	CIRCULAR	1.50	1.77	0.38	1.50
1	5727.28					

1	(2F) 011 1885.64	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 012 1836.49	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 013 1702.29	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 014 1731.79	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 015 1750.22	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 016 1702.27	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 017 1702.29	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 018 1719.63	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 019 1719.72	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 020 1685.27	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 021 1708.05	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 022 2071.46	CIRCULAR	1.50	1.77	0.38	1.50
1	(2F) 023 602.60	CIRCULAR	1.00	0.79	0.25	1.00
1	(2F) 024 618.23	CIRCULAR	1.00	0.79	0.25	1.00
1	(2F) 025 194.86	CIRCULAR	1.00	0.79	0.25	1.00
1	(2F) 026 207.85	CIRCULAR	1.00	0.79	0.25	1.00
1	(2F) 027 207.85	CIRCULAR	1.00	0.79	0.25	1.00
1	(2F) 028 207.85	CIRCULAR	1.00	0.79	0.25	1.00
1	(2F) 029 207.85	CIRCULAR	1.00	0.79	0.25	1.00
1	(2F) 030 207.85	CIRCULAR	1.00	0.79	0.25	1.00
1	(2F) 031 207.85	CIRCULAR	1.00	0.79	0.25	1.00
1	(2F) 032 207.85	CIRCULAR	1.00	0.79	0.25	1.00
1	(2F) 033 207.85	CIRCULAR	1.00	0.79	0.25	1.00
1	(2G) 001 754.64	CIRCULAR	1.00	0.79	0.25	1.00
1	(2G) 002 735.24	CIRCULAR	1.00	0.79	0.25	1.00
1	(2G) 002A 746.92	CIRCULAR	1.00	0.79	0.25	1.00
1	(2G) 003 740.28	CIRCULAR	1.00	0.79	0.25	1.00
1	(2G) 004 746.70	CIRCULAR	1.00	0.79	0.25	1.00
1	(2G) 005 745.85	CIRCULAR	1.00	0.79	0.25	1.00
1	(2G) 006 567.38	CIRCULAR	0.83	0.54	0.21	0.83
1	(2G) 007	CIRCULAR	0.83	0.54	0.21	0.83

1	559.87					
	(2G)008	CIRCULAR	0.83	0.54	0.21	0.83
1	476.52					
	(2G)009	CIRCULAR	0.83	0.54	0.21	0.83
1	590.75					
	(2G)010	CIRCULAR	0.83	0.54	0.21	0.83
1	549.21					
	(2G)011	CIRCULAR	0.83	0.54	0.21	0.83
1	562.60					
	(2G)012	CIRCULAR	0.83	0.54	0.21	0.83
1	369.07					
	(2G)012A	CIRCULAR	0.83	0.54	0.21	0.83
1	594.62					
	(2G)013	CIRCULAR	0.83	0.54	0.21	0.83
1	632.16					
	(2G)013A	CIRCULAR	0.83	0.54	0.21	0.83
1	797.92					
	(2G)014	CIRCULAR	0.83	0.54	0.21	0.83
1	652.85					
	(2G)015	CIRCULAR	0.83	0.54	0.21	0.83
1	323.96					
	(2G)016	CIRCULAR	0.83	0.54	0.21	0.83
1	360.19					
	(2G)016A	CIRCULAR	0.83	0.54	0.21	0.83
1	338.87					
	(2G)018	CIRCULAR	0.83	0.54	0.21	0.83
1	364.66					
	(2G)019	CIRCULAR	0.83	0.54	0.21	0.83
1	355.09					
	(2G)020	CIRCULAR	0.83	0.54	0.21	0.83
1	354.96					
	(2G)021	CIRCULAR	0.83	0.54	0.21	0.83
1	357.92					
	(2G)022	CIRCULAR	0.83	0.54	0.21	0.83
1	357.72					
	(2G)023	CIRCULAR	0.83	0.54	0.21	0.83
1	357.62					
	(2G)024	CIRCULAR	0.83	0.54	0.21	0.83
1	355.73					
	(2G)025	CIRCULAR	0.83	0.54	0.21	0.83
1	561.58					
	(2G)026	CIRCULAR	0.83	0.54	0.21	0.83
1	802.70					
	(2G)040	CIRCULAR	1.00	0.79	0.25	1.00
1	915.00					
	(2G)041	CIRCULAR	1.00	0.79	0.25	1.00
1	309.89					
	(2G)042	CIRCULAR	1.00	0.79	0.25	1.00
1	309.89					
	(2G)043	CIRCULAR	1.00	0.79	0.25	1.00
1	309.89					
	(2G)043A	CIRCULAR	1.00	0.79	0.25	1.00
1	309.89					
	(2G)044	CIRCULAR	1.00	0.79	0.25	1.00
1	309.89					
	(2G)045	CIRCULAR	1.00	0.79	0.25	1.00
1	309.89					
	(2G)359	CIRCULAR	0.83	0.54	0.21	0.83
1	362.32					
	(2H)001	CIRCULAR	1.75	2.41	0.44	1.75
1	2813.84					

1	(2H)002 2346.29	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)003 2289.32	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)005 2324.96	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)006 2312.74	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)007 2561.14	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)008 3587.28	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)009 3325.59	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)010 3234.76	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)011 3526.04	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)012 2690.95	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)013 2479.85	CIRCULAR	1.75	2.41	0.44	1.75
1	(2H)014 2387.77	CIRCULAR	1.50	1.77	0.38	1.50
1	(2H)015 2022.37	CIRCULAR	1.50	1.77	0.38	1.50
1	(2H)016 1463.60	CIRCULAR	1.50	1.77	0.38	1.50
1	(2H)017 3717.55	CIRCULAR	1.50	1.77	0.38	1.50
1	(2H)017A 1990.19	CIRCULAR	1.50	1.77	0.38	1.50
1	(2H)018 1883.35	CIRCULAR	1.50	1.77	0.38	1.50
1	(2H)019 1935.77	CIRCULAR	1.50	1.77	0.38	1.50
1	(2H)020 1841.33	CIRCULAR	1.50	1.77	0.38	1.50
1	(2H)021 2067.07	CIRCULAR	1.50	1.77	0.38	1.50
1	(2H)022 1820.78	CIRCULAR	1.25	1.23	0.31	1.25
1	(2H)023 1871.49	CIRCULAR	1.25	1.23	0.31	1.25
1	(2H)024 1691.10	CIRCULAR	1.25	1.23	0.31	1.25
1	(2H)025 931.82	CIRCULAR	1.25	1.23	0.31	1.25
1	(2H)026 1102.63	CIRCULAR	1.00	0.79	0.25	1.00
1	(2H)027 765.53	CIRCULAR	1.00	0.79	0.25	1.00
1	(2H)028 776.53	CIRCULAR	1.00	0.79	0.25	1.00
1	(2H)029 791.03	CIRCULAR	1.00	0.79	0.25	1.00
1	(2H)030 684.58	CIRCULAR	1.00	0.79	0.25	1.00
1	(2H)031 396.08	CIRCULAR	1.00	0.79	0.25	1.00
1	(2H)032	CIRCULAR	1.00	0.79	0.25	1.00

1	502.67					
	(2H)033	CIRCULAR	1.00	0.79	0.25	1.00
1	2457.42					
	(2H)034	CIRCULAR	1.00	0.79	0.25	1.00
1	755.88					
	(2H)036	CIRCULAR	1.00	0.79	0.25	1.00
1	775.25					
	(2H)037	CIRCULAR	1.00	0.79	0.25	1.00
1	858.69					
	(2H)038	CIRCULAR	1.00	0.79	0.25	1.00
1	777.40					
	(2H)039	CIRCULAR	1.00	0.79	0.25	1.00
1	846.62					
	(2H)040	CIRCULAR	1.00	0.79	0.25	1.00
1	624.21					
	(2H)041	CIRCULAR	1.00	0.79	0.25	1.00
1	777.10					
	(2H)042	CIRCULAR	1.00	0.79	0.25	1.00
1	973.03					
	(2H)043	CIRCULAR	1.00	0.79	0.25	1.00
1	642.33					
	(2H)044	CIRCULAR	1.00	0.79	0.25	1.00
1	715.66					
	(2H)045	CIRCULAR	1.00	0.79	0.25	1.00
1	722.62					
	(2H)046	CIRCULAR	1.00	0.79	0.25	1.00
1	773.42					
	(2H)047	CIRCULAR	1.00	0.79	0.25	1.00
1	386.00					
	(2H)048	CIRCULAR	1.00	0.79	0.25	1.00
1	1395.01					
	(2H)049	CIRCULAR	1.00	0.79	0.25	1.00
1	684.39					
	(2H)050	CIRCULAR	1.00	0.79	0.25	1.00
1	573.31					
	(2H)051	CIRCULAR	1.00	0.79	0.25	1.00
1	563.47					
	(2H)051A	CIRCULAR	1.00	0.79	0.25	1.00
1	669.24					
	(2H)052	CIRCULAR	1.00	0.79	0.25	1.00
1	798.81					
	(2H)053	CIRCULAR	1.00	0.79	0.25	1.00
1	333.32					
	(2H)054	CIRCULAR	0.83	0.54	0.21	0.83
1	512.64					
	(2H)054A	CIRCULAR	0.83	0.54	0.21	0.83
1	512.95					
	(2H)055	CIRCULAR	0.83	0.54	0.21	0.83
1	513.55					
	(2H)055A	CIRCULAR	0.83	0.54	0.21	0.83
1	513.55					
	(2H)056	CIRCULAR	0.83	0.54	0.21	0.83
1	513.55					
	(2H)057	CIRCULAR	0.83	0.54	0.21	0.83
1	513.55					
	(2H)058	CIRCULAR	0.83	0.54	0.21	0.83
1	513.55					
	(2H)285	CIRCULAR	0.83	0.54	0.21	0.83
1	482.52					
	(2H)286	CIRCULAR	0.83	0.54	0.21	0.83
1	459.62					

1	(2H) 287 458.67	CIRCULAR	0.83	0.54	0.21	0.83
1	(2H) 288 458.63	CIRCULAR	0.83	0.54	0.21	0.83
1	(2H) 289 457.41	CIRCULAR	0.83	0.54	0.21	0.83
1	(2H) 290 460.81	CIRCULAR	0.83	0.54	0.21	0.83
1	(2I) 001 1317.11	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 001A 941.02	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 002 2363.70	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 003 1505.25	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 004 1453.82	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 005 1510.84	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 006 1531.40	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 008 1503.14	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 009 1475.18	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 010 1538.62	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 011 1502.87	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 012 1505.92	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 013 1481.37	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 014 1283.31	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 015 1286.11	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 016 1325.24	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 017 1459.56	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 018 651.87	CIRCULAR	1.00	0.79	0.25	1.00
1	(2I) 019 1397.26	CIRCULAR	1.25	1.23	0.31	1.25
1	(2I) 020 797.91	CIRCULAR	1.00	0.79	0.25	1.00
1	(2I) 021 711.82	CIRCULAR	1.00	0.79	0.25	1.00
1	(2I) 021A 1062.23	CIRCULAR	1.17	1.07	0.29	1.17
1	(2I) 021B 1057.05	CIRCULAR	1.17	1.07	0.29	1.17
1	(2I) 021C 572.94	CIRCULAR	1.17	1.07	0.29	1.17
1	(2I) 022 1032.37	CIRCULAR	1.17	1.07	0.29	1.17
1	(2I) 023 709.42	CIRCULAR	1.00	0.79	0.25	1.00
1	(2I) 024	CIRCULAR	1.00	0.79	0.25	1.00

1	707.04					
	(2I)025	CIRCULAR	1.00	0.79	0.25	1.00
1	709.40					
	(2I)025A	CIRCULAR	1.00	0.79	0.25	1.00
1	702.88					
	(2I)026	CIRCULAR	1.00	0.79	0.25	1.00
1	740.86					
	(2I)027	CIRCULAR	1.00	0.79	0.25	1.00
1	709.93					
	(2I)028	CIRCULAR	1.00	0.79	0.25	1.00
1	675.56					
	(2I)029	CIRCULAR	1.00	0.79	0.25	1.00
1	734.04					
	(2I)044	CIRCULAR	1.00	0.79	0.25	1.00
1	1299.27					
	(2I)045	CIRCULAR	1.00	0.79	0.25	1.00
1	1299.27					
	(2I)046	CIRCULAR	1.00	0.79	0.25	1.00
1	1299.27					
	(2I)047	CIRCULAR	1.00	0.79	0.25	1.00
1	1299.27					
	(2I)048	CIRCULAR	1.00	0.79	0.25	1.00
1	1299.27					
	(2I)049	CIRCULAR	1.00	0.79	0.25	1.00
1	1299.27					
	(2I)050	CIRCULAR	1.00	0.79	0.25	1.00
1	821.73					
	(2I)051	CIRCULAR	1.00	0.79	0.25	1.00
1	821.73					
	(2I)052	CIRCULAR	1.00	0.79	0.25	1.00
1	821.73					
	(2I)053	CIRCULAR	1.00	0.79	0.25	1.00
1	821.73					
	(2I)054	CIRCULAR	1.00	0.79	0.25	1.00
1	821.73					
	(2I)055	CIRCULAR	1.00	0.79	0.25	1.00
1	821.73					
	(2I)056	CIRCULAR	1.00	0.79	0.25	1.00
1	821.73					
	(2I)057	CIRCULAR	1.00	0.79	0.25	1.00
1	821.73					
	(2I)058	CIRCULAR	1.00	0.79	0.25	1.00
1	821.73					
	(2I)059	CIRCULAR	1.00	0.79	0.25	1.00
1	821.73					
	(2J)001	CIRCULAR	2.25	3.98	0.56	2.25
1	4754.69					
	(2J)002	CIRCULAR	2.25	3.98	0.56	2.25
1	3878.35					
	(2J)003	CIRCULAR	2.25	3.98	0.56	2.25
1	3923.49					
	(2J)004	CIRCULAR	2.25	3.98	0.56	2.25
1	3840.88					
	(2J)005	CIRCULAR	2.25	3.98	0.56	2.25
1	4282.25					
	(2J)006	CIRCULAR	2.25	3.98	0.56	2.25
1	3933.94					
	(2J)007	CIRCULAR	2.25	3.98	0.56	2.25
1	3894.78					
	(2J)008	CIRCULAR	2.25	3.98	0.56	2.25
1	3894.91					

1	(2J)009	CIRCULAR	2.25	3.98	0.56	2.25
	5141.41					
1	(2J)010	CIRCULAR	2.25	3.98	0.56	2.25
	5189.38					
1	(2J)011	CIRCULAR	2.00	3.14	0.50	2.00
	5046.16					
1	(2J)012	CIRCULAR	2.00	3.14	0.50	2.00
	3698.22					
1	(2J)013	CIRCULAR	2.00	3.14	0.50	2.00
	3639.35					
1	(2J)014	CIRCULAR	2.00	3.14	0.50	2.00
	3750.51					
1	(2J)015	CIRCULAR	2.00	3.14	0.50	2.00
	3643.82					
1	(2J)016	CIRCULAR	2.00	3.14	0.50	2.00
	3711.02					
1	(2J)017	CIRCULAR	2.00	3.14	0.50	2.00
	3989.50					
1	(2J)018	CIRCULAR	2.00	3.14	0.50	2.00
	3710.83					
1	(2J)019	CIRCULAR	1.75	2.41	0.44	1.75
	2862.13					
1	(2J)020	CIRCULAR	0.75	0.44	0.19	0.75
	76.97					
1	(2J)021	CIRCULAR	0.75	0.44	0.19	0.75
	729.52					
1	(2J)022	CIRCULAR	0.75	0.44	0.19	0.75
	331.72					
1	(2J)023	CIRCULAR	0.83	0.54	0.21	0.83
	361.26					
1	(2J)024	CIRCULAR	0.83	0.54	0.21	0.83
	771.41					
1	(2J)0250	CIRCULAR	0.83	0.54	0.21	0.83
	4101.86					
1	(2J)026	CIRCULAR	0.83	0.54	0.21	0.83
	445.64					
1	(2J)027	CIRCULAR	0.83	0.54	0.21	0.83
	455.80					
1	(2J)028	CIRCULAR	0.83	0.54	0.21	0.83
	442.88					
1	(2J)029	CIRCULAR	0.83	0.54	0.21	0.83
	456.23					
1	(2J)030	CIRCULAR	0.67	0.35	0.17	0.67
	303.35					
1	(2J)031	CIRCULAR	0.67	0.35	0.17	0.67
	293.29					
1	(2J)032	CIRCULAR	0.67	0.35	0.17	0.67
	280.94					
1	(2J)033	CIRCULAR	0.67	0.35	0.17	0.67
	286.66					
1	(2J)040	CIRCULAR	0.83	0.54	0.21	0.83
	597.59					
1	(2J)041	CIRCULAR	0.83	0.54	0.21	0.83
	450.32					
1	(2J)042	CIRCULAR	0.83	0.54	0.21	0.83
	443.78					
1	(2J)043	CIRCULAR	0.83	0.54	0.21	0.83
	477.06					
1	(2J)044	CIRCULAR	0.83	0.54	0.21	0.83
	432.76					
1	(2J)045	CIRCULAR	0.83	0.54	0.21	0.83

1	459.69					
	(2J) 045A	CIRCULAR	0.83	0.54	0.21	0.83
1	426.15					
	(2J) 046	CIRCULAR	0.83	0.54	0.21	0.83
1	448.36					
	(2J) 047	CIRCULAR	0.83	0.54	0.21	0.83
1	435.24					
	(2J) 048	CIRCULAR	0.83	0.54	0.21	0.83
1	440.74					
	(2J) 049	CIRCULAR	0.83	0.54	0.21	0.83
1	567.32					
	(2J) 050	CIRCULAR	0.83	0.54	0.21	0.83
1	451.46					
	(2J) 051	CIRCULAR	0.83	0.54	0.21	0.83
1	438.92					
	(2J) 052	CIRCULAR	0.67	0.35	0.17	0.67
1	293.44					
	(2J) 053	CIRCULAR	0.67	0.35	0.17	0.67
1	282.76					
	(2J) 054	CIRCULAR	0.67	0.35	0.17	0.67
1	287.78					
	(2J) 055	CIRCULAR	0.67	0.35	0.17	0.67
1	290.40					
	(2J) 056	CIRCULAR	0.67	0.35	0.17	0.67
1	291.16					
	(2J) 057	CIRCULAR	0.67	0.35	0.17	0.67
1	280.52					
	(2J) 058	CIRCULAR	0.67	0.35	0.17	0.67
1	268.18					
	(2K) 001	CIRCULAR	1.75	2.41	0.44	1.75
1	1121.85					
	(2K) 002	CIRCULAR	1.25	1.23	0.31	1.25
1	3087.32					
	(2K) 003	CIRCULAR	1.25	1.23	0.31	1.25
1	1410.42					
	(2K) 004	CIRCULAR	1.25	1.23	0.31	1.25
1	1278.70					
	(2K) 005	CIRCULAR	1.25	1.23	0.31	1.25
1	1290.55					
	(2K) 006	CIRCULAR	1.25	1.23	0.31	1.25
1	1303.70					
	(2K) 007	CIRCULAR	1.25	1.23	0.31	1.25
1	1504.42					
	(2K) 008	CIRCULAR	1.25	1.23	0.31	1.25
1	1309.71					
	(2K) 009	CIRCULAR	1.25	1.23	0.31	1.25
1	1355.73					
	(2K) 010	CIRCULAR	1.25	1.23	0.31	1.25
1	1271.78					
	(2K) 011	CIRCULAR	1.25	1.23	0.31	1.25
1	1174.94					
	(2K) 012	CIRCULAR	1.25	1.23	0.31	1.25
1	1403.75					
	(2K) 013	CIRCULAR	1.25	1.23	0.31	1.25
1	1267.51					
	(2K) 014	CIRCULAR	1.00	0.79	0.25	1.00
1	860.38					
	(2K) 015	CIRCULAR	1.00	0.79	0.25	1.00
1	644.79					
	(2K) 016	CIRCULAR	1.00	0.79	0.25	1.00
1	838.01					

1	(2K) 017	CIRCULAR	1.00	0.79	0.25	1.00
	815.82					
1	(2K) 018	CIRCULAR	1.00	0.79	0.25	1.00
	759.31					
1	(2K) 018A	CIRCULAR	1.00	0.79	0.25	1.00
	801.66					
1	(2K) 019	CIRCULAR	1.00	0.79	0.25	1.00
	875.31					
1	(2K) 020	CIRCULAR	1.00	0.79	0.25	1.00
	844.09					
1	(2K) 021	CIRCULAR	1.00	0.79	0.25	1.00
	662.60					
1	(2K) 022	CIRCULAR	1.00	0.79	0.25	1.00
	886.52					
1	(2K) 022A	CIRCULAR	1.00	0.79	0.25	1.00
	824.08					
1	(2K) 023	CIRCULAR	1.00	0.79	0.25	1.00
	797.51					
1	(2K) 024	CIRCULAR	1.00	0.79	0.25	1.00
	874.53					
1	(2K) 024A	CIRCULAR	1.00	0.79	0.25	1.00
	779.67					
1	(2K) 025	CIRCULAR	1.00	0.79	0.25	1.00
	845.71					
1	(2K) 026	CIRCULAR	1.00	0.79	0.25	1.00
	715.03					
1	(2K) 027	CIRCULAR	1.00	0.79	0.25	1.00
	3500.23					
1	(2K) 028	CIRCULAR	1.00	0.79	0.25	1.00
	614.52					
1	(2K) 029	CIRCULAR	1.00	0.79	0.25	1.00
	603.71					
1	(2K) 030	CIRCULAR	1.00	0.79	0.25	1.00
	611.35					
1	(2K) 031	CIRCULAR	1.00	0.79	0.25	1.00
	607.89					
1	(2K) 032	CIRCULAR	1.00	0.79	0.25	1.00
	613.14					
1	(2K) 033	CIRCULAR	1.00	0.79	0.25	1.00
	604.88					
1	(2K) 033A	CIRCULAR	1.00	0.79	0.25	1.00
	588.36					
1	(2K) 034	CIRCULAR	1.00	0.79	0.25	1.00
	597.24					
1	(2K) 035	CIRCULAR	1.00	0.79	0.25	1.00
	628.97					
1	(2K) 036	CIRCULAR	1.00	0.79	0.25	1.00
	613.12					
1	(2K) 037	CIRCULAR	1.00	0.79	0.25	1.00
	599.96					
1	(2K) 038	CIRCULAR	1.00	0.79	0.25	1.00
	600.06					
1	(2K) 039	CIRCULAR	1.00	0.79	0.25	1.00
	600.06					
1	(2K) 040	CIRCULAR	1.00	0.79	0.25	1.00
	600.06					
1	(2K) 041	CIRCULAR	1.00	0.79	0.25	1.00
	600.06					
1	(2K) 042	CIRCULAR	1.00	0.79	0.25	1.00
	600.06					
1	(2K) 043	CIRCULAR	1.00	0.79	0.25	1.00

1	600.06					
	(2K)044	CIRCULAR	1.00	0.79	0.25	1.00
1	600.06					
	(2K)045	CIRCULAR	1.00	0.79	0.25	1.00
1	600.06					
	(2K)046	CIRCULAR	1.00	0.79	0.25	1.00
1	600.06					
	(2K)047	CIRCULAR	1.00	0.79	0.25	1.00
1	600.06					
	(2K)048	CIRCULAR	1.00	0.79	0.25	1.00
1	600.06					
	(2K)049	CIRCULAR	1.00	0.79	0.25	1.00
1	600.06					
	(2K)050	CIRCULAR	1.00	0.79	0.25	1.00
1	600.06					
	(2K)051	CIRCULAR	1.00	0.79	0.25	1.00
1	600.06					
	(2K)052	CIRCULAR	1.00	0.79	0.25	1.00
1	600.06					
	(2K)314	CIRCULAR	0.83	0.54	0.21	0.83
1	570.99					
	(2K)315	CIRCULAR	0.83	0.54	0.21	0.83
1	385.19					
	(2K)316	CIRCULAR	0.83	0.54	0.21	0.83
1	471.10					
	(2K)317	CIRCULAR	0.83	0.54	0.21	0.83
1	460.77					
	FordedMain2	CIRCULAR	0.67	0.35	0.17	0.67
1	137.76					
	Line2ToPlant	CIRCULAR	2.75	5.94	0.69	2.75
1	10917.24					
	NorthEnid	CIRCULAR	1.00	0.79	0.25	1.00
1	40.80					
	1	CIRCULAR	1.00	0.79	0.25	1.00
1	6307.99					

*****	Volume	Volume
Rainfall Dependent I/I	acre-feet	Mgallons
*****	-----	-----
Sewershed Rainfall	7.129	2.323
RDII Produced	0.643	0.210
RDII Ratio	0.090	

*****	Volume	Depth
Runoff Quantity Continuity	acre-feet	inches
*****	-----	-----
Total Precipitation	967.651	0.980
Evaporation Loss	0.000	0.000
Infiltration Loss	418.507	0.424
Surface Runoff	504.700	0.511
Final Surface Storage	44.267	0.045
Continuity Error (%)	0.018	

*****	Volume	Volume
Flow Routing Continuity	acre-feet	Mgallons
*****	-----	-----
Dry Weather Inflow	87.042	28.364

Wet Weather Inflow	504.699	164.464
Groundwater Inflow	0.000	0.000
RDII Inflow	0.643	0.210
External Inflow	3.898	1.270
External Outflow	71.944	23.444
Surface Flooding	513.729	167.406
Evaporation Loss	0.000	0.000
Initial Stored Volume	0.000	0.000
Final Stored Volume	10.693	3.484
Continuity Error (%)	-0.014	

Subcatchment Runoff Summary

Peak Runoff Subcatchment GPM	Runoff Coeff	Total Precip in	Total Runon in	Total Evap in	Total Infil in	Total Runoff in
Basin1A1 2441.291	0.099	0.980	0.000	0.000	0.833	0.097
Basin1A2 10485.074	0.837	0.980	0.000	0.000	0.104	0.821
Basin1A3 7684.863	0.718	0.980	0.000	0.000	0.226	0.703
Basin1B1 3520.517	0.413	0.980	0.000	0.000	0.530	0.404
Basin1B2 8355.060	0.706	0.980	0.000	0.000	0.245	0.692
Basin1B3 16596.611	0.665	0.980	0.000	0.000	0.284	0.652
Basin1B4 8609.841	0.676	0.980	0.000	0.000	0.274	0.662
Basin1C1 12567.899	0.665	0.980	0.000	0.000	0.285	0.652
Basin1C1A 8666.274	0.663	0.980	0.000	0.000	0.287	0.650
Basin1C1B 9366.611	0.624	0.980	0.000	0.000	0.325	0.611
Basin1C1C 10613.581	0.571	0.980	0.000	0.000	0.376	0.560
Basin1C1D 6374.860	0.425	0.980	0.000	0.000	0.518	0.416
Basin1C2 9140.888	0.703	0.980	0.000	0.000	0.248	0.689
Basin1C3 10068.859	0.677	0.980	0.000	0.000	0.274	0.663
Basin1C4 8938.294	0.664	0.980	0.000	0.000	0.286	0.651
Basin1D1 4819.147	0.398	0.980	0.000	0.000	0.544	0.390
Basin1D2		0.980	0.000	0.000	0.374	0.562

6452.397	0.573						
Basin1D3		0.980	0.000	0.000	0.280	0.657	
14871.396	0.670						
Basin1D4		0.980	0.000	0.000	0.381	0.555	
10871.928	0.567						
Basin1E1		0.980	0.000	0.000	0.763	0.168	
1651.961	0.171						
Basin1E2		0.980	0.000	0.000	0.398	0.538	
6874.224	0.549						
Basin1F1		0.980	0.000	0.000	0.531	0.403	
16706.775	0.412						
Basin1F2		0.980	0.000	0.000	0.651	0.281	
3215.587	0.287						
Basin1F3		0.980	0.000	0.000	0.413	0.523	
10506.898	0.534						
Basin1F4		0.980	0.000	0.000	0.329	0.608	
9781.890	0.621						
Basin1F5		0.980	0.000	0.000	0.086	0.854	
14059.284	0.871						
Basin1G1		0.980	0.000	0.000	0.140	0.797	
6979.829	0.813						
Basin1G2		0.980	0.000	0.000	0.349	0.587	
20281.951	0.599						
Basin1G3		0.980	0.000	0.000	0.280	0.657	
13981.578	0.671						
Basin1G4		0.980	0.000	0.000	0.263	0.674	
18221.377	0.687						
Basin1G5		0.980	0.000	0.000	0.338	0.596	
15856.390	0.608						
Basin1G6		0.980	0.000	0.000	0.330	0.607	
9318.534	0.619						
Basin1G8		0.980	0.000	0.000	0.367	0.569	
11528.483	0.581						
Basin1G9		0.980	0.000	0.000	0.516	0.418	
5398.789	0.426						
Basin1H1		0.980	0.000	0.000	0.202	0.733	
19574.069	0.748						
Basin1I1		0.980	0.000	0.000	0.209	0.725	
15240.436	0.740						
Basin1J1		0.980	0.000	0.000	0.194	0.742	
18429.132	0.757						
Basin1J2		0.980	0.000	0.000	0.267	0.671	
6349.742	0.685						
Basin1K1		0.980	0.000	0.000	0.358	0.579	
8588.449	0.590						
Basin1K2		0.980	0.000	0.000	0.547	0.388	
5935.036	0.396						
Basin1K3		0.980	0.000	0.000	0.423	0.512	
17143.857	0.523						
Basin1K4		0.980	0.000	0.000	0.354	0.583	
10677.666	0.595						
Basin1M1		0.980	0.000	0.000	0.504	0.430	
5485.024	0.438						
Basin1M2		0.980	0.000	0.000	0.430	0.504	
6081.850	0.514						
Basin1M3		0.980	0.000	0.000	0.320	0.616	
10927.564	0.628						
Basin1M4		0.980	0.000	0.000	0.313	0.624	
11688.184	0.636						
Basin1M5		0.980	0.000	0.000	0.568	0.365	
11576.089	0.372						

Basin1M6		0.980	0.000	0.000	0.171	0.767
10739.830	0.783					
Basin1N1		0.980	0.000	0.000	0.355	0.581
10595.094	0.593					
Basin1N2		0.980	0.000	0.000	0.260	0.677
10558.020	0.690					
Basin1N3		0.980	0.000	0.000	0.445	0.489
5551.138	0.499					
Basin1N4		0.980	0.000	0.000	0.704	0.229
7288.103	0.233					
Basin1N5		0.980	0.000	0.000	0.351	0.585
3263.628	0.597					
Basin1N6		0.980	0.000	0.000	0.363	0.573
20481.760	0.584					
Basin1N7		0.980	0.000	0.000	0.632	0.300
11479.953	0.306					
Basin1N8		0.980	0.000	0.000	0.277	0.660
3883.859	0.673					
Basin1O1		0.980	0.000	0.000	0.356	0.580
26573.767	0.592					
Basin1O2		0.980	0.000	0.000	0.091	0.830
8128.319	0.847					
Basin1O3		0.980	0.000	0.000	0.365	0.572
14553.794	0.583					
Basin1O4		0.980	0.000	0.000	0.602	0.332
12676.644	0.339					
Basin1O5		0.980	0.000	0.000	0.308	0.628
9064.934	0.640					
Basin1P1		0.980	0.000	0.000	0.594	0.338
17556.376	0.345					
Basin1P2		0.980	0.000	0.000	0.591	0.342
5183.497	0.349					
Basin1P3		0.980	0.000	0.000	0.684	0.248
9004.163	0.253					
Basin2A1		0.980	0.000	0.000	0.838	0.094
1084.572	0.096					
Basin2A2		0.980	0.000	0.000	0.903	0.027
857.123	0.028					
Basin2B1		0.980	0.000	0.000	0.310	0.626
8995.105	0.639					
Basin2B2		0.980	0.000	0.000	0.274	0.663
9905.917	0.677					
Basin2B3		0.980	0.000	0.000	0.289	0.648
16470.338	0.661					
Basin2C1		0.980	0.000	0.000	0.459	0.476
8080.925	0.486					
Basin2C2		0.980	0.000	0.000	0.550	0.384
2907.203	0.392					
Basin2C3		0.980	0.000	0.000	0.386	0.550
14078.695	0.561					
Basin2D1		0.980	0.000	0.000	0.853	0.077
457.051	0.078					
Basin2D2		0.980	0.000	0.000	0.351	0.586
39382.951	0.598					
Basin2D3		0.980	0.000	0.000	0.896	0.034
1649.981	0.035					
Basin2D4		0.980	0.000	0.000	0.236	0.701
12173.054	0.715					
Basin2D5		0.980	0.000	0.000	0.531	0.403
12669.296	0.411					
Basin2E1		0.980	0.000	0.000	0.000	0.940

2358.020	0.960						
Basin2E2		0.980	0.000	0.000	0.811	0.121	
309.945	0.123						
Basin2F1		0.980	0.000	0.000	0.577	0.377	
3766.268	0.384						
Basin2F2		0.980	0.000	0.000	0.273	0.664	
16817.966	0.678						
Basin2F3		0.980	0.000	0.000	0.568	0.377	
5272.488	0.384						
Basin2F4		0.980	0.000	0.000	0.427	0.507	
2298.314	0.518						
Basin2F5		0.980	0.000	0.000	0.517	0.424	
7730.837	0.432						
Basin2G1		0.980	0.000	0.000	0.274	0.664	
9691.476	0.677						
Basin2G2		0.980	0.000	0.000	0.268	0.669	
36750.020	0.683						
Basin2G3		0.980	0.000	0.000	0.041	0.900	
17616.558	0.918						
Basin2G4		0.980	0.000	0.000	0.272	0.665	
23201.236	0.679						
Basin2G5		0.980	0.000	0.000	0.280	0.656	
12448.156	0.670						
Basin2G6		0.980	0.000	0.000	0.605	0.330	
14534.390	0.336						
Basin2H10		0.980	0.000	0.000	0.352	0.584	
4784.192	0.596						
Basin2H2		0.980	0.000	0.000	0.536	0.398	
4381.817	0.406						
Basin2H3		0.980	0.000	0.000	0.455	0.480	
13956.665	0.490						
Basin2H4		0.980	0.000	0.000	0.602	0.332	
10897.170	0.339						
Basin2H5		0.980	0.000	0.000	0.465	0.471	
3523.153	0.480						
Basin2H6		0.980	0.000	0.000	0.697	0.236	
1717.732	0.241						
Basin2H7		0.980	0.000	0.000	0.363	0.573	
7111.252	0.584						
Basin2H8		0.980	0.000	0.000	0.414	0.522	
10416.577	0.532						
Basin2H9		0.980	0.000	0.000	0.829	0.102	
1296.960	0.104						
Basin2I1		0.980	0.000	0.000	0.540	0.395	
4987.077	0.403						
Basin2I10		0.980	0.000	0.000	0.398	0.539	
7931.127	0.550						
Basin2I11		0.980	0.000	0.000	0.464	0.472	
10105.592	0.482						
Basin2I2		0.980	0.000	0.000	0.398	0.538	
3922.348	0.549						
Basin2I3		0.980	0.000	0.000	0.428	0.508	
1475.507	0.519						
Basin2I4		0.980	0.000	0.000	0.527	0.407	
4813.886	0.415						
Basin2I5		0.980	0.000	0.000	0.366	0.569	
11364.573	0.581						
Basin2I6		0.980	0.000	0.000	0.466	0.469	
17130.821	0.479						
Basin2I7		0.980	0.000	0.000	0.315	0.621	
2148.329	0.634						

Basin2I8		0.980	0.000	0.000	0.349	0.586
7825.418	0.598					
Basin2I9		0.980	0.000	0.000	0.512	0.424
12405.361	0.432					
Basin2J1		0.980	0.000	0.000	0.047	0.894
7797.906	0.912					
Basin2J2		0.980	0.000	0.000	0.254	0.684
12025.945	0.698					
Basin2J3		0.980	0.000	0.000	0.227	0.709
23258.152	0.723					
Basin2J4		0.980	0.000	0.000	0.245	0.693
9899.569	0.707					
Basin2J5		0.980	0.000	0.000	0.216	0.721
7656.490	0.736					
Basin2J6		0.980	0.000	0.000	0.304	0.631
5342.098	0.644					
Basin2K1		0.980	0.000	0.000	0.080	0.850
10619.730	0.867					
Basin2K2		0.980	0.000	0.000	0.333	0.602
6700.603	0.615					
Basin2K3		0.980	0.000	0.000	0.436	0.499
4028.908	0.509					
Basin2K4		0.980	0.000	0.000	0.472	0.463
6055.480	0.472					
Basin2K5		0.980	0.000	0.000	0.452	0.484
7759.793	0.494					
Basin2K6		0.980	0.000	0.000	0.507	0.429
15655.865	0.437					
Basin2K7		0.980	0.000	0.000	0.491	0.444
4944.197	0.453					
Basin2K8		0.980	0.000	0.000	0.567	0.366
6427.887	0.374					
Basin2K9		0.980	0.000	0.000	0.688	0.245
12940.673	0.250					

 System 0.980 0.000 0.000 0.424
 0.5111232951.070 0.522

 Node Depth Summary

Max Vol.	Total		Average	Maximum	Maximum	Time of Max
Ponded	Minutes		Depth	Depth	HGL	Occurrence
Node		Type	Feet	Feet	Feet	days hr:min
acre-in	Flooded					
(1A)000		JUNCTION	1.02	1.08	1148.57	3 07:09
0	0					
(1A)000A		JUNCTION	1.13	1.19	1149.68	3 07:08
0	0					

0	(1A)000B 0	JUNCTION	2.35	2.54	1151.94	0	07:13
0	(1A)001 4034	JUNCTION	5.75	6.74	1156.29	0	07:13
0	(1A)002 22	JUNCTION	1.54	6.55	1156.21	1	06:51
0	(1A)003 0	JUNCTION	1.29	1.95	1152.81	1	07:04
0	(1A)004 0	JUNCTION	1.29	1.95	1153.44	1	07:02
0	(1A)005 0	JUNCTION	1.20	1.77	1154.13	1	07:01
0	(1A)006 0	JUNCTION	1.04	1.51	1155.86	1	07:00
0	(1A)007 0	JUNCTION	1.04	1.51	1157.91	1	07:00
0	(1A)008 0	JUNCTION	1.32	1.54	1159.99	1	17:13
0	(1A)009 0	JUNCTION	1.32	1.53	1160.83	1	17:12
0	(1A)010 0	JUNCTION	2.00	2.51	1163.66	1	07:09
0	(1A)011 699	JUNCTION	2.71	7.50	1168.90	1	05:34
0	(1A)012 570	JUNCTION	2.04	3.95	1165.70	1	05:37
0	(1A)013 166	JUNCTION	1.55	10.33	1173.05	1	06:20
0	(1A)014 95	JUNCTION	1.17	3.58	1166.93	1	06:37
0	(1A)015 0	JUNCTION	1.30	1.48	1165.68	1	10:13
0	(1A)016 0	JUNCTION	1.48	1.71	1166.76	1	10:11
0	(1A)017 0	JUNCTION	1.48	1.71	1167.34	1	10:09
0	(1A)018 0	JUNCTION	2.15	2.37	1169.02	0	07:31
0	(1A)019 3929	JUNCTION	9.52	11.75	1178.50	0	07:10
0	(1A)020 0	JUNCTION	1.22	1.39	1169.47	2	08:25
0	(1A)021 0	JUNCTION	1.22	1.39	1171.24	2	20:06
0	(1A)022 0	JUNCTION	1.25	1.43	1173.41	2	21:45
0	(1A)023 0	JUNCTION	1.25	1.43	1174.91	2	21:44
0	(1A)024 0	JUNCTION	1.87	2.32	1177.95	0	20:10
0	(1A)024A 1299	JUNCTION	3.40	8.06	1184.16	0	20:10
0	(1A)025 0	JUNCTION	1.12	2.29	1180.07	1	06:37
0	(1A)026 81	JUNCTION	1.30	13.58	1193.56	1	06:37
0	(1A)027 27	JUNCTION	1.55	18.54	1200.25	1	06:53
0	(1A)028 0	JUNCTION	1.46	1.68	1183.93	3	08:24
0	(1A)029 0	JUNCTION	1.51	1.74	1184.71	3	08:23

0	0						
0	(1A) 030	JUNCTION	1.51	1.74	1185.22	3	08:21
0	0						
0	(1A) 031	JUNCTION	1.34	1.53	1186.04	3	08:19
0	0						
0	(1A) 032	JUNCTION	1.34	1.53	1186.83	3	08:17
0	0						
0	(1A) 033	JUNCTION	1.56	1.80	1187.93	2	22:36
0	0						
0	(1A) 034	JUNCTION	1.56	1.80	1188.40	3	08:53
0	0						
0	(1A) 035	JUNCTION	1.52	1.76	1189.27	2	09:17
0	0						
0	(1A) 035A	JUNCTION	1.53	1.76	1189.72	0	08:35
0	0						
0	(1A) 036	JUNCTION	1.32	1.50	1189.91	2	22:33
0	0						
0	(1A) 037	JUNCTION	1.89	2.31	1191.55	3	07:54
0	0						
0	(1A) 038	JUNCTION	4.86	11.16	1200.64	0	08:01
0	1673						
0	(1A) 039	JUNCTION	1.22	2.28	1192.71	1	06:14
0	0						
0	(1A) 040	JUNCTION	2.01	10.91	1202.00	1	05:32
0	460						
0	(1A) 041	JUNCTION	2.27	14.50	1205.93	1	05:32
0	440						
0	(1A) 042	JUNCTION	1.58	13.90	1206.00	1	05:46
0	209						
0	(1B) 001	JUNCTION	0.50	0.74	1178.20	1	14:49
0	0						
0	(1B) 002	JUNCTION	0.51	0.76	1179.08	1	14:49
0	0						
0	(1B) 003	JUNCTION	1.05	1.83	1181.26	1	15:10
0	0						
0	(1B) 004	JUNCTION	2.11	11.00	1190.50	1	05:06
0	584						
0	(1B) 005	JUNCTION	0.79	9.87	1191.00	1	05:34
0	140						
0	(1B) 006	JUNCTION	1.22	13.68	1195.85	1	05:24
0	277						
0	(1B) 009	JUNCTION	1.29	18.33	1201.16	1	05:24
0	220						
0	(1B) 010	JUNCTION	0.52	1.83	1187.26	1	11:01
0	0						
0	(1B) 011	JUNCTION	1.08	10.00	1196.63	1	05:23
0	341						
0	(1B) 013	JUNCTION	0.51	1.82	1189.76	1	05:57
0	0						
0	(1B) 014	JUNCTION	1.40	15.35	1204.49	1	05:22
0	329						
0	(1C) 001	JUNCTION	1.20	17.11	1206.78	1	05:30
0	253						
0	(1C) 001A	JUNCTION	0.87	13.37	1204.00	1	05:32
0	223						
0	(1C) 001C	JUNCTION	0.38	1.82	1198.82	1	06:09
0	0						
0	(1C) 001D	JUNCTION	0.94	15.70	1213.48	1	05:40
0	205						
0	(1C) 001E	JUNCTION	0.27	1.21	1202.17	1	05:45
0	0						

0	(1C)001F 0	JUNCTION	0.30	1.41	1204.92	1	05:44
0	(1C)001G 0	JUNCTION	0.10	0.21	1192.71	1	07:09
0	(1C)002 0	JUNCTION	0.21	0.91	1198.68	1	10:17
0	(1C)003 0	JUNCTION	0.15	0.19	1198.21	0	20:37
0	(1C)004 0	JUNCTION	0.15	0.19	1199.39	0	08:01
0	(1C)005 0	JUNCTION	0.15	0.20	1199.41	0	08:01
0	(1C)006 0	JUNCTION	0.08	0.10	1200.29	0	21:00
0	(1C)006A 0	JUNCTION	0.07	0.09	1201.61	0	20:31
0	(1C)007 0	JUNCTION	0.07	0.10	1201.82	0	19:01
0	(1C)009 0	JUNCTION	0.30	1.41	1205.89	1	05:42
0	(1C)010 0	JUNCTION	0.27	1.25	1207.78	1	05:42
0	(1C)011 0	JUNCTION	0.35	1.99	1209.34	1	08:52
0	(1C)012 0	JUNCTION	0.00	0.00	1213.57	0	00:00
0	(1C)015A 187	JUNCTION	0.74	12.27	1219.80	1	05:41
0	(1C)015B 0	JUNCTION	0.29	1.50	1211.61	1	06:05
0	(1C)015C 0	JUNCTION	0.32	1.82	1213.27	1	06:04
0	(1C)015D 176	JUNCTION	0.71	12.75	1225.76	1	05:40
0	(1C)016 0	JUNCTION	0.29	2.00	1216.45	1	05:45
0	(1C)016A 0	JUNCTION	0.28	1.80	1217.04	1	08:08
0	(1C)016B 0	JUNCTION	0.29	2.00	1218.58	1	05:42
0	(1C)016C 141	JUNCTION	0.71	16.94	1234.85	1	05:42
0	(1C)017 0	JUNCTION	0.07	0.09	1217.71	0	08:04
0	(1C)018 0	JUNCTION	0.07	0.09	1219.27	0	08:01
0	(1C)019 0	JUNCTION	0.07	0.09	1220.32	0	08:00
0	(1C)020 0	JUNCTION	0.06	0.07	1221.60	0	07:00
0	(1C)021 103	JUNCTION	2.28	10.58	1230.80	1	05:52
0	(1C)021A 181	JUNCTION	0.81	15.62	1236.60	1	05:33
0	(1C)021B 156	JUNCTION	0.76	17.83	1239.65	1	05:36
0	(1C)021C 0	JUNCTION	0.10	0.20	1223.18	1	08:00
0	(1C)021D 0	JUNCTION	0.10	0.20	1224.16	1	08:00
0	(1C)022 0	JUNCTION	0.15	0.54	1223.47	1	08:00

0	0						
	(1C) 023	JUNCTION	0.14	0.54	1224.79	1	08:00
0	0						
	(1C) 024	JUNCTION	0.16	0.76	1225.92	1	11:22
0	0						
	(1C) 025	JUNCTION	0.98	12.67	1238.23	1	05:23
0	349						
	(1C) 027	JUNCTION	0.82	11.62	1239.56	1	05:26
0	306						
	(1C) 028	JUNCTION	0.76	10.71	1239.72	1	05:20
0	312						
	(1C) 041	JUNCTION	0.05	0.06	1203.89	0	07:00
0	0						
	(1C) 176	JUNCTION	0.20	1.00	1201.93	1	05:13
0	0						
	(1C) 177	JUNCTION	0.47	12.58	1216.51	1	06:00
0	121						
	(1C) 178	JUNCTION	0.97	14.25	1221.37	1	05:12
0	295						
	(1C) 179	JUNCTION	0.98	17.25	1227.38	1	05:20
0	254						
	(1C) 179A	JUNCTION	0.83	17.55	1227.78	1	05:34
0	208						
	(1C) 180	JUNCTION	0.14	14.92	1228.16	1	08:45
0	1						
	(1C) 180A	JUNCTION	0.13	1.00	1217.23	1	05:33
0	0						
	(1C) 181	JUNCTION	0.13	1.00	1220.17	1	05:31
0	0						
	(1C) 182	JUNCTION	0.54	12.00	1232.72	1	05:31
0	191						
	(1D) 001	JUNCTION	0.25	0.73	1173.71	1	10:09
0	0						
	(1D) 002	JUNCTION	0.25	0.83	1175.62	1	05:17
0	0						
	(1D) 003	JUNCTION	0.23	0.62	1176.96	1	05:43
0	0						
	(1D) 004	JUNCTION	0.26	0.76	1181.92	1	05:42
0	0						
	(1D) 005	JUNCTION	0.69	8.08	1191.18	1	05:13
0	296						
	(1D) 006	JUNCTION	0.23	0.52	1185.67	1	11:35
0	0						
	(1D) 007	JUNCTION	0.23	0.52	1189.50	1	11:34
0	0						
	(1D) 008	JUNCTION	0.29	0.75	1193.74	1	13:11
0	0						
	(1D) 009	JUNCTION	0.30	0.83	1195.51	1	05:12
0	0						
	(1D) 010	JUNCTION	1.24	13.04	1208.54	1	05:11
0	386						
	(1D) 011	JUNCTION	0.28	0.76	1196.98	1	10:58
0	0						
	(1D) 012	JUNCTION	1.04	11.51	1208.55	1	05:10
0	353						
	(1D) 013	JUNCTION	0.26	0.76	1204.94	1	05:56
0	0						
	(1D) 014	JUNCTION	0.63	6.35	1212.18	1	05:08
0	323						
	(1D) 015	JUNCTION	0.28	0.78	1208.03	1	06:15
0	0						

0	(1D)016 121	JUNCTION	0.52	10.29	1218.52	1	06:00
0	(1D)017 503	JUNCTION	1.18	9.75	1218.96	1	05:10
0	(1D)018 500	JUNCTION	1.56	13.83	1224.02	1	05:06
0	(1D)019 0	JUNCTION	0.24	0.83	1212.02	1	05:20
0	(1D)020 390	JUNCTION	1.45	16.45	1228.59	1	05:19
0	(1D)021 377	JUNCTION	1.43	17.21	1230.31	1	05:18
0	(1D)022 370	JUNCTION	1.37	16.91	1231.03	1	05:18
0	(1D)023 375	JUNCTION	1.21	14.72	1229.82	1	05:12
0	(1E)001 0	JUNCTION	0.16	1.00	1192.96	1	05:33
0	(1E)002 0	JUNCTION	0.16	1.00	1194.20	1	05:25
0	(1E)003 220	JUNCTION	0.42	6.75	1201.47	1	05:25
0	(1E)003A 220	JUNCTION	0.38	5.91	1201.91	1	05:22
0	(1E)005 3	JUNCTION	0.16	10.95	1208.55	1	08:41
0	(1E)006 0	JUNCTION	0.16	1.00	1200.00	1	05:26
0	(1E)007 0	JUNCTION	0.16	1.00	1201.04	1	05:23
0	(1E)008 196	JUNCTION	0.51	10.00	1211.70	1	05:20
0	(1E)009 190	JUNCTION	0.41	7.81	1210.34	1	05:20
0	(1F)001 206	JUNCTION	0.87	17.39	1212.62	1	05:35
0	(1F)003 0	JUNCTION	0.22	1.60	1200.80	1	06:13
0	(1F)004 208	JUNCTION	0.58	9.94	1209.72	1	05:31
0	(1F)005 120	JUNCTION	0.31	6.43	1206.31	1	05:41
0	(1F)006 0	JUNCTION	0.17	1.41	1201.52	1	07:21
0	(1F)008 0	JUNCTION	0.14	1.60	1202.02	1	06:14
0	(1F)008A 103	JUNCTION	0.25	7.27	1207.81	1	05:38
0	(1F)009 0	JUNCTION	0.12	1.60	1202.24	1	06:11
0	(1F)010 89	JUNCTION	0.23	7.96	1208.77	1	05:41
0	(1F)011 0	JUNCTION	0.04	0.05	1201.50	0	07:00
0	(1F)012A 0	JUNCTION	0.11	0.15	1202.62	0	08:00
0	(1F)013 0	JUNCTION	0.13	0.17	1203.97	0	08:04
0	(1F)014 0	JUNCTION	0.13	0.17	1204.07	0	21:00
0	(1F)015	JUNCTION	0.08	0.11	1205.09	0	08:00

0	0						
	(1F) 016	JUNCTION	0.08	0.10	1205.85	0	07:00
0	0						
	(1F) 017	JUNCTION	0.97	3.00	1203.94	1	05:40
0	0						
	(1F) 017A	JUNCTION	1.39	17.37	1218.70	1	05:41
0	146						
	(1F) 017B	JUNCTION	0.93	2.08	1203.56	1	07:08
0	0						
	(1F) 017C	JUNCTION	1.09	3.00	1204.83	1	10:17
0	0						
	(1F) 017D	JUNCTION	1.72	14.25	1216.20	1	05:41
0	279						
	(1F) 017E	JUNCTION	0.98	3.00	1205.33	1	05:52
0	0						
	(1F) 017F	JUNCTION	0.16	0.30	1203.50	1	12:36
0	0						
	(1F) 017G	JUNCTION	0.23	0.45	1206.56	1	12:36
0	0						
	(1F) 018	JUNCTION	0.31	0.74	1207.88	1	12:35
0	0						
	(1F) 019	JUNCTION	0.31	0.83	1208.71	1	12:31
0	0						
	(1F) 020	JUNCTION	0.33	0.83	1211.27	1	05:15
0	0						
	(1F) 021	JUNCTION	0.96	8.00	1220.29	1	05:06
0	445						
	(1F) 022	JUNCTION	0.28	0.57	1214.37	1	08:00
0	0						
	(1F) 023	JUNCTION	0.27	0.54	1215.43	1	08:00
0	0						
	(1F) 024	JUNCTION	0.06	0.08	1221.71	0	08:00
0	0						
	(1F) 025	JUNCTION	0.06	0.08	1227.15	0	20:42
0	0						
	(1F) 026	JUNCTION	0.10	0.13	1233.19	0	08:00
0	0						
	(1F) 026A	JUNCTION	0.10	0.13	1233.76	0	20:37
0	0						
	(1F) 027	JUNCTION	0.09	0.11	1234.34	0	20:32
0	0						
	(1F) 028	JUNCTION	0.08	0.10	1234.84	0	20:29
0	0						
	(1F) 029	JUNCTION	0.08	0.10	1235.43	0	08:01
0	0						
	(1F) 029A	JUNCTION	0.08	0.10	1236.03	0	08:00
0	0						
	(1F) 030	JUNCTION	0.08	0.10	1236.77	0	07:00
0	0						
	(1G) 001	JUNCTION	1.30	14.39	1217.60	1	05:56
0	145						
	(1G) 001A	JUNCTION	1.20	14.91	1218.51	1	06:05
0	113						
	(1G) 002	JUNCTION	1.36	15.43	1219.50	1	06:06
0	109						
	(1G) 003	JUNCTION	1.88	17.96	1222.30	1	05:37
0	263						
	(1G) 004	JUNCTION	0.86	1.75	1206.42	1	07:11
0	0						
	(1G) 005	JUNCTION	1.16	2.74	1207.91	1	06:09
0	0						

0	(1G)006 256	JUNCTION	1.95	18.23	1223.50	1	05:36
0	(1G)007 0	JUNCTION	0.88	2.74	1208.39	1	08:24
0	(1G)008A 0	JUNCTION	0.89	3.00	1209.37	1	05:43
0	(1G)008B 0	JUNCTION	0.89	2.74	1210.01	1	06:07
0	(1G)008C 153	JUNCTION	1.37	18.85	1226.50	1	05:44
0	(1G)009A 140	JUNCTION	1.26	18.48	1226.50	1	05:45
0	(1G)009B 140	JUNCTION	1.26	18.23	1226.70	1	05:44
0	(1G)009C 0	JUNCTION	0.82	2.53	1211.45	1	06:20
0	(1G)009D 0	JUNCTION	0.85	3.00	1211.98	1	06:12
0	(1G)009E 55	JUNCTION	1.06	22.47	1231.70	1	06:19
0	(1G)010 0	JUNCTION	0.75	3.00	1212.71	1	06:56
0	(1G)011 0	JUNCTION	0.75	3.00	1213.07	1	06:58
0	(1G)012 0	JUNCTION	0.76	3.00	1213.60	1	06:52
0	(1G)013 0	JUNCTION	0.76	3.00	1214.10	1	06:44
0	(1G)014 0	JUNCTION	0.21	0.27	1220.21	1	08:01
0	(1G)014A 0	JUNCTION	0.21	0.27	1220.85	1	08:00
0	(1G)015 0	JUNCTION	0.21	0.27	1221.97	1	08:00
0	(1G)016 0	JUNCTION	0.21	0.27	1222.75	1	07:44
0	(1G)017 0	JUNCTION	0.19	0.25	1223.45	1	08:00
0	(1G)018 0	JUNCTION	0.19	0.24	1224.26	1	07:00
0	(1G)018A 0	JUNCTION	0.14	0.18	1224.37	1	21:01
0	(1G)020 959	JUNCTION	2.71	12.75	1238.54	1	05:03
0	(1G)045 0	JUNCTION	0.34	0.76	1228.51	1	05:57
0	(1G)046 801	JUNCTION	2.21	12.54	1241.28	1	05:12
0	(1G)047 0	JUNCTION	0.28	0.53	1229.62	1	07:00
0	(1G)048 0	JUNCTION	0.13	0.42	1230.72	1	06:31
0	(1G)049 0	JUNCTION	0.14	0.47	1231.33	1	06:30
0	(1G)050 0	JUNCTION	0.14	0.47	1231.72	1	06:30
0	(1G)051 0	JUNCTION	0.17	0.63	1232.30	1	06:31
0	(1G)052 1	JUNCTION	0.17	8.50	1240.58	1	16:45
0	(1G)053 1	JUNCTION	1.24	8.50	1241.41	1	05:03

0	686						
	(1G) 054	JUNCTION	0.11	8.50	1242.21	1	13:09
0	1						
	(1G) 055	JUNCTION	0.11	0.67	1235.18	1	05:35
0	0						
	(1G) 056	JUNCTION	0.84	9.00	1244.32	1	05:31
0	443						
	(1G) 057	JUNCTION	0.10	0.67	1237.81	1	06:10
0	0						
	(1G) 058	JUNCTION	0.10	0.67	1239.63	1	05:33
0	0						
	(1G) 059	JUNCTION	0.10	0.67	1241.34	1	05:32
0	0						
	(1G) 060	JUNCTION	0.09	0.67	1241.49	1	05:31
0	0						
	(1G) 061	JUNCTION	0.82	10.00	1252.52	1	05:31
0	390						
	(1G) 062	JUNCTION	0.09	0.67	1245.19	1	05:29
0	0						
	(1G) 063	JUNCTION	0.09	0.67	1245.55	1	05:28
0	0						
	(1G) 064	JUNCTION	0.09	0.67	1247.68	1	05:26
0	0						
	(1G) 065	JUNCTION	0.09	0.67	1249.15	1	05:24
0	0						
	(1G) 066	JUNCTION	0.09	0.67	1250.11	1	05:22
0	0						
	(1G) 067	JUNCTION	0.09	0.67	1251.82	1	05:20
0	0						
	(1G) 068	JUNCTION	0.10	10.15	1263.41	1	11:43
0	1						
	(1G) 069	JUNCTION	0.10	10.15	1265.93	1	11:39
0	1						
	(1G) 070	JUNCTION	0.09	0.67	1258.61	1	05:12
0	0						
	(1G) 071	JUNCTION	0.80	10.15	1269.75	1	05:12
0	375						
	(1G) 146	JUNCTION	0.00	0.00	1204.48	0	00:00
0	0						
	(1G) 146A	JUNCTION	0.00	0.00	1204.74	0	00:00
0	0						
	(1G) 162	JUNCTION	0.43	15.00	1232.52	1	21:03
0	3						
	(1G) 162A	JUNCTION	0.42	15.00	1233.46	1	21:05
0	1						
	(1G) 162B	JUNCTION	0.39	0.83	1219.99	1	21:03
0	0						
	(1G) 162C	JUNCTION	0.42	0.83	1220.82	1	05:05
0	0						
	(1G) 162D	JUNCTION	0.40	0.83	1216.76	1	21:04
0	0						
	(1G) 243	JUNCTION	0.00	0.00	1229.12	0	00:00
0	0						
	(1H) 001	JUNCTION	0.25	0.53	1216.49	1	07:12
0	0						
	(1H) 004	JUNCTION	0.68	0.83	1219.09	0	08:09
0	0						
	(1H) 005	JUNCTION	6.06	9.73	1228.01	0	06:08
0	3016						
	(1H) 006	JUNCTION	0.28	0.60	1220.38	1	16:36
0	0						

0	(1H)007	JUNCTION	0.28	0.59	1221.28	1	16:35
0	0						
0	(1H)008	JUNCTION	0.28	0.59	1222.45	1	07:00
0	0						
0	(1H)009	JUNCTION	0.33	0.76	1222.76	1	05:43
0	0						
0	(1H)010	JUNCTION	1.88	12.27	1234.66	1	05:16
0	680						
0	(1H)011	JUNCTION	1.20	12.00	1235.00	1	05:33
0	434						
0	(1H)038	JUNCTION	0.19	0.38	1219.19	1	07:00
0	0						
0	(1H)039	JUNCTION	0.17	0.35	1224.38	1	06:06
0	0						
0	(1H)040	JUNCTION	0.32	0.76	1229.22	1	06:06
0	0						
0	(1H)041	JUNCTION	1.50	9.00	1238.00	1	05:11
0	725						
0	(1H)042	JUNCTION	0.26	0.83	1231.68	1	14:56
0	0						
0	(1H)043	JUNCTION	1.33	10.11	1241.45	1	05:19
0	578						
0	(1H)044	JUNCTION	0.14	0.19	1232.81	0	08:00
0	0						
0	(1H)045	JUNCTION	0.14	0.18	1233.74	0	07:00
0	0						
0	(1J)001	JUNCTION	1.02	2.35	1195.31	1	08:03
0	0						
0	(1J)002	JUNCTION	1.04	2.35	1196.37	1	08:02
0	0						
0	(1J)003	JUNCTION	1.10	2.21	1196.99	1	08:01
0	0						
0	(1J)004	JUNCTION	1.13	2.30	1197.84	1	08:00
0	0						
0	(1J)005	JUNCTION	1.13	2.30	1198.60	1	08:00
0	0						
0	(1J)006	JUNCTION	1.09	2.18	1199.20	1	07:00
0	0						
0	(1J)007	JUNCTION	1.04	2.05	1199.57	1	10:58
0	0						
0	(1J)008	JUNCTION	1.12	2.30	1200.15	1	10:58
0	0						
0	(1J)009	JUNCTION	1.12	2.30	1200.53	1	10:57
0	0						
0	(1J)010	JUNCTION	1.24	2.74	1201.56	1	05:56
0	0						
0	(1J)011	JUNCTION	1.85	12.30	1211.35	1	05:34
0	324						
0	(1J)012	JUNCTION	1.50	13.24	1212.80	1	05:42
0	186						
0	(1J)013	JUNCTION	1.59	19.59	1219.66	1	05:42
0	154						
0	(1J)014	JUNCTION	1.03	3.00	1203.42	1	05:42
0	0						
0	(1J)041	JUNCTION	0.43	0.56	1201.46	1	08:02
0	0						
0	(1J)042	JUNCTION	0.38	0.49	1204.65	1	08:01
0	0						
0	(1J)042A	JUNCTION	0.38	0.49	1206.97	1	08:01
0	0						
0	(1J)042B	JUNCTION	0.41	0.53	1210.63	1	08:00

0	0						
	(1J) 043	JUNCTION	0.69	0.97	1214.03	1	08:00
0	0						
	(1J) 044	JUNCTION	0.69	0.93	1214.78	1	20:02
0	0						
	(1J) 045	JUNCTION	0.55	0.70	1215.18	1	08:00
0	0						
	(1J) 046	JUNCTION	0.55	0.69	1215.38	1	19:35
0	0						
	(1J) 047	JUNCTION	0.47	0.59	1215.38	1	08:00
0	0						
	(1J) 048	JUNCTION	0.36	0.45	1215.79	1	08:00
0	0						
	(1J) 050	JUNCTION	0.37	0.48	1217.37	1	22:46
0	0						
	(1J) 050A	JUNCTION	0.37	0.48	1217.46	1	22:45
0	0						
	(1J) 051	JUNCTION	0.78	1.15	1219.92	1	23:25
0	0						
	(1J) 052	JUNCTION	2.81	10.80	1229.62	1	05:06
0	1060						
	(1J) 053	JUNCTION	1.33	9.51	1228.48	1	05:22
0	504						
	(1J) 054	JUNCTION	0.31	0.46	1220.76	1	07:28
0	0						
	(1J) 054A	JUNCTION	0.66	1.14	1221.75	1	13:39
0	0						
	(1J) 055	JUNCTION	2.75	23.66	1244.36	1	05:19
0	469						
	(1J) 056	JUNCTION	0.41	0.75	1222.27	1	11:23
0	0						
	(1J) 057	JUNCTION	0.41	0.75	1222.83	1	11:22
0	0						
	(1J) 058	JUNCTION	0.49	0.96	1223.71	1	11:21
0	0						
	(1J) 059	JUNCTION	0.55	1.15	1224.19	1	11:36
0	0						
	(1J) 060	JUNCTION	1.24	10.58	1233.83	1	05:10
0	372						
	(1K) 001	JUNCTION	0.51	13.83	1242.98	1	05:49
0	104						
	(1K) 002	JUNCTION	0.22	0.37	1230.05	1	07:00
0	0						
	(1K) 002A	JUNCTION	0.36	0.66	1230.79	1	06:23
0	0						
	(1K) 003	JUNCTION	0.44	0.91	1231.42	1	11:04
0	0						
	(1K) 004	JUNCTION	0.91	7.95	1239.06	1	05:14
0	336						
	(1K) 005	JUNCTION	0.70	0.92	1232.89	0	08:11
0	0						
	(1K) 006	JUNCTION	2.58	7.45	1239.43	0	07:12
0	1443						
	(1K) 007	JUNCTION	0.41	1.00	1233.87	1	05:19
0	0						
	(1K) 008	JUNCTION	1.14	11.04	1244.70	1	05:18
0	367						
	(1K) 008A	JUNCTION	0.44	0.91	1235.01	1	06:25
0	0						
	(1K) 009	JUNCTION	2.15	18.33	1252.79	1	05:22
0	495						

(1K) 010	JUNCTION	0.68	12.91	1248.15	1	06:02
0 120						
(1K) 011	JUNCTION	0.37	1.00	1236.70	1	07:00
0 0						
(1K) 012	JUNCTION	0.17	0.94	1237.52	1	13:04
0 0						
(1K) 013	JUNCTION	2.23	23.41	1260.59	1	05:13
0 460						
(1K) 014	JUNCTION	0.83	8.77	1246.43	1	05:14
0 427						
(1M) 000	JUNCTION	0.71	2.30	1213.82	1	07:02
0 0						
(1M) 001	JUNCTION	0.70	2.26	1216.81	1	07:01
0 0						
(1M) 001A	JUNCTION	0.70	2.25	1215.33	1	07:01
0 0						
(1M) 001B	JUNCTION	0.70	2.25	1214.29	1	07:02
0 0						
(1M) 002	JUNCTION	0.70	2.26	1217.71	1	07:00
0 0						
(1M) 003	JUNCTION	0.69	2.08	1218.13	1	07:00
0 0						
(1M) 010	JUNCTION	0.56	0.91	1221.25	1	06:26
0 0						
(1M) 011	JUNCTION	2.20	13.54	1234.84	1	05:16
0 658						
(1M) 013	JUNCTION	0.45	0.78	1223.36	1	08:08
0 0						
(1M) 014	JUNCTION	0.45	0.78	1224.39	1	08:06
0 0						
(1M) 015	JUNCTION	0.46	0.79	1225.45	1	08:03
0 0						
(1M) 016	JUNCTION	0.46	0.78	1226.62	1	08:02
0 0						
(1M) 017	JUNCTION	0.44	0.74	1226.71	1	08:02
0 0						
(1M) 018	JUNCTION	0.45	0.77	1227.26	1	08:01
0 0						
(1M) 019	JUNCTION	0.45	0.77	1228.07	1	08:00
0 0						
(1M) 021	JUNCTION	0.42	0.48	1229.59	0	19:18
0 0						
(1M) 022	JUNCTION	0.41	0.47	1230.22	0	19:17
0 0						
(1M) 023	JUNCTION	0.42	0.48	1230.88	0	19:16
0 0						
(1M) 024	JUNCTION	0.42	0.48	1232.28	0	19:14
0 0						
(1M) 025	JUNCTION	0.41	0.47	1233.17	0	19:13
0 0						
(1M) 026	JUNCTION	0.41	0.48	1233.99	0	19:11
0 0						
(1M) 027	JUNCTION	0.41	0.48	1235.34	0	19:09
0 0						
(1M) 028	JUNCTION	0.41	0.47	1236.32	0	07:06
0 0						
(1M) 035	JUNCTION	0.18	0.24	1219.66	1	07:59
0 0						
(1M) 036	JUNCTION	0.18	0.24	1220.11	1	08:00
0 0						
(1M) 037	JUNCTION	0.18	0.24	1220.69	1	07:59

0	0						
	(1M) 038	JUNCTION	0.22	0.29	1221.29	1	08:00
0	0						
	(1M) 039	JUNCTION	0.34	0.68	1223.05	1	13:27
0	0						
	(1M) 040	JUNCTION	0.36	0.77	1223.79	1	13:23
0	0						
	(1M) 041	JUNCTION	1.19	9.25	1233.29	1	05:12
0	496						
	(1M) 092	JUNCTION	1.11	8.65	1233.72	1	05:11
0	490						
	(1M) 093	JUNCTION	0.32	0.77	1226.00	1	13:23
0	0						
	(1M) 094	JUNCTION	1.25	10.50	1237.25	1	05:06
0	485						
	(1M) 116	JUNCTION	0.21	0.60	1227.54	1	10:48
0	0						
	(1M) 117	JUNCTION	0.24	0.74	1227.91	1	10:47
0	0						
	(1M) 118	JUNCTION	0.25	0.83	1228.59	1	05:15
0	0						
	(1M) 119	JUNCTION	0.25	0.83	1229.75	1	05:10
0	0						
	(1M) 120	JUNCTION	0.24	0.76	1229.86	1	10:43
0	0						
	(1M) 121	JUNCTION	0.58	5.80	1236.02	1	05:07
0	336						
	(1M) 122	JUNCTION	0.90	10.87	1241.70	1	05:07
0	328						
	(1M) 123	JUNCTION	0.20	0.27	1232.00	1	07:59
0	0						
	(1M) 124	JUNCTION	0.09	0.17	1233.10	0	08:04
0	0						
	(1M) 125	JUNCTION	0.08	0.17	1233.77	1	08:02
0	0						
	(1M) 126	JUNCTION	0.09	0.17	1234.36	0	08:01
0	0						
	(1M) 127	JUNCTION	0.09	0.17	1235.68	1	08:00
0	0						
	(1M) 128	JUNCTION	0.08	0.17	1236.36	0	08:09
0	0						
	(1M) 129	JUNCTION	0.06	0.15	1237.27	0	20:29
0	0						
	(1M) 130	JUNCTION	0.11	0.14	1237.49	0	08:00
0	0						
	(1M) 131	JUNCTION	0.11	0.14	1238.02	0	20:31
0	0						
	(1M) 132	JUNCTION	0.10	0.12	1239.06	0	20:25
0	0						
	(1M) 133	JUNCTION	0.08	0.10	1240.04	0	07:00
0	0						
	(1M) 161	JUNCTION	0.12	0.61	1236.61	1	06:03
0	0						
	(1M) 162	JUNCTION	1.55	12.50	1250.27	1	05:03
0	606						
	(1M) 163	JUNCTION	0.13	17.79	1257.35	1	14:59
0	1						
	(1M) 164	JUNCTION	0.12	0.67	1242.03	1	05:11
0	0						
	(1M) 165	JUNCTION	1.84	15.81	1259.00	1	05:09
0	571						

0	(1M) 278	JUNCTION	0.68	1.47	1218.50	1	07:56
0	0						
0	(1M) 279	JUNCTION	0.67	1.45	1218.95	1	07:56
0	0						
0	(1M) 279B	JUNCTION	0.65	1.40	1219.34	1	07:56
0	0						
0	(1M) 281	JUNCTION	0.69	2.00	1220.99	1	07:57
0	0						
0	(1M) 281B	JUNCTION	1.31	18.35	1238.00	1	05:41
0	136						
0	(1M) 282	JUNCTION	1.71	18.35	1238.50	1	05:46
0	256						
0	(1M) 283	JUNCTION	0.66	2.00	1222.70	1	05:57
0	0						
0	(1M) 284	JUNCTION	0.48	24.03	1252.50	1	08:17
0	3						
0	(1M) 285	JUNCTION	0.46	2.00	1231.45	1	05:44
0	0						
0	(1M) 285A	JUNCTION	0.47	2.00	1231.86	1	05:43
0	0						
0	(1M) 286	JUNCTION	1.21	27.12	1257.50	1	05:43
0	149						
0	(1M) 286A	JUNCTION	1.17	28.15	1259.20	1	05:44
0	139						
0	(1M) 287	JUNCTION	0.38	0.65	1232.37	1	08:14
0	0						
0	(1M) 288	JUNCTION	0.38	0.65	1233.12	1	08:12
0	0						
0	(1M) 288A	JUNCTION	0.38	0.65	1233.67	1	08:12
0	0						
0	(1M) 288B	JUNCTION	0.40	0.68	1234.34	1	08:11
0	0						
0	(1M) 288C	JUNCTION	0.40	0.69	1234.90	1	08:10
0	0						
0	(1N) 004	JUNCTION	1.16	17.39	1238.60	1	05:58
0	165						
0	(1N) 005	JUNCTION	1.02	13.00	1235.11	1	05:52
0	166						
0	(1N) 006	JUNCTION	1.28	22.14	1245.30	1	05:56
0	159						
0	(1N) 007	JUNCTION	1.15	17.91	1242.10	1	05:52
0	161						
0	(1N) 007D	JUNCTION	0.38	0.63	1225.10	1	17:13
0	0						
0	(1N) 007E	JUNCTION	0.45	0.83	1225.55	1	14:07
0	0						
0	(1N) 008	JUNCTION	0.93	5.42	1231.19	1	05:13
0	523						
0	(1N) 009	JUNCTION	0.45	0.83	1227.13	1	05:09
0	0						
0	(1N) 011	JUNCTION	0.72	3.44	1230.87	1	05:08
0	526						
0	(1N) 013	JUNCTION	0.86	4.85	1233.45	1	05:04
0	524						
0	(1N) 014	JUNCTION	0.99	6.75	1236.52	1	05:18
0	477						
0	(1N) 015	JUNCTION	0.42	0.83	1231.15	1	05:17
0	0						
0	(1N) 016	JUNCTION	0.42	6.54	1237.76	1	13:02
0	3						
0	(1N) 017	JUNCTION	1.09	8.00	1240.30	1	05:12

0	473						
	(1N)018	JUNCTION	1.16	9.13	1242.01	1	05:13
0	459						
	(1N)019	JUNCTION	1.11	8.92	1242.36	1	05:10
0	463						
	(1N)020	JUNCTION	0.35	0.83	1235.34	1	05:11
0	0						
	(1N)021	JUNCTION	1.17	10.21	1245.79	1	05:09
0	443						
	(1N)022	JUNCTION	1.26	11.25	1247.89	1	05:04
0	447						
	(1N)023	JUNCTION	0.33	0.83	1238.56	1	05:16
0	0						
	(1N)024	JUNCTION	0.33	0.83	1239.61	1	05:13
0	0						
	(1N)025	JUNCTION	1.03	10.79	1250.97	1	05:11
0	356						
	(1N)045	JUNCTION	0.42	0.76	1228.72	1	17:11
0	0						
	(1N)046	JUNCTION	0.44	0.83	1230.38	1	05:00
0	0						
	(1N)047	JUNCTION	2.81	17.50	1248.18	1	04:58
0	715						
	(1N)109A	JUNCTION	0.48	20.24	1245.30	1	08:15
0	3						
	(1N)110	JUNCTION	0.46	2.00	1227.92	1	08:17
0	0						
	(1N)111A	JUNCTION	0.47	22.42	1249.20	1	08:14
0	3						
	(1N)112A	JUNCTION	0.45	2.00	1229.62	1	05:51
0	0						
	(1N)112B	JUNCTION	0.46	2.00	1230.10	1	08:19
0	0						
	(1O)001	JUNCTION	0.40	0.46	1236.70	0	07:05
0	0						
	(1O)001A	JUNCTION	0.40	0.46	1237.51	0	07:04
0	0						
	(1O)002	JUNCTION	0.32	0.37	1237.57	0	07:04
0	0						
	(1O)002A	JUNCTION	0.39	0.45	1237.79	0	07:04
0	0						
	(1O)003	JUNCTION	0.39	0.45	1238.45	0	07:03
0	0						
	(1O)004	JUNCTION	0.39	0.45	1239.00	0	07:02
0	0						
	(1O)005A	JUNCTION	0.39	0.44	1239.73	0	07:02
0	0						
	(1O)005B	JUNCTION	0.32	0.36	1239.84	2	18:13
0	0						
	(1O)005C	JUNCTION	0.31	0.35	1240.01	2	18:13
0	0						
	(1O)005D	JUNCTION	0.74	1.00	1240.82	0	07:02
0	0						
	(1O)005E	JUNCTION	0.00	0.00	1239.83	0	00:00
0	0						
	(1O)010	JUNCTION	0.00	0.00	1251.71	0	00:00
0	0						
	(1O)011	JUNCTION	0.00	0.00	1251.77	0	00:00
0	0						
	(1O)012	JUNCTION	0.00	0.00	1252.51	0	00:00
0	0						

0	(10) 013	JUNCTION	0.00	0.00	1253.50	0	00:00
0	0						
0	(10) 014	JUNCTION	0.00	0.00	1253.87	0	00:00
0	0						
0	(10) 015	JUNCTION	0.00	0.00	1255.16	0	00:00
0	0						
0	(10) 016	JUNCTION	0.00	0.00	1256.10	0	00:00
0	0						
0	(10) 017	JUNCTION	0.00	0.00	1257.34	0	00:00
0	0						
0	(10) 018	JUNCTION	0.00	0.00	1258.62	0	00:00
0	0						
0	(10) 019	JUNCTION	0.00	0.00	1260.25	0	00:00
0	0						
0	(10) 020	JUNCTION	0.00	0.00	1261.74	0	00:00
0	0						
0	(10) 021	JUNCTION	0.00	0.00	1262.57	0	00:00
0	0						
0	(10) 072	JUNCTION	0.36	0.94	1239.10	1	08:03
0	0						
0	(10) 157	JUNCTION	0.75	14.03	1265.80	1	05:38
0	178						
0	(10) 300	JUNCTION	0.38	0.68	1235.52	1	08:10
0	0						
0	(10) 301	JUNCTION	0.38	0.71	1236.33	1	08:06
0	0						
0	(10) 302	JUNCTION	0.38	0.70	1237.15	1	08:05
0	0						
0	(10) 303	JUNCTION	0.37	0.81	1238.12	1	08:03
0	0						
0	(10) 304A	JUNCTION	0.15	0.58	1250.27	1	08:29
0	0						
0	(10) 304B	JUNCTION	2.02	20.00	1260.00	1	05:10
0	424						
0	(10) 305	JUNCTION	2.37	12.65	1261.20	1	05:05
0	693						
0	(10) 305A	JUNCTION	0.88	1.83	1250.33	1	17:02
0	0						
0	(10) 306	JUNCTION	0.49	12.61	1262.00	1	10:05
0	1						
0	(10) 306A	JUNCTION	0.48	2.00	1252.23	1	05:28
0	0						
0	(10) 307	JUNCTION	0.48	2.00	1252.66	1	05:27
0	0						
0	(10) 308	JUNCTION	1.11	13.96	1265.13	1	05:28
0	267						
0	(10) 308A	JUNCTION	0.33	2.00	1253.31	1	05:38
0	0						
0	(10) 309	JUNCTION	0.61	13.14	1264.72	1	05:38
0	137						
0	(1P) 002	JUNCTION	0.55	1.00	1131.00	1	05:10
0	0						
0	(1P) 003	JUNCTION	1.61	12.25	1142.67	1	05:11
0	412						
0	(1P) 004	JUNCTION	3.23	12.50	1144.38	0	07:17
0	1106						
0	(1P) 005	JUNCTION	0.66	0.96	1135.46	0	08:05
0	0						
0	(1P) 006	JUNCTION	3.06	12.78	1149.40	0	07:17
0	1021						
0	(1P) 007	JUNCTION	0.64	1.00	1141.56	0	08:00

0	0						
	(1P)008	JUNCTION	2.04	14.00	1157.00	1	05:03
0	537						
	(1P)008A	JUNCTION	0.40	1.00	1144.50	1	11:18
0	0						
	(1P)009	JUNCTION	1.27	11.67	1158.43	1	05:13
0	365						
	(1P)010	JUNCTION	0.45	0.61	1147.66	0	08:07
0	0						
	(1P)011	JUNCTION	0.44	0.59	1150.01	0	08:06
0	0						
	(1P)012	JUNCTION	0.44	0.60	1152.41	0	08:04
0	0						
	(1P)013	JUNCTION	0.44	0.60	1154.78	0	08:03
0	0						
	(1P)014	JUNCTION	0.44	0.60	1157.14	0	08:02
0	0						
	(1P)015	JUNCTION	0.47	0.66	1159.57	0	08:01
0	0						
	(1P)016	JUNCTION	0.47	0.66	1161.37	0	08:01
0	0						
	(1P)016A	JUNCTION	0.47	0.66	1162.21	0	08:00
0	0						
	(1P)017	JUNCTION	0.47	0.69	1162.57	0	08:00
0	0						
	(1P)018	JUNCTION	0.45	0.60	1164.37	0	07:00
0	0						
	(1P)024	JUNCTION	0.12	0.15	1164.24	0	07:00
0	0						
	(1P)042	JUNCTION	0.21	0.78	1134.06	1	12:01
0	0						
	(1P)042A	JUNCTION	1.13	12.37	1147.09	1	05:10
0	402						
	(1P)043	JUNCTION	1.26	13.92	1150.08	1	05:04
0	404						
	(1P)044	JUNCTION	0.00	0.00	1136.52	0	00:00
0	0						
	(1P)065	JUNCTION	0.06	0.08	1137.32	0	07:00
0	0						
	(1P)073	JUNCTION	0.04	0.05	1164.31	0	07:00
0	0						
	(1P)079	JUNCTION	0.04	0.05	1162.62	0	07:00
0	0						
	(2A)001	JUNCTION	1.23	12.25	1159.10	1	06:03
0	185						
	(2A)002	JUNCTION	0.59	1.72	1150.37	1	08:50
0	0						
	(2A)003	JUNCTION	0.62	1.81	1151.58	1	08:50
0	0						
	(2A)004	JUNCTION	0.62	1.82	1152.81	1	08:51
0	0						
	(2A)005	JUNCTION	0.80	3.00	1155.28	1	08:51
0	0						
	(2A)006	JUNCTION	1.28	15.99	1168.80	1	06:01
0	180						
	(2A)007	JUNCTION	0.78	3.00	1156.44	1	08:51
0	0						
	(2A)008	JUNCTION	0.80	3.00	1156.93	1	05:54
0	0						
	(2A)009	JUNCTION	0.80	3.00	1157.63	1	05:51
0	0						

0	(2A) 010	JUNCTION	0.81	3.00	1158.34	1	05:48
0	0						
0	(2A) 011	JUNCTION	0.81	10.55	1166.60	1	08:47
0	2						
0	(2A) 012	JUNCTION	0.81	3.00	1159.66	1	05:43
0	0						
0	(2A) 013	JUNCTION	0.98	7.69	1164.95	1	05:41
0	180						
0	(2A) 014	JUNCTION	0.77	6.06	1164.00	1	05:44
0	34						
0	(2A) 015	JUNCTION	0.77	3.00	1161.17	1	05:43
0	0						
0	(2A) 016	JUNCTION	1.02	10.51	1169.00	1	05:42
0	167						
0	(2A) 017	JUNCTION	1.01	10.93	1170.05	1	05:42
0	160						
0	(2A) 018	JUNCTION	0.76	3.00	1162.49	1	05:46
0	0						
0	(2A) 019	JUNCTION	0.75	2.74	1162.59	1	08:16
0	0						
0	(2A) 020	JUNCTION	1.05	13.01	1173.70	1	05:45
0	146						
0	(2A) 021	JUNCTION	0.52	1.07	1163.54	1	07:26
0	0						
0	(2A) 022	JUNCTION	0.51	1.05	1165.40	1	07:24
0	0						
0	(2A) 023	JUNCTION	0.51	1.04	1166.31	1	07:24
0	0						
0	(2A) 024	JUNCTION	0.49	1.01	1166.75	1	07:24
0	0						
0	(2A) 025	JUNCTION	0.48	1.00	1167.00	1	07:23
0	0						
0	(2A) 026	JUNCTION	0.63	1.33	1167.72	1	07:23
0	0						
0	(2A) 027	JUNCTION	0.69	1.45	1168.54	1	07:22
0	0						
0	(2A) 028	JUNCTION	0.69	1.46	1168.91	1	07:21
0	0						
0	(2A) 029	JUNCTION	0.66	1.38	1169.18	1	07:20
0	0						
0	(2A) 030	JUNCTION	0.63	1.31	1169.51	1	07:19
0	0						
0	(2A) 031	JUNCTION	0.66	1.40	1170.91	1	07:18
0	0						
0	(2A) 032	JUNCTION	0.66	1.40	1171.09	1	07:17
0	0						
0	(2A) 033	JUNCTION	0.61	1.27	1171.33	1	07:17
0	0						
0	(2A) 034	JUNCTION	0.54	1.12	1171.41	1	07:16
0	0						
0	(2A) 035	JUNCTION	0.54	1.12	1173.15	1	07:15
0	0						
0	(2A) 036	JUNCTION	0.56	1.16	1174.93	1	07:14
0	0						
0	(2A) 037	JUNCTION	0.56	1.17	1176.67	1	07:12
0	0						
0	(2A) 038	JUNCTION	0.54	1.12	1178.36	1	07:11
0	0						
0	(2A) 039	JUNCTION	0.55	1.13	1179.92	1	07:10
0	0						
0	(2A) 040	JUNCTION	0.55	1.13	1181.35	1	07:09

0	0						
	(2A) 041	JUNCTION	0.54	1.12	1183.07	1	07:07
0	0						
	(2A) 042	JUNCTION	0.54	1.12	1184.67	1	07:06
0	0						
	(2A) 043	JUNCTION	0.55	1.13	1186.51	1	07:05
0	0						
	(2A) 044	JUNCTION	0.56	1.15	1187.85	1	07:04
0	0						
	(2A) 045	JUNCTION	0.57	1.17	1189.07	1	07:03
0	0						
	(2A) 046	JUNCTION	0.67	1.41	1190.81	1	07:02
0	0						
	(2A) 047	JUNCTION	0.68	1.42	1191.42	1	07:00
0	0						
	(2A) 049	JUNCTION	1.03	1.69	1193.16	1	07:15
0	0						
	(2A) 050	JUNCTION	1.03	1.69	1193.98	1	07:13
0	0						
	(2A) 051	JUNCTION	0.81	1.30	1194.99	1	07:12
0	0						
	(2A) 052	JUNCTION	0.82	1.30	1196.39	1	07:11
0	0						
	(2A) 053	JUNCTION	0.81	1.28	1197.42	1	07:10
0	0						
	(2A) 054	JUNCTION	1.01	1.65	1200.84	1	07:09
0	0						
	(2A) 055	JUNCTION	1.02	1.66	1201.51	1	07:08
0	0						
	(2A) 056	JUNCTION	1.02	1.66	1202.33	1	07:07
0	0						
	(2A) 057	JUNCTION	0.90	1.44	1203.44	1	07:05
0	0						
	(2A) 058	JUNCTION	0.94	1.55	1204.65	1	07:03
0	0						
	(2A) 059	JUNCTION	0.94	1.55	1205.77	1	07:02
0	0						
	(2A) 060	JUNCTION	0.86	1.38	1207.12	1	07:01
0	0						
	(2A) 061	JUNCTION	0.86	1.38	1208.35	1	07:00
0	0						
	(2A) 062	JUNCTION	1.13	1.50	1210.76	1	10:20
0	0						
	(2A) 063	JUNCTION	1.09	7.36	1219.37	1	05:41
0	279						
	(2A) 064	JUNCTION	0.76	1.65	1215.58	1	07:00
0	0						
	(2A) 065	JUNCTION	0.76	1.31	1217.18	1	09:00
0	0						
	(2A) 066	JUNCTION	0.73	1.26	1226.27	1	08:59
0	0						
	(2A) 067	JUNCTION	0.75	1.29	1227.08	1	08:59
0	0						
	(2A) 068	JUNCTION	1.12	2.28	1229.30	1	06:44
0	0						
	(2A) 069	JUNCTION	0.45	0.92	1206.74	1	09:51
0	0						
	(2C) 001	JUNCTION	1.19	13.90	1220.00	1	05:06
0	288						
	(2C) 002	JUNCTION	1.18	13.60	1220.00	1	05:02
0	289						

(2C)003	JUNCTION	0.95	10.94	1218.00	1	05:02
0 268						
(2C)004	JUNCTION	0.41	1.00	1208.78	1	05:22
0 0						
(2C)005	JUNCTION	0.42	1.00	1209.49	1	08:43
0 0						
(2C)006	JUNCTION	0.62	5.79	1214.81	1	05:17
0 210						
(2C)007	JUNCTION	0.41	5.21	1214.71	1	08:38
0 2						
(2C)008	JUNCTION	0.41	1.00	1210.91	1	05:13
0 0						
(2D)001	JUNCTION	0.54	1.00	1212.09	1	05:33
0 0						
(2D)001A	JUNCTION	0.84	5.83	1217.28	1	05:33
0 305						
(2D)002	JUNCTION	0.46	7.00	1220.00	1	06:55
0 71						
(2D)003	JUNCTION	0.47	8.17	1222.87	1	06:55
0 66						
(2D)004	JUNCTION	0.29	0.44	1216.71	1	08:01
0 0						
(2D)005	JUNCTION	0.28	0.42	1218.28	1	08:00
0 0						
(2D)006	JUNCTION	0.29	0.43	1219.92	1	08:02
0 0						
(2D)007	JUNCTION	0.30	0.45	1221.80	1	08:00
0 0						
(2D)008	JUNCTION	0.30	0.45	1222.79	1	08:00
0 0						
(2D)009	JUNCTION	0.35	0.66	1225.70	1	17:04
0 0						
(2D)010	JUNCTION	3.26	20.56	1246.00	1	04:52
0 735						
(2D)011	JUNCTION	2.97	19.88	1246.00	1	04:52
0 688						
(2D)012	JUNCTION	0.24	0.34	1228.30	0	08:00
0 0						
(2D)013	JUNCTION	0.24	0.32	1229.47	0	07:00
0 0						
(2D)014	JUNCTION	0.00	0.00	1229.96	0	00:00
0 0						
(2D)015	JUNCTION	0.00	0.00	1240.96	0	00:00
0 0						
(2D)016	JUNCTION	0.00	0.00	1243.40	0	00:00
0 0						
(2D)017	JUNCTION	0.00	0.00	1245.11	0	00:00
0 0						
(2D)018	JUNCTION	0.00	0.00	1245.82	0	00:00
0 0						
(2D)019	JUNCTION	0.00	0.00	1246.10	0	00:00
0 0						
(2D)020	JUNCTION	0.00	0.00	1246.74	0	00:00
0 0						
(2D)021	JUNCTION	0.00	0.00	1248.58	0	00:00
0 0						
(2D)022	JUNCTION	0.00	0.00	1249.58	0	00:00
0 0						
(2D)023	JUNCTION	0.00	0.00	1249.81	0	00:00
0 0						
(2D)024	JUNCTION	0.00	0.00	1251.25	0	00:00

0	0						
0	(2D) 025	JUNCTION	0.00	0.00	1251.56	0	00:00
0	0						
0	(2D) 039	JUNCTION	0.19	0.30	1216.36	1	06:52
0	0						
0	(2D) 040	JUNCTION	2.59	21.42	1239.06	1	05:08
0	529						
0	(2D) 041	JUNCTION	0.33	0.83	1220.07	1	07:04
0	0						
0	(2D) 042	JUNCTION	0.35	24.71	1245.45	1	08:08
0	2						
0	(2D) 043	JUNCTION	0.33	0.83	1223.37	1	07:04
0	0						
0	(2D) 044	JUNCTION	0.33	0.83	1225.17	1	07:04
0	0						
0	(2D) 045	JUNCTION	0.35	0.76	1226.90	1	05:37
0	0						
0	(2D) 045A	JUNCTION	1.90	18.00	1244.86	1	05:01
0	456						
0	(2D) 046	JUNCTION	0.34	0.83	1228.59	1	05:08
0	0						
0	(2D) 046A	JUNCTION	108.36	1305.00	2533.58	1	05:06
0	418						
0	(2D) 241	JUNCTION	0.36	1.09	1214.96	1	07:13
0	0						
0	(2D) 242	JUNCTION	0.36	1.08	1215.99	1	07:12
0	0						
0	(2D) 243	JUNCTION	0.36	1.08	1216.91	1	07:10
0	0						
0	(2D) 245	JUNCTION	0.43	19.50	1237.00	1	06:51
0	20						
0	(2D) 246	JUNCTION	0.30	1.15	1219.42	1	07:05
0	0						
0	(2D) 247	JUNCTION	0.31	1.15	1220.20	1	07:03
0	0						
0	(2D) 248	JUNCTION	0.31	1.16	1221.03	1	07:02
0	0						
0	(2D) 249	JUNCTION	0.31	1.17	1221.90	1	07:01
0	0						
0	(2D) 250	JUNCTION	0.30	1.15	1222.37	1	07:00
0	0						
0	(2D) 251	JUNCTION	0.34	1.15	1223.07	1	07:00
0	0						
0	(2D) 252	JUNCTION	0.32	0.42	1223.43	1	08:13
0	0						
0	(2D) 253	JUNCTION	0.28	0.36	1223.85	1	08:12
0	0						
0	(2D) 254	JUNCTION	0.28	0.36	1224.79	1	08:11
0	0						
0	(2D) 255	JUNCTION	0.28	0.36	1225.67	1	08:08
0	0						
0	(2D) 256	JUNCTION	0.28	0.36	1226.44	1	08:07
0	0						
0	(2D) 257	JUNCTION	0.28	0.36	1227.08	1	08:06
0	0						
0	(2D) 258	JUNCTION	0.28	0.36	1227.76	1	08:05
0	0						
0	(2D) 259	JUNCTION	0.28	0.36	1228.48	1	08:04
0	0						
0	(2D) 260	JUNCTION	0.28	0.36	1229.11	1	08:03
0	0						

0	(2D) 261	JUNCTION	0.28	0.36	1229.82	1	08:02
0	0						
0	(2D) 262	JUNCTION	0.28	0.36	1230.97	1	08:00
0	0						
0	(2D) 263	JUNCTION	0.28	0.36	1232.00	0	08:04
0	0						
0	(2D) 264	JUNCTION	0.28	0.38	1232.94	0	08:02
0	0						
0	(2D) 265	JUNCTION	0.28	0.38	1233.69	0	08:01
0	0						
0	(2D) 266	JUNCTION	0.28	0.40	1234.61	0	08:00
0	0						
0	(2D) 267	JUNCTION	0.28	0.37	1235.55	0	07:00
0	0						
0	(2E) 001	JUNCTION	1.79	19.08	1246.54	1	05:39
0	201						
0	(2E) 002	JUNCTION	1.63	22.41	1250.66	1	05:39
0	161						
0	(2E) 003	JUNCTION	1.25	15.41	1244.63	1	05:51
0	101						
0	(2E) 004	JUNCTION	1.33	2.26	1231.84	1	14:56
0	0						
0	(2E) 005	JUNCTION	1.38	2.50	1232.22	1	05:46
0	0						
0	(2E) 006	JUNCTION	3.04	18.50	1248.46	1	05:42
0	522						
0	(2E) 007	JUNCTION	1.02	2.50	1233.16	1	05:54
0	0						
0	(2E) 008	JUNCTION	0.92	1.84	1233.21	1	09:51
0	0						
0	(2E) 009	JUNCTION	1.02	2.29	1234.37	1	09:50
0	0						
0	(2E) 010	JUNCTION	1.04	2.50	1235.29	1	05:46
0	0						
0	(2E) 011	JUNCTION	1.04	2.50	1235.85	1	05:43
0	0						
0	(2E) 012	JUNCTION	1.06	2.50	1236.40	1	05:41
0	0						
0	(2E) 013	JUNCTION	1.82	20.25	1254.87	1	05:42
0	215						
0	(2E) 014	JUNCTION	12.43	20.87	1255.99	1	05:36
0	221						
0	(2E) 043	JUNCTION	0.21	0.27	1247.78	0	07:00
0	0						
0	(2F) 001	JUNCTION	1.49	22.25	1258.02	1	05:53
0	117						
0	(2F) 002	JUNCTION	1.03	22.48	1258.90	1	08:03
0	1						
0	(2F) 003	JUNCTION	1.03	2.50	1239.57	1	05:36
0	0						
0	(2F) 004	JUNCTION	1.46	19.02	1256.40	1	05:36
0	132						
0	(2F) 005	JUNCTION	0.99	1.80	1239.53	1	07:00
0	0						
0	(2F) 006	JUNCTION	0.96	1.77	1239.64	1	12:20
0	0						
0	(2F) 007	JUNCTION	0.99	1.84	1240.15	1	12:19
0	0						
0	(2F) 008	JUNCTION	1.02	2.25	1240.73	1	12:20
0	0						
0	(2F) 009	JUNCTION	2.26	17.45	1256.00	1	05:32

0	408						
	(2F) 010	JUNCTION	1.16	17.58	1257.00	1	05:41
0	165						
	(2F) 011	JUNCTION	1.11	16.28	1256.00	1	05:36
0	159						
	(2F) 012	JUNCTION	0.65	1.07	1241.89	1	08:07
0	0						
	(2F) 013	JUNCTION	0.65	1.07	1242.82	1	08:04
0	0						
	(2F) 014	JUNCTION	0.65	1.06	1243.74	1	08:03
0	0						
	(2F) 015	JUNCTION	0.65	1.07	1244.68	1	08:01
0	0						
	(2F) 016	JUNCTION	0.65	1.07	1245.61	1	08:00
0	0						
	(2F) 017	JUNCTION	0.66	1.07	1246.54	1	07:00
0	0						
	(2F) 018	JUNCTION	0.65	1.05	1247.45	1	08:43
0	0						
	(2F) 019	JUNCTION	0.65	1.07	1248.40	1	08:37
0	0						
	(2F) 020	JUNCTION	0.65	1.07	1249.33	1	08:37
0	0						
	(2F) 021	JUNCTION	0.65	1.06	1250.25	1	08:36
0	0						
	(2F) 022	JUNCTION	0.67	1.00	1251.52	2	08:15
0	0						
	(2F) 023	JUNCTION	1.11	22.17	1272.74	1	05:14
0	203						
	(2F) 024	JUNCTION	0.41	1.00	1252.93	1	11:23
0	0						
	(2F) 025	JUNCTION	1.80	19.94	1272.00	1	05:03
0	368						
	(2F) 026	JUNCTION	0.34	0.45	1252.66	0	21:46
0	0						
	(2F) 027	JUNCTION	0.34	0.46	1252.78	0	21:36
0	0						
	(2F) 028	JUNCTION	0.34	0.46	1252.92	0	21:29
0	0						
	(2F) 029	JUNCTION	0.34	0.46	1253.06	0	08:21
0	0						
	(2F) 030	JUNCTION	0.34	0.47	1253.18	1	08:00
0	0						
	(2F) 031	JUNCTION	0.34	0.48	1253.32	1	08:05
0	0						
	(2F) 032	JUNCTION	0.34	0.51	1253.49	1	08:00
0	0						
	(2F) 033	JUNCTION	0.34	0.45	1253.52	0	07:00
0	0						
	(2G) 001	JUNCTION	0.71	1.00	1253.28	0	07:33
0	0						
	(2G) 002	JUNCTION	4.70	16.58	1269.58	0	07:47
0	1288						
	(2G) 002A	JUNCTION	3.96	17.21	1270.70	1	05:02
0	1016						
	(2G) 003	JUNCTION	0.51	0.72	1254.53	1	08:00
0	0						
	(2G) 004	JUNCTION	0.50	0.71	1256.13	1	07:01
0	0						
	(2G) 005	JUNCTION	0.48	0.78	1257.82	1	08:01
0	0						

0	(2G) 006	JUNCTION	0.47	0.83	1260.40	1	07:01
0	0						
0	(2G) 007	JUNCTION	0.50	0.83	1261.20	1	07:00
0	0						
0	(2G) 008	JUNCTION	1.57	10.46	1270.94	1	05:02
0	556						
0	(2G) 009	JUNCTION	1.28	10.12	1271.47	1	05:04
0	445						
0	(2G) 010	JUNCTION	0.42	0.53	1262.43	3	07:25
0	0						
0	(2G) 011	JUNCTION	0.54	0.77	1263.80	2	08:01
0	0						
0	(2G) 012	JUNCTION	0.56	0.83	1264.65	0	07:12
0	0						
0	(2G) 012A	JUNCTION	0.40	0.48	1264.76	0	19:16
0	0						
0	(2G) 013	JUNCTION	0.38	0.47	1265.57	0	19:16
0	0						
0	(2G) 013A	JUNCTION	0.36	0.44	1266.07	2	21:19
0	0						
0	(2G) 014	JUNCTION	0.59	0.83	1268.78	0	07:06
0	0						
0	(2G) 015	JUNCTION	3.03	9.29	1277.29	0	07:10
0	1447						
0	(2G) 016	JUNCTION	2.46	12.58	1281.20	1	04:59
0	815						
0	(2G) 016A	JUNCTION	1.95	13.25	1282.02	1	04:59
0	598						
0	(2G) 018	JUNCTION	1.77	12.46	1281.68	1	05:00
0	566						
0	(2G) 019	JUNCTION	1.37	9.15	1278.87	1	04:55
0	563						
0	(2G) 020	JUNCTION	1.09	9.42	1279.97	1	05:08
0	410						
0	(2G) 021	JUNCTION	1.15	10.46	1281.64	1	05:08
0	398						
0	(2G) 022	JUNCTION	1.03	8.83	1280.71	1	05:02
0	404						
0	(2G) 023	JUNCTION	0.97	8.17	1280.65	1	05:00
0	405						
0	(2G) 024	JUNCTION	0.87	6.87	1279.74	1	04:55
0	410						
0	(2G) 025	JUNCTION	0.74	7.08	1280.51	1	05:01
0	348						
0	(2G) 026	JUNCTION	0.42	5.62	1282.15	1	05:12
0	248						
0	(2G) 040	JUNCTION	1.89	16.00	1271.99	1	05:08
0	453						
0	(2G) 041	JUNCTION	0.50	0.71	1256.95	0	08:13
0	0						
0	(2G) 042	JUNCTION	0.50	0.71	1257.21	1	08:08
0	0						
0	(2G) 043	JUNCTION	0.50	0.71	1257.45	0	08:04
0	0						
0	(2G) 043A	JUNCTION	0.50	0.73	1257.61	1	08:02
0	0						
0	(2G) 044	JUNCTION	0.50	0.78	1257.82	1	08:00
0	0						
0	(2G) 045	JUNCTION	0.50	0.68	1257.87	0	07:00
0	0						
0	(2G) 359	JUNCTION	0.66	6.67	1280.89	1	05:00

0	317						
	(2H)001	JUNCTION	0.53	1.64	1250.54	1	11:00
0	0						
	(2H)002	JUNCTION	0.55	1.75	1251.34	1	05:23
0	0						
	(2H)003	JUNCTION	1.81	21.68	1272.00	1	05:25
0	320						
	(2H)005	JUNCTION	0.55	1.75	1252.80	1	05:16
0	0						
	(2H)006	JUNCTION	1.62	18.34	1270.00	1	05:14
0	327						
	(2H)007	JUNCTION	1.44	16.73	1269.00	1	05:14
0	309						
	(2H)008	JUNCTION	0.43	1.27	1254.76	1	09:44
0	0						
	(2H)009	JUNCTION	0.44	1.30	1254.89	1	09:44
0	0						
	(2H)010	JUNCTION	0.44	1.30	1255.00	1	09:44
0	0						
	(2H)011	JUNCTION	0.49	1.60	1257.12	1	05:53
0	0						
	(2H)012	JUNCTION	1.15	13.83	1270.00	1	05:13
0	272						
	(2H)013	JUNCTION	0.77	16.91	1274.00	1	05:32
0	104						
	(2H)014	JUNCTION	0.41	0.95	1258.68	1	08:01
0	0						
	(2H)015	JUNCTION	0.49	1.23	1259.69	1	08:00
0	0						
	(2H)016	JUNCTION	0.49	1.23	1260.23	1	07:56
0	0						
	(2H)017	JUNCTION	0.41	0.96	1260.52	1	08:00
0	0						
	(2H)017A	JUNCTION	0.42	0.99	1261.39	1	08:00
0	0						
	(2H)018	JUNCTION	0.42	0.99	1261.69	1	08:00
0	0						
	(2H)019	JUNCTION	0.42	1.00	1262.30	1	07:54
0	0						
	(2H)020	JUNCTION	0.42	1.00	1262.40	1	07:53
0	0						
	(2H)021	JUNCTION	0.40	0.93	1263.47	1	07:50
0	0						
	(2H)022	JUNCTION	0.29	0.66	1265.88	1	10:06
0	0						
	(2H)023	JUNCTION	0.30	0.70	1266.19	1	10:06
0	0						
	(2H)024	JUNCTION	0.42	1.22	1269.40	1	10:15
0	0						
	(2H)025	JUNCTION	0.90	9.26	1278.00	1	05:09
0	299						
	(2H)026	JUNCTION	0.25	0.54	1265.48	1	08:03
0	0						
	(2H)027	JUNCTION	0.25	0.54	1266.66	1	08:02
0	0						
	(2H)028	JUNCTION	0.24	0.54	1267.82	1	08:01
0	0						
	(2H)029	JUNCTION	0.26	0.58	1269.06	1	08:00
0	0						
	(2H)030	JUNCTION	0.34	0.94	1270.34	1	11:53
0	0						

0	(2H) 031 381	JUNCTION	0.82	7.20	1276.84	1	05:22
0	(2H) 032 179	JUNCTION	0.55	7.73	1277.46	1	05:26
0	(2H) 033 0	JUNCTION	0.23	0.72	1271.53	1	06:30
0	(2H) 034 0	JUNCTION	0.23	0.53	1272.36	1	08:00
0	(2H) 036 0	JUNCTION	0.23	0.52	1273.34	1	07:00
0	(2H) 037 0	JUNCTION	0.22	0.52	1274.54	1	11:33
0	(2H) 038 0	JUNCTION	0.22	0.52	1275.74	1	11:32
0	(2H) 039 0	JUNCTION	0.25	0.60	1277.24	1	11:31
0	(2H) 040 0	JUNCTION	0.25	0.60	1278.14	1	11:29
0	(2H) 041 0	JUNCTION	0.23	0.52	1278.97	1	11:28
0	(2H) 042 0	JUNCTION	0.25	0.59	1280.46	1	11:27
0	(2H) 043 0	JUNCTION	0.25	0.59	1281.41	1	11:26
0	(2H) 044 0	JUNCTION	0.24	0.55	1282.19	1	11:25
0	(2H) 045 0	JUNCTION	0.23	0.55	1282.89	1	11:25
0	(2H) 046 0	JUNCTION	0.33	0.96	1283.97	1	11:30
0	(2H) 047 378	JUNCTION	1.53	16.92	1300.17	1	05:08
0	(2H) 048 0	JUNCTION	0.26	0.92	1285.29	1	09:44
0	(2H) 049 263	JUNCTION	0.86	12.17	1297.77	1	05:11
0	(2H) 050 0	JUNCTION	0.25	0.58	1287.14	1	10:58
0	(2H) 051 0	JUNCTION	0.25	0.58	1287.86	1	10:57
0	(2H) 051A 0	JUNCTION	0.23	0.52	1288.58	1	10:57
0	(2H) 052 0	JUNCTION	0.34	1.00	1290.23	1	11:04
0	(2H) 053 355	JUNCTION	1.58	18.44	1307.98	1	05:02
0	(2H) 054 10	JUNCTION	0.18	18.94	1308.99	1	06:42
0	(2H) 054A 50	JUNCTION	0.32	19.10	1310.00	1	05:30
0	(2H) 055 0	JUNCTION	0.14	0.83	1292.75	1	05:21
0	(2H) 055A 0	JUNCTION	0.14	0.83	1293.29	1	05:20
0	(2H) 056 0	JUNCTION	0.14	0.83	1294.94	1	05:18
0	(2H) 057 209	JUNCTION	0.71	14.53	1309.34	1	05:18
0	(2H) 058 209	JUNCTION	0.73	15.24	1310.52	1	05:17
0	(2H) 285	JUNCTION	0.22	0.83	1290.81	1	05:07

0	0						
	(2H) 286	JUNCTION	1.19	17.75	1308.37	1	05:06
0	290						
	(2H) 287	JUNCTION	0.17	0.83	1292.52	1	05:39
0	0						
	(2H) 288	JUNCTION	0.17	0.83	1293.92	1	05:35
0	0						
	(2H) 289	JUNCTION	0.68	22.15	1316.58	1	05:33
0	122						
	(2H) 290	JUNCTION	0.49	20.92	1315.98	1	05:32
0	115						
	(2I) 001	JUNCTION	0.83	9.71	1279.00	1	05:08
0	275						
	(2I) 001A	JUNCTION	1.00	10.90	1280.00	1	05:05
0	302						
	(2I) 002	JUNCTION	0.31	1.14	1273.00	1	05:51
0	0						
	(2I) 003	JUNCTION	0.69	8.80	1282.00	1	05:10
0	248						
	(2I) 004	JUNCTION	0.70	9.30	1283.00	1	05:15
0	240						
	(2I) 005	JUNCTION	0.70	9.46	1285.00	1	05:12
0	237						
	(2I) 006	JUNCTION	0.18	1.25	1277.85	1	05:33
0	0						
	(2I) 008	JUNCTION	0.49	12.00	1290.00	1	05:32
0	144						
	(2I) 009	JUNCTION	0.14	0.97	1280.61	1	07:45
0	0						
	(2I) 010	JUNCTION	0.14	0.95	1280.95	1	07:45
0	0						
	(2I) 011	JUNCTION	0.14	0.95	1281.55	1	07:44
0	0						
	(2I) 012	JUNCTION	0.13	0.96	1282.24	1	07:44
0	0						
	(2I) 013	JUNCTION	0.14	1.14	1283.90	1	06:02
0	0						
	(2I) 014	JUNCTION	0.34	8.61	1292.00	1	05:31
0	133						
	(2I) 015	JUNCTION	0.00	0.00	1283.87	0	00:00
0	0						
	(2I) 016	JUNCTION	0.00	0.00	1284.40	0	00:00
0	0						
	(2I) 017	JUNCTION	0.00	0.00	1284.54	0	00:00
0	0						
	(2I) 017A	JUNCTION	12.25	12.40	1297.00	0	01:00
0	4981						
	(2I) 018	JUNCTION	1.08	11.66	1297.00	1	05:05
0	361						
	(2I) 019	JUNCTION	0.28	0.92	1287.07	1	10:54
0	0						
	(2I) 020	JUNCTION	1.36	16.52	1304.00	1	05:04
0	346						
	(2I) 021	JUNCTION	0.94	15.44	1304.00	1	05:11
0	229						
	(2I) 021A	JUNCTION	0.28	1.17	1290.03	1	05:30
0	0						
	(2I) 021B	JUNCTION	0.73	14.54	1304.00	1	05:31
0	150						
	(2I) 021C	JUNCTION	1.21	14.45	1304.00	1	05:09
0	330						

0	(2I)022	JUNCTION	0.26	0.98	1290.62	1	10:29
0	0						
0	(2I)023	JUNCTION	0.27	1.00	1291.72	1	05:08
0	0						
0	(2I)024	JUNCTION	0.27	11.20	1303.00	1	10:22
0	2						
0	(2I)025	JUNCTION	0.27	1.00	1293.88	1	05:03
0	0						
0	(2I)025A	JUNCTION	0.79	9.38	1303.00	1	05:02
0	313						
0	(2I)026	JUNCTION	0.22	1.00	1294.96	1	09:05
0	0						
0	(2I)027	JUNCTION	0.23	1.00	1295.94	1	05:13
0	0						
0	(2I)028	JUNCTION	0.73	11.90	1306.99	1	05:13
0	232						
0	(2I)029	JUNCTION	0.64	12.10	1307.39	1	05:15
0	221						
0	(2I)044	JUNCTION	0.23	1.00	1277.65	1	05:13
0	0						
0	(2I)045	JUNCTION	0.23	10.43	1287.81	1	09:05
0	1						
0	(2I)046	JUNCTION	0.23	1.00	1282.61	1	05:11
0	0						
0	(2I)047	JUNCTION	0.23	1.00	1286.58	1	05:09
0	0						
0	(2I)048	JUNCTION	0.23	1.00	1290.53	1	05:08
0	0						
0	(2I)049	JUNCTION	0.93	16.16	1307.00	1	05:08
0	222						
0	(2I)050	JUNCTION	0.26	1.00	1293.77	1	05:13
0	0						
0	(2I)051	JUNCTION	0.27	14.56	1307.80	1	05:16
0	3						
0	(2I)052	JUNCTION	0.24	1.00	1294.62	1	05:12
0	0						
0	(2I)053	JUNCTION	0.24	13.21	1308.20	1	09:15
0	1						
0	(2I)054	JUNCTION	0.76	11.84	1308.00	1	05:09
0	242						
0	(2I)055	JUNCTION	0.61	10.74	1307.80	1	05:20
0	199						
0	(2I)056	JUNCTION	0.20	9.55	1308.00	1	08:27
0	1						
0	(2I)057	JUNCTION	0.20	1.00	1300.11	1	05:13
0	0						
0	(2I)058	JUNCTION	0.20	11.57	1312.00	1	08:31
0	1						
0	(2I)059	JUNCTION	0.56	10.24	1312.50	1	05:10
0	198						
0	(2J)001	JUNCTION	0.81	2.25	1241.61	1	11:12
0	0						
0	(2J)002	JUNCTION	0.82	2.25	1241.98	1	05:45
0	0						
0	(2J)003	JUNCTION	0.83	2.25	1242.06	1	05:44
0	0						
0	(2J)004	JUNCTION	1.63	17.96	1258.00	1	05:48
0	258						
0	(2J)005	JUNCTION	0.80	2.25	1242.34	1	11:08
0	0						
0	(2J)006	JUNCTION	0.82	2.25	1242.82	1	05:40

0	0						
	(2J) 007	JUNCTION	1.62	19.90	1261.00	1	05:54
0	227						
	(2J) 008	JUNCTION	1.79	22.37	1264.00	1	05:35
0	244						
	(2J) 009	JUNCTION	0.68	1.50	1243.35	1	11:19
0	0						
	(2J) 010	JUNCTION	0.93	1.49	1243.58	1	11:18
0	0						
	(2J) 011	JUNCTION	0.68	1.83	1244.49	1	11:00
0	0						
	(2J) 012	JUNCTION	0.71	2.00	1245.17	1	05:42
0	0						
	(2J) 013	JUNCTION	0.73	21.86	1266.00	1	11:01
0	5						
	(2J) 014	JUNCTION	0.66	2.00	1246.99	1	11:00
0	0						
	(2J) 015	JUNCTION	0.68	2.00	1247.91	1	05:41
0	0						
	(2J) 016	JUNCTION	0.65	1.63	1248.44	1	08:02
0	0						
	(2J) 017	JUNCTION	0.65	1.63	1249.35	1	11:02
0	0						
	(2J) 018	JUNCTION	0.65	1.63	1249.51	1	11:01
0	0						
	(2J) 019	JUNCTION	0.72	1.63	1250.53	1	12:56
0	0						
	(2J) 020	JUNCTION	21.42	21.69	1264.00	0	01:04
0	4977						
	(2J) 021	JUNCTION	0.41	0.75	1246.95	1	21:27
0	0						
	(2J) 022	JUNCTION	3.72	17.63	1264.00	1	05:06
0	982						
	(2J) 023	JUNCTION	3.35	16.65	1264.00	1	05:02
0	924						
	(2J) 026	JUNCTION	1.43	16.79	1266.00	1	05:03
0	367						
	(2J) 027	JUNCTION	0.07	0.83	1251.25	1	05:09
0	0						
	(2J) 028	JUNCTION	1.12	18.94	1270.00	1	05:09
0	291						
	(2J) 029	JUNCTION	1.05	17.83	1270.00	1	05:06
0	289						
	(2J) 030	JUNCTION	0.05	0.67	1254.53	1	05:25
0	0						
	(2J) 031	JUNCTION	0.05	0.67	1256.10	1	05:10
0	0						
	(2J) 032	JUNCTION	0.73	13.22	1270.00	1	05:07
0	271						
	(2J) 033	JUNCTION	0.00	0.00	1258.11	0	00:00
0	0						
	(2J) 040	JUNCTION	0.37	0.76	1249.71	1	13:14
0	0						
	(2J) 041	JUNCTION	0.38	0.83	1250.20	1	05:21
0	0						
	(2J) 042	JUNCTION	0.38	0.83	1252.57	1	05:13
0	0						
	(2J) 043	JUNCTION	0.37	0.83	1252.90	1	12:47
0	0						
	(2J) 044	JUNCTION	1.06	8.52	1261.21	1	05:16
0	448						

0	(2J) 045	JUNCTION	0.37	0.83	1253.95	1	05:11
0	0						
0	(2J) 045A	JUNCTION	1.06	8.47	1262.00	1	05:09
0	452						
0	(2J) 046	JUNCTION	0.37	0.83	1254.87	1	05:07
0	0						
0	(2J) 047	JUNCTION	1.26	11.04	1266.00	1	05:05
0	440						
0	(2J) 048	JUNCTION	0.31	0.54	1256.42	1	20:06
0	0						
0	(2J) 049	JUNCTION	0.29	0.51	1256.53	1	20:06
0	0						
0	(2J) 050	JUNCTION	0.29	0.52	1257.52	1	20:05
0	0						
0	(2J) 051	JUNCTION	0.30	0.62	1258.16	1	20:05
0	0						
0	(2J) 052	JUNCTION	0.32	0.67	1258.85	1	05:10
0	0						
0	(2J) 053	JUNCTION	2.44	12.58	1271.31	1	05:10
0	896						
0	(2J) 054	JUNCTION	1.92	10.09	1270.28	1	05:08
0	860						
0	(2J) 055	JUNCTION	1.23	6.42	1267.53	1	05:08
0	817						
0	(2J) 056	JUNCTION	1.06	5.33	1267.07	1	05:05
0	819						
0	(2J) 057	JUNCTION	0.17	0.24	1262.54	0	08:00
0	0						
0	(2J) 060	JUNCTION	0.17	0.22	1263.64	0	07:00
0	0						
0	(2K) 001	JUNCTION	2.49	21.95	1271.00	1	05:25
0	437						
0	(2K) 002	JUNCTION	0.38	0.93	1255.70	1	08:00
0	0						
0	(2K) 003	JUNCTION	0.40	1.02	1257.08	1	10:02
0	0						
0	(2K) 004	JUNCTION	0.40	1.02	1258.16	1	10:02
0	0						
0	(2K) 005	JUNCTION	0.40	1.01	1259.23	1	09:57
0	0						
0	(2K) 006	JUNCTION	0.40	1.00	1260.48	1	09:57
0	0						
0	(2K) 007	JUNCTION	0.40	0.99	1262.12	1	09:56
0	0						
0	(2K) 008	JUNCTION	0.40	1.00	1263.27	1	09:57
0	0						
0	(2K) 009	JUNCTION	0.40	1.03	1264.44	1	09:56
0	0						
0	(2K) 010	JUNCTION	0.43	1.16	1265.71	1	10:12
0	0						
0	(2K) 011	JUNCTION	0.84	8.31	1274.00	1	05:13
0	289						
0	(2K) 012	JUNCTION	0.41	1.14	1267.97	1	05:54
0	0						
0	(2K) 013	JUNCTION	0.90	10.29	1278.00	1	05:11
0	270						
0	(2K) 014	JUNCTION	0.90	9.58	1278.00	1	05:09
0	279						
0	(2K) 015	JUNCTION	1.08	8.98	1278.00	1	05:12
0	414						
0	(2K) 016	JUNCTION	0.37	1.00	1271.08	1	10:19

0	0						
	(2K) 017	JUNCTION	0.39	1.00	1271.60	1	05:14
0	0						
	(2K) 018	JUNCTION	0.89	9.00	1280.60	1	05:10
0	314						
	(2K) 018A	JUNCTION	0.82	8.12	1280.12	1	05:10
0	309						
	(2K) 019	JUNCTION	0.68	6.80	1279.50	1	05:10
0	275						
	(2K) 020	JUNCTION	0.40	1.00	1274.70	1	11:53
0	0						
	(2K) 021	JUNCTION	0.90	7.17	1280.97	1	05:12
0	402						
	(2K) 022	JUNCTION	0.35	0.89	1275.89	1	10:09
0	0						
	(2K) 022A	JUNCTION	0.37	1.00	1276.40	1	05:12
0	0						
	(2K) 023	JUNCTION	0.37	1.00	1277.20	1	05:10
0	0						
	(2K) 024	JUNCTION	0.37	1.00	1278.00	1	10:07
0	0						
	(2K) 024A	JUNCTION	0.85	9.00	1286.10	1	05:09
0	299						
	(2K) 025	JUNCTION	0.79	9.18	1287.68	1	05:08
0	269						
	(2K) 026	JUNCTION	0.33	0.77	1280.59	1	11:41
0	0						
	(2K) 027	JUNCTION	0.37	0.93	1285.13	1	11:41
0	0						
	(2K) 028	JUNCTION	0.38	1.00	1286.03	1	05:08
0	0						
	(2K) 029	JUNCTION	1.07	10.00	1296.00	1	05:04
0	386						
	(2K) 030	JUNCTION	0.33	1.00	1287.96	1	05:26
0	0						
	(2K) 031	JUNCTION	0.33	12.90	1301.00	1	10:58
0	2						
	(2K) 032	JUNCTION	0.32	1.00	1290.21	1	05:16
0	0						
	(2K) 033	JUNCTION	1.17	13.70	1304.00	1	05:13
0	336						
	(2K) 033A	JUNCTION	0.92	11.23	1302.19	1	05:41
0	300						
	(2K) 034	JUNCTION	0.81	9.70	1301.09	1	05:46
0	291						
	(2K) 035	JUNCTION	0.31	1.00	1293.49	1	05:32
0	0						
	(2K) 036	JUNCTION	0.31	1.00	1294.59	1	05:25
0	0						
	(2K) 037	JUNCTION	0.94	11.29	1306.00	1	05:22
0	307						
	(2K) 038	JUNCTION	0.21	1.00	1296.09	1	05:20
0	0						
	(2K) 039	JUNCTION	0.21	1.00	1296.96	1	05:17
0	0						
	(2K) 040	JUNCTION	0.21	1.00	1297.66	1	05:13
0	0						
	(2K) 041	JUNCTION	0.21	11.99	1309.50	1	10:11
0	1						
	(2K) 042	JUNCTION	0.87	12.18	1310.20	1	05:09
0	297						

0	(2K) 043	JUNCTION	0.19	1.00	1299.87	1	05:33
0	0						
0	(2K) 044	JUNCTION	0.20	12.28	1312.00	1	09:24
0	1						
0	(2K) 045	JUNCTION	0.19	1.00	1301.58	1	05:25
0	0						
0	(2K) 046	JUNCTION	0.20	1.00	1302.43	1	05:22
0	0						
0	(2K) 047	JUNCTION	0.20	11.72	1314.00	1	09:13
0	1						
0	(2K) 048	JUNCTION	0.20	1.00	1304.14	1	05:14
0	0						
0	(2K) 049	JUNCTION	0.20	11.21	1315.20	1	09:05
0	1						
0	(2K) 050	JUNCTION	0.20	1.00	1305.68	1	05:07
0	0						
0	(2K) 051	JUNCTION	0.19	1.00	1306.36	1	05:04
0	0						
0	(2K) 052	JUNCTION	0.62	10.35	1316.40	1	05:02
0	231						
0	(2K) 314	JUNCTION	0.19	0.76	1251.40	1	06:31
0	0						
0	(2K) 315	JUNCTION	2.12	17.08	1268.60	1	05:12
0	595						
0	(2K) 316	JUNCTION	0.19	0.83	1253.23	1	05:12
0	0						
0	(2K) 317	JUNCTION	1.68	14.67	1267.43	1	05:12
0	545						
0	ForcedMain	JUNCTION	9.88	10.00	1158.50	0	01:00
0	4981						
0	(PLANT)	OUTFALL	0.00	0.00	1145.00	0	00:00
0	0						
0	(1C) 026	DIVIDER	0.16	0.77	1227.64	1	10:46
0	0						
0	(1F) 012	DIVIDER	0.11	0.15	1202.45	0	08:01
0	0						
0	(1G) 019	DIVIDER	0.42	0.76	1225.85	1	05:35
0	0						
0	(2A) 048	DIVIDER	2.23	2.41	1193.06	1	07:00
0	0						
0	(2C) 009	DIVIDER	0.88	9.83	1220.49	1	05:11
0	202						
0	(2D) 244	DIVIDER	1.62	1.72	1218.89	1	06:51
0	0						
0	(1M) 012	DIVIDER	0.46	0.79	1222.23	1	07:59
0	0						
0	(2J) 025	DIVIDER	5.06	17.72	1266.00	1	05:34
0	337						
0	(1C) 001B	DIVIDER	1.09	1.20	1194.70	1	07:00
0	0						
0	(1M) 020	DIVIDER	4.07	4.15	1232.20	1	07:59
0	0						
0	(1A) STOR	STORAGE	0.00	0.00	1100.00	0	00:00
0	0						
0	(1A) DIV	STORAGE	0.00	0.00	1147.99	0	00:00
0	0						
0	(2A) 000	STORAGE	13.58	29.00	1159.00	1	06:14
0	226						
0	NorthEnidStorage	STORAGE	0.00	0.00	1239.83	0	00:00
0	4981						
0	(10) 304C	STORAGE	2.90	9.39	1249.22	1	17:16

0	0	LiftStation	STORAGE	7.18	22.00	1146.35	1	05:29
0	528	(10)304	STORAGE	0.25	3.45	1242.26	1	08:00
0	0	(1C)Storage	STORAGE	0.13	0.27	1191.57	1	09:05
0	0	PlantStorage	STORAGE	1.26	2.20	1154.20	3	00:31
0	0							

Node Flow Summary

Maximum			Maximum	Maximum			
Maximum	Time of Max		Lateral	Total	Time of Max		
Overflow	Occurrence		Inflow	Inflow	Occurrence		
Node		Type	GPM	GPM	days	hr:min	
GPM	days hr:min						

(1A)000		JUNCTION	0.00	3540.94	3	07:09	0.00
(1A)000A		JUNCTION	0.00	3541.00	3	07:08	0.00
(1A)000B		JUNCTION	0.00	3541.08	0	07:30	0.00
(1A)001		JUNCTION	1.95	6953.57	1	07:00	3419.17
1	07:00						
(1A)002		JUNCTION	0.00	7160.28	1	07:05	193.80
1	07:05						
(1A)003		JUNCTION	0.00	7162.46	1	07:04	0.00
(1A)004		JUNCTION	5.24	7165.45	1	07:02	0.00
(1A)005		JUNCTION	0.00	7164.18	1	07:01	0.00
(1A)006		JUNCTION	0.00	7168.40	1	07:00	0.00
(1A)007		JUNCTION	2442.83	7173.75	1	07:00	0.00
(1A)008		JUNCTION	0.00	4746.70	1	17:13	0.00
(1A)009		JUNCTION	0.00	4734.81	1	17:12	0.00
(1A)010		JUNCTION	0.00	4730.92	1	07:09	0.00
(1A)011		JUNCTION	0.00	5228.20	1	07:10	497.28
1	07:10						
(1A)012		JUNCTION	0.00	9957.57	1	06:56	4729.37
1	06:57						
(1A)013		JUNCTION	0.00	12163.88	1	06:37	2206.30
1	06:38						
(1A)014		JUNCTION	10488.93	15016.99	1	07:00	2821.16
1	07:00						
(1A)015		JUNCTION	6.42	4532.59	1	10:13	0.00
(1A)016		JUNCTION	0.00	4531.70	1	10:11	0.00
(1A)017		JUNCTION	0.00	4549.71	1	10:09	0.00
(1A)018		JUNCTION	0.00	3778.87	1	00:20	0.00
(1A)019		JUNCTION	0.00	5126.58	0	20:41	1354.88
0	20:41						
(1A)020		JUNCTION	0.00	5129.30	2	08:25	0.00
(1A)021		JUNCTION	0.00	5127.07	2	20:06	0.00
(1A)022		JUNCTION	0.00	5133.80	2	21:45	0.00

	(1A) 023	JUNCTION	0.15	5133.46	2	21:44	0.00
	(1A) 024	JUNCTION	0.00	5128.17	2	20:04	0.00
	(1A) 024A	JUNCTION	0.00	11468.04	1	06:38	6346.76
1	06:38						
	(1A) 025	JUNCTION	0.00	10068.26	1	06:38	0.00
	(1A) 026	JUNCTION	9.30	11452.53	1	07:19	1395.53
1	07:19						
	(1A) 027	JUNCTION	7721.96	12033.11	1	07:00	592.40
1	07:00						
	(1A) 028	JUNCTION	0.00	4316.47	3	08:24	0.00
	(1A) 029	JUNCTION	0.00	4316.51	3	08:23	0.00
	(1A) 030	JUNCTION	0.00	4316.76	3	08:21	0.00
	(1A) 031	JUNCTION	0.00	4316.97	3	08:19	0.00
	(1A) 032	JUNCTION	0.00	4317.20	3	08:17	0.00
	(1A) 033	JUNCTION	0.00	4318.09	2	22:36	0.00
	(1A) 034	JUNCTION	0.00	4322.60	3	08:53	0.00
	(1A) 035	JUNCTION	0.00	4323.08	2	09:17	0.00
	(1A) 035A	JUNCTION	0.00	4320.49	0	08:35	0.00
	(1A) 036	JUNCTION	0.00	4329.97	2	22:33	0.00
	(1A) 037	JUNCTION	0.00	4319.39	0	08:09	0.00
	(1A) 038	JUNCTION	0.00	8919.34	1	07:00	4607.95
1	07:00						
	(1A) 039	JUNCTION	0.00	6781.11	1	06:14	0.00
	(1A) 040	JUNCTION	0.00	7078.84	1	05:51	297.73
1	05:52						
	(1A) 041	JUNCTION	0.00	12512.32	1	09:11	5418.72
1	09:09						
	(1A) 042	JUNCTION	5.50	12026.49	1	07:42	341.03
1	07:42						
	(1B) 001	JUNCTION	0.00	1401.12	1	14:49	0.00
	(1B) 002	JUNCTION	0.00	1400.27	1	14:49	0.00
	(1B) 003	JUNCTION	0.00	1399.16	1	15:10	0.00
	(1B) 004	JUNCTION	0.00	7387.08	1	05:35	5988.69
1	05:35						
	(1B) 005	JUNCTION	8474.22	13441.02	1	07:00	6022.42
1	07:00						
	(1B) 006	JUNCTION	0.00	5090.50	1	05:43	123.70
1	05:44						
	(1B) 009	JUNCTION	3649.08	8490.47	1	07:00	3386.65
1	07:00						
	(1B) 010	JUNCTION	67.01	4856.20	1	07:00	0.00
	(1B) 011	JUNCTION	0.00	5090.05	1	10:50	298.69
1	10:50						
	(1B) 013	JUNCTION	0.00	5085.72	1	05:57	0.00
	(1B) 014	JUNCTION	25358.09	30682.39	1	07:00	25548.52
1	07:00						
	(1C) 001	JUNCTION	7.71	6599.14	1	07:59	1264.07
1	07:59						
	(1C) 001A	JUNCTION	12567.90	17139.93	1	07:00	12143.67
1	07:00						
	(1C) 001C	JUNCTION	0.00	4757.27	1	06:09	0.00
	(1C) 001D	JUNCTION	0.00	5778.59	1	05:46	1021.31
1	05:46						
	(1C) 001E	JUNCTION	0.00	5778.58	1	05:45	0.00
	(1C) 001F	JUNCTION	0.00	5779.01	1	05:44	0.00
	(1C) 001G	JUNCTION	0.00	195.69	1	07:09	0.00
	(1C) 002	JUNCTION	12.18	1409.27	1	07:59	0.00
	(1C) 003	JUNCTION	13.41	35.45	0	20:38	0.00
	(1C) 004	JUNCTION	4.63	22.04	0	20:36	0.00
	(1C) 005	JUNCTION	0.00	17.69	0	08:01	0.00
	(1C) 006	JUNCTION	1.95	17.60	0	21:00	0.00

	(1C)006A	JUNCTION	0.00	15.47	0	20:31	0.00
	(1C)007	JUNCTION	9.30	15.47	0	20:32	0.00
	(1C)009	JUNCTION	0.00	5786.41	1	05:42	0.00
	(1C)010	JUNCTION	0.00	5798.76	1	05:42	0.00
	(1C)011	JUNCTION	0.00	5778.58	1	05:41	0.00
	(1C)012	JUNCTION	0.00	0.00	0	00:00	0.00
	(1C)015A	JUNCTION	29.14	6369.69	1	07:00	579.43
1	07:00						
	(1C)015B	JUNCTION	0.00	6340.56	1	06:05	0.00
	(1C)015C	JUNCTION	0.00	6340.56	1	06:04	0.00
	(1C)015D	JUNCTION	8736.36	14369.16	1	07:00	8011.84
1	07:00						
	(1C)016	JUNCTION	3.08	5635.62	1	07:59	0.00
	(1C)016A	JUNCTION	1.54	5657.50	1	08:08	0.00
	(1C)016B	JUNCTION	0.00	5620.21	1	06:11	0.00
	(1C)016C	JUNCTION	0.00	7561.21	1	06:11	1941.00
1	06:12						
	(1C)017	JUNCTION	0.00	11.45	0	08:04	0.00
	(1C)018	JUNCTION	0.00	11.24	0	08:01	0.00
	(1C)019	JUNCTION	3.08	11.41	0	08:00	0.00
	(1C)020	JUNCTION	7.71	7.71	0	07:00	0.00
	(1C)021	JUNCTION	10613.58	12714.28	1	07:00	5144.38
1	07:00						
	(1C)021A	JUNCTION	0.00	2504.89	1	06:03	753.03
1	06:03						
	(1C)021B	JUNCTION	9473.29	9551.42	1	07:00	7028.94
1	07:00						
	(1C)021C	JUNCTION	0.00	78.51	1	08:00	0.00
	(1C)021D	JUNCTION	0.00	78.42	1	08:00	0.00
	(1C)022	JUNCTION	6.94	352.11	1	07:53	0.00
	(1C)023	JUNCTION	0.00	346.08	1	08:00	0.00
	(1C)024	JUNCTION	9.30	345.17	1	07:00	0.00
	(1C)025	JUNCTION	0.00	434.44	1	08:00	97.42
1	08:00						
	(1C)027	JUNCTION	6.94	498.97	1	07:00	4.05
1	07:00						
	(1C)028	JUNCTION	6388.79	6388.79	1	07:00	5889.69
1	07:00						
	(1C)041	JUNCTION	6.17	6.17	0	07:00	0.00
	(1C)176	JUNCTION	4.37	1364.22	1	08:00	0.00
	(1C)177	JUNCTION	7.24	1361.93	1	07:00	1.92
1	07:00						
	(1C)178	JUNCTION	10096.40	11458.78	1	07:00	10094.10
1	07:00						
	(1C)179	JUNCTION	9146.69	10230.66	1	07:00	8861.23
1	07:00						
	(1C)179A	JUNCTION	0.00	1358.90	1	08:51	267.82
1	07:31						
	(1C)180	JUNCTION	4.37	1362.45	1	08:45	2.28
1	08:46						
	(1C)180A	JUNCTION	4.37	1354.08	1	08:48	0.00
	(1C)181	JUNCTION	4.37	1345.25	1	07:00	0.00
	(1C)182	JUNCTION	8951.35	8951.35	1	07:00	7599.83
1	07:00						
	(1D)001	JUNCTION	3.49	790.17	1	10:09	0.00
	(1D)002	JUNCTION	0.00	748.18	1	05:44	0.00
	(1D)003	JUNCTION	0.00	748.18	1	05:43	0.00
	(1D)004	JUNCTION	0.00	748.18	1	05:42	0.00
	(1D)005	JUNCTION	4827.11	5367.60	1	07:00	4614.89
1	07:00						
	(1D)006	JUNCTION	0.00	540.73	1	11:35	0.00

	(1D)007	JUNCTION	0.00	540.75	1	11:34	0.00
	(1D)008	JUNCTION	0.00	547.32	1	13:11	0.00
	(1D)009	JUNCTION	0.00	540.49	1	05:45	0.00
	(1D)010	JUNCTION	0.00	574.58	1	10:59	33.53
1	10:59						
	(1D)011	JUNCTION	0.00	573.90	1	11:00	0.00
	(1D)012	JUNCTION	18.96	624.92	1	07:00	52.07
1	07:00						
	(1D)013	JUNCTION	0.00	605.96	1	05:56	0.00
	(1D)014	JUNCTION	6455.43	6925.33	1	07:00	6316.07
1	07:00						
	(1D)015	JUNCTION	6.06	471.53	1	07:00	0.00
	(1D)016	JUNCTION	8.12	468.98	1	07:00	2.68
1	07:00						
	(1D)017	JUNCTION	10.79	476.84	1	07:00	15.97
1	07:00						
	(1D)018	JUNCTION	14882.85	15354.31	1	07:00	14873.02
1	07:00						
	(1D)019	JUNCTION	0.00	472.27	1	11:48	0.00
	(1D)020	JUNCTION	25.79	499.94	1	07:00	28.49
1	07:00						
	(1D)021	JUNCTION	17.88	488.33	1	07:00	14.18
1	07:00						
	(1D)022	JUNCTION	6.06	476.34	1	07:00	5.89
1	07:00						
	(1D)023	JUNCTION	10889.86	10889.86	1	07:00	10407.72
1	07:00						
	(1E)001	JUNCTION	0.00	804.18	1	09:10	0.00
	(1E)002	JUNCTION	0.00	787.91	1	06:39	0.00
	(1E)003	JUNCTION	0.00	802.73	1	06:23	14.83
1	06:23						
	(1E)003A	JUNCTION	1651.96	2434.79	1	07:00	1626.61
1	07:00						
	(1E)005	JUNCTION	2.31	805.13	1	08:45	9.25
1	08:45						
	(1E)006	JUNCTION	0.00	802.86	1	08:38	0.00
	(1E)007	JUNCTION	0.00	780.91	1	06:46	0.00
	(1E)008	JUNCTION	0.00	836.74	1	08:33	54.42
1	05:56						
	(1E)009	JUNCTION	6901.30	6901.30	1	07:00	6061.23
1	07:00						
	(1F)001	JUNCTION	17.78	2796.41	1	07:13	56.43
1	07:13						
	(1F)003	JUNCTION	7.24	2778.63	1	07:00	0.00
	(1F)004	JUNCTION	16711.14	18207.24	1	07:00	15423.39
1	07:00						
	(1F)005	JUNCTION	0.00	1744.78	1	07:21	247.95
1	07:22						
	(1F)006	JUNCTION	19.06	1748.93	1	07:21	0.00
	(1F)008	JUNCTION	1.75	1720.11	1	07:00	0.00
	(1F)008A	JUNCTION	0.00	2040.67	1	07:00	322.28
1	07:01						
	(1F)009	JUNCTION	2.31	2040.63	1	07:00	0.00
	(1F)010	JUNCTION	3218.47	3220.54	1	07:00	1175.39
1	07:00						
	(1F)011	JUNCTION	2.98	2.98	0	07:00	0.00
	(1F)012A	JUNCTION	0.00	39.01	0	08:00	0.00
	(1F)013	JUNCTION	14.28	36.53	0	20:42	0.00
	(1F)014	JUNCTION	0.00	24.28	0	08:01	0.00
	(1F)015	JUNCTION	0.00	26.07	0	08:00	0.00
	(1F)016	JUNCTION	22.25	22.25	0	07:00	0.00

	(1F) 017	JUNCTION	0.00	11916.31	1	05:42	0.00
	(1F) 017A	JUNCTION	9798.33	19147.32	1	07:00	7200.91
1	07:00						
	(1F) 017B	JUNCTION	0.00	9350.81	1	07:08	0.00
	(1F) 017C	JUNCTION	10.23	9350.81	1	07:00	0.00
	(1F) 017D	JUNCTION	0.00	11873.94	1	05:57	2327.39
1	05:57						
	(1F) 017E	JUNCTION	0.00	11638.69	1	07:04	0.00
	(1F) 017F	JUNCTION	0.00	589.65	1	12:36	0.00
	(1F) 017G	JUNCTION	1.34	594.11	1	12:36	0.00
	(1F) 018	JUNCTION	1.08	602.09	1	12:35	0.00
	(1F) 019	JUNCTION	0.00	609.62	1	12:31	0.00
	(1F) 020	JUNCTION	0.00	567.63	1	06:12	0.00
	(1F) 021	JUNCTION	14076.91	14508.11	1	07:00	13932.41
1	07:00						
	(1F) 022	JUNCTION	0.00	439.69	1	08:00	0.00
	(1F) 023	JUNCTION	0.00	439.71	1	08:00	0.00
	(1F) 024	JUNCTION	0.00	24.94	0	08:00	0.00
	(1F) 025	JUNCTION	2.72	24.56	0	20:42	0.00
	(1F) 026	JUNCTION	0.00	22.72	0	08:00	0.00
	(1F) 026A	JUNCTION	5.50	21.84	0	20:37	0.00
	(1F) 027	JUNCTION	2.21	16.34	0	20:32	0.00
	(1F) 028	JUNCTION	2.21	14.13	0	20:29	0.00
	(1F) 029	JUNCTION	0.00	12.79	0	08:01	0.00
	(1F) 029A	JUNCTION	0.00	14.10	0	08:00	0.00
	(1F) 030	JUNCTION	11.92	11.92	0	07:00	0.00
	(1G) 001	JUNCTION	2.06	11988.21	1	07:00	919.55
1	07:00						
	(1G) 001A	JUNCTION	0.00	12122.64	1	07:54	99.47
1	07:55						
	(1G) 002	JUNCTION	6996.22	15531.03	1	07:00	3411.14
1	07:00						
	(1G) 003	JUNCTION	20682.60	26886.63	1	07:00	18286.69
1	07:00						
	(1G) 004	JUNCTION	0.00	6204.93	1	07:11	0.00
	(1G) 005	JUNCTION	4.63	6204.93	1	07:00	0.00
	(1G) 006	JUNCTION	0.00	10728.55	1	08:26	4512.44
1	07:33						
	(1G) 007	JUNCTION	0.00	10874.41	1	08:24	0.00
	(1G) 008A	JUNCTION	0.87	10712.75	1	07:00	0.00
	(1G) 008B	JUNCTION	0.00	10711.88	1	06:07	0.00
	(1G) 008C	JUNCTION	5.14	12279.05	1	07:00	1567.17
1	07:00						
	(1G) 009A	JUNCTION	4.52	12325.59	1	05:46	25.03
1	05:46						
	(1G) 009B	JUNCTION	13981.58	24822.53	1	07:00	12487.28
1	07:00						
	(1G) 009C	JUNCTION	3.08	10888.19	1	06:20	0.00
	(1G) 009D	JUNCTION	0.00	10743.59	1	06:19	0.00
	(1G) 009E	JUNCTION	0.00	12547.92	1	07:10	1575.96
1	07:10						
	(1G) 010	JUNCTION	3.85	11972.07	1	07:09	0.00
	(1G) 011	JUNCTION	0.00	11887.47	1	07:08	0.00
	(1G) 012	JUNCTION	5.55	11618.08	1	07:07	0.00
	(1G) 013	JUNCTION	0.00	11461.19	1	07:03	0.00
	(1G) 014	JUNCTION	1.95	106.20	1	20:04	0.00
	(1G) 014A	JUNCTION	0.00	106.34	1	08:00	0.00
	(1G) 015	JUNCTION	0.00	106.80	1	08:00	0.00
	(1G) 016	JUNCTION	16.50	104.25	1	07:44	0.00
	(1G) 017	JUNCTION	0.00	92.56	1	08:00	0.00
	(1G) 018	JUNCTION	39.93	87.75	1	07:00	0.00

	(1G)018A	JUNCTION	0.00	47.95	1	21:01	0.00
	(1G)020	JUNCTION	17034.00	17567.32	1	07:00	17021.82
1	07:00						
	(1G)045	JUNCTION	15.47	536.28	1	07:00	0.00
	(1G)046	JUNCTION	15856.39	16169.85	1	07:00	15617.46
1	07:00						
	(1G)047	JUNCTION	111.45	334.56	1	07:00	0.00
	(1G)048	JUNCTION	0.00	223.57	1	06:31	0.00
	(1G)049	JUNCTION	0.00	223.60	1	06:30	0.00
	(1G)050	JUNCTION	0.00	223.62	1	06:30	0.00
	(1G)051	JUNCTION	0.00	223.53	1	06:29	0.00
	(1G)052	JUNCTION	0.00	223.85	1	16:45	0.16
1	16:45						
	(1G)053	JUNCTION	18221.38	18444.91	1	07:00	18195.89
1	07:00						
	(1G)054	JUNCTION	0.00	223.63	1	13:09	0.05
1	13:09						
	(1G)055	JUNCTION	0.00	223.53	1	07:04	0.00
	(1G)056	JUNCTION	0.00	337.50	1	06:20	113.54
1	06:21						
	(1G)057	JUNCTION	0.00	336.74	1	12:06	0.00
	(1G)058	JUNCTION	0.00	336.63	1	06:35	0.00
	(1G)059	JUNCTION	0.00	336.30	1	06:20	0.00
	(1G)060	JUNCTION	0.00	336.98	1	07:15	0.00
	(1G)061	JUNCTION	0.00	369.61	1	05:33	31.42
1	07:17						
	(1G)062	JUNCTION	0.00	368.40	1	06:24	0.00
	(1G)063	JUNCTION	0.00	369.15	1	06:33	0.00
	(1G)064	JUNCTION	0.00	369.15	1	06:29	0.00
	(1G)065	JUNCTION	0.00	369.15	1	06:26	0.00
	(1G)066	JUNCTION	0.00	369.15	1	06:25	0.00
	(1G)067	JUNCTION	0.00	369.15	1	06:24	0.00
	(1G)068	JUNCTION	0.00	369.32	1	11:43	0.09
1	11:43						
	(1G)069	JUNCTION	0.00	369.30	1	11:39	0.08
1	11:39						
	(1G)070	JUNCTION	0.00	369.15	1	05:54	0.00
	(1G)071	JUNCTION	9318.53	9318.53	1	07:00	8940.63
1	07:00						
	(1G)146	JUNCTION	0.00	0.00	0	00:00	0.00
	(1G)146A	JUNCTION	0.00	0.00	0	00:00	0.00
	(1G)162	JUNCTION	5.03	503.19	1	21:07	11.15
1	21:08						
	(1G)162A	JUNCTION	0.00	501.86	1	21:05	1.63
1	21:05						
	(1G)162B	JUNCTION	0.00	493.85	1	21:03	0.00
	(1G)162C	JUNCTION	0.00	468.73	1	05:36	0.00
	(1G)162D	JUNCTION	0.00	488.46	1	21:13	0.00
	(1G)243	JUNCTION	0.00	0.00	0	00:00	0.00
	(1H)001	JUNCTION	10.33	414.72	1	07:13	0.00
	(1H)004	JUNCTION	0.00	71.85	0	22:14	0.00
	(1H)005	JUNCTION	0.00	457.46	1	16:37	385.57
1	08:02						
	(1H)006	JUNCTION	0.00	457.35	1	16:36	0.00
	(1H)007	JUNCTION	0.00	457.57	1	16:35	0.00
	(1H)008	JUNCTION	0.00	457.25	1	07:00	0.00
	(1H)009	JUNCTION	1.29	457.23	1	07:00	0.00
	(1H)010	JUNCTION	0.00	1171.03	1	05:33	715.08
1	05:33						
	(1H)011	JUNCTION	15338.07	15338.07	1	07:00	14130.05
1	07:00						

	(1H) 038	JUNCTION	6.58	404.39	1	07:00	0.00
	(1H) 039	JUNCTION	0.00	397.82	1	06:06	0.00
	(1H) 040	JUNCTION	0.00	397.82	1	06:06	0.00
	(1H) 041	JUNCTION	0.00	685.90	1	05:29	288.08
1	05:29						
	(1H) 042	JUNCTION	0.00	685.90	1	05:19	0.00
	(1H) 043	JUNCTION	19581.73	19632.50	1	07:00	18906.63
1	07:00						
	(1H) 044	JUNCTION	2.21	67.83	0	08:00	0.00
	(1H) 045	JUNCTION	60.12	60.12	0	07:00	0.00
	(1J) 001	JUNCTION	0.00	12021.59	1	08:03	0.00
	(1J) 002	JUNCTION	0.00	12021.81	1	08:02	0.00
	(1J) 003	JUNCTION	0.77	9282.11	1	08:01	0.00
	(1J) 004	JUNCTION	0.00	9282.42	1	08:00	0.00
	(1J) 005	JUNCTION	0.00	9282.80	1	08:00	0.00
	(1J) 006	JUNCTION	27.59	9280.24	1	07:00	0.00
	(1J) 007	JUNCTION	0.00	9257.01	1	10:58	0.00
	(1J) 008	JUNCTION	0.00	9264.07	1	10:58	0.00
	(1J) 009	JUNCTION	0.00	9258.75	1	10:57	0.00
	(1J) 010	JUNCTION	0.00	9252.65	1	05:56	0.00
	(1J) 011	JUNCTION	10524.93	21882.46	1	07:00	12621.55
1	07:00						
	(1J) 012	JUNCTION	0.00	11917.35	1	06:05	589.25
1	06:06						
	(1J) 013	JUNCTION	0.00	12906.85	1	08:08	843.16
1	08:03						
	(1J) 014	JUNCTION	0.00	12772.46	1	08:07	0.00
	(1J) 041	JUNCTION	0.00	849.76	1	08:02	0.00
	(1J) 042	JUNCTION	0.00	853.00	1	08:01	0.00
	(1J) 042A	JUNCTION	0.00	856.10	1	08:01	0.00
	(1J) 042B	JUNCTION	0.00	861.55	1	08:00	0.00
	(1J) 043	JUNCTION	0.00	878.86	1	08:00	0.00
	(1J) 044	JUNCTION	225.22	838.32	1	20:02	0.00
	(1J) 045	JUNCTION	0.00	616.93	1	08:00	0.00
	(1J) 046	JUNCTION	58.06	613.10	1	19:35	0.00
	(1J) 047	JUNCTION	0.00	560.08	1	08:00	0.00
	(1J) 048	JUNCTION	0.00	564.74	1	08:00	0.00
	(1J) 050	JUNCTION	113.46	555.04	1	19:00	0.00
	(1J) 050A	JUNCTION	0.00	371.40	1	22:45	0.00
	(1J) 051	JUNCTION	0.00	370.22	1	23:25	0.00
	(1J) 052	JUNCTION	0.00	1069.13	1	05:23	699.27
1	05:24						
	(1J) 053	JUNCTION	18439.36	18882.64	1	07:00	17777.95
1	07:00						
	(1J) 054	JUNCTION	0.00	443.28	1	07:28	0.00
	(1J) 054A	JUNCTION	0.00	444.05	1	13:39	0.00
	(1J) 055	JUNCTION	0.00	640.69	1	11:25	197.40
1	11:25						
	(1J) 056	JUNCTION	0.00	641.09	1	11:23	0.00
	(1J) 057	JUNCTION	0.00	641.87	1	11:22	0.00
	(1J) 058	JUNCTION	0.00	643.97	1	11:21	0.00
	(1J) 059	JUNCTION	0.00	640.08	1	11:36	0.00
	(1J) 060	JUNCTION	0.00	3780.44	1	05:49	3140.81
1	05:50						
	(1K) 001	JUNCTION	6352.82	6962.94	1	07:00	3170.08
1	07:00						
	(1K) 002	JUNCTION	0.00	610.93	1	07:00	0.00
	(1K) 002A	JUNCTION	9.30	610.76	1	07:00	0.00
	(1K) 003	JUNCTION	0.00	601.57	1	11:04	0.00
	(1K) 004	JUNCTION	8610.08	8838.13	1	07:00	8227.93
1	07:00						

	(1K)005	JUNCTION	12.95	231.96	2	07:10	0.00
	(1K)006	JUNCTION	4.63	679.45	1	12:08	456.22
1	12:09						
	(1K)007	JUNCTION	1.75	669.11	1	07:00	0.00
	(1K)008	JUNCTION	5938.22	6466.07	1	07:00	5794.56
1	07:00						
	(1K)008A	JUNCTION	10.43	529.58	1	07:00	0.00
	(1K)009	JUNCTION	6.94	656.20	1	07:59	137.05
1	07:59						
	(1K)010	JUNCTION	4.63	700.30	1	08:00	45.28
1	07:40						
	(1K)011	JUNCTION	208.98	689.92	1	07:29	0.00
	(1K)012	JUNCTION	0.00	481.79	1	13:05	0.00
	(1K)013	JUNCTION	0.00	599.00	1	06:09	118.07
1	06:09						
	(1K)014	JUNCTION	17143.86	17143.86	1	07:00	16524.64
1	07:00						
	(1M)000	JUNCTION	0.00	11481.16	1	07:02	0.00
	(1M)001	JUNCTION	0.00	11499.67	1	07:01	0.00
	(1M)001A	JUNCTION	0.00	11490.19	1	07:01	0.00
	(1M)001B	JUNCTION	0.00	11481.73	1	07:02	0.00
	(1M)002	JUNCTION	0.00	11505.87	1	07:00	0.00
	(1M)003	JUNCTION	5499.77	11526.41	1	07:00	0.00
	(1M)010	JUNCTION	0.00	690.40	1	06:26	0.00
	(1M)011	JUNCTION	0.00	1032.63	1	07:59	342.22
1	07:59						
	(1M)013	JUNCTION	0.00	608.40	1	08:08	0.00
	(1M)014	JUNCTION	0.00	609.06	1	08:06	0.00
	(1M)015	JUNCTION	0.00	610.06	1	08:03	0.00
	(1M)016	JUNCTION	0.00	609.49	1	08:02	0.00
	(1M)017	JUNCTION	0.00	609.55	1	08:02	0.00
	(1M)018	JUNCTION	0.00	610.78	1	08:01	0.00
	(1M)019	JUNCTION	0.00	613.30	1	08:00	0.00
	(1M)021	JUNCTION	0.00	288.56	0	19:18	0.00
	(1M)022	JUNCTION	5.81	288.74	0	19:17	0.00
	(1M)023	JUNCTION	0.00	283.02	0	19:16	0.00
	(1M)024	JUNCTION	0.00	283.26	0	19:14	0.00
	(1M)025	JUNCTION	0.00	283.89	0	19:13	0.00
	(1M)026	JUNCTION	0.00	284.25	0	19:11	0.00
	(1M)027	JUNCTION	0.00	284.89	0	19:09	0.00
	(1M)028	JUNCTION	0.00	285.17	0	07:06	0.00
	(1M)035	JUNCTION	2.72	85.18	1	07:59	0.00
	(1M)036	JUNCTION	0.00	82.78	1	08:00	0.00
	(1M)037	JUNCTION	3.49	82.47	1	07:59	0.00
	(1M)038	JUNCTION	0.00	79.02	1	08:00	0.00
	(1M)039	JUNCTION	7.71	504.68	1	07:00	0.00
	(1M)040	JUNCTION	0.00	497.90	1	13:26	0.00
	(1M)041	JUNCTION	23.69	515.29	1	07:00	18.32
1	07:00						
	(1M)092	JUNCTION	12.49	521.05	1	07:00	29.16
1	07:01						
	(1M)093	JUNCTION	23.69	508.19	1	07:00	0.00
	(1M)094	JUNCTION	10983.21	11477.92	1	07:00	10975.76
1	07:00						
	(1M)116	JUNCTION	0.00	510.73	1	10:48	0.00
	(1M)117	JUNCTION	0.00	514.82	1	10:47	0.00
	(1M)118	JUNCTION	0.00	504.41	1	10:53	0.00
	(1M)119	JUNCTION	1.18	496.15	1	10:43	0.00
	(1M)120	JUNCTION	0.00	494.65	1	10:43	0.00
	(1M)121	JUNCTION	0.00	520.57	1	05:35	26.81
1	05:35						

1	(1M)122	JUNCTION	11688.18	11785.55	1	07:00	11255.71
	07:00						
	(1M)123	JUNCTION	2.31	106.86	1	07:59	0.00
	(1M)124	JUNCTION	0.00	40.04	0	08:04	0.00
	(1M)125	JUNCTION	0.00	40.24	1	08:02	0.00
	(1M)126	JUNCTION	0.00	40.36	0	08:01	0.00
	(1M)127	JUNCTION	0.00	40.28	1	08:00	0.00
	(1M)128	JUNCTION	6.68	43.34	0	08:09	0.00
	(1M)129	JUNCTION	3.49	33.04	0	20:29	0.00
	(1M)130	JUNCTION	0.00	30.32	0	08:00	0.00
	(1M)131	JUNCTION	7.55	29.54	0	20:31	0.00
	(1M)132	JUNCTION	8.12	21.99	0	20:25	0.00
	(1M)133	JUNCTION	13.87	13.87	0	07:00	0.00
	(1M)161	JUNCTION	0.00	336.98	1	06:03	0.00
	(1M)162	JUNCTION	10739.83	11076.18	1	07:00	10731.66
1	07:00						
	(1M)163	JUNCTION	0.00	337.45	1	14:59	0.23
1	14:59						
	(1M)164	JUNCTION	0.00	336.98	1	06:10	0.00
	(1M)165	JUNCTION	11576.09	11576.09	1	07:00	11226.22
1	07:00						
	(1M)278	JUNCTION	11.61	6031.25	1	07:56	0.00
	(1M)279	JUNCTION	0.00	6019.64	1	07:56	0.00
	(1M)279B	JUNCTION	0.00	6019.65	1	07:56	0.00
	(1M)281	JUNCTION	0.00	6019.65	1	07:56	0.00
	(1M)281B	JUNCTION	6117.92	9816.50	1	07:00	3857.93
1	07:00						
	(1M)282	JUNCTION	0.00	5473.49	1	08:39	1683.32
1	08:46						
	(1M)283	JUNCTION	1.75	4575.26	1	08:41	0.00
	(1M)284	JUNCTION	0.00	4382.93	1	08:17	122.56
1	08:17						
	(1M)285	JUNCTION	0.00	4261.39	1	08:15	0.00
	(1M)285A	JUNCTION	0.00	4170.12	1	06:11	0.00
	(1M)286	JUNCTION	0.00	4665.42	1	06:10	495.31
1	06:10						
	(1M)286A	JUNCTION	10602.34	11545.38	1	07:00	6874.77
1	07:00						
	(1M)287	JUNCTION	0.00	987.29	1	08:14	0.00
	(1M)288	JUNCTION	0.00	987.51	1	08:12	0.00
	(1M)288A	JUNCTION	0.00	998.31	1	08:12	0.00
	(1M)288B	JUNCTION	0.00	1007.72	1	08:11	0.00
	(1M)288C	JUNCTION	0.00	1047.73	1	08:10	0.00
	(1N)004	JUNCTION	5.81	4619.97	1	08:39	38.33
1	07:00						
	(1N)005	JUNCTION	6.58	4744.32	1	07:00	136.55
1	07:00						
	(1N)006	JUNCTION	9.04	4788.14	1	07:00	50.39
1	07:00						
	(1N)007	JUNCTION	2.88	5211.06	1	08:30	427.03
1	08:16						
	(1N)007D	JUNCTION	0.00	506.74	1	17:13	0.00
	(1N)007E	JUNCTION	0.00	497.21	1	06:05	0.00
	(1N)008	JUNCTION	4.26	512.62	1	14:04	8.66
1	14:05						
	(1N)009	JUNCTION	7.71	501.10	1	07:00	0.00
	(1N)011	JUNCTION	12.38	508.45	1	07:00	15.06
1	07:00						
	(1N)013	JUNCTION	10570.40	11062.59	1	07:00	10556.31
1	07:00						
	(1N)014	JUNCTION	10.07	521.71	1	13:10	22.99

1	13:11						
	(1N)015	JUNCTION	2.57	500.28	1	07:00	0.00
	(1N)016	JUNCTION	0.00	498.37	1	13:03	0.44
1	13:03						
	(1N)017	JUNCTION	0.00	518.54	1	12:52	20.80
1	12:52						
	(1N)018	JUNCTION	103.33	561.29	1	07:00	43.25
1	07:00						
	(1N)019	JUNCTION	0.00	531.82	1	12:30	68.04
1	12:31						
	(1N)020	JUNCTION	4.11	500.58	1	07:00	0.00
	(1N)021	JUNCTION	8.48	504.78	1	07:00	8.31
1	07:00						
	(1N)022	JUNCTION	9443.63	9934.64	1	07:00	9427.22
1	07:00						
	(1N)023	JUNCTION	0.00	494.74	1	11:25	0.00
	(1N)024	JUNCTION	0.00	491.91	1	11:20	0.00
	(1N)025	JUNCTION	7467.44	7467.44	1	07:00	6953.62
1	07:00						
	(1N)045	JUNCTION	0.00	519.65	1	17:11	0.00
	(1N)046	JUNCTION	0.00	501.22	1	05:55	0.00
	(1N)047	JUNCTION	35521.17	35521.17	1	07:00	34949.56
1	07:00						
	(1N)109A	JUNCTION	0.00	4230.15	1	08:15	17.18
1	08:15						
	(1N)110	JUNCTION	3.91	4280.21	1	08:26	0.00
	(1N)111A	JUNCTION	0.00	4418.00	1	08:19	100.08
1	08:15						
	(1N)112A	JUNCTION	0.00	4194.69	1	08:18	0.00
	(1N)112B	JUNCTION	0.00	4204.38	1	08:17	0.00
	(1O)001	JUNCTION	7.71	285.70	0	07:05	0.00
	(1O)001A	JUNCTION	0.00	278.09	0	07:04	0.00
	(1O)002	JUNCTION	8.12	278.81	0	07:04	0.00
	(1O)002A	JUNCTION	0.00	270.74	0	07:04	0.00
	(1O)003	JUNCTION	0.00	271.13	0	07:03	0.00
	(1O)004	JUNCTION	7.97	271.89	0	07:02	0.00
	(1O)005A	JUNCTION	24.92	264.09	0	07:02	0.00
	(1O)005B	JUNCTION	0.00	241.15	2	18:13	0.00
	(1O)005C	JUNCTION	0.00	242.30	2	18:13	0.00
	(1O)005D	JUNCTION	0.00	243.59	0	19:02	0.00
	(1O)005E	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)010	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)011	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)012	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)013	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)014	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)015	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)016	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)017	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)018	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)019	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)020	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)021	JUNCTION	0.00	0.00	0	00:00	0.00
	(1O)072	JUNCTION	16.86	1876.45	1	08:03	0.00
	(1O)157	JUNCTION	21903.13	21903.13	1	07:00	17257.78
1	07:00						
	(1O)300	JUNCTION	16.75	1101.57	1	08:10	0.00
	(1O)301	JUNCTION	0.00	1157.91	1	08:06	0.00
	(1O)302	JUNCTION	14.70	1131.91	1	08:05	0.00
	(1O)303	JUNCTION	2.72	1471.86	1	08:03	0.00
	(1O)304A	JUNCTION	0.00	1863.50	1	08:29	0.00

1	(10) 304B	JUNCTION	0.00	1296.81	1	08:33	399.63
	08:24						
1	(10) 305	JUNCTION	26578.39	31253.17	1	07:00	30031.09
	07:00						
	(10) 305A	JUNCTION	69.57	1252.48	1	07:13	0.00
1	(10) 306	JUNCTION	17.78	4694.94	1	10:05	4.07
	10:05						
	(10) 306A	JUNCTION	2.36	4660.06	1	07:00	0.00
	(10) 307	JUNCTION	0.00	4657.70	1	05:47	0.00
1	(10) 308	JUNCTION	8128.32	16987.12	1	07:00	12314.03
	07:00						
	(10) 308A	JUNCTION	0.00	4608.07	1	05:40	0.00
1	(10) 309	JUNCTION	14748.80	14748.80	1	07:00	10212.28
	07:00						
	(1P) 002	JUNCTION	0.00	1630.85	1	05:11	0.00
1	(1P) 003	JUNCTION	0.00	1656.42	1	11:49	22.15
	11:49						
0	(1P) 004	JUNCTION	0.00	1161.48	0	21:05	87.42
	21:05						
	(1P) 005	JUNCTION	0.00	1159.35	0	21:03	0.00
1	(1P) 006	JUNCTION	0.00	1232.06	1	21:00	67.78
	13:59						
	(1P) 007	JUNCTION	0.00	1224.73	0	08:00	0.00
1	(1P) 008	JUNCTION	412.26	2453.91	1	07:00	1230.87
	07:00						
	(1P) 008A	JUNCTION	0.00	2041.64	1	05:14	0.00
1	(1P) 009	JUNCTION	17556.38	18199.92	1	07:00	16124.45
	07:00						
	(1P) 010	JUNCTION	0.00	809.49	0	08:07	0.00
	(1P) 011	JUNCTION	5.14	811.23	0	08:06	0.00
	(1P) 012	JUNCTION	0.00	811.74	0	08:04	0.00
	(1P) 013	JUNCTION	0.00	817.28	0	08:03	0.00
	(1P) 014	JUNCTION	0.00	822.99	0	08:02	0.00
	(1P) 015	JUNCTION	0.00	832.23	0	08:01	0.00
	(1P) 016	JUNCTION	0.00	827.86	0	08:01	0.00
	(1P) 016A	JUNCTION	0.00	833.91	0	08:00	0.00
	(1P) 017	JUNCTION	9.04	879.77	0	08:00	0.00
	(1P) 018	JUNCTION	721.50	721.50	0	07:00	0.00
	(1P) 024	JUNCTION	51.54	51.54	0	07:00	0.00
	(1P) 042	JUNCTION	0.00	583.99	1	11:48	0.00
1	(1P) 042A	JUNCTION	0.00	591.43	1	11:56	8.06
	06:12						
1	(1P) 043	JUNCTION	14239.20	14246.23	1	07:00	13636.03
	07:00						
	(1P) 044	JUNCTION	0.00	0.00	0	00:00	0.00
	(1P) 065	JUNCTION	10.33	10.33	0	07:00	0.00
	(1P) 073	JUNCTION	6.27	6.27	0	07:00	0.00
	(1P) 079	JUNCTION	5.70	5.70	0	07:00	0.00
1	(2A) 001	JUNCTION	0.00	9981.89	1	08:50	331.88
	08:50						
	(2A) 002	JUNCTION	0.00	9834.10	1	08:50	0.00
	(2A) 003	JUNCTION	0.00	9841.85	1	08:50	0.00
	(2A) 004	JUNCTION	0.00	9867.21	1	08:51	0.00
	(2A) 005	JUNCTION	0.00	9826.94	1	06:37	0.00
1	(2A) 006	JUNCTION	0.00	10453.43	1	08:52	529.08
	09:01						
	(2A) 007	JUNCTION	0.00	10395.05	1	09:00	0.00
	(2A) 008	JUNCTION	0.00	10324.72	1	08:58	0.00
	(2A) 009	JUNCTION	0.00	10299.21	1	08:55	0.00
	(2A) 010	JUNCTION	0.00	10021.88	1	08:49	0.00
	(2A) 011	JUNCTION	0.00	10205.11	1	08:47	93.93

1	08:47						
	(2A) 012	JUNCTION	0.00	9937.19	1	06:29	0.00
	(2A) 013	JUNCTION	0.00	12017.61	1	07:02	2067.70
1	07:02						
	(2A) 014	JUNCTION	1084.57	12238.85	1	05:44	165.55
1	07:00						
	(2A) 015	JUNCTION	8.68	11089.80	1	07:00	0.00
	(2A) 016	JUNCTION	0.00	11871.40	1	06:11	767.89
1	06:11						
	(2A) 017	JUNCTION	8995.11	20063.76	1	07:00	8185.08
1	07:00						
	(2A) 018	JUNCTION	0.00	11068.65	1	06:34	0.00
	(2A) 019	JUNCTION	0.00	11085.53	1	08:16	0.00
	(2A) 020	JUNCTION	26543.41	30726.97	1	07:00	19620.16
1	07:00						
	(2A) 021	JUNCTION	0.00	4249.39	1	07:26	0.00
	(2A) 022	JUNCTION	0.00	4250.10	1	07:24	0.00
	(2A) 023	JUNCTION	0.00	4250.37	1	07:24	0.00
	(2A) 024	JUNCTION	0.00	4250.38	1	07:24	0.00
	(2A) 025	JUNCTION	0.00	4250.36	1	07:23	0.00
	(2A) 026	JUNCTION	0.00	4250.51	1	07:23	0.00
	(2A) 027	JUNCTION	0.00	4251.84	1	07:22	0.00
	(2A) 028	JUNCTION	0.00	4252.42	1	07:21	0.00
	(2A) 029	JUNCTION	0.00	4252.99	1	07:20	0.00
	(2A) 030	JUNCTION	0.00	4253.53	1	07:19	0.00
	(2A) 031	JUNCTION	0.00	4255.02	1	07:18	0.00
	(2A) 032	JUNCTION	0.00	4255.35	1	07:17	0.00
	(2A) 033	JUNCTION	0.00	4255.75	1	07:17	0.00
	(2A) 034	JUNCTION	1.03	4255.81	1	07:16	0.00
	(2A) 035	JUNCTION	0.00	4256.16	1	07:15	0.00
	(2A) 036	JUNCTION	0.00	4257.99	1	07:14	0.00
	(2A) 037	JUNCTION	0.00	4259.99	1	07:12	0.00
	(2A) 038	JUNCTION	0.00	4261.78	1	07:11	0.00
	(2A) 039	JUNCTION	0.00	4264.25	1	07:10	0.00
	(2A) 040	JUNCTION	0.00	4263.48	1	07:09	0.00
	(2A) 041	JUNCTION	0.00	4262.12	1	07:07	0.00
	(2A) 042	JUNCTION	0.00	4263.83	1	07:06	0.00
	(2A) 043	JUNCTION	0.00	4266.23	1	07:05	0.00
	(2A) 044	JUNCTION	0.00	4270.63	1	07:04	0.00
	(2A) 045	JUNCTION	0.00	4271.35	1	07:03	0.00
	(2A) 046	JUNCTION	0.00	4271.71	1	07:02	0.00
	(2A) 047	JUNCTION	0.00	4275.09	1	07:00	0.00
	(2A) 049	JUNCTION	0.00	5557.50	1	07:15	0.00
	(2A) 050	JUNCTION	0.00	5557.61	1	07:13	0.00
	(2A) 051	JUNCTION	0.00	5557.68	1	07:12	0.00
	(2A) 052	JUNCTION	0.00	5557.76	1	07:11	0.00
	(2A) 053	JUNCTION	0.00	5557.83	1	07:10	0.00
	(2A) 054	JUNCTION	0.00	5557.87	1	07:09	0.00
	(2A) 055	JUNCTION	0.00	5558.13	1	07:08	0.00
	(2A) 056	JUNCTION	0.00	5558.48	1	07:07	0.00
	(2A) 057	JUNCTION	0.00	5558.18	1	07:05	0.00
	(2A) 058	JUNCTION	0.00	5009.27	1	07:03	0.00
	(2A) 059	JUNCTION	0.00	5009.35	1	07:02	0.00
	(2A) 060	JUNCTION	0.00	5009.54	1	07:01	0.00
	(2A) 061	JUNCTION	0.00	5009.55	1	07:00	0.00
	(2A) 062	JUNCTION	0.00	5009.43	1	07:00	0.00
	(2A) 063	JUNCTION	0.00	9170.41	1	07:00	4289.59
1	07:01						
	(2A) 064	JUNCTION	2358.02	7504.05	1	07:00	0.00
	(2A) 065	JUNCTION	0.00	5146.39	1	09:00	0.00
	(2A) 066	JUNCTION	0.00	5146.53	1	08:59	0.00

	(2A)067	JUNCTION	0.00	5148.56	1	08:59	0.00
	(2A)068	JUNCTION	0.00	5146.03	1	06:44	0.00
	(2A)069	JUNCTION	0.00	550.03	1	09:52	0.00
	(2C)001	JUNCTION	0.00	556.44	1	05:48	7.45
1	05:49						
	(2C)002	JUNCTION	0.00	660.58	1	09:37	103.17
1	06:00						
	(2C)003	JUNCTION	8080.93	8712.58	1	07:00	8046.24
1	07:00						
	(2C)004	JUNCTION	0.00	643.63	1	08:43	0.00
	(2C)005	JUNCTION	0.00	632.87	1	08:43	0.00
	(2C)006	JUNCTION	0.00	668.60	1	08:45	33.21
1	06:17						
	(2C)007	JUNCTION	0.00	677.95	1	08:38	5.04
1	08:39						
	(2C)008	JUNCTION	0.00	665.88	1	08:40	0.00
	(2D)001	JUNCTION	0.00	466.33	1	06:53	0.00
	(2D)001A	JUNCTION	0.00	895.98	1	08:18	428.85
1	07:47						
	(2D)002	JUNCTION	0.00	908.95	1	07:47	13.77
1	07:48						
	(2D)003	JUNCTION	457.05	968.07	1	07:00	56.11
1	07:00						
	(2D)004	JUNCTION	0.00	311.87	1	08:01	0.00
	(2D)005	JUNCTION	0.00	313.14	1	08:00	0.00
	(2D)006	JUNCTION	21.27	310.53	1	07:59	0.00
	(2D)007	JUNCTION	0.00	289.82	1	08:00	0.00
	(2D)008	JUNCTION	0.00	289.73	1	08:00	0.00
	(2D)009	JUNCTION	6.68	289.26	1	07:00	0.00
	(2D)010	JUNCTION	0.00	313.00	1	05:22	30.43
1	05:22						
	(2D)011	JUNCTION	39388.45	39514.51	1	07:00	39169.05
1	07:00						
	(2D)012	JUNCTION	0.26	167.39	0	08:00	0.00
	(2D)013	JUNCTION	153.74	153.74	0	07:00	0.00
	(2D)014	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)015	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)016	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)017	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)018	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)019	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)020	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)021	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)022	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)023	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)024	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)025	JUNCTION	0.00	0.00	0	00:00	0.00
	(2D)039	JUNCTION	0.00	206.30	1	06:52	0.00
	(2D)040	JUNCTION	0.00	541.60	1	08:17	205.60
1	08:17						
	(2D)041	JUNCTION	0.00	533.99	1	07:13	0.00
	(2D)042	JUNCTION	0.00	541.31	1	08:08	4.12
1	08:09						
	(2D)043	JUNCTION	0.00	539.62	1	08:01	0.00
	(2D)044	JUNCTION	0.00	504.41	1	12:36	0.00
	(2D)045	JUNCTION	5.14	503.56	1	07:00	0.00
	(2D)045A	JUNCTION	12173.05	12691.51	1	07:00	12185.08
1	07:00						
	(2D)046	JUNCTION	2.57	518.84	1	07:00	0.00
	(2D)046A	JUNCTION	12867.95	12867.95	1	07:00	12322.09
1	07:00						

(2D) 241	JUNCTION	0.00	1691.78	1	07:13	0.00
(2D) 242	JUNCTION	0.00	1681.76	1	07:12	0.00
(2D) 243	JUNCTION	0.00	1676.52	1	07:10	0.00
(2D) 245	JUNCTION	0.00	1804.26	1	07:06	259.12
1 07:06						
(2D) 246	JUNCTION	0.00	1812.58	1	07:05	0.00
(2D) 247	JUNCTION	0.00	1820.28	1	07:03	0.00
(2D) 248	JUNCTION	0.00	1827.66	1	07:02	0.00
(2D) 249	JUNCTION	0.00	1835.87	1	07:01	0.00
(2D) 250	JUNCTION	0.00	1849.42	1	07:00	0.00
(2D) 251	JUNCTION	1649.98	1847.60	1	07:00	0.00
(2D) 252	JUNCTION	0.00	246.22	1	08:13	0.00
(2D) 253	JUNCTION	0.00	246.34	1	08:12	0.00
(2D) 254	JUNCTION	0.00	246.20	1	08:11	0.00
(2D) 255	JUNCTION	0.00	246.07	1	08:08	0.00
(2D) 256	JUNCTION	0.00	246.03	1	08:07	0.00
(2D) 257	JUNCTION	0.00	246.32	1	08:06	0.00
(2D) 258	JUNCTION	0.00	246.51	1	08:05	0.00
(2D) 259	JUNCTION	0.00	247.08	1	08:04	0.00
(2D) 260	JUNCTION	0.00	247.08	1	08:03	0.00
(2D) 261	JUNCTION	0.00	247.39	1	08:02	0.00
(2D) 262	JUNCTION	0.00	247.83	1	08:00	0.00
(2D) 263	JUNCTION	18.04	247.85	0	08:04	0.00
(2D) 264	JUNCTION	0.00	240.36	0	08:02	0.00
(2D) 265	JUNCTION	0.00	247.65	0	08:01	0.00
(2D) 266	JUNCTION	0.00	265.93	0	08:00	0.00
(2D) 267	JUNCTION	227.38	227.38	0	07:00	0.00
(2E) 001	JUNCTION	0.00	6560.14	1	08:29	1409.82
1 06:38						
(2E) 002	JUNCTION	0.00	11022.88	1	05:51	4467.04
1 05:52						
(2E) 003	JUNCTION	14480.31	18013.98	1	07:00	6952.04
1 07:00						
(2E) 004	JUNCTION	0.00	3604.29	1	14:56	0.00
(2E) 005	JUNCTION	0.00	3536.36	1	14:52	0.00
(2E) 006	JUNCTION	0.00	6276.52	1	09:55	2650.68
1 09:55						
(2E) 007	JUNCTION	0.00	5963.78	1	09:52	0.00
(2E) 008	JUNCTION	0.00	5975.27	1	09:51	0.00
(2E) 009	JUNCTION	0.00	6126.92	1	09:50	0.00
(2E) 010	JUNCTION	0.00	6063.07	1	09:57	0.00
(2E) 011	JUNCTION	0.00	6037.05	1	09:41	0.00
(2E) 012	JUNCTION	0.00	5931.28	1	09:57	0.00
(2E) 013	JUNCTION	0.00	5937.41	1	06:25	17.13
1 06:25						
(2E) 014	JUNCTION	10677.67	16517.65	1	07:00	10573.00
1 07:00						
(2E) 043	JUNCTION	133.34	133.34	0	07:00	0.00
(2F) 001	JUNCTION	0.00	5818.48	1	08:11	37.65
1 08:11						
(2F) 002	JUNCTION	0.00	5838.51	1	08:03	11.68
1 08:03						
(2F) 003	JUNCTION	0.00	5751.88	1	06:09	0.00
(2F) 004	JUNCTION	3806.74	8469.56	1	06:30	2717.11
1 06:30						
(2F) 005	JUNCTION	147.17	4691.45	1	07:00	0.00
(2F) 006	JUNCTION	0.00	4591.76	1	12:20	0.00
(2F) 007	JUNCTION	0.00	4546.15	1	12:19	0.00
(2F) 008	JUNCTION	0.00	4544.29	1	05:32	0.00
(2F) 009	JUNCTION	0.00	10323.81	1	05:57	5768.11
1 05:57						

	(2F)010	JUNCTION	16817.97	18850.34	1	07:00	12648.29
1	07:00						
	(2F)011	JUNCTION	2298.31	3754.62	1	07:00	1714.60
1	07:00						
	(2F)012	JUNCTION	0.00	1459.98	1	08:07	0.00
	(2F)013	JUNCTION	0.00	1460.10	1	08:04	0.00
	(2F)014	JUNCTION	0.00	1460.29	1	08:03	0.00
	(2F)015	JUNCTION	0.00	1460.72	1	08:01	0.00
	(2F)016	JUNCTION	0.00	1461.91	1	08:00	0.00
	(2F)017	JUNCTION	15.83	1459.37	1	07:00	0.00
	(2F)018	JUNCTION	0.00	1445.82	1	08:43	0.00
	(2F)019	JUNCTION	0.00	1445.04	1	08:37	0.00
	(2F)020	JUNCTION	0.00	1447.22	1	08:37	0.00
	(2F)021	JUNCTION	0.00	1447.14	1	08:36	0.00
	(2F)022	JUNCTION	0.00	1443.55	1	06:35	0.00
	(2F)023	JUNCTION	5282.13	5492.52	1	06:30	4841.04
1	06:30						
	(2F)024	JUNCTION	0.00	210.70	1	11:35	0.00
	(2F)025	JUNCTION	7730.84	7774.80	1	07:00	7562.16
1	07:00						
	(2F)026	JUNCTION	0.00	87.97	0	21:46	0.00
	(2F)027	JUNCTION	0.00	88.37	0	21:36	0.00
	(2F)028	JUNCTION	0.00	88.73	0	21:29	0.00
	(2F)029	JUNCTION	0.00	90.16	0	08:21	0.00
	(2F)030	JUNCTION	0.00	93.68	1	08:00	0.00
	(2F)031	JUNCTION	0.00	95.54	1	08:05	0.00
	(2F)032	JUNCTION	0.00	107.82	1	08:00	0.00
	(2F)033	JUNCTION	86.94	86.94	0	07:00	0.00
	(2G)001	JUNCTION	0.00	795.54	0	21:06	0.00
	(2G)002	JUNCTION	9733.36	10540.03	1	07:00	9740.82
1	07:00						
	(2G)002A	JUNCTION	0.00	1625.50	1	08:00	816.97
1	08:01						
	(2G)003	JUNCTION	0.00	640.69	1	08:00	0.00
	(2G)004	JUNCTION	55.65	639.23	1	07:01	0.00
	(2G)005	JUNCTION	0.00	612.25	1	08:01	0.00
	(2G)006	JUNCTION	14.90	603.05	1	08:00	0.00
	(2G)007	JUNCTION	47.02	560.62	1	07:00	0.00
	(2G)008	JUNCTION	0.00	638.01	1	05:25	123.37
1	05:25						
	(2G)009	JUNCTION	17620.41	18000.18	1	07:00	17351.55
1	07:00						
	(2G)010	JUNCTION	0.00	406.17	3	07:25	0.00
	(2G)011	JUNCTION	9.66	408.78	0	19:18	0.00
	(2G)012	JUNCTION	0.00	378.25	2	19:21	0.00
	(2G)012A	JUNCTION	0.00	378.48	0	19:16	0.00
	(2G)013	JUNCTION	0.00	379.00	0	19:16	0.00
	(2G)013A	JUNCTION	28.36	381.13	0	19:16	0.00
	(2G)014	JUNCTION	0.00	349.17	0	07:09	0.00
	(2G)015	JUNCTION	10.07	399.80	2	07:32	49.90
2	07:32						
	(2G)016	JUNCTION	108.22	474.19	1	07:00	85.18
1	07:00						
	(2G)016A	JUNCTION	0.00	393.83	1	05:44	27.86
1	05:45						
	(2G)018	JUNCTION	27.85	411.34	1	07:00	17.51
1	07:00						
	(2G)019	JUNCTION	23242.96	23626.32	1	07:00	23222.27
1	07:00						
	(2G)020	JUNCTION	3.85	390.41	1	07:00	7.05
1	07:00						

1	(2G)021 07:00	JUNCTION	3.85	390.19	1	07:00	3.64
1	(2G)022 07:00	JUNCTION	6.17	392.40	1	07:00	6.06
1	(2G)023 07:00	JUNCTION	5.81	390.00	1	07:00	3.77
1	(2G)024 05:04	JUNCTION	0.00	605.28	1	05:03	221.09
1	(2G)025 06:25	JUNCTION	0.00	1258.22	1	06:25	651.71
1	(2G)026 07:00	JUNCTION	12520.45	12520.45	1	07:00	11637.81
1	(2G)040 07:00	JUNCTION	36750.02	36952.19	1	07:00	35928.02
	(2G)041	JUNCTION	0.00	262.20	0	08:13	0.00
	(2G)042	JUNCTION	0.00	263.81	1	08:08	0.00
	(2G)043	JUNCTION	0.00	265.85	0	08:04	0.00
	(2G)043A	JUNCTION	0.00	271.89	1	08:02	0.00
	(2G)044	JUNCTION	0.00	296.58	1	08:00	0.00
	(2G)045	JUNCTION	250.45	250.45	0	07:00	0.00
1	(2G)359 07:00	JUNCTION	14646.10	14646.10	1	07:00	14243.05
	(2H)001	JUNCTION	0.00	2530.38	1	11:00	0.00
	(2H)002	JUNCTION	13.51	2485.98	1	07:00	0.00
1	(2H)003 10:52	JUNCTION	0.00	2507.52	1	10:52	34.55
	(2H)005	JUNCTION	0.00	2501.16	1	10:48	0.00
1	(2H)006 05:58	JUNCTION	0.00	2766.03	1	05:58	268.27
1	(2H)007 07:00	JUNCTION	4400.73	7306.95	1	07:00	4533.23
	(2H)008	JUNCTION	0.00	2910.04	1	09:44	0.00
	(2H)009	JUNCTION	0.00	2911.93	1	09:44	0.00
	(2H)010	JUNCTION	0.00	2918.42	1	09:44	0.00
	(2H)011	JUNCTION	0.00	2906.23	1	05:53	0.00
1	(2H)012 07:00	JUNCTION	24898.92	27577.16	1	07:00	24650.26
1	(2H)013 06:00	JUNCTION	3530.23	4983.65	1	06:00	2303.25
	(2H)014	JUNCTION	2.72	1465.88	1	07:59	0.00
	(2H)015	JUNCTION	0.00	1463.50	1	08:00	0.00
	(2H)016	JUNCTION	3.08	1463.16	1	07:56	0.00
	(2H)017	JUNCTION	0.00	1460.67	1	08:00	0.00
	(2H)017A	JUNCTION	6.17	1460.08	1	07:55	0.00
	(2H)018	JUNCTION	0.00	1454.19	1	08:00	0.00
	(2H)019	JUNCTION	3.85	1453.91	1	07:54	0.00
	(2H)020	JUNCTION	1.18	1450.06	1	07:54	0.00
	(2H)021	JUNCTION	1.18	1448.88	1	07:50	0.00
	(2H)022	JUNCTION	0.00	1008.67	1	10:06	0.00
	(2H)023	JUNCTION	0.00	1010.18	1	10:06	0.00
	(2H)024	JUNCTION	0.00	1008.27	1	10:16	0.00
1	(2H)025 05:50	JUNCTION	0.00	1017.06	1	10:12	9.93
	(2H)026	JUNCTION	1.95	441.33	1	07:49	0.00
	(2H)027	JUNCTION	0.00	439.79	1	08:02	0.00
	(2H)028	JUNCTION	0.00	439.99	1	08:01	0.00
	(2H)029	JUNCTION	0.00	440.94	1	08:00	0.00
	(2H)030	JUNCTION	11.61	439.38	1	07:00	0.00
1	(2H)031 05:27	JUNCTION	0.00	541.79	1	05:26	114.02
	(2H)032	JUNCTION	7.71	2143.39	1	06:30	1600.35

1	06:30						
	(2H)033	JUNCTION	1717.73	2137.22	1	06:30	0.00
	(2H)034	JUNCTION	0.00	420.45	1	08:00	0.00
	(2H)036	JUNCTION	3.24	420.12	1	07:00	0.00
	(2H)037	JUNCTION	0.00	417.26	1	11:33	0.00
	(2H)038	JUNCTION	0.00	417.24	1	11:32	0.00
	(2H)039	JUNCTION	0.00	417.25	1	11:31	0.00
	(2H)040	JUNCTION	0.00	417.27	1	11:29	0.00
	(2H)041	JUNCTION	0.00	417.33	1	11:28	0.00
	(2H)042	JUNCTION	0.00	417.59	1	11:27	0.00
	(2H)043	JUNCTION	0.00	417.40	1	11:26	0.00
	(2H)044	JUNCTION	0.00	417.49	1	11:25	0.00
	(2H)045	JUNCTION	0.00	417.74	1	11:25	0.00
	(2H)046	JUNCTION	0.00	417.10	1	11:31	0.00
	(2H)047	JUNCTION	0.00	739.15	1	06:26	322.26
1	06:26						
	(2H)048	JUNCTION	0.00	740.13	1	09:44	0.00
	(2H)049	JUNCTION	7117.06	7477.05	1	07:00	6731.04
1	07:00						
	(2H)050	JUNCTION	0.00	360.54	1	10:58	0.00
	(2H)051	JUNCTION	0.00	361.36	1	10:57	0.00
	(2H)051A	JUNCTION	0.00	361.52	1	10:57	0.00
	(2H)052	JUNCTION	0.00	360.24	1	11:09	0.00
	(2H)053	JUNCTION	0.00	1058.09	1	07:53	697.58
1	07:53						
	(2H)054	JUNCTION	0.00	553.84	1	06:42	0.17
1	06:42						
	(2H)054A	JUNCTION	3.85	556.99	1	05:42	3.00
1	05:42						
	(2H)055	JUNCTION	0.00	554.64	1	05:42	0.00
	(2H)055A	JUNCTION	0.00	554.64	1	05:42	0.00
	(2H)056	JUNCTION	0.00	554.64	1	05:45	0.00
	(2H)057	JUNCTION	4.63	558.14	1	07:00	3.51
1	07:00						
	(2H)058	JUNCTION	4802.74	4802.74	1	07:00	4241.89
1	07:00						
	(2H)285	JUNCTION	8.12	504.51	1	07:00	0.00
	(2H)286	JUNCTION	10430.50	10924.51	1	07:00	10420.87
1	07:00						
	(2H)287	JUNCTION	0.00	495.27	1	07:42	0.00
	(2H)288	JUNCTION	0.00	494.18	1	07:39	0.00
	(2H)289	JUNCTION	50.25	548.68	1	07:31	53.93
1	07:00						
	(2H)290	JUNCTION	1296.96	1296.96	1	07:00	798.43
1	07:00						
	(2I)001	JUNCTION	3960.63	5597.15	1	07:00	4166.61
1	07:00						
	(2I)001A	JUNCTION	0.00	1419.61	1	05:09	403.31
1	05:09						
	(2I)002	JUNCTION	13.41	1639.08	1	07:00	0.00
	(2I)003	JUNCTION	4992.11	6559.07	1	07:00	4930.87
1	07:00						
	(2I)004	JUNCTION	0.00	1633.82	1	09:14	62.04
1	09:08						
	(2I)005	JUNCTION	0.00	2953.72	1	08:02	1299.00
1	08:02						
	(2I)006	JUNCTION	0.00	1626.05	1	08:00	0.00
	(2I)008	JUNCTION	1501.81	2895.66	1	07:00	1268.85
1	07:00						
	(2I)009	JUNCTION	3.49	1396.68	1	07:45	0.00
	(2I)010	JUNCTION	0.00	1394.25	1	07:45	0.00

	(2I)011	JUNCTION	6.58	1395.18	1	07:44	0.00
	(2I)012	JUNCTION	0.00	1391.66	1	07:44	0.00
	(2I)013	JUNCTION	0.00	1385.97	1	06:02	0.00
1	(2I)014	JUNCTION	4838.60	4838.60	1	07:00	3447.53
	07:00						
	(2I)015	JUNCTION	0.00	0.00	0	00:00	0.00
	(2I)016	JUNCTION	0.00	0.00	0	00:00	0.00
	(2I)017	JUNCTION	0.00	0.00	0	00:00	0.00
	(2I)017A	JUNCTION	6.17	710.19	1	07:00	0.00
	(2I)018	JUNCTION	0.00	863.46	1	10:49	158.58
1	10:49						
	(2I)019	JUNCTION	0.00	862.71	1	10:54	0.00
	(2I)020	JUNCTION	11371.51	12140.27	1	07:00	11268.26
1	07:00						
	(2I)021	JUNCTION	0.00	1139.34	1	05:35	370.29
1	05:35						
	(2I)021A	JUNCTION	0.00	1141.61	1	06:02	0.00
	(2I)021B	JUNCTION	2181.83	2800.61	1	07:00	1653.88
1	07:00						
	(2I)021C	JUNCTION	0.00	768.19	1	10:30	143.08
1	10:30						
	(2I)022	JUNCTION	0.00	765.33	1	10:30	0.00
	(2I)023	JUNCTION	0.00	764.11	1	10:26	0.00
	(2I)024	JUNCTION	0.00	765.04	1	10:22	0.81
1	10:23						
	(2I)025	JUNCTION	0.00	759.11	1	05:44	0.00
	(2I)025A	JUNCTION	17154.00	17882.13	1	07:00	17111.19
1	07:00						
	(2I)026	JUNCTION	0.00	768.03	1	09:05	0.00
	(2I)027	JUNCTION	0.00	728.13	1	05:14	0.00
	(2I)028	JUNCTION	56.42	847.58	1	07:00	117.98
1	07:00						
	(2I)029	JUNCTION	7850.55	7850.55	1	07:00	7048.08
1	07:00						
	(2I)044	JUNCTION	0.00	1392.70	1	08:54	0.00
	(2I)045	JUNCTION	0.00	1403.65	1	09:05	0.22
1	09:05						
	(2I)046	JUNCTION	0.00	1401.75	1	08:55	0.00
	(2I)047	JUNCTION	0.00	1400.38	1	05:44	0.00
	(2I)048	JUNCTION	0.00	1400.38	1	05:09	0.00
	(2I)049	JUNCTION	12425.06	13264.83	1	06:30	11859.17
1	06:30						
	(2I)050	JUNCTION	0.00	885.68	1	05:16	0.00
	(2I)051	JUNCTION	22.40	892.95	1	05:16	3.99
1	05:16						
	(2I)052	JUNCTION	0.00	887.47	1	06:01	0.00
	(2I)053	JUNCTION	0.00	889.05	1	09:15	0.79
1	09:15						
	(2I)054	JUNCTION	7931.13	8818.59	1	07:00	7928.65
1	07:00						
	(2I)055	JUNCTION	36.07	921.75	1	07:00	34.28
1	07:00						
	(2I)056	JUNCTION	0.00	887.67	1	08:27	0.10
1	08:27						
	(2I)057	JUNCTION	0.00	887.47	1	06:15	0.00
	(2I)058	JUNCTION	0.00	888.51	1	08:31	0.52
1	08:32						
	(2I)059	JUNCTION	10160.43	10160.43	1	06:30	9270.19
1	06:30						
	(2J)001	JUNCTION	0.00	4177.86	1	11:35	0.00
	(2J)002	JUNCTION	0.00	4150.08	1	10:02	0.00

	(2J) 003	JUNCTION	0.00	4153.24	1	10:01	0.00
	(2J) 004	JUNCTION	0.00	4259.24	1	11:28	84.84
1	11:29						
	(2J) 005	JUNCTION	0.00	4248.52	1	11:28	0.00
	(2J) 006	JUNCTION	0.00	4208.91	1	11:25	0.00
	(2J) 007	JUNCTION	0.00	4207.00	1	11:05	0.32
1	11:05						
	(2J) 008	JUNCTION	7797.91	11726.87	1	07:00	7519.02
1	07:00						
	(2J) 009	JUNCTION	0.00	4012.43	1	11:19	0.00
	(2J) 010	JUNCTION	0.00	4037.72	1	11:18	0.00
	(2J) 011	JUNCTION	35.45	4021.96	1	11:00	0.00
	(2J) 012	JUNCTION	0.00	3927.13	1	11:15	0.00
	(2J) 013	JUNCTION	0.00	4071.35	1	11:01	116.19
1	11:03						
	(2J) 014	JUNCTION	0.00	3901.93	1	11:00	0.00
	(2J) 015	JUNCTION	0.00	3697.82	1	08:03	0.00
	(2J) 016	JUNCTION	0.00	3697.80	1	08:02	0.00
	(2J) 017	JUNCTION	0.00	3699.77	1	11:02	0.00
	(2J) 018	JUNCTION	0.00	3701.83	1	11:01	0.00
	(2J) 019	JUNCTION	0.00	1213.86	1	12:56	0.00
	(2J) 020	JUNCTION	27.59	391.24	1	07:17	308.11
1	07:17						
	(2J) 021	JUNCTION	6.11	363.65	1	07:00	0.00
	(2J) 022	JUNCTION	0.00	390.91	1	18:03	32.64
1	18:03						
	(2J) 023	JUNCTION	0.00	831.44	1	05:34	441.27
1	05:34						
	(2J) 026	JUNCTION	9999.67	10477.98	1	07:00	9980.04
1	07:00						
	(2J) 027	JUNCTION	0.00	479.02	1	09:59	0.00
	(2J) 028	JUNCTION	0.00	492.72	1	06:06	14.41
1	06:07						
	(2J) 029	JUNCTION	7656.49	7959.90	1	07:00	7462.23
1	07:00						
	(2J) 030	JUNCTION	0.00	316.96	1	09:42	0.00
	(2J) 031	JUNCTION	0.00	303.41	1	06:09	0.00
	(2J) 032	JUNCTION	5342.10	5342.10	1	07:00	5033.06
1	07:00						
	(2J) 033	JUNCTION	0.00	0.00	0	00:00	0.00
	(2J) 040	JUNCTION	6.83	491.28	1	13:14	0.00
	(2J) 041	JUNCTION	0.00	479.90	1	13:10	0.00
	(2J) 042	JUNCTION	0.00	475.08	1	07:12	0.00
	(2J) 043	JUNCTION	7.71	475.08	1	07:00	0.00
	(2J) 044	JUNCTION	7.61	492.12	1	12:37	17.50
1	12:38						
	(2J) 045	JUNCTION	4.26	464.51	1	07:00	0.00
	(2J) 045A	JUNCTION	0.00	477.03	1	12:57	15.61
1	07:32						
	(2J) 046	JUNCTION	5.81	475.86	1	07:00	0.00
	(2J) 047	JUNCTION	12051.33	12371.70	1	07:00	11891.07
1	07:00						
	(2J) 048	JUNCTION	14.28	328.48	1	20:06	0.00
	(2J) 049	JUNCTION	0.00	314.61	1	20:06	0.00
	(2J) 050	JUNCTION	5.40	319.83	1	20:05	0.00
	(2J) 051	JUNCTION	0.00	316.99	1	20:05	0.00
	(2J) 052	JUNCTION	0.00	305.55	1	20:08	0.00
	(2J) 053	JUNCTION	14.28	325.09	1	07:00	19.72
1	07:00						
	(2J) 054	JUNCTION	10.43	324.06	1	07:00	13.26
1	07:00						

	(2J)055	JUNCTION	0.00	314.46	1	05:31	0.82
1	05:31						
	(2J)056	JUNCTION	23268.99	23322.20	1	07:00	22964.18
1	07:00						
	(2J)057	JUNCTION	0.00	76.07	0	08:00	0.00
	(2J)060	JUNCTION	64.95	64.95	0	07:00	0.00
	(2K)001	JUNCTION	54.11	1780.01	1	07:31	568.41
1	07:32						
	(2K)002	JUNCTION	38.64	1309.89	1	07:30	0.00
	(2K)003	JUNCTION	2.31	1271.25	1	07:00	0.00
	(2K)004	JUNCTION	0.00	1269.34	1	10:02	0.00
	(2K)005	JUNCTION	0.00	1269.74	1	09:57	0.00
	(2K)006	JUNCTION	0.00	1270.09	1	09:57	0.00
	(2K)007	JUNCTION	0.00	1269.70	1	09:56	0.00
	(2K)008	JUNCTION	0.00	1273.65	1	09:57	0.00
	(2K)009	JUNCTION	0.00	1275.74	1	09:56	0.00
	(2K)010	JUNCTION	0.00	1270.94	1	09:57	0.00
	(2K)011	JUNCTION	3.24	1376.03	1	09:40	104.52
1	09:40						
	(2K)012	JUNCTION	0.00	1368.91	1	05:54	0.00
	(2K)013	JUNCTION	6708.72	7637.93	1	07:00	6261.88
1	07:00						
	(2K)014	JUNCTION	6094.12	6790.49	1	07:00	5854.44
1	07:00						
	(2K)015	JUNCTION	0.00	860.24	1	10:19	160.23
1	10:20						
	(2K)016	JUNCTION	2.31	863.53	1	10:19	0.00
	(2K)017	JUNCTION	1.54	821.60	1	07:00	0.00
	(2K)018	JUNCTION	2.31	866.36	1	07:00	46.30
1	07:00						
	(2K)018A	JUNCTION	0.00	945.34	1	05:31	79.55
1	05:32						
	(2K)019	JUNCTION	4039.75	4753.91	1	07:00	3802.64
1	07:00						
	(2K)020	JUNCTION	0.00	714.16	1	05:12	0.00
	(2K)021	JUNCTION	3.49	866.55	1	10:10	148.25
1	10:10						
	(2K)022	JUNCTION	3.08	876.75	1	10:09	0.00
	(2K)022A	JUNCTION	0.00	860.25	1	10:08	0.00
	(2K)023	JUNCTION	0.00	842.01	1	10:07	0.00
	(2K)024	JUNCTION	0.00	840.34	1	05:09	0.00
	(2K)024A	JUNCTION	24.72	938.09	1	07:00	96.04
1	07:00						
	(2K)025	JUNCTION	7791.76	8444.34	1	07:00	7526.03
1	07:00						
	(2K)026	JUNCTION	0.00	666.72	1	11:41	0.00
	(2K)027	JUNCTION	0.77	663.43	1	11:41	0.00
	(2K)028	JUNCTION	0.00	652.01	1	06:31	0.00
	(2K)029	JUNCTION	15708.43	16364.02	1	07:00	15703.91
1	07:00						
	(2K)030	JUNCTION	0.00	657.11	1	11:05	0.00
	(2K)031	JUNCTION	0.00	662.86	1	10:58	5.27
1	10:58						
	(2K)032	JUNCTION	2.88	656.14	1	07:00	0.00
	(2K)033	JUNCTION	4951.75	5587.18	1	07:00	4931.26
1	07:00						
	(2K)033A	JUNCTION	1.95	646.71	1	10:33	11.19
1	10:34						
	(2K)034	JUNCTION	0.00	678.05	1	10:33	30.17
1	10:34						
	(2K)035	JUNCTION	0.00	663.19	1	10:32	0.00

	(2K) 036	JUNCTION	0.00	648.37	1	10:22	0.00
	(2K) 037	JUNCTION	78.31	725.14	1	07:00	77.19
1	07:00						
	(2K) 038	JUNCTION	0.00	648.06	1	05:47	0.00
	(2K) 039	JUNCTION	0.00	648.06	1	05:47	0.00
	(2K) 040	JUNCTION	0.00	648.06	1	05:47	0.00
	(2K) 041	JUNCTION	0.00	649.12	1	10:11	0.53
1	10:11						
	(2K) 042	JUNCTION	6427.89	7072.12	1	07:00	6412.11
1	07:00						
	(2K) 043	JUNCTION	0.00	648.02	1	05:59	0.00
	(2K) 044	JUNCTION	0.00	648.56	1	09:24	0.25
1	09:24						
	(2K) 045	JUNCTION	0.00	648.06	1	05:56	0.00
	(2K) 046	JUNCTION	0.00	648.06	1	05:54	0.00
	(2K) 047	JUNCTION	0.00	648.18	1	09:13	0.06
1	09:13						
	(2K) 048	JUNCTION	0.00	648.06	1	05:54	0.00
	(2K) 049	JUNCTION	0.00	648.82	1	09:05	0.38
1	09:05						
	(2K) 050	JUNCTION	0.00	648.06	1	05:54	0.00
	(2K) 051	JUNCTION	0.00	648.06	1	06:05	0.00
	(2K) 052	JUNCTION	12943.14	12943.14	1	06:30	12292.43
1	06:30						
	(2K) 314	JUNCTION	0.00	416.01	1	06:31	0.00
	(2K) 315	JUNCTION	0.00	503.62	1	14:31	83.01
1	14:31						
	(2K) 316	JUNCTION	0.00	497.63	1	05:31	0.00
	(2K) 317	JUNCTION	10619.73	10619.73	1	07:00	10106.27
1	07:00						
	ForcedMain	JUNCTION	0.00	1200.00	1	05:08	1051.22
1	05:09						
	(PLANT)	OUTFALL	0.00	6000.00	1	06:03	0.00
	(1C) 026	DIVIDER	15.47	510.38	1	07:00	0.00
	(1F) 012	DIVIDER	0.00	38.25	0	08:01	0.00
	(1G) 019	DIVIDER	0.00	516.56	1	05:35	0.00
	(2A) 048	DIVIDER	857.12	6410.82	1	07:00	0.00
	(2C) 009	DIVIDER	2907.20	3373.53	1	07:00	2564.31
1	07:00						
	(2D) 244	DIVIDER	0.00	1879.55	1	06:51	0.00
	(1M) 012	DIVIDER	0.00	1111.60	1	07:59	0.00
	(2J) 025	DIVIDER	0.00	963.21	1	07:59	7.63
1	07:59						
	(1C) 001B	DIVIDER	11.61	4768.88	1	07:00	0.00
	(1M) 020	DIVIDER	54.26	671.77	1	07:59	0.00
	(1A) STOR	STORAGE	0.00	0.00	0	00:00	0.00
	(1A) DIV	STORAGE	0.00	0.00	0	00:00	0.00
	(2A) 000	STORAGE	0.00	13199.01	1	08:57	3198.27
1	08:57						
	NorthEnidStorage	STORAGE	0.00	1780.84	1	17:16	925.01
1	05:17						
	(10) 304C	STORAGE	0.00	715.04	1	08:03	0.00
	LiftStation	STORAGE	0.00	1632.03	1	05:12	430.87
1	12:03						
	(10) 304	STORAGE	0.00	1253.33	1	07:00	0.00
	(1C) Storage	STORAGE	0.00	195.69	1	07:09	0.00
	PlantStorage	STORAGE	0.00	4000.00	1	05:53	0.00

Storage Volume Summary

of Max Occurrence hr:min	Maximum Storage Unit Outflow GPM	Average Volume 1000 ft3	Avg Pcnt Full	Maximum Volume 1000 ft3	Max Pcnt Full	Time days
(1A) STOR 00:00	0.00	0.000	0	0.000	0	0
(1A) DIV 00:00	0.00	0.000	0	0.000	0	0
(2A) 000 06:14	10000.00	1.092	12	9.032	100	1
NorthEnidStorage 00:00	0.00	0.000	0	0.000	0	0
(10) 304C 17:16	2006.84	0.031	12	0.112	43	1
LiftStation 05:29	1200.00	0.568	31	1.828	100	1
(10) 304 08:00	3727.00	0.002	1	0.037	15	1
(1C) Storage 09:05	195.56	0.342	1	0.964	2	1
PlantStorage 00:31	0.00	179.539	8	316.422	15	3

Outfall Loading Summary

Outfall Node	Flow Freq. Pcnt.	Avg. Flow GPM	Max. Flow GPM
(PLANT)	98.82	4554.57	6000.00
System	98.82	4554.57	6000.00

Link Flow Summary

Max/ Full Link Depth	Total Minutes Surcharged	Type	Maximum Flow GPM	Time of Max Occurrence days hr:min	Maximum Velocity ft/sec	Max/ Full Flow
-------------------------------	--------------------------------	------	------------------------	--	-------------------------------	----------------------

(1A)000A		CONDUIT	3540.94	3	07:09	5.53	0.18
0.29	0						
(1A)000B		CONDUIT	3541.00	3	07:08	3.29	0.39
0.43	0						
(1A)001		CONDUIT	3541.08	0	07:30	1.44	1.08
0.95	4170						
(1A)002		CONDUIT	6951.62	1	06:51	2.81	1.08
1.00	67						
(1A)003		CONDUIT	7160.28	1	07:05	4.30	0.67
0.60	0						
(1A)004		CONDUIT	7162.46	1	07:04	3.55	0.85
0.71	0						
(1A)005		CONDUIT	7160.20	1	07:02	3.95	0.75
0.65	0						
(1A)006		CONDUIT	7164.18	1	07:01	4.96	0.56
0.53	0						
(1A)007		CONDUIT	7168.40	1	07:00	4.79	0.58
0.55	0						
(1A)008		CONDUIT	4739.47	1	17:14	4.34	0.38
0.43	0						
(1A)009		CONDUIT	4746.70	1	17:13	3.12	0.60
0.56	0						
(1A)010		CONDUIT	4734.81	1	17:12	4.18	0.40
0.44	0						
(1A)011		CONDUIT	4730.92	1	07:09	1.95	1.08
0.95	942						
(1A)012		CONDUIT	5228.20	1	07:10	2.13	1.08
0.95	666						
(1A)013		CONDUIT	9957.57	1	06:56	4.04	1.08
0.95	198						
(1A)014		CONDUIT	12163.88	1	06:37	4.93	1.08
1.00	121						
(1A)015		CONDUIT	4532.40	1	10:13	4.45	0.35
0.41	0						
(1A)016		CONDUIT	4528.67	1	10:13	3.09	0.57
0.54	0						
(1A)017		CONDUIT	4531.70	1	10:11	2.61	0.71
0.62	0						
(1A)018		CONDUIT	3774.29	1	00:21	3.99	0.41
0.45	0						
(1A)019		CONDUIT	3778.87	1	00:20	1.85	1.08
0.96	4031						
(1A)020		CONDUIT	5126.58	0	20:41	4.57	0.51
0.51	0						
(1A)021		CONDUIT	5129.30	2	08:25	4.08	0.60
0.56	0						
(1A)022		CONDUIT	5127.07	2	20:06	4.97	0.46
0.48	0						
(1A)023		CONDUIT	5133.80	2	21:45	3.94	0.63
0.57	0						
(1A)024		CONDUIT	5133.35	2	08:23	4.67	0.51
0.51	0						
(1A)024A		CONDUIT	5128.17	2	20:04	2.52	1.08
0.95	1959						
(1A)025		CONDUIT	10069.65	1	06:38	13.95	0.28
0.36	0						
(1A)026		CONDUIT	10068.26	1	06:38	4.94	1.08
0.95	108						

(1A)027		CONDUIT	11443.23	1	07:19	5.60	1.08
0.96	61						
(1A)028		CONDUIT	4316.28	3	08:26	2.74	0.79
0.67	0						
(1A)029		CONDUIT	4316.47	3	08:24	3.80	0.52
0.51	0						
(1A)030		CONDUIT	4316.51	3	08:23	2.64	0.83
0.70	0						
(1A)031		CONDUIT	4316.76	3	08:21	3.26	0.64
0.58	0						
(1A)032		CONDUIT	4316.97	3	08:19	3.06	0.69
0.61	0						
(1A)033		CONDUIT	4317.20	3	08:17	3.13	0.67
0.60	0						
(1A)034		CONDUIT	4318.09	2	22:36	2.55	0.87
0.72	0						
(1A)035		CONDUIT	4322.60	3	08:53	3.54	0.58
0.54	0						
(1A)035A		CONDUIT	4323.08	2	09:17	2.63	0.84
0.70	0						
(1A)036		CONDUIT	4320.49	0	08:35	4.00	0.49
0.49	0						
(1A)037		CONDUIT	4329.97	2	22:33	3.21	0.67
0.60	0						
(1A)038		CONDUIT	4319.39	0	08:09	2.13	1.08
0.95	1992						
(1A)039		CONDUIT	6791.30	1	13:10	4.23	0.82
0.69	0						
(1A)040		CONDUIT	6781.11	1	06:14	3.33	1.08
0.95	507						
(1A)041		CONDUIT	7078.84	1	05:51	3.47	1.08
0.95	478						
(1A)042		CONDUIT	11685.46	1	06:17	3.98	1.08
0.95	251						
(1B)001		CONDUIT	1400.21	1	14:49	6.04	0.11
0.22	0						
(1B)002		CONDUIT	1401.12	1	14:49	2.95	0.29
0.37	0						
(1B)003		CONDUIT	1400.27	1	14:49	2.86	0.31
0.38	0						
(1B)004		CONDUIT	1399.16	1	15:10	1.08	1.08
0.95	608						
(1B)005		CONDUIT	7387.08	1	05:35	5.66	1.08
1.00	154						
(1B)006		CONDUIT	4972.76	1	11:15	3.83	1.08
0.96	354						
(1B)009		CONDUIT	5090.50	1	05:43	3.91	1.08
0.95	350						
(1B)010		CONDUIT	4859.76	1	08:00	5.11	0.74
0.64	0						
(1B)011		CONDUIT	4798.26	1	11:02	3.69	1.08
0.95	351						
(1B)013		CONDUIT	5090.05	1	10:50	4.58	0.90
0.74	0						
(1B)014		CONDUIT	5085.72	1	05:57	3.91	1.08
0.95	342						
(1C)001		CONDUIT	5324.31	1	05:30	4.08	1.08
1.00	266						
(1C)001A		CONDUIT	4987.15	1	06:03	3.83	1.08
0.95	231						
(1C)001B		CONDUIT	4573.36	1	07:00	7.76	0.39

0.44	0						
(1C)001BO		CONDUIT	195.69	1	07:09	2.78	0.02
0.10	0						
(1C)001C		CONDUIT	4757.27	1	06:10	6.96	0.48
0.49	0						
(1C)001D		CONDUIT	4757.27	1	06:09	3.66	1.08
0.95	214						
(1C)001E		CONDUIT	5778.59	1	05:46	8.03	0.51
0.51	0						
(1C)001F		CONDUIT	5778.58	1	05:45	6.49	0.68
0.60	0						
(1C)001G		CONDUIT	195.69	1	07:09	2.61	0.02
0.10	0						
(1C)002		CONDUIT	1409.27	1	07:59	6.44	0.67
0.60	0						
(1C)003		CONDUIT	37.01	0	08:00	0.94	0.11
0.22	0						
(1C)004		CONDUIT	22.42	0	08:00	1.23	0.04
0.13	0						
(1C)005		CONDUIT	17.60	0	08:01	0.42	0.12
0.23	0						
(1C)006		CONDUIT	17.69	0	08:01	1.06	0.03
0.12	0						
(1C)006A		CONDUIT	16.07	0	08:00	1.16	0.02
0.11	0						
(1C)007		CONDUIT	15.47	0	20:31	1.01	0.03
0.11	0						
(1C)009		CONDUIT	5779.01	1	05:44	5.44	0.85
0.71	0						
(1C)010		CONDUIT	5786.41	1	05:42	7.10	0.61
0.56	0						
(1C)011		CONDUIT	5798.76	1	05:42	6.26	0.71
0.62	0						
(1C)012		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(1C)015A		CONDUIT	5778.58	1	05:41	4.37	1.08
1.00	193						
(1C)015B		CONDUIT	6341.24	1	08:36	5.76	0.88
0.73	0						
(1C)015C		CONDUIT	6340.56	1	06:05	5.62	0.91
0.75	0						
(1C)016		CONDUIT	5903.53	1	08:05	4.66	1.06
0.92	142						
(1C)016A		CONDUIT	5621.75	1	07:06	5.05	0.91
0.75	0						
(1C)016B		CONDUIT	5656.56	1	08:08	4.40	1.07
0.94	148						
(1C)016C		CONDUIT	5620.21	1	06:11	4.32	1.08
0.95	150						
(1C)017		CONDUIT	11.41	0	08:04	2.40	0.00
0.02	0						
(1C)018		CONDUIT	11.45	0	08:04	0.91	0.02
0.10	0						
(1C)019		CONDUIT	11.24	0	08:01	0.89	0.02
0.10	0						
(1C)01D		CONDUIT	6340.56	1	06:04	4.86	1.08
0.95	185						
(1C)020		CONDUIT	9.53	0	08:00	1.02	0.02
0.09	0						
(1C)021		CONDUIT	7561.21	1	06:11	5.80	1.08
0.95	112						

(1C)021A		CONDUIT	1754.45	1	08:39	2.41	1.08
0.95	188						
(1C)021B		CONDUIT	2504.89	1	06:03	3.42	1.08
0.95	161						
(1C)021C		CONDUIT	78.46	1	08:02	1.32	0.04
0.13	0						
(1C)021D		CONDUIT	78.51	1	08:00	1.28	0.04
0.13	0						
(1C)022		CONDUIT	352.31	1	08:00	2.33	0.66
0.60	0						
(1C)023		CONDUIT	346.06	1	08:00	2.07	0.76
0.65	0						
(1C)024		CONDUIT	346.08	1	08:00	2.16	0.72
0.63	0						
(1C)025		CONDUIT	336.39	1	11:22	1.50	1.08
0.95	362						
(1C)026		CONDUIT	434.44	1	08:00	2.16	0.95
0.77	0						
(1C)026A		CONDUIT	78.42	1	08:00	2.33	0.02
0.09	0						
(1C)027		CONDUIT	495.70	1	05:26	2.20	1.08
0.95	327						
(1C)028		CONDUIT	492.03	1	06:16	2.19	1.08
0.95	326						
(1C)041		CONDUIT	7.51	0	08:00	1.10	0.01
0.07	0						
(1C)176		CONDUIT	1365.61	1	10:17	4.22	1.08
0.96	304						
(1C)177		CONDUIT	1361.55	1	08:00	4.19	1.08
0.97	304						
(1C)178		CONDUIT	1354.69	1	05:43	4.16	1.08
0.95	303						
(1C)179		CONDUIT	1362.38	1	05:49	4.19	1.08
0.95	262						
(1C)179A		CONDUIT	1083.97	1	05:34	3.27	1.08
1.00	216						
(1C)180		CONDUIT	1358.90	1	08:51	4.19	1.08
0.95	197						
(1C)180A		CONDUIT	1359.79	1	08:45	4.27	1.08
0.95	196						
(1C)181		CONDUIT	1351.41	1	08:48	4.17	1.08
0.95	197						
(1C)182		CONDUIT	1340.88	1	05:33	4.12	1.08
1.00	197						
(1C)Storage		CONDUIT	195.56	1	09:06	2.49	0.16
0.27	0						
(1D)001		CONDUIT	778.02	1	10:09	5.51	0.62
0.57	0						
(1D)002		CONDUIT	788.04	1	10:09	3.58	1.06
0.91	292						
(1D)003		CONDUIT	748.18	1	05:44	3.84	0.91
0.75	0						
(1D)004		CONDUIT	748.18	1	05:43	4.77	0.70
0.62	0						
(1D)005		CONDUIT	748.18	1	05:42	3.33	1.08
0.95	322						
(1D)006		CONDUIT	540.67	1	11:36	3.45	0.70
0.62	0						
(1D)007		CONDUIT	540.73	1	11:35	3.44	0.71
0.62	0						
(1D)008		CONDUIT	540.75	1	11:34	3.53	0.71

0.62	0						
(1D)009		CONDUIT	547.32	1	13:11	2.46	1.07
0.94	486						
(1D)010		CONDUIT	540.49	1	05:45	2.41	1.08
0.95	512						
(1D)011		CONDUIT	574.58	1	10:59	3.95	0.63
0.58	0						
(1D)012		CONDUIT	573.90	1	11:00	2.55	1.08
0.95	408						
(1D)013		CONDUIT	606.67	1	10:30	4.74	0.54
0.52	0						
(1D)014		CONDUIT	605.96	1	05:56	2.70	1.08
0.95	353						
(1D)015		CONDUIT	471.85	1	08:00	2.42	0.92
0.76	0						
(1D)016		CONDUIT	466.72	1	08:00	2.09	1.08
0.96	518						
(1D)017		CONDUIT	461.12	1	13:43	2.06	1.08
0.95	517						
(1D)018		CONDUIT	466.12	1	13:36	2.09	1.08
0.95	513						
(1D)019		CONDUIT	473.43	1	11:57	2.11	1.08
0.95	398						
(1D)020		CONDUIT	472.27	1	11:48	2.09	1.08
0.95	398						
(1D)021		CONDUIT	474.14	1	06:16	2.11	1.08
0.95	393						
(1D)022		CONDUIT	470.45	1	06:17	2.09	1.08
0.95	390						
(1D)023		CONDUIT	470.75	1	11:37	2.09	1.08
0.95	388						
(1E)001		CONDUIT	826.86	1	09:11	2.65	1.06
0.92	217						
(1E)002		CONDUIT	804.18	1	09:10	2.50	1.08
0.94	227						
(1E)003		CONDUIT	787.91	1	06:39	2.49	1.08
0.95	229						
(1E)003A		CONDUIT	802.73	1	06:23	2.49	1.08
0.95	227						
(1E)005		CONDUIT	792.72	1	08:49	2.50	1.08
0.95	198						
(1E)006		CONDUIT	803.71	1	08:45	2.52	1.08
0.94	197						
(1E)007		CONDUIT	802.86	1	08:38	2.50	1.08
0.94	197						
(1E)008		CONDUIT	780.91	1	06:46	2.47	1.08
0.95	202						
(1E)009		CONDUIT	836.74	1	08:33	2.58	1.08
0.95	195						
(1F)001		CONDUIT	2739.98	1	06:02	3.75	1.08
0.95	217						
(1F)003		CONDUIT	2778.65	1	08:00	5.64	0.45
0.47	0						
(1F)004		CONDUIT	2771.39	1	06:13	2.79	1.08
0.95	215						
(1F)005		CONDUIT	1497.77	1	07:45	1.50	1.08
0.95	126						
(1F)006		CONDUIT	1744.78	1	07:21	2.16	0.85
0.71	0						
(1F)008		CONDUIT	1729.86	1	07:21	1.90	0.98
0.80	0						

(1F)008A		CONDUIT	1718.36	1	06:14	1.73	1.08
0.95	116						
(1F)009		CONDUIT	2040.67	1	07:00	3.80	0.50
0.50	0						
(1F)010		CONDUIT	2038.32	1	06:11	2.05	1.08
0.95	95						
(1F)011		CONDUIT	3.74	0	08:00	0.52	0.00
0.03	0						
(1F)012		CONDUIT	0.12	0	01:00	0.00	0.00
0.00	0						
(1F)012A		CONDUIT	38.25	0	08:01	0.90	0.01
0.08	0						
(1F)012O		CONDUIT	38.02	0	08:02	2.07	0.00
0.05	0						
(1F)013		CONDUIT	39.01	0	08:00	1.04	0.01
0.08	0						
(1F)014		CONDUIT	23.68	0	08:04	0.52	0.03
0.11	0						
(1F)015		CONDUIT	24.28	0	08:01	1.10	0.01
0.07	0						
(1F)016		CONDUIT	26.07	0	08:00	1.21	0.01
0.07	0						
(1F)017		CONDUIT	12004.39	1	08:07	4.10	1.08
0.95	156						
(1F)017A		CONDUIT	11916.31	1	05:42	4.06	1.08
1.00	169						
(1F)017B		CONDUIT	9350.81	1	07:08	3.99	0.83
0.69	0						
(1F)017C		CONDUIT	9350.81	1	07:08	4.17	0.79
0.67	0						
(1F)017D		CONDUIT	9340.59	1	05:41	3.18	1.08
1.00	296						
(1F)017E		CONDUIT	11873.94	1	05:57	4.12	1.07
0.94	173						
(1F)017F		CONDUIT	589.27	1	12:33	5.34	0.08
0.20	0						
(1F)017G-1		CONDUIT	589.65	1	12:36	5.15	0.09
0.20	0						
(1F)018		CONDUIT	593.30	1	12:36	2.98	0.20
0.30	0						
(1F)019		CONDUIT	601.43	1	12:35	2.75	1.06
0.93	6						
(1F)020		CONDUIT	609.62	1	12:31	2.72	1.08
0.91	436						
(1F)021		CONDUIT	567.63	1	06:12	2.52	1.08
0.95	510						
(1F)022		CONDUIT	440.06	1	08:01	2.48	0.81
0.68	0						
(1F)023		CONDUIT	439.69	1	08:00	2.60	0.76
0.65	0						
(1F)024		CONDUIT	24.99	1	08:00	2.06	0.02
0.10	0						
(1F)025		CONDUIT	24.94	0	08:00	2.10	0.02
0.10	0						
(1F)026		CONDUIT	22.10	0	21:01	2.03	0.02
0.09	0						
(1F)026A		CONDUIT	22.72	0	08:00	0.95	0.06
0.16	0						
(1F)027		CONDUIT	16.62	0	08:00	0.87	0.04
0.13	0						
(1F)028		CONDUIT	14.57	0	08:00	0.83	0.03

0.13	0						
(1F)029		CONDUIT	12.40	0	08:03	0.81	0.03
0.12	0						
(1F)029A		CONDUIT	12.79	0	08:01	0.81	0.03
0.12	0						
(1F)030		CONDUIT	14.10	0	08:00	0.98	0.03
0.12	0						
(1G)001		CONDUIT	11068.65	1	06:47	3.78	1.08
0.95	185						
(1G)001A		CONDUIT	11986.15	1	06:06	4.10	1.08
1.00	142						
(1G)002		CONDUIT	12122.64	1	07:54	4.12	1.08
0.96	140						
(1G)003		CONDUIT	8534.81	1	06:11	2.91	1.08
0.95	284						
(1G)004		CONDUIT	6204.94	1	08:00	3.24	0.64
0.58	0						
(1G)005		CONDUIT	6204.93	1	07:11	3.87	0.51
0.51	0						
(1G)006		CONDUIT	6200.31	1	06:09	2.11	1.08
0.95	284						
(1G)007		CONDUIT	10728.55	1	08:26	4.80	0.80
0.68	0						
(1G)008		CONDUIT	10874.41	1	08:24	3.73	1.08
0.95	163						
(1G)008C		CONDUIT	10711.88	1	06:07	3.65	1.08
0.95	164						
(1G)009		CONDUIT	10711.88	1	06:08	5.44	0.67
0.60	0						
(1G)009A		CONDUIT	12273.91	1	05:46	4.20	1.08
0.97	148						
(1G)009B		CONDUIT	12322.83	1	05:46	4.24	1.08
1.00	147						
(1G)009C		CONDUIT	10758.66	1	07:14	4.09	0.97
0.80	0						
(1G)009D		CONDUIT	10885.71	1	06:20	3.89	1.02
0.92	59						
(1G)009E		CONDUIT	10743.59	1	06:19	3.66	1.08
1.00	86						
(1G)010		CONDUIT	12074.20	1	07:10	4.19	1.08
0.93	12						
(1G)011		CONDUIT	11968.21	1	07:09	4.15	1.07
0.93	10						
(1G)012		CONDUIT	11887.47	1	07:08	4.11	1.07
0.93	16						
(1G)013		CONDUIT	11612.53	1	07:07	4.02	1.07
0.94	22						
(1G)014		CONDUIT	106.20	1	20:05	4.67	0.05
0.15	0						
(1G)014A		CONDUIT	104.95	1	08:01	1.57	0.22
0.32	0						
(1G)015		CONDUIT	106.34	1	08:00	1.56	0.23
0.33	0						
(1G)016		CONDUIT	106.80	1	08:00	1.60	0.23
0.32	0						
(1G)017		CONDUIT	90.45	1	08:00	1.54	0.19
0.29	0						
(1G)018		CONDUIT	92.56	1	08:00	1.62	0.20
0.29	0						
(1G)018A		CONDUIT	47.90	1	21:01	1.68	0.07
0.17	0						

(1G)019		CONDUIT	468.73	1	05:36	4.57	0.40
0.44	0						
(1G)0190		CONDUIT	47.95	1	21:01	1.21	0.11
0.22	0						
(1G)020		CONDUIT	516.56	1	05:35	2.28	1.08
0.95	978						
(1G)045		CONDUIT	536.28	1	07:13	3.56	0.67
0.60	0						
(1G)046		CONDUIT	520.81	1	05:57	2.31	1.08
0.95	841						
(1G)047		CONDUIT	334.56	1	07:11	2.13	0.74
0.64	0						
(1G)048		CONDUIT	223.58	1	06:33	1.84	0.50
0.50	0						
(1G)049		CONDUIT	223.57	1	06:31	1.79	0.52
0.51	0						
(1G)050		CONDUIT	223.60	1	06:30	1.58	0.61
0.56	0						
(1G)051		CONDUIT	223.62	1	06:30	1.60	0.60
0.56	0						
(1G)052		CONDUIT	223.53	1	06:29	1.55	1.08
0.96	705						
(1G)053		CONDUIT	223.85	1	16:45	1.55	1.08
0.95	705						
(1G)054		CONDUIT	223.82	1	13:14	1.56	1.08
0.96	454						
(1G)055		CONDUIT	223.63	1	13:09	1.56	1.08
0.96	454						
(1G)056		CONDUIT	223.53	1	07:04	1.55	1.08
0.95	454						
(1G)057		CONDUIT	337.50	1	06:20	2.41	1.08
0.95	358						
(1G)058		CONDUIT	336.74	1	12:06	2.37	1.08
0.95	360						
(1G)059		CONDUIT	336.63	1	06:35	2.35	1.08
0.95	390						
(1G)060		CONDUIT	336.30	1	06:20	2.30	1.08
1.00	398						
(1G)061		CONDUIT	336.98	1	07:15	2.34	1.08
0.95	398						
(1G)062		CONDUIT	369.61	1	05:33	2.59	1.08
0.95	373						
(1G)063		CONDUIT	368.40	1	06:24	2.54	1.08
1.00	391						
(1G)064		CONDUIT	369.15	1	06:33	2.60	1.08
0.96	389						
(1G)065		CONDUIT	369.15	1	06:29	2.57	1.08
0.96	389						
(1G)066		CONDUIT	369.15	1	06:26	2.56	1.08
0.96	389						
(1G)067		CONDUIT	369.15	1	06:25	2.56	1.08
0.96	389						
(1G)068		CONDUIT	369.15	1	06:24	2.57	1.08
0.96	389						
(1G)069		CONDUIT	369.32	1	11:43	2.57	1.08
0.96	388						
(1G)070		CONDUIT	369.30	1	11:39	2.56	1.08
0.96	388						
(1G)071		CONDUIT	369.15	1	05:54	2.55	1.08
0.95	387						
(1G)146		CONDUIT	0.00	0	00:00	0.00	0.00

0.00	0							
(1G)146A		CONDUIT	0.00	0	00:00	0.00	0.00	
0.00	0							
(1G)162		CONDUIT	488.46	1	21:13	2.17	1.08	
0.94	962							
(1G)162A		CONDUIT	499.14	1	21:07	2.23	1.08	
0.92	956							
(1G)162B		CONDUIT	501.86	1	21:05	2.27	1.06	
0.90	2							
(1G)162C		CONDUIT	493.85	1	21:03	2.21	1.07	
0.92	958							
(1G)162D		CONDUIT	490.13	1	21:13	8.79	0.17	
0.28	0							
(1G)243		CONDUIT	0.00	0	00:00	0.00	0.00	
0.00	0							
(1H)001		CONDUIT	415.29	1	08:00	2.56	0.73	
0.63	0							
(1H)004		CONDUIT	71.79	2	23:12	2.65	0.04	
0.13	0							
(1H)005		CONDUIT	71.85	0	22:14	0.35	1.08	
0.95	3292							
(1H)006		CONDUIT	457.46	1	16:37	2.43	0.88	
0.73	0							
(1H)007		CONDUIT	457.35	1	16:36	2.58	0.82	
0.69	0							
(1H)008		CONDUIT	457.57	1	16:35	2.51	0.85	
0.71	0							
(1H)009		CONDUIT	457.25	1	07:00	2.68	0.77	
0.66	0							
(1H)010		CONDUIT	455.94	1	05:43	2.01	1.08	
0.95	706							
(1H)011		CONDUIT	1171.03	1	05:33	5.08	1.08	
1.00	451							
(1H)038		CONDUIT	404.39	1	07:13	3.73	0.43	
0.46	0							
(1H)039		CONDUIT	397.92	1	17:15	4.17	0.36	
0.41	0							
(1H)040		CONDUIT	397.82	1	06:06	7.90	0.15	
0.26	0							
(1H)041		CONDUIT	397.82	1	06:06	1.76	1.08	
0.95	749							
(1H)042		CONDUIT	685.90	1	05:29	4.02	0.48	
0.49	0							
(1H)043		CONDUIT	685.90	1	05:19	3.02	1.08	
1.00	597							
(1H)044		CONDUIT	67.09	0	08:00	1.73	0.12	
0.23	0							
(1H)045		CONDUIT	66.48	0	08:00	1.87	0.12	
0.22	0							
(1J)001		CONDUIT	12021.46	1	08:04	5.09	0.83	
0.70	0							
(1J)002		CONDUIT	12021.59	1	08:03	4.52	0.96	
0.78	0							
(1J)003		CONDUIT	9281.83	1	08:02	4.12	0.79	
0.67	0							
(1J)004		CONDUIT	9281.64	1	08:01	3.71	0.89	
0.74	0							
(1J)005		CONDUIT	9282.42	1	08:00	3.56	0.94	
0.77	0							
(1J)006		CONDUIT	9282.80	1	08:00	3.77	0.88	
0.73	0							

(1J)007		CONDUIT	9255.56	1	10:58	4.02	0.81
0.68	0						
(1J)008		CONDUIT	9257.01	1	10:58	4.75	0.66
0.59	0						
(1J)009		CONDUIT	9264.07	1	10:58	3.56	0.93
0.77	0						
(1J)010		CONDUIT	9258.75	1	10:57	4.08	0.80
0.68	0						
(1J)011		CONDUIT	9252.65	1	05:56	3.15	1.08
0.95	345						
(1J)012		CONDUIT	11328.10	1	06:10	3.87	1.08
0.95	262						
(1J)013		CONDUIT	11917.35	1	06:05	4.05	1.08
0.95	203						
(1J)014		CONDUIT	12906.85	1	08:08	4.58	1.05
0.93	146						
(1J)041		CONDUIT	846.88	1	08:02	3.59	0.41
0.45	0						
(1J)042		CONDUIT	849.76	1	08:02	4.48	0.30
0.38	0						
(1J)042A		CONDUIT	853.00	1	08:01	4.33	0.32
0.39	0						
(1J)042B		CONDUIT	856.10	1	08:01	4.81	0.28
0.36	0						
(1J)043		CONDUIT	861.55	1	08:00	3.94	0.37
0.42	0						
(1J)044		CONDUIT	878.86	1	08:00	2.05	0.94
0.74	0						
(1J)045		CONDUIT	616.09	1	08:00	1.84	0.27
0.35	0						
(1J)046		CONDUIT	616.93	1	08:00	1.56	0.33
0.40	0						
(1J)047		CONDUIT	558.50	1	08:00	1.76	0.24
0.34	0						
(1J)048		CONDUIT	560.08	1	08:00	3.37	0.10
0.21	0						
(1J)050		CONDUIT	564.74	1	08:00	2.63	0.15
0.26	0						
(1J)050A		CONDUIT	370.65	1	22:46	1.57	0.16
0.27	0						
(1J)051		CONDUIT	371.40	1	22:45	2.40	0.09
0.20	0						
(1J)052		CONDUIT	370.22	1	23:25	0.73	1.08
0.95	1104						
(1J)053		CONDUIT	1069.13	1	05:23	2.10	1.08
1.00	523						
(1J)054		CONDUIT	444.04	1	13:08	2.49	0.28
0.36	0						
(1J)054A		CONDUIT	443.28	1	07:28	2.44	0.28
0.36	0						
(1J)055		CONDUIT	444.05	1	13:39	0.88	1.08
0.95	504						
(1J)056		CONDUIT	640.69	1	11:25	2.01	0.61
0.56	0						
(1J)057		CONDUIT	641.09	1	11:23	1.86	0.68
0.60	0						
(1J)058		CONDUIT	641.87	1	11:22	2.08	0.59
0.55	0						
(1J)059		CONDUIT	643.97	1	11:21	1.44	0.93
0.76	0						
(1J)060		CONDUIT	640.08	1	11:36	1.26	1.08

0.95	389						
(1K)001		CONDUIT	3780.44	1	05:49	7.43	1.08
1.00	110						
(1K)002		CONDUIT	610.96	1	07:00	4.51	0.19
0.29	0						
(1K)002A		CONDUIT	610.93	1	07:00	4.51	0.19
0.29	0						
(1K)003		CONDUIT	601.46	1	06:23	2.45	0.77
0.66	0						
(1K)004		CONDUIT	601.57	1	11:04	1.86	1.08
0.95	353						
(1K)005		CONDUIT	233.63	1	08:00	1.71	0.37
0.42	0						
(1K)006		CONDUIT	219.01	2	07:10	0.68	1.08
0.95	1541						
(1K)007		CONDUIT	676.63	1	12:08	2.10	1.07
0.94	416						
(1K)008		CONDUIT	667.36	1	06:23	2.05	1.08
0.95	432						
(1K)008A		CONDUIT	529.58	1	07:09	2.54	0.63
0.57	0						
(1K)009		CONDUIT	519.15	1	06:25	1.60	1.08
0.95	513						
(1K)010		CONDUIT	649.26	1	08:01	2.00	1.08
0.95	457						
(1K)011		CONDUIT	697.47	1	08:00	2.23	1.07
0.94	61						
(1K)012		CONDUIT	484.06	1	12:53	1.90	0.81
0.68	0						
(1K)013		CONDUIT	481.79	1	13:05	1.49	1.08
0.95	473						
(1K)014		CONDUIT	599.00	1	06:09	1.85	1.08
0.95	440						
(1M)000		CONDUIT	11461.19	1	07:03	4.41	0.93
0.77	0						
(1M)000A		CONDUIT	11481.16	1	07:02	7.22	0.50
0.50	0						
(1M)000B		CONDUIT	11481.73	1	07:02	4.54	0.91
0.75	0						
(1M)001		CONDUIT	11490.19	1	07:01	5.76	0.68
0.60	0						
(1M)002		CONDUIT	11499.67	1	07:01	4.52	0.92
0.75	0						
(1M)003		CONDUIT	11505.87	1	07:00	4.94	0.82
0.69	0						
(1M)010		CONDUIT	690.40	1	06:26	2.75	0.12
0.23	0						
(1M)011		CONDUIT	690.40	1	06:26	2.13	1.08
0.95	687						
(1M)012		CONDUIT	1032.63	1	07:59	3.45	0.97
0.79	0						
(1M)012O		CONDUIT	79.02	1	08:00	1.05	0.26
0.35	0						
(1M)013		CONDUIT	608.30	1	08:10	2.07	0.96
0.78	0						
(1M)014		CONDUIT	608.40	1	08:08	2.08	0.95
0.78	0						
(1M)015		CONDUIT	609.06	1	08:06	2.08	0.95
0.78	0						
(1M)016		CONDUIT	610.06	1	08:03	2.07	0.96
0.78	0						

(1M) 017		CONDUIT	609.49	1	08:02	3.51	0.49
0.49	0						
(1M) 018		CONDUIT	609.55	1	08:02	2.18	0.90
0.74	0						
(1M) 019		CONDUIT	610.78	1	08:01	2.12	0.94
0.77	0						
(1M) 020		CONDUIT	613.30	1	08:00	2.14	0.94
0.77	0						
(1M) 020O		CONDUIT	64.83	1	07:59	2.22	0.07
0.18	0						
(1M) 021		CONDUIT	288.23	0	19:20	1.98	0.63
0.57	0						
(1M) 022		CONDUIT	288.56	0	19:18	2.05	0.60
0.56	0						
(1M) 023		CONDUIT	282.94	0	19:17	2.05	0.59
0.55	0						
(1M) 024		CONDUIT	283.02	0	19:16	1.96	0.63
0.57	0						
(1M) 024A		CONDUIT	283.26	0	19:14	2.00	0.61
0.56	0						
(1M) 025		CONDUIT	283.89	0	19:13	2.00	0.61
0.56	0						
(1M) 027		CONDUIT	284.25	0	19:11	2.00	0.62
0.57	0						
(1M) 028		CONDUIT	284.89	0	19:09	2.01	0.62
0.57	0						
(1M) 035		CONDUIT	85.45	1	08:00	1.35	0.12
0.24	0						
(1M) 036		CONDUIT	82.75	1	08:00	1.33	0.12
0.23	0						
(1M) 037		CONDUIT	82.78	1	08:00	1.47	0.17
0.28	0						
(1M) 038		CONDUIT	79.01	1	08:01	1.44	0.17
0.28	0						
(1M) 039		CONDUIT	504.68	1	07:05	3.39	0.65
0.59	0						
(1M) 040		CONDUIT	498.80	1	13:27	2.35	1.00
0.82	0						
(1M) 041		CONDUIT	497.90	1	13:26	2.21	1.08
0.95	511						
(1M) 092		CONDUIT	491.61	1	06:04	2.18	1.08
0.95	507						
(1M) 093		CONDUIT	508.56	1	07:00	3.56	0.61
0.57	0						
(1M) 094		CONDUIT	485.07	1	13:23	2.15	1.08
0.95	500						
(1M) 116		CONDUIT	508.80	1	10:48	2.99	0.77
0.66	0						
(1M) 117		CONDUIT	510.73	1	10:48	2.72	0.87
0.72	0						
(1M) 118		CONDUIT	514.82	1	10:47	2.34	1.06
0.92	335						
(1M) 119		CONDUIT	504.41	1	10:53	2.24	1.08
0.94	344						
(1M) 120		CONDUIT	495.43	1	10:43	3.04	0.73
0.63	0						
(1M) 121		CONDUIT	494.65	1	10:43	2.20	1.08
0.95	345						
(1M) 122		CONDUIT	520.57	1	05:35	2.30	1.08
0.95	338						
(1M) 123		CONDUIT	107.43	1	08:00	1.55	0.23

0.33	0							
(1M) 124		CONDUIT	40.04	0	08:07	1.22	0.09	
0.20	0							
(1M) 125		CONDUIT	40.04	0	08:04	1.20	0.09	
0.20	0							
(1M) 126		CONDUIT	40.24	1	08:02	1.25	0.08	
0.19	0							
(1M) 127		CONDUIT	40.36	0	08:01	1.35	0.09	
0.20	0							
(1M) 128		CONDUIT	40.28	1	08:00	1.33	0.08	
0.19	0							
(1M) 129		CONDUIT	39.26	0	08:09	2.26	0.09	
0.18	0							
(1M) 130		CONDUIT	30.06	1	08:00	0.29	0.00	
0.00	0							
(1M) 131		CONDUIT	30.32	0	08:00	1.16	0.06	
0.17	0							
(1M) 132		CONDUIT	22.93	0	08:01	1.06	0.05	
0.15	0							
(1M) 133		CONDUIT	16.48	0	08:00	1.09	0.04	
0.12	0							
(1M) 161		CONDUIT	337.99	1	15:09	3.98	0.56	
0.53	0							
(1M) 162		CONDUIT	336.98	1	06:03	2.33	1.08	
0.95	622							
(1M) 163		CONDUIT	336.98	1	06:01	2.34	1.08	
0.96	590							
(1M) 164		CONDUIT	337.45	1	14:59	2.34	1.08	
0.96	589							
(1M) 165		CONDUIT	336.98	1	06:10	2.33	1.08	
0.95	589							
(1M) 278		CONDUIT	6040.29	1	07:57	3.96	0.48	
0.49	0							
(1M) 279		CONDUIT	6019.64	1	07:56	3.99	0.47	
0.48	0							
(1M) 279B		CONDUIT	6019.64	1	07:56	4.17	0.44	
0.47	0							
(1M) 281		CONDUIT	6019.65	1	07:56	4.65	0.39	
0.43	0							
(1M) 281B		CONDUIT	5934.49	1	05:42	4.54	1.08	
1.00	151							
(1M) 282		CONDUIT	3698.58	1	06:25	2.84	1.08	
0.95	298							
(1M) 283		CONDUIT	4783.09	1	08:39	3.81	1.06	
0.92	165							
(1M) 284		CONDUIT	4204.38	1	08:17	3.25	1.08	
0.95	157							
(1M) 285		CONDUIT	4382.93	1	08:17	3.46	1.08	
0.92	153							
(1M) 285A		CONDUIT	4261.39	1	08:15	3.33	1.06	
0.93	154							
(1M) 286		CONDUIT	4170.12	1	06:11	3.20	1.08	
0.95	158							
(1M) 287		CONDUIT	979.25	1	08:15	2.50	0.23	
0.32	0							
(1M) 2876A		CONDUIT	4665.42	1	06:10	3.59	1.08	
0.95	147							
(1M) 288		CONDUIT	987.29	1	08:14	2.51	0.23	
0.32	0							
(1M) 288A		CONDUIT	987.51	1	08:12	2.56	0.22	
0.32	0							

(1M)288B		CONDUIT	998.31	1	08:12	2.58	0.23
0.32	0						
(1M)288C		CONDUIT	1007.72	1	08:11	2.46	0.25
0.34	0						
(1N)004		CONDUIT	4574.19	1	08:41	3.61	1.08
1.00	177						
(1N)005		CONDUIT	4616.42	1	08:39	3.63	1.08
0.95	176						
(1N)006		CONDUIT	4737.74	1	06:34	3.79	1.08
0.95	172						
(1N)007		CONDUIT	4779.10	1	06:31	3.73	1.08
0.95	171						
(1N)007D		CONDUIT	506.53	1	17:13	2.57	0.92
0.76	0						
(1N)007E		CONDUIT	497.21	1	06:05	2.73	0.85
0.71	0						
(1N)008		CONDUIT	497.21	1	06:05	2.21	1.08
0.95	544						
(1N)009		CONDUIT	510.02	1	14:04	2.29	1.06
0.93	538						
(1N)011		CONDUIT	494.08	1	14:07	2.19	1.08
0.95	543						
(1N)013		CONDUIT	496.07	1	06:07	2.21	1.08
0.95	539						
(1N)014		CONDUIT	492.37	1	13:24	2.19	1.08
0.95	491						
(1N)015		CONDUIT	515.56	1	13:10	2.32	1.06
0.93	476						
(1N)016		CONDUIT	498.26	1	13:03	2.22	1.08
0.96	486						
(1N)017		CONDUIT	498.37	1	13:03	2.21	1.08
0.95	486						
(1N)018		CONDUIT	518.54	1	12:52	2.29	1.08
0.95	478						
(1N)019		CONDUIT	457.95	1	05:49	2.03	1.08
0.95	475						
(1N)020		CONDUIT	531.82	1	12:30	2.38	1.07
0.91	441						
(1N)021		CONDUIT	496.78	1	12:46	2.20	1.08
0.95	462						
(1N)022		CONDUIT	496.31	1	06:01	2.21	1.08
0.95	460						
(1N)023		CONDUIT	496.40	1	11:28	2.21	1.08
0.95	373						
(1N)024		CONDUIT	494.74	1	11:25	2.20	1.08
0.95	373						
(1N)025		CONDUIT	491.91	1	11:20	2.26	1.08
0.95	373						
(1N)045		CONDUIT	506.74	1	17:13	3.55	0.65
0.58	0						
(1N)046		CONDUIT	519.65	1	17:11	2.36	1.08
0.93	735						
(1N)047		CONDUIT	501.22	1	05:55	2.55	1.08
0.95	746						
(1N)109A		CONDUIT	4210.87	1	08:30	3.27	1.08
0.95	157						
(1N)110		CONDUIT	4230.15	1	08:15	4.10	0.84
0.70	0						
(1N)111A		CONDUIT	4277.82	1	08:26	3.33	1.08
0.95	155						
(1N)112A		CONDUIT	4418.00	1	08:19	3.49	1.07

0.91	145						
(1N) 112B		CONDUIT	4194.69	1	08:18	3.83	0.90
0.74	0						
(10) 001		CONDUIT	285.17	0	07:06	2.08	0.58
0.55	0						
(10) 001A		CONDUIT	277.99	0	07:05	2.05	0.59
0.55	0						
(10) 002		CONDUIT	278.09	0	07:04	2.69	0.40
0.44	0						
(10) 002A		CONDUIT	270.69	0	07:04	2.70	0.38
0.43	0						
(10) 003		CONDUIT	270.74	0	07:04	2.05	0.56
0.54	0						
(10) 004		CONDUIT	271.13	0	07:03	2.06	0.57
0.54	0						
(10) 005A		CONDUIT	263.92	0	07:02	2.09	0.56
0.53	0						
(10) 005B		CONDUIT	241.05	2	18:13	2.09	0.28
0.36	0						
(10) 005C		CONDUIT	241.15	2	18:13	2.22	0.26
0.35	0						
(10) 005D		CONDUIT	242.30	2	18:13	2.25	0.26
0.35	0						
(10) 005E		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 010		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 011		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 012		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 013		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 014		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 015		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 016		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 017		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 018		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 019		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 020		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 021		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(10) 072		CONDUIT	1470.20	1	08:03	3.72	0.34
0.36	0						
(10) 157		CONDUIT	4608.07	1	05:40	3.54	1.08
1.00	185						
(10) 300		CONDUIT	1047.73	1	08:10	2.69	0.24
0.33	0						
(10) 301		CONDUIT	1091.34	1	08:10	2.87	0.24
0.33	0						
(10) 302		CONDUIT	1157.91	1	08:06	3.08	0.27
0.34	0						
(10) 303		CONDUIT	1122.94	1	08:05	3.18	0.26
0.34	0						

(1O)304		CONDUIT	1866.15	1	08:03	7.34	0.45
0.39	0						
(1O)304A		CONDUIT	1296.81	1	08:33	20.77	0.44
0.49	0						
(1O)304B		CONDUIT	715.04	1	08:03	3.59	1.04
0.90	129						
(1O)304C		CONDUIT	243.59	0	19:02	0.87	1.08
1.00	1601						
(1O)305		CONDUIT	1184.94	1	17:02	0.91	1.08
0.95	722						
(1O)305A		CONDUIT	1253.33	1	07:00	13.01	0.03
0.12	0						
(1O)306		CONDUIT	4684.71	1	10:09	3.62	1.08
0.95	280						
(1O)306A		CONDUIT	4684.09	1	10:05	3.62	1.08
0.95	280						
(1O)307		CONDUIT	4657.70	1	05:48	3.59	1.07
0.95	279						
(1O)308		CONDUIT	4657.70	1	05:47	3.57	1.08
0.95	280						
(1O)308A		CONDUIT	4534.34	1	08:40	3.59	1.04
1.00	181						
(1O)309		CONDUIT	4504.59	1	05:40	3.51	1.08
1.00	144						
(1P)003		CONDUIT	1630.85	1	05:11	4.93	1.08
1.00	439						
(1P)004		CONDUIT	1074.32	0	21:22	3.40	1.08
0.95	1238						
(1P)005		CONDUIT	1161.48	0	21:05	4.35	0.89
0.73	0						
(1P)006		CONDUIT	1159.35	0	21:03	3.59	1.08
0.95	1107						
(1P)007		CONDUIT	1232.06	1	21:00	4.80	0.84
0.70	0						
(1P)008		CONDUIT	1224.73	0	08:00	3.88	1.08
0.95	1043						
(1P)008A		CONDUIT	2052.73	1	05:14	7.03	0.94
0.77	0						
(1P)009		CONDUIT	2041.64	1	05:14	6.25	1.08
1.00	382						
(1P)010		CONDUIT	809.44	0	08:07	3.60	0.69
0.61	0						
(1P)011		CONDUIT	809.49	0	08:07	3.84	0.65
0.59	0						
(1P)012		CONDUIT	808.09	0	08:06	3.84	0.66
0.59	0						
(1P)013		CONDUIT	811.74	0	08:04	3.84	0.66
0.59	0						
(1P)014		CONDUIT	817.28	0	08:03	3.87	0.67
0.59	0						
(1P)015		CONDUIT	822.99	0	08:02	3.93	0.67
0.59	0						
(1P)016		CONDUIT	832.23	0	08:01	3.61	0.78
0.65	0						
(1P)016A		CONDUIT	827.86	0	08:01	3.58	0.77
0.66	0						
(1P)017		CONDUIT	826.72	0	08:00	3.51	0.77
0.67	0						
(1P)018		CONDUIT	805.86	0	08:00	4.07	0.75
0.60	0						
(1P)024		CONDUIT	62.00	0	08:00	2.06	0.06

0.15	0						
(1P)042		CONDUIT	583.91	1	11:49	4.74	0.51
0.50	0						
(1P)042A		CONDUIT	583.99	1	11:48	2.60	1.08
0.95	417						
(1P)043		CONDUIT	591.43	1	11:56	2.62	1.08
0.95	415						
(1P)044		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(1P)065		CONDUIT	12.91	0	08:00	1.14	0.02
0.10	0						
(1P)073		CONDUIT	7.73	0	08:00	1.20	0.01
0.05	0						
(1P)079		CONDUIT	6.39	0	08:00	1.09	0.01
0.05	0						
(2A)001		CONDUIT	9664.61	1	08:57	3.32	1.08
0.95	193						
(2A)002		CONDUIT	9833.11	1	08:50	11.86	0.21
0.31	0						
(2A)003		CONDUIT	9834.10	1	08:50	5.27	0.63
0.57	0						
(2A)004		CONDUIT	9841.85	1	08:50	5.00	0.68
0.60	0						
(2A)005		CONDUIT	9867.21	1	08:51	5.04	0.68
0.61	0						
(2A)006		CONDUIT	9826.94	1	06:37	3.38	1.08
0.95	188						
(2A)007		CONDUIT	10453.43	1	08:52	3.87	1.02
0.87	3						
(2A)008		CONDUIT	10395.05	1	09:00	3.63	1.08
0.93	183						
(2A)009		CONDUIT	10324.72	1	08:58	3.59	1.08
0.93	184						
(2A)010		CONDUIT	10299.21	1	08:55	3.54	1.08
0.93	185						
(2A)011		CONDUIT	10021.88	1	08:49	3.44	1.08
0.95	189						
(2A)012		CONDUIT	10205.11	1	08:47	3.52	1.07
0.93	186						
(2A)013		CONDUIT	9937.19	1	06:29	3.41	1.08
0.95	190						
(2A)014		CONDUIT	12017.61	1	07:02	4.16	1.08
0.97	166						
(2A)015		CONDUIT	11396.34	1	08:28	4.15	1.03
0.91	163						
(2A)016		CONDUIT	11083.59	1	05:44	3.79	1.08
1.00	173						
(2A)017		CONDUIT	11871.40	1	06:11	4.06	1.08
0.95	167						
(2A)018		CONDUIT	11068.65	1	06:34	3.82	1.07
0.95	154						
(2A)019		CONDUIT	11068.65	1	06:34	4.28	0.93
0.76	0						
(2A)020		CONDUIT	11085.53	1	08:16	3.80	1.08
0.95	155						
(2A)021		CONDUIT	4248.80	1	07:27	4.16	0.27
0.36	0						
(2A)022		CONDUIT	4249.39	1	07:26	4.28	0.26
0.35	0						
(2A)023		CONDUIT	4250.10	1	07:24	4.32	0.26
0.35	0						

(2A) 024		CONDUIT	4250.37	1	07:24	4.54	0.24
0.34	0						
(2A) 025		CONDUIT	4250.38	1	07:24	4.87	0.22
0.32	0						
(2A) 026		CONDUIT	4250.36	1	07:23	4.61	0.24
0.33	0						
(2A) 027		CONDUIT	4250.51	1	07:23	3.12	0.41
0.44	0						
(2A) 028		CONDUIT	4251.84	1	07:22	2.79	0.47
0.48	0						
(2A) 029		CONDUIT	4252.42	1	07:21	2.98	0.43
0.46	0						
(2A) 030		CONDUIT	4252.99	1	07:20	3.19	0.40
0.44	0						
(2A) 031		CONDUIT	4253.53	1	07:19	3.47	0.35
0.41	0						
(2A) 032		CONDUIT	4255.02	1	07:18	2.93	0.44
0.47	0						
(2A) 033		CONDUIT	4255.35	1	07:17	3.33	0.37
0.42	0						
(2A) 034		CONDUIT	4255.75	1	07:17	3.92	0.30
0.37	0						
(2A) 035		CONDUIT	4254.78	1	07:16	3.94	0.30
0.37	0						
(2A) 036		CONDUIT	4256.16	1	07:15	3.95	0.30
0.37	0						
(2A) 037		CONDUIT	4257.99	1	07:14	3.75	0.32
0.39	0						
(2A) 038		CONDUIT	4259.99	1	07:12	4.00	0.29
0.37	0						
(2A) 039		CONDUIT	4261.78	1	07:11	3.95	0.30
0.37	0						
(2A) 040		CONDUIT	4264.25	1	07:10	3.92	0.30
0.38	0						
(2A) 041		CONDUIT	4263.48	1	07:09	3.96	0.30
0.37	0						
(2A) 042		CONDUIT	4262.12	1	07:07	3.96	0.30
0.37	0						
(2A) 043		CONDUIT	4263.83	1	07:06	4.15	0.28
0.36	0						
(2A) 044		CONDUIT	4266.23	1	07:05	3.90	0.30
0.38	0						
(2A) 045		CONDUIT	4270.63	1	07:04	3.81	0.31
0.38	0						
(2A) 046		CONDUIT	4271.35	1	07:03	3.75	0.32
0.39	0						
(2A) 047		CONDUIT	4271.71	1	07:02	2.92	0.45
0.47	0						
(2A) 048		CONDUIT	4275.09	1	07:00	2.90	0.46
0.47	0						
(2A) 0480		CONDUIT	2138.23	1	07:00	9.99	0.64
0.58	0						
(2A) 049		CONDUIT	5557.42	1	07:17	3.16	0.57
0.54	0						
(2A) 050		CONDUIT	5557.50	1	07:15	3.02	0.61
0.56	0						
(2A) 051		CONDUIT	5557.61	1	07:13	4.28	0.38
0.43	0						
(2A) 052		CONDUIT	5557.68	1	07:12	4.23	0.39
0.43	0						
(2A) 053		CONDUIT	5557.76	1	07:11	4.29	0.38

0.43	0						
(2A) 054		CONDUIT	5557.83	1	07:10	6.24	0.23
0.32	0						
(2A) 055		CONDUIT	5557.87	1	07:09	3.11	0.59
0.55	0						
(2A) 056		CONDUIT	5558.13	1	07:08	3.10	0.59
0.55	0						
(2A) 057		CONDUIT	5558.48	1	07:07	3.70	0.46
0.48	0						
(2A) 058		CONDUIT	5009.19	1	07:05	3.45	0.45
0.47	0						
(2A) 059		CONDUIT	5009.27	1	07:03	3.53	0.70
0.62	0						
(2A) 060		CONDUIT	5009.35	1	07:02	4.33	0.54
0.52	0						
(2A) 061		CONDUIT	5009.54	1	07:01	4.05	0.59
0.55	0						
(2A) 062		CONDUIT	5009.55	1	07:00	4.72	0.49
0.49	0						
(2A) 063		CONDUIT	4868.40	1	05:42	6.62	1.08
1.00	319						
(2A) 064		CONDUIT	7503.11	1	07:00	4.88	0.77
0.66	0						
(2A) 065		CONDUIT	5152.13	1	09:01	4.42	0.54
0.52	0						
(2A) 066		CONDUIT	5146.39	1	09:00	7.83	0.25
0.34	0						
(2A) 067		CONDUIT	5146.53	1	08:59	4.62	0.51
0.51	0						
(2A) 068		CONDUIT	5148.56	1	08:59	4.49	0.53
0.52	0						
(2A) 069		CONDUIT	551.40	1	09:51	8.85	0.12
0.23	0						
(2C) 001		CONDUIT	550.03	1	09:52	1.69	1.08
0.95	303						
(2C) 002		CONDUIT	556.44	1	05:48	1.71	1.08
0.95	300						
(2C) 003		CONDUIT	660.58	1	09:37	2.03	1.08
0.95	277						
(2C) 004		CONDUIT	668.24	1	08:51	2.08	1.08
0.92	207						
(2C) 005		CONDUIT	643.63	1	08:43	2.07	1.02
0.87	5						
(2C) 006		CONDUIT	632.87	1	08:43	1.95	1.08
0.95	219						
(2C) 007		CONDUIT	668.60	1	08:45	2.06	1.08
0.95	211						
(2C) 008		CONDUIT	677.95	1	08:38	2.11	1.07
0.93	209						
(2C) 009		CONDUIT	665.88	1	08:40	2.05	1.08
0.95	212						
(2C) 0090		CONDUIT	141.03	1	07:00	2.80	0.27
0.36	0						
(2D) 001		CONDUIT	491.97	1	10:47	1.52	1.08
0.92	316						
(2D) 001A		CONDUIT	466.33	1	06:53	1.44	1.08
0.95	351						
(2D) 002		CONDUIT	895.98	1	08:18	2.79	1.08
0.95	88						
(2D) 003		CONDUIT	908.95	1	07:47	2.80	1.08
0.95	85						

(2D) 004		CONDUIT	311.78	1	08:02	2.12	0.39
0.44	0						
(2D) 005		CONDUIT	311.87	1	08:01	2.23	0.37
0.42	0						
(2D) 006		CONDUIT	313.14	1	08:00	2.32	0.35
0.41	0						
(2D) 007		CONDUIT	289.70	1	08:02	2.01	0.38
0.43	0						
(2D) 008		CONDUIT	289.82	1	08:00	1.90	0.42
0.45	0						
(2D) 009		CONDUIT	289.73	1	08:00	3.02	0.66
0.59	0						
(2D) 010		CONDUIT	282.89	1	17:11	1.93	1.08
0.96	859						
(2D) 011		CONDUIT	313.00	1	05:22	2.14	1.08
0.95	719						
(2D) 012		CONDUIT	166.84	0	08:00	2.37	0.49
0.48	0						
(2D) 013		CONDUIT	167.24	0	08:00	2.55	0.50
0.48	0						
(2D) 014		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 015		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 016		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 017		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 018		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 019		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 020		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 021		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 022		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 023		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 024		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 025		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2D) 039		CONDUIT	206.15	1	06:53	2.64	0.28
0.36	0						
(2D) 040		CONDUIT	332.38	1	14:10	1.49	1.08
0.95	546						
(2D) 041		CONDUIT	541.60	1	08:17	2.52	1.07
0.92	33						
(2D) 042		CONDUIT	533.99	1	07:13	2.46	1.08
0.94	441						
(2D) 043		CONDUIT	541.31	1	08:08	2.50	1.08
0.93	60						
(2D) 044		CONDUIT	539.62	1	08:01	2.43	1.07
0.91	54						
(2D) 045		CONDUIT	504.41	1	12:36	2.40	1.00
0.82	1						
(2D) 045A		CONDUIT	498.42	1	05:37	2.22	1.08
0.95	470						
(2D) 046		CONDUIT	542.45	1	12:06	2.43	1.07

0.92	419							
(2D) 046A		CONDUIT	516.27	1	05:45	2.33	1.08	
0.95	433							
(2D) 241		CONDUIT	1681.97	1	07:14	4.12	0.52	
0.51	0							
(2D) 242		CONDUIT	1691.78	1	07:13	2.80	0.87	
0.72	0							
(2D) 243		CONDUIT	1681.76	1	07:12	2.82	0.87	
0.72	0							
(2D) 244		CONDUIT	1676.52	1	07:10	3.17	0.75	
0.65	0							
(2D) 244O		CONDUIT	206.30	1	06:52	3.98	0.15	
0.26	0							
(2D) 245		CONDUIT	1547.71	1	06:51	2.16	1.08	
0.95	29							
(2D) 246		CONDUIT	1804.26	1	07:06	2.87	0.92	
0.76	0							
(2D) 247		CONDUIT	1812.58	1	07:05	2.86	0.93	
0.76	0							
(2D) 248		CONDUIT	1820.28	1	07:03	2.95	0.91	
0.74	0							
(2D) 249		CONDUIT	1827.66	1	07:02	2.88	0.95	
0.77	0							
(2D) 250		CONDUIT	1835.87	1	07:01	2.99	0.89	
0.73	0							
(2D) 251		CONDUIT	1849.42	1	07:00	2.93	0.93	
0.76	0							
(2D) 252		CONDUIT	246.22	1	08:15	1.79	0.37	
0.42	0							
(2D) 253		CONDUIT	246.22	1	08:13	1.71	0.12	
0.24	0							
(2D) 254		CONDUIT	246.34	1	08:12	1.72	0.12	
0.24	0							
(2D) 255		CONDUIT	246.20	1	08:11	1.72	0.12	
0.24	0							
(2D) 256		CONDUIT	246.07	1	08:08	1.72	0.12	
0.24	0							
(2D) 257		CONDUIT	246.03	1	08:07	1.71	0.12	
0.24	0							
(2D) 258		CONDUIT	246.32	1	08:06	1.71	0.12	
0.24	0							
(2D) 259		CONDUIT	246.51	1	08:05	1.72	0.12	
0.24	0							
(2D) 260		CONDUIT	247.08	1	08:04	1.72	0.12	
0.24	0							
(2D) 261		CONDUIT	247.08	1	08:03	1.73	0.12	
0.24	0							
(2D) 262		CONDUIT	247.39	1	08:02	1.76	0.12	
0.24	0							
(2D) 263		CONDUIT	247.83	1	08:00	1.77	0.13	
0.24	0							
(2D) 264		CONDUIT	236.83	0	08:04	1.76	0.12	
0.23	0							
(2D) 265		CONDUIT	240.36	0	08:02	1.80	0.20	
0.30	0							
(2D) 266		CONDUIT	247.65	0	08:01	1.88	0.20	
0.30	0							
(2D) 267		CONDUIT	265.93	0	08:00	2.18	0.22	
0.29	0							
(2E) 001		CONDUIT	5146.03	1	06:44	2.54	1.08	
0.95	225							

(2E)002		CONDUIT	6560.14	1	08:29	3.24	1.08
0.95	173						
(2E)003		CONDUIT	11022.88	1	05:51	5.41	1.08
1.00	108						
(2E)004		CONDUIT	3534.79	1	14:23	2.78	0.63
0.58	0						
(2E)005		CONDUIT	3604.29	1	14:56	1.79	1.07
0.94	545						
(2E)006		CONDUIT	3536.36	1	14:52	1.75	1.08
0.95	555						
(2E)007		CONDUIT	6276.52	1	09:55	3.14	1.08
0.92	230						
(2E)008		CONDUIT	5963.78	1	09:52	4.46	0.67
0.60	0						
(2E)009		CONDUIT	5975.27	1	09:51	3.62	0.89
0.74	0						
(2E)010		CONDUIT	6126.92	1	09:50	3.16	1.08
0.93	251						
(2E)011		CONDUIT	6063.07	1	09:57	3.07	1.08
0.94	253						
(2E)012		CONDUIT	6037.05	1	09:41	3.00	1.07
0.94	248						
(2E)013		CONDUIT	5931.28	1	09:57	2.92	1.08
0.95	264						
(2E)014		CONDUIT	5937.41	1	06:25	2.92	1.08
0.95	260						
(2E)043		CONDUIT	134.18	0	08:00	2.01	0.16
0.27	0						
(2F)001		CONDUIT	5749.12	1	07:48	2.84	1.08
0.96	156						
(2F)002		CONDUIT	5818.48	1	08:11	2.89	1.08
0.95	152						
(2F)003		CONDUIT	5838.51	1	08:03	2.88	1.08
0.95	150						
(2F)004		CONDUIT	5751.88	1	06:09	2.82	1.08
0.95	153						
(2F)005		CONDUIT	4704.12	1	08:00	2.80	0.87
0.72	0						
(2F)006		CONDUIT	4573.47	1	12:21	2.78	0.84
0.70	0						
(2F)007		CONDUIT	4591.76	1	12:20	2.82	0.85
0.70	0						
(2F)008		CONDUIT	4546.15	1	12:19	2.68	0.89
0.74	0						
(2F)009		CONDUIT	4544.29	1	05:32	2.74	1.08
1.00	433						
(2F)010		CONDUIT	6172.98	1	05:41	8.33	1.08
1.00	175						
(2F)011		CONDUIT	2032.38	1	05:38	2.77	1.08
1.00	180						
(2F)012		CONDUIT	1459.89	1	08:09	2.57	0.79
0.67	0						
(2F)013		CONDUIT	1459.98	1	08:07	2.42	0.86
0.71	0						
(2F)014		CONDUIT	1460.10	1	08:04	2.45	0.84
0.70	0						
(2F)015		CONDUIT	1460.29	1	08:03	2.47	0.83
0.70	0						
(2F)016		CONDUIT	1460.72	1	08:01	2.42	0.86
0.71	0						
(2F)017		CONDUIT	1461.91	1	08:00	2.42	0.86

0.71	0						
(2F)018		CONDUIT	1445.66	1	08:44	2.44	0.84
0.70	0						
(2F)019		CONDUIT	1445.82	1	08:43	2.44	0.84
0.70	0						
(2F)020		CONDUIT	1445.04	1	08:37	2.40	0.86
0.71	0						
(2F)021		CONDUIT	1447.22	1	08:37	2.43	0.85
0.71	0						
(2F)022		CONDUIT	1447.14	1	08:36	2.84	0.70
0.61	0						
(2F)023		CONDUIT	649.49	1	05:14	1.97	1.08
1.00	209						
(2F)024		CONDUIT	212.06	1	11:10	1.63	0.34
0.40	0						
(2F)025		CONDUIT	210.70	1	11:35	0.67	1.08
0.95	383						
(2F)026		CONDUIT	87.83	0	22:01	0.58	0.42
0.45	0						
(2F)027		CONDUIT	87.97	0	21:46	0.58	0.42
0.45	0						
(2F)028		CONDUIT	88.37	0	21:36	0.59	0.43
0.45	0						
(2F)029		CONDUIT	88.73	0	21:29	0.59	0.43
0.45	0						
(2F)030		CONDUIT	90.16	0	08:21	0.60	0.43
0.46	0						
(2F)031		CONDUIT	93.68	1	08:00	0.62	0.45
0.46	0						
(2F)032		CONDUIT	95.54	1	08:05	0.64	0.46
0.46	0						
(2F)033		CONDUIT	107.82	1	08:00	0.75	0.52
0.45	0						
(2G)001		CONDUIT	816.46	3	08:11	2.56	1.08
0.94	1462						
(2G)002		CONDUIT	795.54	0	21:06	2.44	1.08
0.96	1511						
(2G)002A		CONDUIT	806.68	1	05:25	2.47	1.08
0.96	1321						
(2G)003		CONDUIT	637.29	1	08:00	2.38	0.86
0.71	0						
(2G)004		CONDUIT	640.69	1	08:00	2.43	0.86
0.71	0						
(2G)005		CONDUIT	598.15	1	08:03	2.47	0.80
0.68	0						
(2G)006		CONDUIT	612.25	1	08:01	2.75	1.08
0.92	60						
(2G)007		CONDUIT	593.95	1	08:00	2.70	1.06
0.91	58						
(2G)008		CONDUIT	513.60	1	05:02	2.25	1.08
1.00	623						
(2G)009		CONDUIT	638.01	1	05:25	2.82	1.08
0.95	477						
(2G)010		CONDUIT	402.88	3	07:25	2.49	0.73
0.64	0						
(2G)011		CONDUIT	406.17	3	07:25	2.60	0.72
0.62	0						
(2G)012		CONDUIT	399.31	0	21:20	1.79	1.08
0.92	757						
(2G)012A		CONDUIT	378.25	2	19:21	2.59	0.64
0.58	0						

(2G)013		CONDUIT	378.48	0	19:16	2.73	0.60
0.56	0						
(2G)013A		CONDUIT	379.00	0	19:16	3.23	0.47
0.49	0						
(2G)014		CONDUIT	352.84	2	21:19	2.81	0.54
0.52	0						
(2G)015		CONDUIT	349.17	0	07:09	1.57	1.08
1.00	1559						
(2G)016		CONDUIT	389.74	0	21:02	1.76	1.08
0.95	1221						
(2G)016A		CONDUIT	365.98	1	05:18	1.61	1.08
0.95	627						
(2G)018		CONDUIT	393.83	1	05:44	1.75	1.08
0.95	598						
(2G)019		CONDUIT	383.49	1	05:52	1.70	1.08
0.95	591						
(2G)020		CONDUIT	384.07	1	11:44	1.73	1.08
0.95	430						
(2G)021		CONDUIT	386.55	1	06:09	1.72	1.08
0.95	428						
(2G)022		CONDUIT	386.49	1	12:03	1.72	1.08
0.95	426						
(2G)023		CONDUIT	386.23	1	06:02	1.72	1.08
0.95	424						
(2G)024		CONDUIT	384.19	1	05:39	1.71	1.08
0.95	422						
(2G)025		CONDUIT	605.28	1	05:03	2.68	1.08
1.00	357						
(2G)026		CONDUIT	866.92	1	05:42	3.84	1.08
0.95	255						
(2G)040		CONDUIT	988.20	1	06:12	3.05	1.08
0.95	470						
(2G)041		CONDUIT	260.92	0	08:18	1.04	0.84
0.70	0						
(2G)042		CONDUIT	262.20	0	08:13	1.06	0.85
0.70	0						
(2G)043		CONDUIT	263.81	1	08:08	1.07	0.85
0.70	0						
(2G)043A		CONDUIT	265.85	0	08:04	1.06	0.86
0.70	0						
(2G)044		CONDUIT	271.89	1	08:02	1.09	0.88
0.71	0						
(2G)045		CONDUIT	296.58	1	08:00	1.24	0.96
0.68	0						
(2G)359		CONDUIT	391.31	1	06:25	1.74	1.08
0.95	328						
(2H)001		CONDUIT	2490.23	1	11:01	2.99	0.88
0.73	0						
(2H)002		CONDUIT	2530.38	1	11:00	2.57	1.08
0.94	337						
(2H)003		CONDUIT	2473.11	1	10:57	2.51	1.08
0.95	339						
(2H)005		CONDUIT	2507.52	1	10:52	2.54	1.08
0.95	337						
(2H)006		CONDUIT	2501.16	1	10:48	2.51	1.08
0.95	336						
(2H)007		CONDUIT	2766.03	1	05:58	2.78	1.08
0.95	325						
(2H)008		CONDUIT	2910.80	1	09:45	3.71	0.81
0.68	0						
(2H)009		CONDUIT	2910.04	1	09:44	3.47	0.88

0.73	0						
(2H)010		CONDUIT	2911.93	1	09:44	3.39	0.90
0.74	0						
(2H)011		CONDUIT	2918.42	1	09:44	3.68	0.83
0.69	0						
(2H)012		CONDUIT	2906.23	1	05:53	2.92	1.08
0.95	291						
(2H)013		CONDUIT	2679.54	1	07:22	2.69	1.08
0.95	114						
(2H)014		CONDUIT	1465.88	1	07:59	3.16	0.61
0.57	0						
(2H)015		CONDUIT	1463.47	1	08:01	2.78	0.72
0.63	0						
(2H)016		CONDUIT	1463.50	1	08:00	2.13	1.00
0.82	0						
(2H)017		CONDUIT	1460.42	1	08:00	4.40	0.39
0.44	0						
(2H)017A		CONDUIT	1460.67	1	08:00	2.74	0.73
0.64	0						
(2H)018		CONDUIT	1454.06	1	08:00	2.62	0.77
0.66	0						
(2H)019		CONDUIT	1454.19	1	08:00	2.68	0.75
0.65	0						
(2H)020		CONDUIT	1450.06	1	07:54	2.57	0.79
0.67	0						
(2H)021		CONDUIT	1448.98	1	08:00	2.83	0.70
0.62	0						
(2H)022		CONDUIT	1008.88	1	10:07	3.41	0.55
0.53	0						
(2H)023		CONDUIT	1008.67	1	10:06	3.46	0.54
0.52	0						
(2H)024		CONDUIT	1010.18	1	10:06	3.23	0.60
0.56	0						
(2H)025		CONDUIT	1008.27	1	10:16	2.00	1.08
0.95	310						
(2H)026		CONDUIT	441.51	1	08:00	2.96	0.40
0.44	0						
(2H)027		CONDUIT	439.71	1	08:03	2.25	0.57
0.54	0						
(2H)028		CONDUIT	439.79	1	08:02	2.28	0.57
0.54	0						
(2H)029		CONDUIT	439.99	1	08:01	2.32	0.56
0.53	0						
(2H)030		CONDUIT	440.94	1	08:00	2.07	0.64
0.58	0						
(2H)031		CONDUIT	428.33	1	11:54	1.32	1.08
0.95	395						
(2H)032		CONDUIT	541.79	1	05:26	1.66	1.08
1.00	196						
(2H)033		CONDUIT	2137.18	1	06:30	7.85	0.87
0.72	0						
(2H)034		CONDUIT	420.37	1	08:00	2.21	0.56
0.53	0						
(2H)036		CONDUIT	420.45	1	08:00	2.25	0.54
0.52	0						
(2H)037		CONDUIT	417.18	1	11:37	2.42	0.49
0.49	0						
(2H)038		CONDUIT	417.26	1	11:33	2.25	0.54
0.52	0						
(2H)039		CONDUIT	417.24	1	11:32	2.40	0.49
0.50	0						

(2H)040		CONDUIT	417.25	1	11:31	1.91	0.67
0.60	0						
(2H)041		CONDUIT	417.27	1	11:29	2.25	0.54
0.52	0						
(2H)042		CONDUIT	417.33	1	11:28	2.66	0.43
0.46	0						
(2H)043		CONDUIT	417.59	1	11:27	1.95	0.65
0.59	0						
(2H)044		CONDUIT	417.40	1	11:26	2.11	0.58
0.55	0						
(2H)045		CONDUIT	417.49	1	11:25	2.13	0.58
0.55	0						
(2H)046		CONDUIT	417.74	1	11:25	2.25	0.54
0.52	0						
(2H)047		CONDUIT	417.10	1	11:31	1.29	1.08
0.95	384						
(2H)048		CONDUIT	739.15	1	06:26	4.03	0.53
0.52	0						
(2H)049		CONDUIT	740.13	1	09:44	2.28	1.08
0.95	276						
(2H)050		CONDUIT	360.45	1	11:01	1.74	0.63
0.57	0						
(2H)051		CONDUIT	360.54	1	10:58	1.71	0.64
0.58	0						
(2H)051A		CONDUIT	361.36	1	10:57	1.95	0.54
0.52	0						
(2H)052		CONDUIT	361.52	1	10:57	2.24	0.45
0.47	0						
(2H)053		CONDUIT	360.24	1	11:09	1.14	1.08
0.95	365						
(2H)054		CONDUIT	553.61	1	06:18	2.49	1.08
1.00	218						
(2H)054A		CONDUIT	553.84	1	06:42	2.47	1.08
0.96	218						
(2H)055		CONDUIT	554.63	1	05:42	2.49	1.08
0.96	218						
(2H)055A		CONDUIT	554.64	1	05:42	2.46	1.08
0.96	218						
(2H)056		CONDUIT	554.64	1	05:42	2.50	1.08
0.97	217						
(2H)057		CONDUIT	554.64	1	05:45	2.47	1.08
0.94	216						
(2H)058		CONDUIT	553.52	1	05:19	2.47	1.08
1.00	216						
(2H)285		CONDUIT	511.39	1	09:59	2.31	1.06
0.93	294						
(2H)286		CONDUIT	496.39	1	05:40	2.20	1.08
0.95	298						
(2H)287		CONDUIT	495.41	1	07:46	2.25	1.08
0.95	126						
(2H)288		CONDUIT	495.27	1	07:42	2.25	1.08
0.95	126						
(2H)289		CONDUIT	494.18	1	07:39	2.24	1.08
0.95	127						
(2H)290		CONDUIT	498.43	1	07:31	2.22	1.08
0.95	121						
(2I)001		CONDUIT	1419.61	1	05:09	2.78	1.08
1.00	280						
(2I)001A		CONDUIT	1017.06	1	10:12	2.01	1.08
0.95	309						
(2I)002		CONDUIT	1639.08	1	07:13	4.65	0.69

0.61	0						
(2I)003		CONDUIT	1625.67	1	05:50	3.20	1.08
0.95	259						
(2I)004		CONDUIT	1566.96	1	05:15	3.08	1.08
1.00	249						
(2I)005		CONDUIT	1633.82	1	09:14	3.22	1.08
0.95	244						
(2I)006		CONDUIT	1654.45	1	08:02	3.27	1.08
0.94	150						
(2I)008		CONDUIT	1626.05	1	08:00	3.21	1.08
0.95	150						
(2I)009		CONDUIT	1397.47	1	07:46	3.08	0.95
0.78	0						
(2I)010		CONDUIT	1393.19	1	07:45	3.16	0.91
0.75	0						
(2I)011		CONDUIT	1394.25	1	07:45	3.12	0.93
0.76	0						
(2I)012		CONDUIT	1388.60	1	07:44	3.13	0.92
0.76	0						
(2I)013		CONDUIT	1391.66	1	07:44	3.10	0.94
0.77	0						
(2I)014		CONDUIT	1385.97	1	06:02	2.73	1.08
0.95	139						
(2I)015		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2I)016		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2I)017		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2I)018		CONDUIT	704.33	1	11:11	2.17	1.08
0.95	368						
(2I)019		CONDUIT	863.46	1	10:49	2.68	0.62
0.57	0						
(2I)020		CONDUIT	862.71	1	10:54	2.66	1.08
0.95	352						
(2I)021		CONDUIT	768.76	1	06:10	2.36	1.08
0.95	263						
(2I)021A		CONDUIT	1139.34	1	05:35	2.59	1.07
1.00	159						
(2I)021B		CONDUIT	1141.61	1	06:02	2.58	1.08
0.95	159						
(2I)021C		CONDUIT	618.78	1	05:38	1.40	1.08
0.95	336						
(2I)022		CONDUIT	768.19	1	10:30	2.36	0.74
0.64	0						
(2I)023		CONDUIT	765.33	1	10:30	2.40	1.08
0.95	321						
(2I)024		CONDUIT	764.11	1	10:26	2.38	1.08
0.95	321						
(2I)025		CONDUIT	765.04	1	10:22	2.37	1.08
0.95	320						
(2I)025A		CONDUIT	759.11	1	05:44	2.34	1.08
0.95	321						
(2I)026		CONDUIT	782.67	1	09:06	2.51	1.06
0.92	2						
(2I)027		CONDUIT	768.03	1	09:05	2.41	1.08
0.92	232						
(2I)028		CONDUIT	728.13	1	05:14	2.23	1.08
1.00	239						
(2I)029		CONDUIT	791.16	1	05:16	2.42	1.08
1.00	227						

(2I)044		CONDUIT	1374.63	1	09:06	4.38	1.06
0.93	19						
(2I)045		CONDUIT	1392.70	1	08:54	4.36	1.07
1.00	233						
(2I)046		CONDUIT	1403.65	1	09:05	4.36	1.08
0.95	232						
(2I)047		CONDUIT	1401.75	1	08:55	4.42	1.08
0.95	233						
(2I)048		CONDUIT	1400.38	1	05:44	4.33	1.08
0.95	233						
(2I)049		CONDUIT	1400.38	1	05:09	4.29	1.08
1.00	233						
(2I)050		CONDUIT	886.16	1	09:24	2.80	1.08
0.93	250						
(2I)051		CONDUIT	885.68	1	05:16	2.73	1.08
0.95	249						
(2I)052		CONDUIT	879.27	1	05:16	2.74	1.07
1.00	249						
(2I)053		CONDUIT	887.47	1	06:01	2.75	1.08
0.96	248						
(2I)054		CONDUIT	889.05	1	09:15	2.74	1.08
0.95	248						
(2I)055		CONDUIT	887.47	1	05:49	2.78	1.08
0.95	205						
(2I)056		CONDUIT	887.47	1	06:14	2.81	1.08
0.96	203						
(2I)057		CONDUIT	887.67	1	08:27	2.75	1.08
0.96	203						
(2I)058		CONDUIT	887.47	1	06:15	2.76	1.08
0.96	203						
(2I)059		CONDUIT	888.51	1	08:31	2.78	1.08
0.95	203						
(2J)001		CONDUIT	4183.14	1	11:14	3.18	0.88
0.72	0						
(2J)002		CONDUIT	4177.86	1	11:35	2.59	1.08
0.95	346						
(2J)003		CONDUIT	4150.08	1	10:02	2.60	1.06
0.94	343						
(2J)004		CONDUIT	4153.24	1	10:01	2.57	1.08
0.97	347						
(2J)005		CONDUIT	4259.24	1	11:28	2.78	0.99
0.81	0						
(2J)006		CONDUIT	4248.52	1	11:28	2.64	1.08
0.95	341						
(2J)007		CONDUIT	4208.91	1	11:25	2.58	1.08
0.96	342						
(2J)008		CONDUIT	4207.00	1	11:05	2.58	1.08
0.95	344						
(2J)009		CONDUIT	3995.82	1	11:19	3.20	0.78
0.66	0						
(2J)010		CONDUIT	4012.43	1	11:19	3.25	0.77
0.66	0						
(2J)011		CONDUIT	3954.59	1	11:18	4.07	0.78
0.66	0						
(2J)012		CONDUIT	4000.30	1	11:00	3.14	1.08
0.93	326						
(2J)013		CONDUIT	3927.13	1	11:15	3.04	1.08
0.94	330						
(2J)014		CONDUIT	3949.25	1	11:01	3.23	1.05
0.90	5						
(2J)015		CONDUIT	3901.93	1	11:00	3.03	1.07

0.92	321						
(2J)016		CONDUIT	3697.82	1	08:03	3.04	1.00
0.82	0						
(2J)017		CONDUIT	3697.80	1	08:02	3.24	0.93
0.76	0						
(2J)018		CONDUIT	3699.77	1	11:02	3.01	1.00
0.82	0						
(2J)019		CONDUIT	1217.59	1	12:41	2.56	0.43
0.45	0						
(2J)020		CONDUIT	83.13	0	01:53	0.43	1.08
0.94	4980						
(2J)021		CONDUIT	363.84	1	08:00	3.75	0.50
0.50	0						
(2J)022		CONDUIT	357.53	1	05:06	1.94	1.08
1.00	1007						
(2J)023		CONDUIT	390.91	1	18:03	1.73	1.08
0.96	980						
(2J)024		CONDUIT	831.44	1	05:34	3.67	1.08
1.00	368						
(2J)0250		CONDUIT	122.46	1	07:59	7.53	0.03
0.12	0						
(2J)026		CONDUIT	482.18	1	11:16	2.15	1.08
0.95	376						
(2J)027		CONDUIT	491.84	1	10:06	2.21	1.08
0.94	296						
(2J)028		CONDUIT	479.02	1	09:59	2.12	1.08
0.95	298						
(2J)029		CONDUIT	492.72	1	06:06	2.19	1.08
0.95	295						
(2J)030		CONDUIT	327.94	1	09:44	2.34	1.08
0.91	250						
(2J)031		CONDUIT	316.96	1	09:42	2.20	1.08
0.93	273						
(2J)032		CONDUIT	303.41	1	06:09	2.11	1.08
0.95	279						
(2J)033		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
(2J)040		CONDUIT	481.92	1	07:59	2.84	0.81
0.68	0						
(2J)041		CONDUIT	487.11	1	13:14	2.22	1.08
0.94	478						
(2J)042		CONDUIT	479.90	1	13:10	2.13	1.08
0.95	483						
(2J)043		CONDUIT	475.08	1	07:12	2.28	1.00
0.82	0						
(2J)044		CONDUIT	468.26	1	05:16	2.07	1.08
0.95	488						
(2J)045		CONDUIT	487.47	1	12:37	2.25	1.06
0.91	450						
(2J)045A		CONDUIT	460.25	1	05:36	2.05	1.08
0.95	487						
(2J)046		CONDUIT	477.03	1	12:57	2.15	1.06
0.94	465						
(2J)047		CONDUIT	470.06	1	06:02	2.08	1.08
0.95	473						
(2J)048		CONDUIT	326.85	1	08:00	1.99	0.74
0.64	0						
(2J)049		CONDUIT	314.19	1	20:06	2.38	0.55
0.53	0						
(2J)050		CONDUIT	314.61	1	20:06	2.03	0.70
0.61	0						

(2J)051		CONDUIT	314.43	1	20:05	2.02	0.72
0.62	0						
(2J)052		CONDUIT	316.99	1	20:05	2.21	1.08
0.93	917						
(2J)053		CONDUIT	305.55	1	20:08	2.10	1.08
0.97	938						
(2J)054		CONDUIT	310.81	1	06:10	2.15	1.08
0.95	901						
(2J)055		CONDUIT	313.63	1	05:46	2.17	1.08
0.95	879						
(2J)056		CONDUIT	314.46	1	05:31	2.16	1.08
0.95	877						
(2J)057		CONDUIT	71.31	0	08:00	1.58	0.25
0.34	0						
(2J)058		CONDUIT	76.07	0	08:00	1.82	0.28
0.34	0						
(2K)001		CONDUIT	1213.86	1	12:56	1.22	1.08
0.95	454						
(2K)002		CONDUIT	1310.04	1	08:00	5.40	0.42
0.45	0						
(2K)003		CONDUIT	1271.53	1	08:00	2.90	0.90
0.74	0						
(2K)004		CONDUIT	1269.33	1	10:02	2.66	0.99
0.81	0						
(2K)005		CONDUIT	1269.34	1	10:02	2.68	0.98
0.81	0						
(2K)006		CONDUIT	1269.74	1	09:57	2.72	0.97
0.80	0						
(2K)007		CONDUIT	1270.09	1	09:57	3.08	0.84
0.70	0						
(2K)008		CONDUIT	1269.70	1	09:56	2.75	0.97
0.79	0						
(2K)009		CONDUIT	1273.65	1	09:57	2.83	0.94
0.77	0						
(2K)010		CONDUIT	1275.74	1	09:56	2.70	1.00
0.82	1						
(2K)011		CONDUIT	1270.94	1	09:57	2.51	1.08
0.95	306						
(2K)012		CONDUIT	1374.05	1	09:40	2.93	0.98
0.80	0						
(2K)013		CONDUIT	1368.91	1	05:54	2.69	1.08
0.95	289						
(2K)014		CONDUIT	929.21	1	05:31	2.84	1.08
0.95	305						
(2K)015		CONDUIT	696.37	1	05:56	2.15	1.08
0.95	423						
(2K)016		CONDUIT	860.24	1	10:19	2.81	1.03
0.87	4						
(2K)017		CONDUIT	862.12	1	10:19	2.71	1.06
0.91	310						
(2K)018		CONDUIT	820.06	1	05:55	2.52	1.08
0.95	400						
(2K)018A		CONDUIT	864.04	1	05:12	2.65	1.08
1.00	351						
(2K)019		CONDUIT	945.34	1	05:31	2.89	1.08
0.95	305						
(2K)020		CONDUIT	716.75	1	11:53	2.77	0.85
0.71	0						
(2K)021		CONDUIT	714.16	1	05:12	2.18	1.08
1.00	408						
(2K)022		CONDUIT	864.42	1	10:10	2.96	0.98

0.79	0						
(2K) 022A		CONDUIT	874.87	1	10:09	2.78	1.06
0.92	299						
(2K) 023		CONDUIT	860.25	1	10:08	2.66	1.08
0.94	312						
(2K) 024		CONDUIT	842.01	1	10:07	2.92	0.96
0.79	0						
(2K) 024A		CONDUIT	840.34	1	05:09	2.54	1.08
1.00	346						
(2K) 025		CONDUIT	913.37	1	05:54	2.81	1.08
0.95	291						
(2K) 026		CONDUIT	653.11	1	11:30	2.35	0.91
0.75	0						
(2K) 027		CONDUIT	666.72	1	11:41	7.66	0.19
0.30	0						
(2K) 028		CONDUIT	662.96	1	11:41	2.05	1.08
0.94	394						
(2K) 029		CONDUIT	652.01	1	06:31	2.02	1.08
0.95	396						
(2K) 030		CONDUIT	659.74	1	11:08	2.08	1.08
0.95	341						
(2K) 031		CONDUIT	657.11	1	11:05	2.09	1.08
0.96	340						
(2K) 032		CONDUIT	662.86	1	10:58	2.09	1.08
0.95	340						
(2K) 033		CONDUIT	653.27	1	06:49	2.07	1.08
0.95	342						
(2K) 033A		CONDUIT	635.43	1	06:51	2.00	1.08
0.95	313						
(2K) 034		CONDUIT	645.51	1	10:33	2.00	1.08
0.97	310						
(2K) 035		CONDUIT	678.05	1	10:33	2.12	1.08
0.92	301						
(2K) 036		CONDUIT	663.19	1	10:32	2.07	1.08
0.94	308						
(2K) 037		CONDUIT	648.37	1	10:22	2.05	1.08
0.95	313						
(2K) 038		CONDUIT	648.27	1	10:26	2.01	1.08
0.96	306						
(2K) 039		CONDUIT	648.06	1	05:47	2.05	1.08
0.96	306						
(2K) 040		CONDUIT	648.06	1	05:47	2.02	1.08
0.96	305						
(2K) 041		CONDUIT	648.06	1	05:47	2.03	1.08
0.96	305						
(2K) 042		CONDUIT	649.12	1	10:11	2.00	1.08
0.95	304						
(2K) 043		CONDUIT	649.02	1	09:31	2.11	1.08
0.96	236						
(2K) 044		CONDUIT	648.02	1	05:59	2.09	1.08
0.96	236						
(2K) 045		CONDUIT	648.56	1	09:24	2.10	1.08
0.96	236						
(2K) 046		CONDUIT	648.06	1	05:56	2.09	1.08
0.96	237						
(2K) 047		CONDUIT	648.06	1	05:54	2.08	1.08
0.96	236						
(2K) 048		CONDUIT	648.18	1	09:13	2.08	1.08
0.96	237						
(2K) 049		CONDUIT	648.06	1	05:54	2.07	1.08
0.96	237						

(2K)050		CONDUIT	648.82	1	09:05	2.05	1.08
0.96	237						
(2K)051		CONDUIT	648.06	1	05:54	2.04	1.08
0.96	235						
(2K)052		CONDUIT	648.06	1	06:05	3.44	1.08
0.95	236						
(2K)314		CONDUIT	417.56	1	15:06	2.57	0.73
0.63	0						
(2K)315		CONDUIT	416.01	1	06:31	1.85	1.08
0.95	619						
(2K)316		CONDUIT	503.62	1	14:31	2.25	1.07
0.94	563						
(2K)317		CONDUIT	497.63	1	05:31	2.19	1.08
0.95	567						
ForcedMain2		CONDUIT	148.78	0	10:10	0.98	1.08
0.93	4981						
Line2ToPlant		CONDUIT	3540.80	3	07:10	3.67	0.32
0.39	0						
NorthEnid		CONDUIT	0.00	0	00:00	0.00	0.00
0.00	0						
1		CONDUIT	1632.03	1	05:12	15.02	0.26
0.35	0						
PUMP1@(2A)000-(PLANT)		PUMP	6000.00	1	06:03		1.00
289							
ForcedMain		PUMP	1200.00	1	05:08		1.00
635							
OverflowPump		PUMP	4000.00	1	05:53		1.00
341							
(IO)304C-O		ORIFICE	1780.84	1	17:16		
0.00	0						
WEIR1@(1A)DIV-(1A)STOR		WEIR	0.00	0	00:00		
0.00	0						
(IO)304-1		WEIR	1863.50	1	08:29		
0.00	0						

Highest Flow Instability Indexes

Link (10)304-1 (136)
Link (10)304A (136)
Link (10)303 (136)
Link (10)304 (136)
Link (10)072 (136)

Routing Time Step Summary

Minimum Time Step : 30.00 sec
Average Time Step : 29.65 sec
Maximum Time Step : 30.00 sec
Percent in Steady State : 0.00
Average Iterations per Step : 1.17


Analysis begun on: Mon Aug 11 13:58:14 2008
Analysis ended on: Mon Aug 11 13:58:36 2008
Total elapsed time: 00:00:22

TM 2-7

**FEBRUARY 2007
EVALUATION OF SANITARY
SEWER PIPELINE
EXTENSION FOR THE
OKLAHOMA ETHANOL
PLANT**

EVALUATION OF SANITARY SEWER PIPELINE
EXTENSION

OKLAHOMA ETHANOL PLANT



FEBRUARY 2007

C.A. 1960—Expiration Date 06/30/08
06169-00-OEG



TABLE OF CONTENTS

1. PREFACE..... 1.

2. INTRODUCTION..... 1.

3. BASIS OF SANITARY SEWER ALIGNMENT OPTIONS..... 2.

 3.1 Option 1 - Washington Street..... 2.

 3.2 Option 2 - Elm Street..... 2.

 3.3 Option 3 - 30TH Street..... 2.

 3.4 Option 4 - 42ND Street..... 2.

 3.5 Option 5 - 54TH Street..... 2.

4. OPTION ANALYSIS..... 3.

 4.1 Option 1 - Washington Street Analysis..... 3.

 4.2 Option 2 - Elm Street Analysis..... 4.

 4.3 Option 3 - 30TH Street Analysis..... 5.

 4.4 Option 4 - 42ND Street Analysis..... 7.

 4.5 Option 5 - 54TH Street Analysis..... 8.

5. CONCLUSIONS AND RECOMMENDATIONS..... 8.

LIST OF FIGURES:

FIGURE 1. OKLAHOMA ETHANOL PLANT SANITARY SEWER OPTIONS

FIGURE 2. OKLAHOMA ETHANOL PLANT SANITARY SEWER ACCESS

FIGURE 3. PLAN VIEW - WASHINGTON AVENUE OPTION 1

FIGURE 4. PROFILE - WASHINGTON AVENUE OPTION 1

FIGURE 5. LAYOUT PLAN - WASHINGTON AVENUE OPTION 1

FIGURE 6. PLAN VIEW - ELM STREET OPTION 2

FIGURE 7. PROFILE - ELM STREET OPTION 2

FIGURE 8. LAYOUT PLAN - ELM STREET OPTION 2

FIGURE 9. PLAN VIEW - 30TH STREET OPTION 3

FIGURE 10. PROFILE - 30TH STREET OPTION 3

FIGURE 11. LAYOUT PLAN - 30TH STREET OPTION 3

FIGURE 12. PLAN VIEW - 42ND STREET OPTION 4

FIGURE 13. PROFILE - 42ND STREET OPTION 4

FIGURE 14. ALTERNATE 42ND STREET OPTION

LIST OF TABLES:

TABLE 1. COST ESTIMATE - WASHINGTON AVENUE OPTION 1

TABLE 2a. COST ESTIMATE - 16TH STREET OPTION 2 (TRENCH AND BORE)

TABLE 2b. COST ESTIMATE - 16TH STREET OPTION 2 (TRENCH)

TABLE 3a. COST ESTIMATE - 30TH STREET OPTION 3 (ALL-GRAVITY FLOW)

TABLE 3b. COST ESTIMATE - 30TH STREET OPTION 3 (PUMP AND GRAVITY)

TABLE 4. COST ESTIMATE - 42ND STREET OPTION 4

TABLE 5. SUMMARY OF COST ESTIMATES FOR OPTIONS 1 THROUGH 4

LIST OF APPENDICES:

APPENDIX A. SANITARY SEWER FLOW CALCULATIONS



1. PREFACE

The original concept for sanitary sewer service to the proposed Oklahoma Ethanol Plant was based on the possibility of connecting to the nearest available existing sanitary sewer pipeline. This was presented to ENVIROTECH ENGINEERING & CONSULTING, INC. early in the proposal process as a lift station at the plant on 16TH Street that would pump through a force main into the existing 8-in.-dia. sanitary sewer pipeline just east of 11TH Street. The associated construction cost estimate presented by the City was approximately \$450,000.00. Subsequent to further evaluation, ENVIROTECH discovered that the existing 8-in.-dia. sanitary sewer line was fed by businesses north and south of Willow Road westward to 4TH Street and the neighborhood northeast of Willow Road and 4TH Street. This line then entered a 10-in.-dia. line that extends south on 4TH Street to a larger collector south. Since the design requirement for 300,000-gpd requires nearly all of an 8-in.-dia. line, it was determined that the existing 8-in.-dia. line was already at full capacity. At this point, the City began to search for alternate routes to convey the sanitary sewer flow from the Oklahoma Ethanol Plant into the existing sanitary sewer collection system.

To implement the referenced search for alternate routes, an evaluation for using the existing 24-in.-dia. collectors at the intersections of Washington Street and Willow Road as well as Elm and 16TH Streets (referred to as Options 1 and 2, respectively) was conducted. Utilizing this process, additional prospective alignments that could include other existing and future businesses in the NE/quadrant of Enid were analyzed. These additional alignments evaluated in this report include the 30TH Street Option 3, 42ND Street Option 4, and 54TH Street Option 5. This report summarizes the results of these evaluations and provides a recommended alignment as well as estimated costs for all options ranging from \$867,700.00 to \$3,044,200.00.

2. INTRODUCTION

ENVIROTECH ENGINEERING & CONSULTING, INC., evaluated several alternative routes for a proposed sanitary sewer pipeline for the new Oklahoma Ethanol Plant to be constructed on north 16TH Street (approximately 1,000-ft. north of Willow Avenue) in Enid, Oklahoma. An overview of the plant location and sanitary sewer pipeline routing is graphically depicted on *Figure 1*. It is our understanding that the sanitary sewer flow *initial* design requirement is a 144,000-gpd capacity, but the design will encompass a *future* maximum flow of 300,000-gpd. In addition, this capacity shall be limited to 85% maximum capacity of the selected sanitary sewer pipeline. It has also been proposed that the site may require construction of a sanitary sewer lift station, if necessary.

The Oklahoma Ethanol Plant sanitary sewer flow shall be collected at a common point on-site within the road easement of 16TH Street within a paved section along the east side of the proposed facility. The plant facility will be comprised of several buildings and it is anticipated that the main service connection location (or lift station) will be approximately 800- to 1,000-ft. north of Willow Avenue. The plant site is a triangular-shaped piece of property abutting the City boundary on the north edge (i.e. 1/2-mi. north) of Willow Avenue and abutting the ADM grain elevators on the south edge that runs northwest. For purposes of this analysis, a sanitary sewer service is estimated to originate at the mash/prep buildings at a grade of 1,244-ft. It is assumed a sanitary sewer service line will exit the

NORTH
Scale: NTS




FIG. 1

**OKLAHOMA ETHANOL PLANT
SANITARY SEWER OPTIONS**




building at 1,240-ft. and slope 2% to the west edge of 16TH Street, resulting in an invert of 1,236-ft. This will be the starting point for purposes of analyzing either a gravity flow or forced main flow into the Enid sanitary sewer system, as graphically depicted on *Figure 2*


3. BASIS OF SANITARY SEWER ALIGNMENT OPTIONS

The several alignment options considered would terminate in a larger existing main trunk line in Enid. This evaluation will provide necessary information to the City of Enid for determining the sanitary sewer line construction that affords the most cost-effective solution while providing a maximum contribution to current and future development potential. All options evaluated in this report shall commence at the proposed Oklahoma Ethanol Plant site and proceed down the west side of 16TH Street and pass under three (3) sets of railroad tracks that service the ADM grain elevators. No new railroad tracks are anticipated at this location. From the point at 16TH Street and Willow Road, the various sanitary sewer alignment options will proceed as outlined below and graphically depicted on *Figure 2*.

- 3.1 **Option 1 - Washington Street.** Proceed along Willow Avenue approximately 9,000-ft. to the west where it would connect to an existing 24-in.-dia. sanitary sewer main collector at Washington Street.
- 3.2 **Option 2 - Elm Street.** Proceed south on 16TH Street approximately 8,450-ft. where it would pass under the Burlington Northern 22-track switching yard before terminating at the 24-in.-dia. main collector on Elm Street.
- 3.3 **Option 3 - 30TH Street.** Proceed east along the north side of Willow Avenue and pass under one (1) set of railroad tracks and 30TH Street before turning south under Willow Avenue. The pipeline would then proceed along the east side of 30TH Street and cross several pipelines and three (3) railroad tracks before turning southeast under U.S. Highway 412 and terminating at the existing 33-in. main collector near Market and 30th Streets. The length of this pipeline is estimated to be 16,500-ft.
- 3.4 **Option 4 - 42ND Street.** Proceed east along the north side of Willow Avenue and pass under one (1) set of railroad tracks and 30TH Street before turning south along the west bank of Skeleton Creek. At this point, the pipeline would intersect 42ND Street and pass south to the main sewer collector north of the wastewater treatment plant (WWTP) for a total estimated length of 20,300-ft.
- 3.5 **Option 5 - 54TH Street.** Proceed east from 16TH Street along the north side of Willow Avenue and pass under one (1) set of railroad tracks and 30TH Street before turning south along 30TH Street, east on Chestnut Avenue, and south on 42ND Street, terminating at the existing 33-in. sewer main north of East Market Avenue for a total estimated length of 20,700-ft.



Scale: NTS



X:\Projects\ENG\2006\06169 Enid Oklahoma Ethanol Sanitary Sewer System Impr\Scan\Dk\lahaoma Et

FIG. 2
OKLAHOMA ETHANOL PLANT
SANITARY SEWER ACCESS



ENVIROTECH
ENGINEERING & CONSULTING, INC.

2001 North Phoenix, Suite 200, Phoenix, AZ
Phone: (602) 944-1000 Fax: (602) 944-1001
E-Mail: info@envirotech.com
www.envirotech.com



4. OPTION ANALYSES

The following option analyses includes all general obstacles and perceived pros and cons as well as cost estimates for each option. In addition, each route was analyzed for possible use of a gravity line versus a lift station, even though a gravity line may be fairly deep in some cases. Primary obstacles are state highways, pipelines, and railroad tracks that must be bored under and require steel casing, with the exception of casing for pipelines.

Sanitary sewer line information for invert elevations was obtained from the Enid Sanitary Sewer Atlas and other "As-Built" information provided by the City of Enid's engineering department. Flow calculations of pipe sizes used in the following analysis are provided in *Appendix A*. These calculations clearly show that the pipe sizes evaluated will carry the required design flows and the capacity of existing collector mains.

The required design flow is 300,000 or 208-gpm at 85% flow of the selected sanitary sewer pipe diameter. For instance, a 10-in.-dia. pipe with a 2-fps (0.004 ft/ft) flow would convey 1.1-cfs or .711-mgd. At 85%, this pipe size would convey 0.604-mgd, or twice the required 0.3-mgd. Similarly, an 8-in.-dia. pipe would convey at least 383-gpm that would meet the design requirements. The minimum pipe slopes allowed by the Oklahoma Department of Environmental Quality (ODEQ) were used to minimize depth-of-sewer as well as provide a profile within the limits of the elevation at the Ethanol Plant and the City's existing receiving manhole. In some instances, a larger pipe diameter than needed has been proposed to minimize the slope due to obstacles or depth of excavation. Only the lowest slope pipe within a proposed option will be elaborated on with regard to flow capacity.

For information purposes, the following flows were estimated based on the minimum slope allowed by ODEQ.

Pipe Diameter (in.)	Area (sf)	Q(mgd) 85%	Q(mgd)	Slope (ft/ft)
8	.35	.450	.383	0.004
10	.55	.711	.604	0.0029
12	.79	1.02	.867	0.0022
15	2.45	1.58	1.343	0.0017
18	1.77	2.28	1.938	0.0015
24	3.14	4.10	3.485	0.0012

4.1 Option 1 - Washington Street Analysis. The alignment to the west of 16TH Street for an approximate total length of 9,000-ft. will pass underneath the Union Pacific railroad tracks west of 10TH Street. The pipeline would then proceed to Manhole No. IM288C that connects to the existing 24-in. sanitary sewer collector that flows south on Washington Street, as graphically depicted on *Figure 3*. The vertical alignment (i.e., profile) graphically depicted on



Scale: NTS




FIG. 3



ENVIROTECH

Environmental Consulting & Engineering

06169



Figure 4 shows that installation of a gravity sewer pipeline from 16TH Street at the maximum percent slope of 0.30% (0.29% allowed by ODEQ for a 10-in. line) would terminate approximately 17-ft. below the flow line invert of the 24-in. sanitary sewer line at Washington Street. The ground level at that point rises approximately 12-ft. higher westward which accounts for such a deep gravity flow line connection.

Therefore, an alternative alignment, graphically depicted on Figure 4, utilizes a 10-in. gravity line starting at the Washington Street invert elevation of 1,239.17-ft. and proceeding upward and easterly along Willow Avenue to a point approximately 1,700-ft. east and approximately 3-ft. below grade. Although it could be more practical to use an 8-in.-dia. line, it would intercept the Washington Street manhole at a lower depth. The remaining pipeline to the ethanol plant would be comprised of a force main and lift station at the plant, as graphically depicted on Figure 4. Due to an existing water main and improvements at Willow Avenue, it is likely that construction of a sanitary sewer pipeline would be more appropriate on the north side of the road. A layout plan graphically depicted on Figure 5 reflects the final proposed sanitary sewer pipeline. Both railroad and Oklahoma Department of Transportation (ODOT) permits would be required for this route as well as several main intersection crossings.

The flow capacity of an 8-in. line graphically depicted on Figure 4 corresponds to a 0.29% slope that could convey .383-gpm of sanitary sewer flow (at 85% capacity) that exceeds the design requirement of 300,000-gpd for the ethanol plant sanitary sewer pipeline. The existing 24-in. sanitary sewer main collector at Washington Street and Willow was constructed in the past few years to alleviate inflow and infiltration problems, afford additional service to that area, and provide some capacity for future development in that vicinity of the City. The flow capacity for the 24-in.-dia. line is estimated to be approximately 3.6-mgd. Channeling an additional 300,000-gpd from the east side of the City certainly reduces, and could jeopardize the capacity, of that line. Upgrading that system later would most likely outweigh the benefit and cost to construct the needed sewer pipeline for the ethanol plant in a different location. Furthermore, the Washington Street option would result in routing the sanitary sewer flow an additional 2-mi. in the wrong direction from the WWTP. The estimated cost for this option is \$ 867,700.00, as summarized in Table 1.

- 4.2 Option 2 - Elm Street Analysis.** Aligning a sanitary sewer pipeline directly south on 16TH Street to the existing 24-in. collector at Elm Street is graphically depicted on Figure 6. A series of approximately 22 railroad tracks would need to be bored under. In addition, the remaining portion of 16TH Street is fairly narrow and traverses a residential area. There is an existing waterline along the west side of 16TH Street and waterline crossings at all streets that must be avoided. Furthermore, the first block north of Elm Street will require replacement of an existing manhole and 10-in. line to achieve the depth needed for flow. Power poles exist directly south of Chestnut Avenue behind the curb on both sides of the street. It is most likely that a sanitary sewer pipeline may need to be bored almost the entire length of the residential area. Comparative cost estimates are provided for trenching the entire job or boring the residential area and trenching the remainder. Both railroad and Oklahoma




FIG. 4

**PROFILE
WASHINGTON AVENUE OPTION 1**



Scale: NTS




FIG. 5

**LAYOUT PLAN
WASHINGTON AVENUE OPTION 1**



ENVIROTECH

2500 North 11th Street - End, Oklahoma 73701
Phone (580) 234-8780, Fax (580) 237-4372
C.A. #19861 - Expiration Date: 6-30-2008
www.envirotechconsulting.com

Table 1


City of Enid
Oklahoma Ethanol Sewer Extension
Preliminary Engineers Cost Estimate

Option 1 - Washington Ave.

December 18, 2006

No.	Item	Unit	Quantity	Rate	Total
1	Mobilization	Ea	1	\$6,000.00	\$6,000.00
2	4" FM Sanitary Sewer bore and pipe, complete	LF	1200	\$50.00	\$60,000.00
3	12" steel casing w/4" FM waterline, bored	LF	800	\$100.00	\$80,000.00
4	4" FM Sanitary Sewer trench, complete	LF	6100	\$30.00	\$183,000.00
5	8" D.I.P. Sanitary Sewer bore and pipe, deep, complete	LF	1700	\$200.00	\$340,000.00
6	14" steel casing w/8" DIP waterline, bored	LF	300	\$300.00	\$90,000.00
7	4 ft dia Sanitary Sewer Manhole 8 ft deep complete	Ea	25	\$3,000.00	\$75,000.00
8	Additional depth for 4 ft dia. Manhole	Ft	200	\$30.00	\$6,000.00
10	Concrete/asphalt repair (bore pits, etc)	SF	1500	\$7.00	\$10,500.00
11	Project sign, complete, in place	Ea.	2	\$600.00	\$1,200.00
12	Traffic control, complete, in place	L.S.	1	\$1,000.00	\$1,000.00
13	Lift Station w/ Telemetry	L.S.	1	\$150,000.00	\$150,000.00
	Subtotal Construction Cost				\$1,002,700.00





Scale: NTS

OKLAHOMA
ETHANOL
PLANT
LIFT
STA.




FIG. 6
PLAN VIEW
ELM STREET OPTION 2



ENVIROTECH
ENGINEERING & CONSULTING, INC.

2010 North 11th Street - Suite 400
Tulsa, Oklahoma 74106
Phone: (918) 259-8722 Fax: (918) 259-8727
U.S. #888677 E-mail: info@envirotech.com
www.envirotech.com



Department of Transportation (ODOT) permits would be required for this route as well as several main intersection crossings.

The vertical alignment (profile) graphically depicted on *Figure 7* indicates that the pipeline could possibly be constructed as gravity flow. The number of manholes and final location of existing utilities may nonetheless necessitate a lift station. The flow capacity of the 8-in. line depicted on *Figure 7* corresponds to a slope of .0038-ft/ft. that could convey .39-mgd of sanitary sewer flow (at 85% capacity) that exceeds the design requirement of 300,000-gpd for the ethanol plant sanitary sewer line. It is proposed to use a larger 10-in.-dia. pipe to reduce construction costs by decreasing the trenching depth.

However, the issue of flow pertains to the receiving 24-in. pipeline constructed in the 1997 time frame to relieve flow the Phillips Tributary. The existing 24-in. collector at Elm Street was constructed at the minimal grade of 0.0025-ft/ft between Elm Street and the City's 30-in. collector on Owen K. Garriott Road. Based on our calculations, the 24-in. pipe has the capacity to accommodate 5.4-mgd (3,750-gpm) at that slope and at 85%, normal sewage flow has been observed to half fill this pipe. Flow measurements are being pursued to obtain actual storm flow conditions that may provide evidence that the 24-in. pipeline does not have the capacity to accommodate an additional 300,000-gal. of flow.

Since there is a 500,000-gal. storage tank at 19TH and Randolph Streets to assist in dissipating storm surge flow, it is possible that the 24-in. sanitary sewer relief pipeline may be a likely candidate for accepting the additional 300,000-gpd flow anticipated from the sanitary sewer pipeline extending to the Oklahoma Ethanol Plant.

Again, the existing 24-in. sanitary sewer main at Elm Street was constructed to alleviate inflow and infiltration problems, afford additional service to that area, and provide some capacity for future development in that vicinity of the City. Channeling an additional 300,000-gpd to the east side of the City certainly reduces, and could jeopardize the capacity, of that line. Upgrading that system at a later date would most likely outweigh the benefit and cost to construct the needed sanitary sewer pipeline for the ethanol plant in a different location.

A layout plan graphically depicted on *Figure 8* shows the final proposed sewer line. The estimated cost for trenching and boring is \$1,148,800.00, as summarized in *Table 2a*. An alternative cost of \$1,069,800.00 for trenching the entire job is provided in *Table 2b*.

4.3 Option 3 - 30TH Street Analysis. Routing a sanitary sewer pipeline along 30TH Street could possibly be accomplished with a 16,500-ft.-long gravity line connecting to the existing 33-in. main feeder to the WWTP, as graphically depicted on *Figure 9*. The profile (vertical alignment) is graphically depicted on *Figure 10* that shows varying slopes of sanitary sewer pipeline in order to minimize the pipe size and line depth. Several pipeline markings that cross this route would need to be verified before final acceptance of the alignment. The Magellan Company surveyor was on-site in November 2006 and reported that the two (2) northernmost pipelines were 2.5- to 3-ft. below the edge of the road, as graphically depicted





FIG. 7

**PROFILE
ELM STREET OPTION 2**

NORTH
Scale: NTS

Oklahoma Ethanol
Elevation 1244
Invert 1240



Bore and Case pipe
under railroad tracks
as well as state
highways and other
major thoroughfares

BNSF (22 Tracks)

Gravity Pipe
Size 8' to 10'
Length 8450'

16th St.

Chestnut

Manhole 1C015B
Elevation 1223.27
Invert 1210.11
Depth 13.16

Manhole 1C015A
Elevation 1219.8
Invert 1207.53
Depth 12.27
Inlet 1217.03

Elm St.

FIG. 8
LAYOUT PLAN
ELM STREET OPTION 2



2500 North 11th Street - Enid, Oklahoma 73701
Phone (580) 234-8780, Fax (580) 237-4302
C.A. #1980 - Expiration Date: 6-30-2008
www.envirotechconsulting.com

06169

Table 2a

City of Enid
Oklahoma Ethanol Sewer Extension
Preliminary Engineers Cost Estimate

Option 2 - Elm St

"TRENCH-AND-BORE" METHOD

December 18, 2006

No.	Item	Unit	Quantity	Rate	Total
1	Mobilization	Ea	1	\$6,000.00	\$6,000.00
2	8" D.I.P. Sanitary Sewer, trench and pipe, complete	LF	3500	\$70.00	\$245,000.00
3	8" D.I.P. Sanitary Sewer bore and pipe, complete	LF	4100	\$150.00	\$615,000.00
4	14" steel casing w/8" DIP waterline, bored	LF	850	\$250.00	\$212,500.00
5	4 ft dia Sanitary Sewer Manhole 8 ft deep complete	Ea	23	\$3,000.00	\$69,000.00
6	Additional depth for 4 ft dia Manhole	Ft	120	\$30.00	\$3,600.00
7	Concrete/asphalt repair (bore pits, etc)	SF	4000	\$7.00	\$28,000.00
8	Remove & replace 4" pavement, complete, in place	SF	1000	\$10.00	\$10,000.00
9	Project sign, complete, in place	Ea.	2	\$600.00	\$1,200.00
10	Traffic control, complete, in place	L.S.	1	\$1,000.00	\$1,000.00
	Subtotal Construction Cost				\$1,191,300.00



Table 2b

City of Enid
Oklahoma Ethanol Sewer Extension
Preliminary Engineers Cost Estimate


Option 2 - Elm St

"ALL TRENCH" METHOD

December 18, 2006

No.	Item	Unit	Quantity	Rate	Total
1	Mobilization	Ea	1	\$6,000.00	\$6,000.00
2	8" D.I.P. Sanitary Sewer, trench and pipe, complete	LF	7600	\$70.00	\$532,000.00
3	Compaction	CY	3700	\$20.00	\$74,000.00
4	14" steel casing w/8" DIP waterline, bored	LF	850	\$250.00	\$212,500.00
5	Pressure/Vacuum Relief Valves	LS	1	\$3,000.00	\$3,000.00
6	4 ft dia Sanitary Sewer Manhole 8 ft deep complete	Ea	23	\$3,000.00	\$69,000.00
7	Additional depth for 4 ft dia Manhole	Ft	120	\$30.00	\$3,600.00
8	Concrete/asphalt repair	SF	20000	\$10.00	\$200,000.00
9	Remove & replace 4" pavement, complete, in place	SF	1000	\$10.00	\$10,000.00
10	Project sign, complete, in place	Ea.	2	\$600.00	\$1,200.00
11	Traffic control, complete, in place	L.S.	1	\$1,000.00	\$1,000.00
	Subtotal Construction Cost				\$1,112,300.00





NORTH

Scale: NTS




FIG. 9
PLAN VIEW
30TH STREET OPTION 3



ENVIROTECH
ENGINEERING & CONSULTING, INC.

2500 North 11th Street - 1st Floor, Suite 200
Phoenix, AZ 85016-1778 Tel: (602) 237-4010
Fax: (602) 237-4011
E-mail: info@envirotech.com
www.envirotech.com




FIG. 10

**PROFILE
30TH STREET OPTION 3**





on *Figure 10*. Since the sanitary sewer pipeline reaches deeper depths as the line proceeds south, it is anticipated that the issue of pipelines may be overcome. Again, these would need to be surveyed and otherwise accurately located for depth before proceeding further with this option. An advantage of a deeper sanitary sewer pipeline is that it would allow for better access for facilities located farther east from 30TH Street. Both railroad and Oklahoma Department of Transportation (ODOT) permits would be required for this route as well as several main intersection crossings.

As previously mentioned, an "all-gravity" option would encompass a 12-in.-dia. pipe along Willow Road with a minimum flow of 0.9-mgd to serve existing and future development on both sides of Willow Road. The minimum slope of 0.12% shown on a portion of the profile (for a 24-in. pipe) is required to reduce depth of the overall excavation. The flow afforded by the 24-in.-dia. pipe would be 3.5-mgd at 85% capacity. Upon further analysis of sanitary sewer loading for this line, the sewer size could be increased or reduced which would also change the minimum slope.

An alternative option of "pump and gravity" could reduce the overall cost. This would encompass a lift station and force main along Willow Road and a 12-in.-dia. line south to the Oklahoma Ethanol Plant with an 18-in.-dia. line to the existing 33-in. sewer main near 30TH and Market Streets.

In addition, the actual depth and final slope would be dictated by the number of manholes required by ODEQ, which is typically every 400-ft. This would account for an additional drop of 0.1-ft./manhole, or several feet that could be adjusted by using an appropriate minimum pipe diameter.

This option could offer sanitary sewer service to facilities along 30TH Street to include the Hamm & Phillips facility on the NE/corner of 30TH Street and Willow Avenue; the Johnson Grain Elevators with an existing septic system; and other possible connections along both sides of 30TH Street to Highway 412. This could eliminate the lift station at the Hamm & Phillips facility and reduce maintenance and operating costs for the City of Enid. Due to the number of actual service connections required, the final sanitary sewer design may be deeper than shown and possibly require a sanitary sewer lift station at the Oklahoma Ethanol Plant. For instance, the "As-Built" plans for the 1994 Halliburton 4-in. sanitary sewer force main on the east side of 30TH Street to Chestnut Avenue indicate that pipe crossings are more shallow than the proposed pipe profile graphically depicted on *Figure 10*. The existing lift station invert is at 1,215.46-ft. and the proposed sanitary sewer is shown at almost the same elevation. While it would be impractical to lower the main sanitary sewer much deeper than that along 30TH Street, only a portion of the force main would need to remain intact to its connection at 30TH Street and Willow Road, and the remaining 1-mi. of force main could be deleted.

A layout plan graphically depicted on *Figure 11* shows the final proposed sanitary sewer pipeline. The actual pipeline impact would need to be more accurately ascertained. The

NORTH
Scale: NTS




FIG. 11
LAYOUT PLAN
30TH STREET OPTION 3



2500 North 11th Street - Enid, Oklahoma 73701
Phone (580) 234-8780, Fax (580) 237-4302
C.A. #1960 - Expiration Date: 6-30-2008
www.envirotechconsulting.com

06169



cost to bore and case under four (4) railroad crossings, drainage ditches, and Highway 412 and associated exit ramps will add to the fee significantly.

The extension of the sanitary sewer pipeline along the 30TH Street route will capitalize the 2-mi. of sanitary sewer construction otherwise considered on 16TH Street. This will include the additional cost for 1-mi. of sanitary sewer pipeline along Willow Avenue and the additional distance imposed by a line length equal to the distance from Elm Street to Manhole No. 1A016 on the existing 33-in. main sanitary sewer trunk. The primary emphasis will be to provide access for industry along Willow Road and the 30TH Street corridor.

This alignment would also facilitate future expansion of the collection system by constructing a separate branch pipeline from the south end of the proposed 30TH Street pipeline to a possible future WWTP expansion. The estimated cost for the Option 3 "all-gravity" flow alternative is \$2,388,700.00, as summarized in *Table 3a*. The estimated cost for the Option 3 "pump and gravity" alternative is \$1,680,950.00, as summarized in *Table 3b*.

4.4 Option 4 - 42ND Street Analysis. This route, graphically depicted on *Figure 12*, must traverse the west bank of Skeleton Creek until it intersects 42ND Street and travels south to the existing 33-in. pipeline. The vertical alignment (profile), graphically depicted on *Figure 13*, indicates the possibility of an approximate 0.0030% pipe slope between the 30TH Street and Willow Road intersection to the point of entrance into the existing 33-in. sewer main at 30th and Market Streets. Due to the length of this alignment, the required pipe size may need to be increased to 18-in. at the south end to convey, at minimum, 2-mgd at 85% flow. The pipeline depth is approximately 10-ft., but reaches 26-ft. at the railroad. The west bank of the creek is uneven and could result in exposed lines unless they are deepened or set back at the top of the bank. In addition, this route encompasses two (2) railroad crossings as well Highway 412. Both railroad and Oklahoma Department of Transportation (ODOT) permits would be required for this route as well as several main intersection crossings.

This alignment, as shown, would obviously not provide service along the 30TH Street corridor. Such service would need to either access existing sanitary sewer pipelines in the residential area to the west of 30TH Street or stretch east to the 42ND Street alignment that could result in long service lines. Another alternative would be to consider combining the 30TH Street Option 3 to Chestnut Avenue and construct a sewer line east to the 42ND Street alignment, as graphically depicted on *Figure 14*. At this point, the connection at 30TH Street would be approximately 20-ft.-deep (El. 1,212). This would need to pass under the BNS&F and Skeleton Creek at 1,190-ft. and tie to the 42ND Street line at 1,170-ft. This constitutes an approximate 0.01% slope.

Further evaluation of the 42ND Street collector will need to be supported with additional information concerning possible development in this area. The possibility of flow from 54TH Street to 42ND Street along Chestnut Avenue is explained in the following Option 5.

Table 3a

City of Enid
Oklahoma Ethanol Sewer Extension
Preliminary Engineers Cost Estimate

Option 3 - 30th St

"ALL GRAVITY" FLOW

December 18, 2006

No.	Item	Unit	Quantity	Rate	Total
1	Mobilization	Ea	1	\$6,000.00	\$6,000.00
2	12" D.I.P. Sanitary Sewer, trench and pipe, complete	LF	5500	\$80.00	\$440,000.00
3	12" D.I.P. Sanitary Sewer bore and pipe, complete	LF	250	\$200.00	\$50,000.00
4	20" steel casing w/ 12" DIP waterline, bored	LF	450	\$350.00	\$157,500.00
5	18" D.I.P. Sanitary Sewer, trench and pipe, complete	LF	10400	\$150.00	\$1,560,000.00
6	18" D.I.P. Sanitary Sewer bore and pipe, complete	LF	200	\$250.00	\$50,000.00
7	26" steel casing w/ 18" DIP waterline, bored	LF	800	\$400.00	\$320,000.00
8	Sanitary Sewer Manhole 8 ft deep complete	Ea	47	\$3,000.00	\$141,000.00
9	Additional depth for 4 ft dial Manhole	Ft	150	\$30.00	\$4,500.00
10	Remove & replace 4" pavement, complete, in place	SF	1000	\$10.00	\$10,000.00
11	Project sign, complete, in place	Ea.	2	\$600.00	\$1,200.00
12	Traffic control, complete, in place	L.S.	1	\$1,000.00	\$1,000.00
	Subtotal Construction Cost				\$2,741,200.00



**City of Enid
Oklahoma Ethanol Sewer Extension
Preliminary Engineers Cost Estimate**

Option 3 - 30th St

"PUMP-AND-GRAVITY" METHOD

December 18, 2006

"PUMP-AND-GRAVITY" METHOD

No.	Item	Unit	Quantity	Rate	Total
1	Mobilization	Ea	1	\$6,000.00	\$6,000.00
2	4" FM Sanitary Sewer, trench and pipe, complete	LF	5500	\$20.00	\$110,000.00
3	4" FM Sanitary Sewer bore and pipe, complete	LF	250	\$50.00	\$12,500.00
4	12" steel casing w/ 4" DIP waterline, bored	LF	450	\$100.00	\$45,000.00
5	12" D.I.P. Sanitary Sewer, trench and pipe, complete	LF	2700	\$80.00	\$216,000.00
6	20" steel casing w/12"DIP waterline, bored	LF	300	\$350.00	\$105,000.00
7	18" D.I.P. Sanitary Sewer, trench and pipe, complete	LF	7800	\$150.00	\$1,170,000.00
8	18" D.I.P. Sanitary Sewer bore and pipe, complete	LF	100	\$250.00	\$25,000.00
9	26" steel casing w/ 18" DIP waterline, bored	LF	500	\$300.00	\$150,000.00
10	Sanitary Sewer Manhole 8 ft deep complete	Ea	32	\$3,000.00	\$96,000.00
11	Lift Station complete	LS	1	\$150,000.00	\$150,000.00
12	Additional depth for 4 ft dial Manhole	Ft	150	\$30.00	\$4,500.00
13	Remove & replace 4" pavement, complete, in place	SF	1000	\$10.00	\$10,000.00
14	Project sign, complete, in place	Ea.	2	\$600.00	\$1,200.00
15	Traffic control, complete, in place	L.S.	1	\$1,000.00	\$1,000.00
	Subtotal Construction Cost				\$2,102,200.00





NORTH

Scale: NTS

SAME ALIGNMENT AS OPTION
3 TO OKLAHOMA ETHANOL




FIG. 12
PLAN VIEW
42ND ST OPTION 4



ENVIROTECH
ENGINEERING & CONSULTING, INC.

2500 North 48th Street, Fort Worth, TX 76106
Phone (817) 396-0700 Fax (817) 396-0701
T.A. #1880 E-mail: envirotech@earthlink.net
www.envirotech-consulting.com





FIG. 13

**PROFILE
42ND STREET OPTION 4**



Scale: NTS

Oklahoma Ethanol
Elevation 1244
Invert 1240

Lift Station and
Pump or Gravity Pipe
Size 12"
Length 4900'

Gravity Pipe
Size 12" or 18"
Length 17100'

Willow

1208

1221

54th

42nd

INV 1190

Chestnut

1227

INV 1212

1%

1172

INV 1161.6

0.12%

1175

INV 1170
(EXIS 1160)

0.15%

1170

Randolph

1170

State Hwy 412

Dwen K. Garriott

Market

1147

54th Pump
Station

1152.36

LAYOUT PLAN ALTERNATE 42ND STREET OPTION

FIG. 14



ENVIROTECH

2500 North 11th Street - Enid, Oklahoma 73701
Phone (580) 234-8780 Fax (580) 237-4302
T.C.A. #1959 - Expiration Date 6-30-2008
www.envirotechconsulting.com



The estimated cost for this option, graphically depicted on *Figure 13*, is \$3,044,200.00, as summarized in *Table 4*.

4.5 Option 5 - 54TH Street Analysis. Based on the results of a summary evaluation of routing the sanitary sewer pipeline to 54TH Street along Willow Road, it has been determined that this option is not feasible due to the crossing of Skeleton Creek west of 42ND Street that precludes flow upward on the east side.

However, there is a possibility of directing sewage from 54TH Street and Chestnut Avenue west to the 42ND Street Option 4 alignment. Reducing the slope of the sewer south of Chestnut on 42ND Street to 0.12% or 0.15% would provide the depth needed at 42ND Street and Chestnut Avenue to allow sewage flow from 54TH Street, as graphically depicted on *Figure 14*. This is based on an approximate sewer depth of 6- to 7-ft. at 54TH and Chestnut. Since the actual sewer depth at this intersection is 15-ft., this option would only be useful for new connections in this area. This helps demonstrate a backbone for sanitary sewer collection for the greater area of northeast Enid.

This line would cost approximately \$600,000.00 more than the 30TH Street "all-gravity" Option 3 for a total estimated cost of \$3,000,000.00. This would encompass approximately 22,000-ft. of sanitary sewer line from the Oklahoma Ethanol Plant to the 33-in. main trunk line at Market Street.

5. CONCLUSIONS AND RECOMMENDATIONS

Based on current information regarding maximum capacity, Options 1 and 2 for Washington Street and Elm Street routing, respectively, may impact the usefulness and purpose of the 24-in. collector pipelines. In addition, Option 1 requires reverse routing of sanitary sewer flows.

Based on the analyses and associated cost estimates, the most likely candidates for routing and conveying flows up to 300,000-gpd from the future Oklahoma Ethanol sanitary sewer collection pipeline appear to be Options 2 and 3 (16TH Street and 30TH Street, respectively.) Although Option 2 (16TH Street) is less expensive, it may impact the capability of the existing 24-in. collector line to less than acceptable levels.

The 30TH Street Option 3 should provide the necessary capacity for several existing facilities as well as future development. The length of Hamm & Phillips' force main could be reduced to a short segment to 30TH Street. In addition, this option offers the flexibility of adding a branch line east along Chestnut Avenue as well as a separate feeder at the 33-in. pipeline.

It appears that an evaluation of the developmental possibilities of Option 4 (42ND Street corridor) need to be further studied in order to determine the advantage of constructing a sanitary sewer collector along this route. However, this option presents an opportunity to combine it with Option 3 plus a cross-link on Chestnut Avenue to provide another method of access to future developers along Chestnut Avenue. In addition, it could afford an opportunity to redirect sanitary sewer flow from

Table 4

City of Enid
Oklahoma Ethanol Sewer Extension
Preliminary Engineers Cost Estimate

Option 4 - 42nd St

December 18, 2006

No.	Item	Unit	Quantity	Rate	Total
1	Mobilization	Ea	1	\$6,000.00	\$6,000.00
2	12" D.I.P. Sanitary Sewer, trench and pipe, complete	LF	4250	\$80.00	\$340,000.00
3	12" D.I.P. Sanitary Sewer bore and pipe, complete	LF	650	\$100.00	\$65,000.00
4	20" steel casing w/ 12" DIP waterline, bored	LF	400	\$200.00	\$80,000.00
5	18" D.I.P. Sanitary Sewer, trench and pipe, complete	LF	12300	\$150.00	\$1,845,000.00
6	18" D.I.P. Sanitary Sewer bore and pipe, complete	LF	2700	\$250.00	\$675,000.00
7	26" steel casing w/ 18" DIP waterline, bored	LF	400	\$300.00	\$120,000.00
8	4 ft dia Sanitary Sewer Manhole 8 ft deep complete	Ea	55	\$3,000.00	\$165,000.00
9	Additional depth for 4 ft dia Manhole	Ft	100	\$30.00	\$3,000.00
10	Remove & replace 4" pavement, complete, in place	SF	1000	\$10.00	\$10,000.00
11	Compaction, complete, in place	CY	100	\$20.00	\$2,000.00
12	Project sign, complete, in place	Ea.	2	\$600.00	\$1,200.00
13	Traffic control, complete, in place	L.S.	1	\$1,000.00	\$1,000.00
14	Lift Station w/ Telemetry	L.S.	1	\$150,000.00	\$150,000.00
	Subtotal Construction Cost				\$3,463,200.00





54TH Street by gravity and therefore, reduce the demand and need to upgrade the 54TH Street pump station.

Option 5 (54TH Street) is not a probable candidate due to the creek depression west of 42ND Street and an uphill slope eastward.

Therefore, it is ENVIROTECH'S recommendation that further consideration be given to **Option 3** to provide an overall solution for sanitary sewer collection requirements for current and future development of the northeast portion of Enid. Option 4 should be further evaluated as part of other 54TH Street sanitary sewer line issues. Investment in Option 2 could diminish the capability of the existing 24-in. collector and result in unanticipated upgrade costs in the future. In order to finalize a decision for Option 3, further investigation is recommended to determine exact locations of utilities, drainage, and other physical obstacles existing on this route.

A summary of the estimated costs for Options 1 through 4 is presented in *Table 5*.

Table 5

City of Enid
Oklahoma Ethanol Sewer Extension
Preliminary Engineers Cost Estimate

Summary of Options

December 18, 2006

Description	Method	Table	Est. Cost
Option 1 - Washington Ave.	"PUMP-AND-GRAVITY"	1	\$867,700.00
Option 2 - Elm St	"Gravity - TRENCH-AND-BORE"	2a	\$1,148,800.00
Option 2 - Elm St	"Gravity - ALL TRENCH"	2b	\$1,069,800.00
Option 3 - 30th St	"ALL GRAVITY" FLOW	3a	\$2,388,700.00
Option 3 - 30th St	"PUMP-AND-GRAVITY"	3b	\$1,680,950.00
Option 4 - 42nd St	"PUMP-AND-GRAVITY"	4	\$3,044,200.00



APPENDIX A.

SANITARY SEWER FLOW CALCULATIONS

Table
Rating Table for Circular Channel

Washington -
Elm st. option
30th St option

Project Description	
Project File	x:\projects\leng\2006\oklahoma~1\pipefl~1.fm2
Worksheet	36"
Flow Element	Circular Channel
Method	Manning's Formula
Solve For	Discharge

Constant Data	
Mannings Coefficient	0.016
Channel Slope	0.004000 ft/ft
Diameter	10.00 in

Input Data			
	Minimum	Maximum	Increment
Depth	0.0	10.0	1.0 in

Rating Table

Depth (in)	Discharge (cfs)	Velocity (ft/s)
0.0	0.00	0.00
1.0	0.02	0.83
2.0	0.10	1.27
3.0	0.22	1.60
4.0	0.38	1.86
5.0	0.56	2.06
6.0	0.76	2.21
7.0	0.94	2.31
8.0	1.10	2.35
9.0	1.20	2.32
10.0	1.13	2.06

$1.20 \text{ cfs} = 532.6 \text{ gal/min} = 775,580 \text{ gal/day}$

Table
Rating Table for Circular Channel

Project Description	
Project File	x:\projects\eng\2006\oklaho~1\pipefl~1.fm2
Worksheet	36"
Flow Element	Circular Channel
Method	Manning's Formula
Solve For	Discharge

Constant Data	
Mannings Coefficient	0.016
Channel Slope	0.002900 ft/ft
Diameter	10.00 in

Input Data			
	Minimum	Maximum	Increment
Depth	0.0	10.0	1.0 in

Rating Table		
Depth (in)	Discharge (cfs)	Velocity (ft/s)

0.0	0.00	0.00
1.0	0.02	0.71
2.0	0.08	1.08
3.0	0.19	1.36
4.0	0.32	1.59
5.0	0.48	1.76
6.0	0.64	1.88
7.0	0.80	1.97
8.0	0.94	2.00
9.0	1.02	1.98
10.0	0.96	1.76

→ = 604 MGD

$$1.02 \text{ cfs} = 457.8 \text{ gal/min} = 659,243 \text{ gal/day}$$

Table
Rating Table for Circular Channel

24" COLLECTOR
OPT 1 + 2

Project Description	
Project File	x:\projects\leng\2006\oklaho~1\pipefl~1.fm2
Worksheet	36"
Flow Element	Circular Channel
Method	Manning's Formula
Solve For	Discharge

Constant Data	
Mannings Coefficient	0.016
Channel Slope	0.000800 ft/ft
Diameter	24.00 in

Input Data			
	Minimum	Maximum	Increment
Depth	0.0	24.0	1.0 in

Rating Table

Depth (in)	Discharge (cfs)	Velocity (ft/s)
0.0	0.00	0.00
1.0	0.02	0.38
2.0	0.07	0.59
3.0	0.17	0.76
4.0	0.31	0.91
5.0	0.49	1.04
6.0	0.71	1.16
7.0	0.96	1.26
8.0	1.25	1.36
9.0	1.56	1.45
10.0	1.89	1.52
11.0	2.24	1.59
12.0	2.60	1.65
13.0	2.97	1.71
14.0	3.34	1.76
15.0	3.71	1.80
16.0	4.08	1.83
17.0	4.42	1.86
18.0	4.74	1.88
19.0	5.03	1.89
20.0	5.27	1.89
21.0	5.46	1.87
22.0	5.57	1.85
23.0	5.57	1.80
24.0	5.20	1.65

5.57 cfs = 2499.99 gal/m - = 360 x 10³ gal/day

Table
Rating Table for Circular Channel

30" MAIN COLLECTION
OPT 2

Project Description	
Project File	x:\projects\eng\2006\oklaho~1\pipefl~1.fm2
Worksheet	36"
Flow Element	Circular Channel
Method	Manning's Formula
Solve For	Discharge

Constant Data	
Mannings Coefficient	0.016
Channel Slope	0.001000 ft/ft
Diameter	30.00 in

Input Data			
	Minimum	Maximum	Increment
Depth	0.0	30.0	1.0 in

Rating Table

Depth (in)	Discharge (cfs)	Velocity (ft/s)
0.0	0.00	0.00
1.0	0.02	0.42
2.0	0.09	0.66
3.0	0.22	0.86
4.0	0.40	1.03
5.0	0.64	1.18
6.0	0.92	1.32
7.0	1.26	1.45
8.0	1.64	1.56
9.0	2.06	1.67
10.0	2.53	1.76
11.0	3.02	1.85
12.0	3.55	1.94
13.0	4.10	2.01
14.0	4.68	2.08
15.0	5.27	2.15
16.0	5.87	2.20
17.0	6.48	2.26
18.0	7.08	2.30
19.0	7.68	2.34
20.0	8.26	2.38
21.0	8.82	2.40
22.0	9.36	2.43
23.0	9.85	2.44
24.0	10.30	2.45

Table
Rating Table for Circular Channel

Depth (in)	Discharge (cfs)	Velocity (ft/s)
25.0	10.69	2.45
26.0	11.01	2.44
27.0	11.23	2.41
28.0	11.33	2.38
29.0	11.25	2.32
30.0	10.54	2.15

$$11.33 \text{ cfs} = 5085.26 \text{ gal/min} = 7.32 \times 10^6 \text{ gal/day}$$

Table
Rating Table for Circular Channel

33" MAIN COLLECTOR

Project Description	
Project File	x:\projects\leng\2006\oklaho-1\pipefl-1.fm2
Worksheet	36"
Flow Element	Circular Channel
Method	Manning's Formula
Solve For	Discharge

Constant Data	
Mannings Coefficient	0.016
Channel Slope	0.001000 ft/ft
Diameter	33.00 in

Input Data			
	Minimum	Maximum	Increment
Depth	0.0	33.0	1.0 in

Rating Table

Depth (in)	Discharge (cfs)	Velocity (ft/s)
0.0	0.00	0.00
1.0	0.02	0.42
2.0	0.10	0.67
3.0	0.23	0.86
4.0	0.42	1.04
5.0	0.67	1.19
6.0	0.98	1.33
7.0	1.34	1.46
8.0	1.75	1.57
9.0	2.21	1.68
10.0	2.71	1.79
11.0	3.26	1.88
12.0	3.84	1.97
13.0	4.45	2.05
14.0	5.09	2.12
15.0	5.76	2.19
16.0	6.45	2.26
17.0	7.14	2.32
18.0	7.85	2.37
19.0	8.56	2.42
20.0	9.27	2.46
21.0	9.97	2.50
22.0	10.65	2.53
23.0	11.31	2.56
24.0	11.94	2.58

Table
Rating Table for Circular Channel

Depth (in)	Discharge (cfs)	Velocity (ft/s)
25.0	12.53	2.60
26.0	13.08	2.61
27.0	13.57	2.61
28.0	13.98	2.60
29.0	14.31	2.59
30.0	14.54	2.56
31.0	14.62	2.52
32.0	14.48	2.46
33.0	13.59	2.29

$$14.62 \text{ cfs} = 6561.91 \text{ gal/min} = 9.45 \times 10^4 \text{ gal/day}$$

Table
Rating Table for Circular Channel

36" MAIN COLLECTOR

Project Description	
Project File	x:\projects\eng\2006\oklaho~1\pipefl~1.fm2
Worksheet	36"
Flow Element	Circular Channel
Method	Manning's Formula
Solve For	Discharge

Constant Data	
Mannings Coefficient	0.016
Channel Slope	0.001000 ft/ft
Diameter	36.00 in

Input Data			
	Minimum	Maximum	Increment
Depth	0.0	36.0	1.0 in

Rating Table

Depth (in)	Discharge (cfs)	Velocity (ft/s)
0.0	0.00	0.00
1.0	0.02	0.42
2.0	0.10	0.67
3.0	0.24	0.87
4.0	0.45	1.04
5.0	0.71	1.19
6.0	1.03	1.34
7.0	1.42	1.47
8.0	1.86	1.59
9.0	2.35	1.70
10.0	2.89	1.80
11.0	3.48	1.90
12.0	4.11	1.99
13.0	4.78	2.08
14.0	5.48	2.16
15.0	6.22	2.23
16.0	6.98	2.30
17.0	7.77	2.36
18.0	8.57	2.42
19.0	9.38	2.48
20.0	10.20	2.53
21.0	11.02	2.57
22.0	11.84	2.62
23.0	12.64	2.65
24.0	13.43	2.68

Table
Rating Table for Circular Channel

Rating Table		
Depth (in)	Discharge (cfs)	Velocity (ft/s)
25.0	14.20	2.71
26.0	14.93	2.73
27.0	15.63	2.75
28.0	16.27	2.76
29.0	16.86	2.76
30.0	17.38	2.76
31.0	17.82	2.75
32.0	18.16	2.74
33.0	18.38	2.71
34.0	18.43	2.67
35.0	18.23	2.60
36.0	17.14	2.42

$$18.43 \text{ cfs} = 8271.96 \text{ gal/min} = 1.19 \times 10^7 \text{ gal/day}$$

Table
Rating Table for Circular Channel

**24" MAIN COLLECTOR
OPT 2 ELM ST.**

Project Description	
Project File	c:\program files\academic\fmw\project2.fm2
Worksheet	Elm Street Option 2
Flow Element	Circular Channel
Method	Manning's Formula
Solve For	Discharge

Constant Data	
Mannings Coefficient	0.016
Channel Slope	0.002500 ft/ft
Diameter	24.00 in

Input Data			
	Minimum	Maximum	Increment
Depth	0.0	24.0	2.0 in

Rating Table		
Depth (in)	Discharge (cfs)	Velocity (ft/s)

0.0	0.00	0.00
2.0	0.13	1.04
4.0	0.55	1.61
6.0	1.26	2.05
8.0	2.20	2.40
10.0	3.34	2.69
12.0	4.59	2.93
14.0	5.91	3.11
16.0	7.20	3.24
18.0	8.38	3.32
20.0	9.32	3.33
22.0	9.85	3.27
24.0	9.19	2.93

$\rightarrow 85\% \div 1.55 \Rightarrow 5.4 \text{ MGD} \Rightarrow 3750 \text{ gpm}$

$\rightarrow \div 1.55 \text{ cfs/mgd} \Rightarrow 6.4 \text{ MGD}$

$\Rightarrow 4413 \text{ gpm}$

Culvert Calculator Report NOC Sewer Run at Elm

Solve For: Discharge

Culvert Summary			
Allowable HW Elevation	23.00 ft	Headwater Depth/ Height	1.50
Computed Headwater Elevation	23.00 ft	Discharge	13.705 cfs
Inlet Control HW Elev	22.11 ft	Tailwater Elevation	20.00 ft
Outlet Control HW Elev	23.00 ft	Control Type	Outlet Control

B. PMCO

Grades			
Upstream Invert	20.00 ft	Downstream Invert	19.00 ft
Length	400.00 ft	Constructed Slope	0.002500 ft/ft

Hydraulic Profile			
Profile	CompositeM2Pressure	Depth, Downstream	1.33 ft
Slope Type	Mild	Normal Depth	N/A ft
Flow Regime	Subcritical	Critical Depth	1.33 ft
Velocity Downstream	6.16 ft/s	Critical Slope	0.007954 ft/ft

Section			
Section Shape	Circular	Mannings Coefficient	0.015
Section Material	Concrete	Span	2.00 ft
Section Size	24 inch	Rise	2.00 ft
Number Sections	1		

Outlet Control Properties			
Outlet Control HW Elev	23.00 ft	Upstream Velocity Head	0.30 ft
Ke	0.50	Entrance Loss	0.15 ft

Inlet Control Properties			
Inlet Control HW Elev	22.11 ft	Flow Control	Unsubmerged
Inlet Type	Square edge w/headwall	Area Full	3.1 ft ²
K	0.00980	HDS 5 Chart	1
M	2.00000	HDS 5 Scale	1
C	0.03980	Equation Form	1
Y	0.67000		

Culvert Calculator Report NOC Sewer Run at Elm

Solve For: Discharge

Culvert Summary			
Allowable HW Elevation	22.00 ft	Headwater Depth/ Height	1.00
Computed Headwater Elevation	22.00 ft	Discharge	10.375 cfs
Inlet Control HW Elev	21.73 ft	Tailwater Elevation	20.00 ft
Outlet Control HW Elev	22.00 ft	Control Type	Outlet Control

Grades			
Upstream Invert	20.00 ft	Downstream Invert	19.00 ft
Length	400.00 ft	Constructed Slope	0.002500 ft/ft

Hydraulic Profile			
Profile	M2	Depth, Downstream	1.15 ft
Slope Type	Mild	Normal Depth	1.77 ft
Flow Regime	Subcritical	Critical Depth	1.15 ft
Velocity Downstream	5.53 ft/s	Critical Slope	0.007013 ft/ft

Section			
Section Shape	Circular	Mannings Coefficient	0.015
Section Material	Concrete	Span	2.00 ft
Section Size	24 inch	Rise	2.00 ft
Number Sections	1		

Outlet Control Properties			
Outlet Control HW Elev	22.00 ft	Upstream Velocity Head	0.21 ft
Ke	0.50	Entrance Loss	0.10 ft

Inlet Control Properties			
Inlet Control HW Elev	21.73 ft	Flow Control	Unsubmerged
Inlet Type	Square edge w/headwall	Area Full	3.1 ft ²
K	0.00980	HDS 5 Chart	1
M	2.00000	HDS 5 Scale	1
C	0.03980	Equation Form	1
Y	0.67000		

Culvert Calculator Report NOC Sewer Run at Elm

Solve For: Discharge

Culvert Summary

Allowable HW Elevation	22.00 ft	Headwater Depth/ Height	1.00
Computed Headwater Elevation	22.00 ft	Discharge	9.176 cfs
Inlet Control HW Elev	21.60 ft	Tailwater Elevation	21.00 ft
Outlet Control HW Elev	22.00 ft	Control Type	Outlet Control

5.9MGD

Grades

Upstream Invert	20.00 ft	Downstream Invert	19.00 ft
Length	400.00 ft	Constructed Slope	0.002500 ft/ft

Hydraulic Profile

Profile	M1	Depth, Downstream	2.00 ft
Slope Type	Mild	Normal Depth	1.54 ft
Flow Regime	Subcritical	Critical Depth	1.08 ft
Velocity Downstream	2.92 ft/s	Critical Slope	0.006743 ft/ft

Section

Section Shape	Circular	Mannings Coefficient	0.015
Section Material	Concrete	Span	2.00 ft
Section Size	24 inch	Rise	2.00 ft
Number Sections	1		

Outlet Control Properties

Outlet Control HW Elev	22.00 ft	Upstream Velocity Head	0.15 ft
Ke	0.50	Entrance Loss	0.08 ft

Inlet Control Properties

Inlet Control HW Elev	21.60 ft	Flow Control	Unsubmerged
Inlet Type	Square edge w/headwall	Area Full	3.1 ft ²
K	0.00980	HDS 5 Chart	1
M	2.00000	HDS 5 Scale	1
C	0.03980	Equation Form	1
Y	0.67000		

Culvert Calculator Report NOC Sewer Run

Solve For: Headwater Elevation

Culvert Summary			
Allowable HW Elevation	1,190.00 ft	Headwater Depth/ Height	0.72
Computed Headwater Elevation	1,176.28 ft	Discharge	1,900 gal/min
Inlet Control HW Elev	1,176.09 ft	Tailwater Elevation	1,176.09 ft
Outlet Control HW Elev	1,176.28 ft	Control Type	Outlet Control

2.7MGD

Grades			
Upstream Invert	1,174.85 ft	Downstream Invert	1,174.09 ft
Length	265.00 ft	Constructed Slope	0.002868 ft/ft

Hydraulic Profile			
Profile	M1	Depth, Downstream	2.00 ft
Slope Type	Mild	Normal Depth	0.88 ft
Flow Regime	Subcritical	Critical Depth	0.72 ft
Velocity Downstream	1.35 ft/s	Critical Slope	0.005995 ft/ft

Section			
Section Shape	Circular	Mannings Coefficient	0.015
Section Material	Concrete	Span	2.00 ft
Section Size	24 inch	Rise	2.00 ft
Number Sections	1		

Outlet Control Properties			
Outlet Control HW Elev	1,176.28 ft	Upstream Velocity Head	0.05 ft
Ke	0.50	Entrance Loss	0.03 ft

Inlet Control Properties			
Inlet Control HW Elev	1,176.09 ft	Flow Control	Unsubmerged
Inlet Type	Square edge w/headwall	Area Full	3.1 ft ²
K	0.00980	HDS 5 Chart	1
M	2.00000	HDS 5 Scale	1
C	0.03980	Equation Form	1
Y	0.67000		

Culvert Calculator Report NOC Sewer Run

Solve For: Discharge

Culvert Summary			
Allowable HW Elevation	1,176.85 ft	Headwater Depth/ Height	1.00
Computed Headwater Elevation	1,176.85 ft	Discharge	4,190 gal/min
Inlet Control HW Elev	1,176.47 ft	Tailwater Elevation	1,176.09 ft
Outlet Control HW Elev	1,176.85 ft	Control Type	Outlet Control

Grades			
Upstream Invert	1,174.85 ft	Downstream Invert	1,174.09 ft
Length	265.00 ft	Constructed Slope	0.002868 ft/ft

Hydraulic Profile			
Profile	M1	Depth, Downstream	2.00 ft
Slope Type	Mild	Normal Depth	1.47 ft
Flow Regime	Subcritical	Critical Depth	1.09 ft
Velocity Downstream	2.97 ft/s	Critical Slope	0.006777 ft/ft

Section			
Section Shape	Circular	Mannings Coefficient	0.015
Section Material	Concrete	Span	2.00 ft
Section Size	24 inch	Rise	2.00 ft
Number Sections	1		

Outlet Control Properties			
Outlet Control HW Elev	1,176.85 ft	Upstream Velocity Head	0.16 ft
Ke	0.50	Entrance Loss	0.08 ft

Inlet Control Properties			
Inlet Control HW Elev	1,176.47 ft	Flow Control	Unsubmerged
Inlet Type	Square edge w/headwall	Area Full	3.1 ft ²
K	0.00980	HDS 5 Chart	1
M	2.00000	HDS 5 Scale	1
C	0.03980	Equation Form	1
Y	0.67000		

Table
Rating Table for Circular Channel

ELMST. opt 2

Project Description	
Project File	x:\projects\eng\2006\oklaho-1\pipefl-1.fm2
Worksheet	36"
Flow Element	Circular Channel
Method	Manning's Formula
Solve For	Discharge

Constant Data	
Mannings Coefficient	0.016
Channel Slope	0.004000 ft/ft
Diameter	8.00 in

Input Data			
	Minimum	Maximum	Increment
Depth	0.0	8.0	1.0 in

Rating Table		
Depth (in)	Discharge (cfs)	Velocity (ft/s)

0.0	0.00	0.00
1.0	0.02	0.82
2.0	0.09	1.25
3.0	0.19	1.55
4.0	0.31	1.78
5.0	0.44	1.93
6.0	0.57	2.02
7.0	0.65	2.01
8.0	0.62	1.78

$$0.65 \text{ cfs} = 291.74 \text{ gal/min} = 420,106 \text{ gal/day}$$

APPENDICES

APPENDIX TM 3-1

COST ANALYSIS WORKSHEETS

CITY OF ENID WASTEWATER FACILITY PLAN

TABLE 1

CAPITAL COST ESTIMATES

Sep-06

OPTION 1A: 14 MGD NEW PLANT, CONVENTIONAL ACTIVATED SLUDGE PROCESS

Unit Description	Unit Size/ Design Capacity	Number of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	860,800
Sitework	-	-	2,458,400
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
Primary Clarifiers	90 ft. Dia	2	1,794,600
Aeration Basin	200' L x 50' W x 16.5' D	4	8,115,200
Secondary Clarifiers	100 ft. Dia	3	3,322,900
Nitrification Basin	14 MGD	-	4,643,300
Tertiary clarifiers	100 ft. Dia	3	3,322,900
Disinfection system	28 MGD	-	1,382,000
Electrical	-	-	2,519,600
Instrumentation & Controls	-	-	1,339,400
Piping	-	-	3,739,100
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			37,166,100
Non-Construction Cost (15%)			5,575,000
Contingency (15%)			5,575,000
TOTAL			48,316,100
Improvements at 2020			
Mobilization	-	-	200,000
Sitework	-	-	300,000
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	250,000
Instrumentation & Controls	-	-	150,000
Piping	-	-	400,000
SUB TOTAL			3,796,100
Non-Construction Cost (15%)			569,500
Contingency (15%)			569,500
TOTAL			4,935,100

CITY OF ENID WASTEWATER FACILITY PLAN

CAPITAL COST ESTIMATES

TABLE 2

Sep-06

OPTION 1B: 14 MGD NEW PLANT, SBR (SEQUENTIAL BATCH REACTOR) PROCESS

Unit Description	Unit Size/ Design Capacity	Number of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	860,800
Sitework	-	-	2,458,400
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
SBR Reactors	140' L x 98' W x 22' D	8	18,960,200
Sludge Holding Basins	70' L x 35' W x 12' D	2	1,174,100
Disinfection System	40 MGD	-	1,975,300
Electrical	-	-	2,519,600
Instrumentation & Controls	-	-	1,339,400
Piping	-	-	2,875,600
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			35,831,300
Non-Construction Cost (15%)			5,374,700
Contingency (15%)			5,374,700
TOTAL			46,580,700
Improvements at 2020			
Mobilization	-	-	200,000
Sitework	-	-	300,000
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	250,000
Instrumentation & Controls	-	-	150,000
Piping	-	-	400,000
SUB TOTAL			3,796,100
Non-Construction Cost (15%)			569,500
Contingency (15%)			569,500
TOTAL			4,935,100

CITY OF ENID WASTEWATER FACILITY PLAN

CAPITAL COST ESTIMATES

TABLE 3

Sep-06

OPTION 3A: 12 MGD NEW PLANT, CONVENTIONAL ACTIVATED SLUDGE PROCESS
WITH EXPANSION TO 14 MGD CAPACITY

Unit Description	Unit Size/ Design Capacity	Number of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	773,900
Sitework	-	-	2,220,600
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
Primary Clarifiers	90 ft. Dia	2	1,794,600
Aeration Basin	180' L x 45' W x 17.20' D	4	6,852,200
Secondary Clarifiers	90 ft. Dia	3	2,691,900
Nitrification Basin	12 MGD	-	4,085,500
Tertiary clarifiers	90 ft. Dia	3	2,691,900
Disinfection System	28 MGD	-	1,382,000
Electrical	-	-	2,251,500
Instrumentation & Controls	-	-	1,187,700
Piping	-	-	3,320,600
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			32,920,300
Non-Construction Cost (15%)			4,938,100
Contingency (15%)			4,938,100
TOTAL			42,796,500
Improvements at 2020			
Mobilization	-	-	224,800
Sitework	-	-	680,600
Aeration Basin	180' L x 30' W x 17.20' D	4	1,142,100
Secondary Clarifiers	80 ft. Dia	1	709,000
Nitrification Basin	2 MGD	-	821,400
Tertiary clarifiers	80 ft. Dia	1	709,000
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	608,800
Instrumentation & Controls	-	-	293,600
Piping	-	-	835,700
SUB TOTAL			8,521,100
Non-Construction Cost (15%)			1,278,200
Contingency (15%)			1,278,200
TOTAL			11,077,500

CITY OF ENID WASTEWATER FACILITY PLAN

CAPITAL COST ESTIMATES

TABLE 4

Sep-06

**OPTION 3B: 12 MGD NEW PLANT, SBR (SEQUENTIAL BATCH REACTOR) PROCESS
WITH EXPANSION TO 14 MGD CAPACITY**

Unit Description	Unit Size/ Design Capacity	Number of Units of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	773,900
Sitework	-	-	2,220,600
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
SBR Reactors	140' L x 98' W x 22' D	7	16,590,200
Sludge Holding Basins	70' L x 35' W x 12' D	2	1,174,100
Disinfection System	40 MGD	-	1,975,300
Electrical	-	-	2,251,500
Instrumentation & Controls	-	-	1,187,700
Piping	-	-	2,560,000
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			32,401,200
Non-Construction Cost (15%)			4,860,200
Contingency (15%)			4,860,200
TOTAL			42,121,600
Improvements at 2020			
Mobilization	-	-	224,800
Sitework	-	-	680,600
SBR Reactors	140' L x 98' W x 22' D	1	2,370,100
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	608,800
Instrumentation & Controls	-	-	293,600
Piping	-	-	580,000
SUB TOTAL			7,254,000
Non-Construction Cost (15%)			1,088,100
Contingency (15%)			1,088,100
TOTAL			9,430,200

CITY OF ENID WASTEWATER FACILITY PLAN

CAPITAL COST ESTIMATES

TABLE 5
Sep-06

**OPTION 4A: USING EXISTING TREATMENT FACILITY AND BUILDING A 7 MGD
NEW PLANT, CONVENTIONAL ACTIVATED SLUDGE PROCESS
WITH EXPANSION TO 14 MGD CAPACITY**

Unit Description	Unit Size/ Design Capacity	Number of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	533,600
Sitework	-	-	1,555,900
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
Primary Clarifiers	70 ft. Dia	2	1,085,700
Aeration Basin	150' L x 75' W x 15' D	2	4,149,900
Secondary Clarifiers	90 ft. Dia	2	1,794,600
Nitrification Basin	7 MGD	-	2,721,100
Tertiary clarifiers	90 ft. Dia	2	1,794,600
Disinfection System	28 MGD	-	882,000
Improvements to Existing WWTP	-	-	2,737,700
Electrical	-	-	1,519,000
Instrumentation & Controls	-	-	780,000
Piping	-	-	2,192,700
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			25,414,700
Non-Construction Cost (15%)			3,812,300
Contingency (15%)			3,812,300
TOTAL			33,039,300
Improvements at 2020			
Mobilization	-	-	533,600
Sitework	-	-	1,555,900
Primary Clarifiers	70 ft. Dia	2	1,085,700
Aeration Basin	150' L x 75' W x 15' D	2	4,149,900
Secondary Clarifiers	90 ft. Dia	2	1,794,600
Nitrification Basin	7 MGD	-	1,921,700
Tertiary clarifiers	90 ft. Dia	2	1,794,600
Disinfection System	-	-	500,000
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	1,519,000
Instrumentation & Controls	-	-	780,000
Piping	-	-	2,192,700
SUB TOTAL			20,323,800
Non-Construction Cost (15%)			3,048,600
Contingency (15%)			3,048,600
TOTAL			26,421,000

CITY OF ENID WASTEWATER FACILITY PLAN

TABLE 6

CAPITAL COST ESTIMATES

Sep-06

OPTION 4B: USING EXISTING TREATMENT FACILITY AND BUILDING A 7 MGD NEW PLANT, SBR (SEQUENTIAL BATCH REACTOR) PROCESS WITH EXPANSION TO 14 MGD CAPACITY

Unit Description	Unit Size/ Design Capacity	Number of Units	Estimated Cost in 2006 Dollars
Improvements at 2010			
Mobilization	-	-	533,600
Sitework	-	-	1,555,900
Headworks			
Screening	28 MGD	-	510,400
Grit Removal	28 MGD	-	783,100
Parshal Flume	28 MGD	-	240,500
Liftstation	28 MGD	-	1,383,900
SBR Reactors	140' L x 98' W x 22' D	4	9,480,100
Sludge Holding Basins	70' L x 35' W x 12' D	1	587,100
Disinfection System	40 MGD	-	1,975,300
Improvements to Existing WWTP	-	-	2,737,700
Electrical	-	-	1,519,000
Instrumentation & Controls	-	-	780,000
Piping	-	-	1,725,300
Influent / Effluent outfall	2300 LF, 36"	-	750,000
SUB TOTAL			24,561,900
Non-Construction Cost (15%)			3,684,300
Contingency (15%)			3,684,300
TOTAL			31,930,500
Improvements at 2020			
Mobilization	-	-	553,600
Sitework	-	-	1,555,900
SBR Reactors	140' L x 98' W x 22' D	4	9,480,100
Sludge Holding Basins	70' L x 35' W x 12' D	1	587,100
Aerobic Digesters	60 ft. Dia	2	1,295,800
Dewatering System	4 MGD	-	1,200,300
Electrical	-	-	1,519,000
Instrumentation & Controls	-	-	780,000
Piping	-	-	1,510,000
SUB TOTAL			18,481,800
Non-Construction Cost (15%)			2,772,300
Contingency (15%)			2,772,300
TOTAL			24,026,400

CITY OF ENID WASTEWATER FACILITY PLAN

TABLE 7

Operations & Maintenance Costs

September-06

Unit Component	Base Year Labor Rate (\$/hr)	Annual Operations Costs						Total Annual Costs (\$)
		Operations Labor* (man-hours)	Operations Labor (\$)	Maintenance Labor* (man-hours)	Maintenance Labor (\$)	Additional Energy Costs (\$)	Materials and Supply Costs** (\$)	
OPTION 1A								
Influent Pumping	\$ 11.00	700	\$ 7,700	600	\$ 6,600	\$ 122,400	\$ 12,300	\$ 149,000
Preliminary treatment	\$ 11.00	2700	\$ 29,700	1300	\$ 14,300	-	\$ 17,100	\$ 61,100
Primary sedimentation	\$ 11.00	1300	\$ 14,300	700	\$ 7,700	-	\$ 9,800	\$ 31,800
Activated sludge Process	\$ 11.00	4300	\$ 47,300	2800	\$ 30,800	\$ 424,200	\$ 34,200	\$ 536,500
Secondary Clarifiers	\$ 11.00	1800	\$ 19,800	1000	\$ 11,000	-	\$ 17,600	\$ 48,400
Nitrification Basin	\$ 11.00	3500	\$ 38,500	2100	\$ 23,100	\$ 228,500	\$ 34,200	\$ 324,300
Tertiary clarifiers	\$ 11.00	1800	\$ 19,800	1000	\$ 11,000	-	\$ 17,600	\$ 48,400
Desinfection	\$ 11.00	140	\$ 1,540	140	\$ 1,540	\$ 68,600	\$ 18,000	\$ 89,680
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	-	\$ 165,600	\$ 239,300
				Total:				\$ 1,717,580
OPTION 1A								
Digestion	\$ 11.00	1000	\$ 11,000	600	\$ 6,600	\$ 22,900	\$ 12,300	\$ 52,800
Dewatering	\$ 11.00	3000	\$ 33,000	400	\$ 4,400	-	\$ 80,600	\$ 118,000
				Total:				\$ 1,886,480
OPTION 1B								
Influent Pumping	\$ 11.00	700	\$ 7,700	600	\$ 6,600	\$ 122,400	\$ 12,300	\$ 149,000
Preliminary treatment	\$ 11.00	2700	\$ 29,700	1300	\$ 14,300	-	\$ 17,100	\$ 61,100
Sequential Batch Reactor	\$ 11.00	5500	\$ 60,500	3600	\$ 39,600	\$ 548,200	\$ 34,200	\$ 682,500
Sludge Holding Basin	\$ 11.00	1000	\$ 11,000	550	\$ 6,050	-	\$ 14,200	\$ 31,250
Desinfection	\$ 11.00	140	\$ 1,540	140	\$ 1,540	\$ 68,600	\$ 18,000	\$ 89,680
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	-	\$ 165,600	\$ 239,300
				Total:				\$ 1,442,030
OPTION 1B								
Digestion	\$ 11.00	1000	\$ 11,000	600	\$ 6,600	\$ 22,900	\$ 12,300	\$ 52,800
Dewatering	\$ 11.00	3000	\$ 33,000	400	\$ 4,400	-	\$ 80,600	\$ 118,000
				Total:				\$ 1,612,830

* O&M Costs for the period 2020 - 2030 includes annual O&M costs estimated for the period 2010 - 2020 plus additional O&M costs resulting from expansion in 2020

CITY OF ENID WASTEWATER FACILITY PLAN

Operations & Maintenance Costs

TABLE 8

September-06

Unit Component	Base Year Labor Rate (\$/hr)	Annual Operations Costs							Total Annual Costs (\$)
		Operations Labor (man-hours)	Operations Labor (\$)	Maintenance Labor (man-hours)	Maintenance Labor (\$)	Additional Energy Costs (\$)	Materials and Supply Costs** (\$)		
OPTION 3A									
Influent Pumping	\$ 11.00	650	\$ 7,150	550	\$ 6,050	\$ 81,600	\$ 9,300	\$ 104,100	
Preliminary treatment	\$ 11.00	2300	\$ 25,300	1100	\$ 12,100	-	\$ 14,700	\$ 52,100	
Primary sedimentation	\$ 11.00	1200	\$ 13,200	650	\$ 7,150	-	\$ 10,000	\$ 30,350	
Activated sludge Process	\$ 11.00	4000	\$ 44,000	2500	\$ 27,500	\$ 359,000	\$ 29,300	\$ 459,800	
Secondary Clarifiers	\$ 11.00	1700	\$ 18,700	850	\$ 9,350	-	\$ 13,200	\$ 41,250	
Nitrification Basin	\$ 11.00	3000	\$ 33,000	2000	\$ 22,000	\$ 195,800	\$ 29,300	\$ 280,100	
Tertiary clarifiers	\$ 11.00	1700	\$ 18,700	850	\$ 9,350	-	\$ 13,200	\$ 41,250	
Desinfection	\$ 11.00	120	\$ 1,320	120	\$ 1,320	\$ 58,800	\$ 15,400	\$ 76,840	
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200	
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	-	\$ 165,600	\$ 239,300	
		Total:							\$ 1,514,290
OPTION 3A									
Between 2010 - 2020									
Between 2020 - 2030*									
		Total:							\$ 1,888,480
OPTION 3B									
Influent Pumping	\$ 11.00	650	\$ 7,150	550	\$ 6,050	\$ 81,600	\$ 9,300	\$ 104,100	
Preliminary treatment	\$ 11.00	2300	\$ 25,300	1100	\$ 12,100	-	\$ 14,700	\$ 52,100	
Sequential Batch Reactor	\$ 11.00	5000	\$ 55,000	3000	\$ 33,000	\$ 479,700	\$ 29,300	\$ 597,000	
Sludge Holding Basin	\$ 11.00	1000	\$ 11,000	550	\$ 6,050	-	\$ 14,200	\$ 31,250	
Desinfection	\$ 11.00	120	\$ 1,320	120	\$ 1,320	\$ 58,800	\$ 15,400	\$ 76,840	
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200	
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	-	\$ 165,600	\$ 239,300	
		Total:							\$ 1,289,790
OPTION 3B									
Between 2020 - 2030*									
		Total:							\$ 1,612,830

* O&M Costs for the period 2020 - 2030 includes annual O&M costs estimated for the period 2010 - 2020 plus additional O&M costs resulting from expansion in 2020

CITY OF ENID WASTEWATER FACILITY PLAN

Operations & Maintenance Costs

TABLE 9

September-06

Unit Component	Base Year Labor Rate (\$/hr)	Annual Operations Costs						Total Annual Costs (\$)
		Operations Labor* (man-hours)	Operations Labor (\$)	Maintenance Labor* (man-hours)	Maintenance Labor (\$)	Additional Energy Costs (\$)	Materials and Supply Costs** (\$)	
OPTION 4A								
Influent Pumping	\$ 11.00	650	\$ 7,150	550	\$ 6,050	\$ 81,600	\$ 9,300	\$ 104,100
Preliminary treatment	\$ 11.00	2300	\$ 25,300	1100	\$ 12,100	-	\$ 14,700	\$ 52,100
Primary sedimentation	\$ 11.00	1100	\$ 12,100	600	\$ 6,600	-	\$ 10,800	\$ 29,500
Activated sludge Process	\$ 11.00	4500	\$ 49,500	2900	\$ 31,900	\$ 339,400	\$ 44,500	\$ 465,300
Secondary Clarifiers	\$ 11.00	1850	\$ 20,350	900	\$ 10,800	-	\$ 17,400	\$ 48,640
Nitrification Basin	\$ 11.00	4100	\$ 45,100	2800	\$ 30,800	\$ 244,800	\$ 44,500	\$ 365,200
Tertiary clarifiers	\$ 11.00	2250	\$ 24,750	1180	\$ 12,980	-	\$ 20,000	\$ 57,730
Desinfection	\$ 11.00	120	\$ 1,320	120	\$ 1,320	\$ 58,800	\$ 15,400	\$ 76,840
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	-	\$ 165,600	\$ 239,300
							Total:	\$ 1,627,910
OPTION 4B								
Influent Pumping	\$ 11.00	650	\$ 7,150	550	\$ 6,050	\$ 81,600	\$ 9,300	\$ 104,100
Preliminary treatment	\$ 11.00	2300	\$ 25,300	1100	\$ 12,100	-	\$ 14,700	\$ 52,100
Primary sedimentation	\$ 11.00	650	\$ 7,150	350	\$ 3,850	-	\$ 4,400	\$ 15,400
Activated sludge Process	\$ 11.00	2500	\$ 27,500	1500	\$ 16,500	\$ 195,800	\$ 20,000	\$ 259,800
Secondary Clarifiers	\$ 11.00	900	\$ 9,900	500	\$ 5,500	-	\$ 7,400	\$ 22,800
Nitrification Basin	\$ 11.00	2600	\$ 28,600	1700	\$ 18,700	\$ 130,600	\$ 20,000	\$ 197,900
Tertiary clarifiers	\$ 11.00	1300	\$ 14,300	700	\$ 7,700	-	\$ 10,800	\$ 32,800
Sequential Batch Reactor	\$ 11.00	3600	\$ 39,600	2100	\$ 23,100	\$ 274,100	\$ 24,500	\$ 361,300
Sludge Holding Basin	\$ 11.00	750	\$ 8,250	350	\$ 3,850	-	\$ 13,700	\$ 25,800
Desinfection	\$ 11.00	120	\$ 1,320	120	\$ 1,320	\$ 58,800	\$ 15,400	\$ 76,840
Digestion	\$ 11.00	1800	\$ 19,800	1300	\$ 14,300	\$ 130,600	\$ 24,500	\$ 189,200
Dewatering	\$ 11.00	6000	\$ 66,000	700	\$ 7,700	-	\$ 165,600	\$ 239,300
							Total:	\$ 1,617,340
OPTION 4E								
							Total:	\$ 1,612,830

* O&M Costs for the period 2020 - 2030 includes annual O&M costs estimated for the period 2010 - 2020 plus additional O&M costs resulting from expansion in 2020

CITY OF ENID WASTEWATER FACILITY PLAN

TABLE 10
Sep-06

PRESENT WORTH COST ANALYSIS

OPTION	DESCRIPTION	CAPITAL COST		O & M COST		PRESENT WORTH COST AT 2006
		2010	2020	2010 - 2020	2020 - 2030	
1A	14 MGD New Plant Conventional Activated Sludge Process	\$ 48,316,100	\$ 4,935,100	\$ 1,717,680	\$ 1,888,480	\$ 62,646,975
1B	14 MGD New Plant SBR Process	\$ 46,580,700	\$ 4,935,100	\$ 1,442,030	\$ 1,612,830	\$ 58,184,959
3A	12 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 42,796,500	\$ 11,077,500	\$ 1,514,290	\$ 1,888,480	\$ 59,985,628
3B	12 MGD New Plant SBR Process W/ Expansion to 14 MGD	\$ 42,121,600	\$ 9,430,200	\$ 1,289,790	\$ 1,612,830	\$ 55,862,804
4A	7 MGD New Plant Conventional Activated Sludge Process W/ Expansion to 14 MGD	\$ 33,039,300	\$ 26,421,000	\$ 1,627,910	\$ 1,888,480	\$ 60,842,593
4B	7 MGD New Plant SBR Process W/ Expansion to 14 MGD	\$ 31,930,500	\$ 24,026,400	\$ 1,577,340	\$ 1,612,830	\$ 57,106,473